

Attachment 2

Other Addition Non-Regulated Monitoring Data

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006212-021

Sample Location: 1st Draw 1011 E ST NE
Customer Sample Number: 3120864
Date / Time Collected: 6/22/2020 3:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-021
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 1011 E ST NE
Customer Sample Number: 3120864
Date / Time Collected: 6/22/2020 3:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-022
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006174-016

Sample Location: 1st Draw 1343 Meridian PI NW
Customer Sample Number: 3057467
Date / Time Collected: 6/17/2020 7:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2006174-016
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 1343 Meridian PI NW
Customer Sample Number: 3057467
Date / Time Collected: 6/17/2020 7:47 AM

Customer Program Code: DS
Laboratory Sample Number: 2006174-017
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006212-043

Sample Location: 1st Draw 1383 SOMERSET PL NW
Customer Sample Number: 3048920
Date / Time Collected: 6/23/2020 6:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-043
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 1383 SOMERSET PL NW
Customer Sample Number: 3048920
Date / Time Collected: 6/23/2020 6:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-044
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006174-001

Sample Location: 1st Draw 3813 5th St. NW
Customer Sample Number: 3020539
Date / Time Collected: 6/8/2020 8:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2006174-001
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 3813 5th St. NW
Customer Sample Number: 3020539
Date / Time Collected: 6/8/2020 8:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2006174-002
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006223-003

Sample Location: 1st Draw 4410 35th St NW
Customer Sample Number: 3036533
Date / Time Collected: 6/24/2020 6:42 AM

Customer Program Code: DS
Laboratory Sample Number: 2006223-003
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 4410 35th St NW
Customer Sample Number: 3036533
Date / Time Collected: 6/24/2020 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2006223-004
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006177-001

Sample Location: 1st Draw 4517 Harrison St. NW

Customer Sample Number: 3043288

Date / Time Collected: 6/17/2020 8:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2006177-001

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 4517 Harrison St. NW

Customer Sample Number: 3043288

Date / Time Collected: 6/17/2020 8:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2006177-002

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006185-003

Sample Location: 1st Draw 4620 43rd St NW Apt 2

Customer Sample Number: 3042838

Date / Time Collected: 6/8/2020 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2006185-003

Date / Time Received: 6/23/2020 10:11:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006223-005

Sample Location: 1st Draw 518 Taylor St NW
Customer Sample Number: 3020969
Date / Time Collected: 6/24/2020 8:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2006223-005
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 518 Taylor St NW
Customer Sample Number: 3020969
Date / Time Collected: 6/24/2020 8:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2006223-006
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006212-017

Sample Location: 1st Draw 6219 33rd St NW
Customer Sample Number: 3038058
Date / Time Collected: 6/22/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-017
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 6219 33rd St NW
Customer Sample Number: 3038058
Date / Time Collected: 6/22/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-018
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006212-007

Sample Location: 1st Draw 629 Q St. NW
Customer Sample Number: 3145572
Date / Time Collected: 6/20/2020 6:08 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-007
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 629 Q St. NW
Customer Sample Number: 3145572
Date / Time Collected: 6/20/2020 6:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-008
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006212-011

Sample Location: 1st Draw 708 BUTTERNUT ST NW
Customer Sample Number: 3047168
Date / Time Collected: 6/21/2020 6:39 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-011
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 708 BUTTERNUT ST NW
Customer Sample Number: 3047168
Date / Time Collected: 6/21/2020 6:42 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-012
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006136-007

Sample Location: 1st Draw 768 Upsal St SE
Customer Sample Number: 3085908
Date / Time Collected: 6/3/2020 9:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2006136-007
Date / Time Received: 6/17/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	100	ug/L		6/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006212-035

Sample Location: 1st Draw 804 I ST NE
Customer Sample Number: 3122754
Date / Time Collected: 6/23/2020 7:02 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-035
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 804 I ST NE
Customer Sample Number: 3122754
Date / Time Collected: 6/23/2020 7:04 AM

Customer Program Code: DS
Laboratory Sample Number: 2006212-036
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2006223-001

Sample Location: 1st Draw 905 Emerson St NW

Customer Sample Number: 3022531

Date / Time Collected: 6/24/2020 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2006223-001

Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 905 Emerson St NW

Customer Sample Number: 3022531

Date / Time Collected: 6/24/2020 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2006223-002

Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-015

Sample Location: 1st Draw 1213 EMERSON ST NW
Customer Sample Number: 3049831
Date / Time Collected: 6/27/2020 7:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-015
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 1213 EMERSON ST NW
Customer Sample Number: 3049831
Date / Time Collected: 6/27/2020 7:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-016
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-005

Sample Location: 1st Draw 1224 Irving St NW
Customer Sample Number: 3032925
Date / Time Collected: 6/26/2020 6:06 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-005
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 1224 Irving St NW
Customer Sample Number: 3032925
Date / Time Collected: 6/26/2020 6:11 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-006
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-011

Sample Location: 1st Draw 1304 MONTELLO AVE NE
Customer Sample Number: 3126933
Date / Time Collected: 6/27/2020 12:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2007026-011
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 1304 MONTELLO AVE NE
Customer Sample Number: 3126933
Date / Time Collected: 6/27/2020 12:32 PM

Customer Program Code: DS
Laboratory Sample Number: 2007026-012
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007014-005

Sample Location: 1st Draw 157 Adams St NW
Customer Sample Number: 3018472
Date / Time Collected: 6/17/2020 9:54 AM

Customer Program Code: DS
Laboratory Sample Number: 2007014-005
Date / Time Received: 7/2/2020 8:43:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	7/9/2020	SBrooks

Sample Location: 2nd Draw 157 Adams St NW
Customer Sample Number: 3018472
Date / Time Collected: 6/17/2020 10:11 AM

Customer Program Code: DS
Laboratory Sample Number: 2007014-006
Date / Time Received: 7/2/2020 8:43:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-037

Sample Location: 1st Draw 1762 CORCORAN ST NW UNIT 4
Customer Sample Number: 3001522
Date / Time Collected: 6/30/2020 6:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-037
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 1762 CORCORAN ST NW UNIT 4
Customer Sample Number: 3001522
Date / Time Collected: 6/30/2020 6:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-038
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-021

Sample Location: 1st Draw 2019 13TH ST NW
Customer Sample Number: 3003552
Date / Time Collected: 6/29/2020 11:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-021
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 2019 13TH ST NW
Customer Sample Number: 3003552
Date / Time Collected: 6/29/2020 11:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-022
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-007

Sample Location: 1st Draw 229 17TH ST SE
Customer Sample Number: 3075769
Date / Time Collected: 6/26/2020 12:16 PM

Customer Program Code: DS
Laboratory Sample Number: 2007026-007
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 229 17TH ST SE
Customer Sample Number: 3075769
Date / Time Collected: 6/26/2020 12:19 PM

Customer Program Code: DS
Laboratory Sample Number: 2007026-008
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007014-007

Sample Location: 1st Draw 229 Cromwell Ter. NE

Customer Sample Number: 3124077

Date / Time Collected: 6/1/2020 6:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2007014-007

Date / Time Received: 7/2/2020 8:43:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/9/2020	SBrooks

Sample Location: 2nd Draw 229 Cromwell Ter. NE

Customer Sample Number: 3124077

Date / Time Collected: 6/1/2020 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2007014-008

Date / Time Received: 7/2/2020 8:43:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-001

Sample Location: 1st Draw 2827 ARIZONA AVE NW
Customer Sample Number: 3055652
Date / Time Collected: 6/27/2020 7:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-001
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 2827 ARIZONA AVE NW
Customer Sample Number: 3055652
Date / Time Collected: 6/27/2020 7:39 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-002
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-017

Sample Location: 1st Draw 3128 Patterson PI NW
Customer Sample Number: 3037675
Date / Time Collected: 6/28/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-017
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 3128 Patterson PI NW
Customer Sample Number: 3037675
Date / Time Collected: 6/28/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-018
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-009

Sample Location: 1st Draw 3825 T ST NW
Customer Sample Number: 3010779
Date / Time Collected: 6/26/2020 7:14 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-009
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 3825 T ST NW
Customer Sample Number: 3010779
Date / Time Collected: 6/26/2020 7:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-010
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-027

Sample Location: 1st Draw 3841 BEECHER ST NW
Customer Sample Number: 3010249
Date / Time Collected: 6/29/2020 5:48 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-027
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 3841 BEECHER ST NW
Customer Sample Number: 3010249
Date / Time Collected: 6/29/2020 5:49 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-028
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007014-001

Sample Location: 1st Draw 4518 Lowell St NW
Customer Sample Number: 3044174
Date / Time Collected: 6/23/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007014-001
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.8	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 4518 Lowell St NW
Customer Sample Number: 3044174
Date / Time Collected: 6/23/2020 7:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2007014-002
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.0	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007014-003

Sample Location: 1st Draw 4928 46th St NW
Customer Sample Number: 3043208
Date / Time Collected: 6/26/2020 7:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2007014-003
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 4928 46th St NW
Customer Sample Number: 3043208
Date / Time Collected: 6/26/2020 7:26 AM

Customer Program Code: DS
Laboratory Sample Number: 2007014-004
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-013

Sample Location: 1st Draw 5002 7TH ST NW
Customer Sample Number: 3022921
Date / Time Collected: 6/27/2020 7:54 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-013
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 5002 7TH ST NW
Customer Sample Number: 3022921
Date / Time Collected: 6/27/2020 7:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-014
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-035

Sample Location: 1st Draw 708 19TH ST NE
Customer Sample Number: 3112038
Date / Time Collected: 6/29/2020 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-035
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 708 19TH ST NE
Customer Sample Number: 3112038
Date / Time Collected: 6/29/2020 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-036
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-015

Sample Location: 1st Draw 1125 BRANCH AVE SE
Customer Sample Number: 3079271
Date / Time Collected: 7/2/2020 9:04 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-015
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 1125 BRANCH AVE SE
Customer Sample Number: 3079271
Date / Time Collected: 7/2/2020 9:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-016
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007084-019

Sample Location: 1st Draw 1300 Delafield Place NW
Customer Sample Number: 3049914
Date / Time Collected: 7/8/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-019
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 1300 Delafield Place NW
Customer Sample Number: 3049914
Date / Time Collected: 7/8/2020 6:33 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-020
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007084-013

Sample Location: 1st Draw 1354 Emerald St. NE
Customer Sample Number: 3100031
Date / Time Collected: 7/7/2020 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-013
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 1354 Emerald St. NE
Customer Sample Number: 3100031
Date / Time Collected: 7/7/2020 6:48 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-014
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-019

Sample Location: 1st Draw 1458 T ST NW
Customer Sample Number: 3010931
Date / Time Collected: 7/5/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-019
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 1458 T ST NW
Customer Sample Number: 3010931
Date / Time Collected: 7/5/2020 6:31 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-020
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-021

Sample Location: 1st Draw 1616 4th St NW
Customer Sample Number: 3006060
Date / Time Collected: 7/5/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-021
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 1616 4th St NW
Customer Sample Number: 3006060
Date / Time Collected: 7/5/2020 7:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-022
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-005

Sample Location: 1st Draw 1617 D ST NE
Customer Sample Number: 3101069
Date / Time Collected: 7/1/2020 5:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-005
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 1617 D ST NE
Customer Sample Number: 3101069
Date / Time Collected: 7/1/2020 5:56 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-006
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-023

Sample Location: 1st Draw 1922 37TH ST NW
Customer Sample Number: 3010701
Date / Time Collected: 7/5/2020 11:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-023
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 1922 37TH ST NW
Customer Sample Number: 3010701
Date / Time Collected: 7/5/2020 11:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-024
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007084-009

Sample Location: 1st Draw 2110 Flagler PI NW
Customer Sample Number: 3018587
Date / Time Collected: 7/6/2020 5:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-009
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 2110 Flagler PI NW
Customer Sample Number: 3018587
Date / Time Collected: 7/6/2020 5:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-010
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-009

Sample Location: 1st Draw 235 Cromwell Terrace NE
Customer Sample Number: 3122090
Date / Time Collected: 7/1/2020 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-009
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 235 Cromwell Terrace NE
Customer Sample Number: 3122090
Date / Time Collected: 7/1/2020 8:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-010
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007084-017

Sample Location: 1st Draw 3611 Warder St. NW

Customer Sample Number: 3052506

Date / Time Collected: 7/7/2020 7:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2007084-017

Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 3611 Warder St. NW

Customer Sample Number: 3052506

Date / Time Collected: 7/7/2020 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2007084-018

Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.8	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-017

Sample Location: 1st Draw 3743 JOCELYN ST NW
Customer Sample Number: 3039064
Date / Time Collected: 7/4/2020 7:57 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-017
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 3743 JOCELYN ST NW
Customer Sample Number: 3039064
Date / Time Collected: 7/4/2020 7:59 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-018
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-003

Sample Location: 1st Draw 3830 HARRISON ST NW
Customer Sample Number: 3040390
Date / Time Collected: 6/30/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-003
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 3830 HARRISON ST NW
Customer Sample Number: 3040390
Date / Time Collected: 6/30/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-004
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007084-003

Sample Location: 1st Draw 4137 New Hampshire Ave NW
Customer Sample Number: 3051107
Date / Time Collected: 7/2/2020 8:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-003
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 4137 New Hampshire Ave NW
Customer Sample Number: 3051107
Date / Time Collected: 7/2/2020 8:16 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-004
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007084-007

Sample Location: 1st Draw 508 D St. SE, Apt A
Customer Sample Number: 3071891
Date / Time Collected: 7/4/2020 7:57 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-007
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 508 D St. SE, Apt A
Customer Sample Number: 3071891
Date / Time Collected: 7/4/2020 7:59 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-008
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007084-001

Sample Location: 1st Draw 610 Morton PI NE
Customer Sample Number: 3098810
Date / Time Collected: 7/2/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-001
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 610 Morton PI NE
Customer Sample Number: 3098810
Date / Time Collected: 7/2/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-002
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-013

Sample Location: 1st Draw 6256 29TH ST NW
Customer Sample Number: 3087818
Date / Time Collected: 7/2/2020 7:23 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-013
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 6256 29TH ST NW
Customer Sample Number: 3087818
Date / Time Collected: 7/2/2020 7:26 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-014
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007084-011

Sample Location: 1st Draw 639 F St. NE
Customer Sample Number: 3127879
Date / Time Collected: 7/6/2020 7:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-011
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 639 F St. NE
Customer Sample Number: 3127879
Date / Time Collected: 7/6/2020 7:46 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-012
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007046-029

Sample Location: 1st Draw 742 9th St SE
Customer Sample Number: 3073505
Date / Time Collected: 7/7/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-029
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 742 9th St SE
Customer Sample Number: 3073505
Date / Time Collected: 7/7/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007046-030
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007084-015

Sample Location: 1st Draw 858 Whittier Pl, NW
Customer Sample Number: 3027432
Date / Time Collected: 7/7/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-015
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 858 Whittier Pl, NW
Customer Sample Number: 3027432
Date / Time Collected: 7/7/2020 7:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2007084-016
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007100-011

Sample Location: 1st Draw 1058 Quebec PI NW

Customer Sample Number: 3029367

Date / Time Collected: 7/8/2020 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2007100-011

Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.8	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1058 Quebec PI NW

Customer Sample Number: 3029367

Date / Time Collected: 7/8/2020 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2007100-012

Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007100-013

Sample Location: 1st Draw 120 18th St SE
Customer Sample Number: 3075936
Date / Time Collected: 7/12/2020 5:44 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-013
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 120 18th St SE
Customer Sample Number: 3075936
Date / Time Collected: 7/12/2020 5:46 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-014
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007100-015

Sample Location: 1st Draw 126 44th St NE #3
Customer Sample Number: 3093948
Date / Time Collected: 7/11/2020 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-015
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 126 44th St NE #3
Customer Sample Number: 3093948
Date / Time Collected: 7/11/2020 8:32 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-016
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007100-005

Sample Location: 1st Draw 1316 Juniper St NW

Customer Sample Number: 3047923

Date / Time Collected: 7/11/2020 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2007100-005

Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1316 Juniper St NW

Customer Sample Number: 3047923

Date / Time Collected: 7/11/2020 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2007100-006

Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007182-025

Sample Location: 1st Draw 1324 Massachusetts Ave SE
Customer Sample Number: 3087111
Date / Time Collected: 7/23/2020 7:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-025
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1324 Massachusetts Ave SE
Customer Sample Number: 3087111
Date / Time Collected: 7/23/2020 8:01 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-026
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007170-001

Sample Location: 1st Draw 1336 QUINCY STREET UNIT 1

Customer Sample Number:

Date / Time Collected: 7/18/2020 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2007170-001

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1336 QUINCY STREET UNIT 1

Customer Sample Number:

Date / Time Collected: 7/18/2020 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2007170-002

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007046-027

Sample Location: 1st Draw 1353 TALBERT TERRACE
Customer Sample Number: 3081792
Date / Time Collected: 7/5/2020 5:20 PM

Customer Program Code: DS
Laboratory Sample Number: 2007046-027
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/22/2020	SBrooks

Sample Location: 2nd Draw 1353 TALBERT TERRACE
Customer Sample Number: 3081792
Date / Time Collected: 7/5/2020 5:26 PM

Customer Program Code: DS
Laboratory Sample Number: 2007046-028
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007182-001

Sample Location: 1st Draw 1621 V St SE
Customer Sample Number: 3088109
Date / Time Collected: 7/14/2020 7:22 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-001
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1621 V St SE
Customer Sample Number: 3088109
Date / Time Collected: 7/14/2020 7:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-002
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007100-017

Sample Location: 1st Draw 1733 Upshur St NW
Customer Sample Number: 3028835
Date / Time Collected: 7/10/2020 6:39 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-017
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1733 Upshur St NW
Customer Sample Number: 3028835
Date / Time Collected: 7/10/2020 6:42 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-018
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007170-011

Sample Location: 1st Draw 1857 Monroe St NW

Customer Sample Number:

Date / Time Collected: 7/20/2020 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2007170-011

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.8	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1857 Monroe St NW

Customer Sample Number:

Date / Time Collected: 7/20/2020 8:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2007170-012

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.0	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007182-015

Sample Location: 1st Draw 1916 35th PI NW
Customer Sample Number: 3009626
Date / Time Collected: 7/21/2020 8:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-015
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1916 35th PI NW
Customer Sample Number: 3009626
Date / Time Collected: 7/21/2020 8:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-016
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007129-003

Sample Location: 1st Draw 203 13th St NE
Customer Sample Number: 3121505
Date / Time Collected: 7/11/2020 6:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-003
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 203 13th St NE
Customer Sample Number: 3121505
Date / Time Collected: 7/11/2020 6:16 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-004
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007182-023

Sample Location: 1st Draw 2237 30th St SE
Customer Sample Number: 3079825
Date / Time Collected: 7/23/2020 6:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-023
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 2237 30th St SE
Customer Sample Number: 3079825
Date / Time Collected: 7/23/2020 6:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-024
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007129-005

Sample Location: 1st Draw 232 Gallatin St. NW
Customer Sample Number: 3025237
Date / Time Collected: 7/12/2020 8:04 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-005
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 232 Gallatin St. NW
Customer Sample Number: 3025237
Date / Time Collected: 7/12/2020 8:04 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-006
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007182-027

Sample Location: 1st Draw 243 12TH ST NE
Customer Sample Number: 3121871
Date / Time Collected: 1/14/2020 6:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2007182-027
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 243 12TH ST NE
Customer Sample Number: 3121871
Date / Time Collected: 1/14/2020 6:05 PM

Customer Program Code: DS
Laboratory Sample Number: 2007182-028
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007182-005

Sample Location: 1st Draw 2527 12th St NW
Customer Sample Number: 3033000
Date / Time Collected: 7/18/2020 2:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-005
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 2527 12th St NW
Customer Sample Number: 3033000
Date / Time Collected: 7/18/2020 2:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-006
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007170-009

Sample Location: 1st Draw 310 Upshur St NW

Customer Sample Number:

Date / Time Collected: 7/20/2020 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2007170-009

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 310 Upshur St NW

Customer Sample Number:

Date / Time Collected: 7/20/2020 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2007170-010

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007182-009

Sample Location: 1st Draw 3111 Rittenhouse St NW
Customer Sample Number: 3038009
Date / Time Collected: 7/19/2020 7:06 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-009
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 3111 Rittenhouse St NW
Customer Sample Number: 3038009
Date / Time Collected: 7/19/2020 7:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-010
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007100-007

Sample Location: 1st Draw 3209 13th St NW
Customer Sample Number: 3031927
Date / Time Collected: 7/10/2020 6:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-007
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 3209 13th St NW
Customer Sample Number: 3031927
Date / Time Collected: 7/10/2020 6:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-008
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007182-019

Sample Location: 1st Draw 3223 KLINGLE RD NW
Customer Sample Number: 3035862
Date / Time Collected: 7/22/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-019
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 3223 KLINGLE RD NW
Customer Sample Number: 3035862
Date / Time Collected: 7/22/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-020
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007129-011

Sample Location: 1st Draw 3236 38th St. NW
Customer Sample Number: 2035191
Date / Time Collected: 7/15/2020 7:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-011
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 3236 38th St. NW
Customer Sample Number: 2035191
Date / Time Collected: 7/15/2020 7:16 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-012
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007182-003

Sample Location: 1st Draw 329 C ST SE # 4
Customer Sample Number: 3071586
Date / Time Collected: 7/17/2020 5:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-003
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 329 C ST SE # 4
Customer Sample Number: 3071586
Date / Time Collected: 7/17/2020 5:48 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-004
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007170-013

Sample Location: 1st Draw 3315 12th ST SE

Customer Sample Number:

Date / Time Collected: 7/20/2020 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2007170-013

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 3315 12th ST SE

Customer Sample Number:

Date / Time Collected: 7/20/2020 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2007170-014

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007100-001

Sample Location: 1st Draw 340 Raleigh St SE
Customer Sample Number: 3070425
Date / Time Collected: 7/4/2020 9:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-001
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 340 Raleigh St SE
Customer Sample Number: 3070425
Date / Time Collected: 7/4/2020 9:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-002
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007170-017

Sample Location: 1st Draw 3428 OLIVER ST NW

Customer Sample Number:

Date / Time Collected: 7/21/2020 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2007170-017

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 3428 OLIVER ST NW

Customer Sample Number:

Date / Time Collected: 7/21/2020 6:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2007170-018

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007182-017

Sample Location: 1st Draw 356 M ST SW
Customer Sample Number:
Date / Time Collected: 7/22/2020 6:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-017
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 356 M ST SW
Customer Sample Number:
Date / Time Collected: 7/22/2020 6:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-018
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007026-023

Sample Location: 1st Draw 4421 3RD ST NW
Customer Sample Number: 3021626
Date / Time Collected: 6/29/2020 7:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-023
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		7/22/2020	SBrooks

Sample Location: 2nd Draw 4421 3RD ST NW
Customer Sample Number: 3021626
Date / Time Collected: 6/29/2020 7:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2007026-024
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007100-003

Sample Location: 1st Draw 4636 Verplank PI NW
Customer Sample Number: 3053725
Date / Time Collected: 7/12/2020 9:21 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-003
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 4636 Verplank PI NW
Customer Sample Number: 3053725
Date / Time Collected: 7/12/2020 9:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2007100-004
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007170-007

Sample Location: 1st Draw 6319 8TH ST NW
Customer Sample Number:
Date / Time Collected: 7/20/2020 7:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2007170-007
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 6319 8TH ST NW
Customer Sample Number:
Date / Time Collected: 7/20/2020 7:23 AM

Customer Program Code: DS
Laboratory Sample Number: 2007170-008
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007129-007

Sample Location: 1st Draw 68 W St. NW
Customer Sample Number: 3018155
Date / Time Collected: 7/13/2020 7:04 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-007
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 68 W St. NW
Customer Sample Number: 3018155
Date / Time Collected: 7/13/2020 7:04 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-008
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007129-009

Sample Location: 1st Draw 834 DELAFIELD PL NW
Customer Sample Number: 3022262
Date / Time Collected: 7/14/2020 6:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-009
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 834 DELAFIELD PL NW
Customer Sample Number: 3022262
Date / Time Collected: 7/14/2020 6:19 AM

Customer Program Code: DS
Laboratory Sample Number: 2007129-010
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007182-007

Sample Location: 1st Draw 925 G ST SE
Customer Sample Number: 3073476
Date / Time Collected: 7/19/2020 5:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-007
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 925 G ST SE
Customer Sample Number: 3073476
Date / Time Collected: 7/19/2020 5:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2007182-008
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2007170-015

Sample Location: 1st Draw 940 T ST NW
Customer Sample Number: 3004209
Date / Time Collected: 7/21/2020 3:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2007170-015
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 940 T ST NW
Customer Sample Number: 3004209
Date / Time Collected: 7/21/2020 3:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2007170-016
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-017

Sample Location: 1st Draw 1014 Spring Rd NW

Customer Sample Number:

Date / Time Collected: 7/19/2020 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-017

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1014 Spring Rd NW

Customer Sample Number:

Date / Time Collected: 7/19/2020 7:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-018

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-021

Sample Location: 1st Draw 109 Rhode Island Ave NW

Customer Sample Number:

Date / Time Collected: 7/23/2020 4:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-021

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 109 Rhode Island Ave NW

Customer Sample Number:

Date / Time Collected: 7/23/2020 5:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-022

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-009

Sample Location: 1st Draw 1152 Neal St NE

Customer Sample Number:

Date / Time Collected: 7/24/2020 5:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-009

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1152 Neal St NE

Customer Sample Number:

Date / Time Collected: 7/24/2020 5:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-010

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008011-007

Sample Location: 1st Draw 1404 30TH ST SE
Customer Sample Number: 3077807
Date / Time Collected: 7/26/2020 7:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-007
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1404 30TH ST SE
Customer Sample Number: 3077807
Date / Time Collected: 7/26/2020 7:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-008
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-011

Sample Location: 1st Draw 1436 Kennedy St. NW

Customer Sample Number:

Date / Time Collected: 7/26/2020 8:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-011

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1436 Kennedy St. NW

Customer Sample Number:

Date / Time Collected: 7/26/2020 8:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-012

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008011-013

Sample Location: 1st Draw 1604 C Street NE
Customer Sample Number: 3101034
Date / Time Collected: 7/28/2020 8:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-013
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1604 C Street NE
Customer Sample Number: 3101034
Date / Time Collected: 7/28/2020 8:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-014
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008011-023

Sample Location: 1st Draw 1605 H ST SE
Customer Sample Number: 3075512
Date / Time Collected: 7/31/2020 7:03 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-023
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1605 H ST SE
Customer Sample Number: 3075512
Date / Time Collected: 7/31/2020 7:06 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-024
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008011-021

Sample Location: 1st Draw 1609 ALLISON ST NW
Customer Sample Number: 3100640
Date / Time Collected: 7/30/2020 6:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-021
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1609 ALLISON ST NW
Customer Sample Number: 3100640
Date / Time Collected: 7/30/2020 6:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-022
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-015

Sample Location: 1st Draw 1712 D St NE
Customer Sample Number:
Date / Time Collected: 7/23/2020 5:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007209-015
Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1712 D St NE
Customer Sample Number:
Date / Time Collected: 7/23/2020 5:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007209-016
Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-001

Sample Location: 1st Draw 2211 38TH ST NW

Customer Sample Number:

Date / Time Collected: 7/27/2020 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-001

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 2211 38TH ST NW

Customer Sample Number:

Date / Time Collected: 7/27/2020 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-002

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008011-019

Sample Location: 1st Draw 320 15TH ST NE
Customer Sample Number: 3100565
Date / Time Collected: 7/29/2020 7:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-019
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 320 15TH ST NE
Customer Sample Number: 3100565
Date / Time Collected: 7/29/2020 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-020
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007225-001

Sample Location: 1st Draw 3206 Dubois PL SE
Customer Sample Number: 3077124
Date / Time Collected: 7/20/2020 6:29 AM

Customer Program Code: DS
Laboratory Sample Number: 2007225-001
Date / Time Received: 7/31/2020 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 3206 Dubois PL SE
Customer Sample Number: 3077124
Date / Time Collected: 7/20/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2007225-002
Date / Time Received: 7/31/2020 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-013

Sample Location: 1st Draw 340 14th St. SE

Customer Sample Number:

Date / Time Collected: 7/26/2020 10:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-013

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 340 14th St. SE

Customer Sample Number:

Date / Time Collected: 7/26/2020 10:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-014

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-007

Sample Location: 1st Draw 4719 4th Street NW

Customer Sample Number:

Date / Time Collected: 7/24/2020 7:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-007

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 4719 4th Street NW

Customer Sample Number:

Date / Time Collected: 7/29/2020 7:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-008

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008011-015

Sample Location: 1st Draw 528 SHERIDAN ST NW
Customer Sample Number: 3027044
Date / Time Collected: 7/28/2020 9:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-015
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 528 SHERIDAN ST NW
Customer Sample Number: 3027044
Date / Time Collected: 7/28/2020 9:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-016
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-019

Sample Location: 1st Draw 530 Roxboro PI NW

Customer Sample Number:

Date / Time Collected: 7/25/2020 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-019

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 530 Roxboro PI NW

Customer Sample Number:

Date / Time Collected: 7/25/2020 7:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2007209-020

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008011-003

Sample Location: 1st Draw 5325 Manning Pl. NW
Customer Sample Number: 3045416
Date / Time Collected: 7/22/2020 11:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-003
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 5325 Manning Pl. NW
Customer Sample Number: 3045416
Date / Time Collected: 7/22/2020 11:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-004
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-003

Sample Location: 1st Draw 5461 Central Ave SE

Customer Sample Number:

Date / Time Collected: 7/23/2020 4:42 PM

Customer Program Code: DS

Laboratory Sample Number: 2007209-003

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 5461 Central Ave SE

Customer Sample Number:

Date / Time Collected: 7/23/2020 4:44 PM

Customer Program Code: DS

Laboratory Sample Number: 2007209-004

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008011-025

Sample Location: 1st Draw 609 14TH ST NE
Customer Sample Number: 3100640
Date / Time Collected: 7/30/2020 8:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-025
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 609 14TH ST NE
Customer Sample Number: 3100640
Date / Time Collected: 7/30/2020 8:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-026
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007209-005

Sample Location: 1st Draw 70 W St NW
Customer Sample Number:
Date / Time Collected: 7/20/2020 6:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2007209-005
Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 70 W St NW
Customer Sample Number:
Date / Time Collected: 7/20/2020 6:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2007209-006
Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008011-011

Sample Location: 1st Draw 7244 15TH PL NW
Customer Sample Number: 3047304
Date / Time Collected: 7/28/2020 6:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-011
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 7244 15TH PL NW
Customer Sample Number: 3047304
Date / Time Collected: 7/28/2020 6:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2008011-012
Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008050-005

Sample Location: 1st Draw 1026 HARVARD ST NW APT. 3
Customer Sample Number: 3032447
Date / Time Collected: 7/27/2020 8:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-005
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1026 HARVARD ST NW APT. 3
Customer Sample Number: 3032447
Date / Time Collected: 7/27/2020 8:18 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-006
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008050-025

Sample Location: 1st Draw 103 8TH ST NE
Customer Sample Number: 3126195
Date / Time Collected: 8/3/2020 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-025
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 103 8TH ST NE
Customer Sample Number: 3126195
Date / Time Collected: 8/3/2020 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-026
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008088-007

Sample Location: 1st Draw 110 5th St NE
Customer Sample Number: 3098601
Date / Time Collected: 8/10/2020 5:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-007
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 110 5th St NE
Customer Sample Number: 3098601
Date / Time Collected: 8/10/2020 5:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-008
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008050-019

Sample Location: 1st Draw 110 TODD PL NE
Customer Sample Number: 3125549
Date / Time Collected: 8/3/2020 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-019
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 110 TODD PL NE
Customer Sample Number: 3125549
Date / Time Collected: 8/3/2020 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-020
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008221-001

Sample Location: 1st Draw 122 11th St NE
Customer Sample Number: 3120903
Date / Time Collected: 8/26/2020 6:21 AM

Customer Program Code: DS
Laboratory Sample Number: 2008221-001
Date / Time Received: 8/28/2020 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 122 11th St NE
Customer Sample Number: 3120903
Date / Time Collected: 8/26/2020 6:22 AM

Customer Program Code: DS
Laboratory Sample Number: 2008221-002
Date / Time Received: 8/28/2020 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008159-005

Sample Location: 1st Draw 1353 BITTENHOUSE ST NW
Customer Sample Number: 3048660
Date / Time Collected: 8/18/2020 7:31 AM

Customer Program Code: DS
Laboratory Sample Number: 2008159-005
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1353 BITTENHOUSE ST NW
Customer Sample Number: 3048660
Date / Time Collected: 8/18/2020 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2008159-006
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008159-001

Sample Location: 1st Draw 14 R STREET NE
Customer Sample Number: 3102958
Date / Time Collected: 8/14/2020 7:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2008159-001
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 14 R STREET NE
Customer Sample Number: 3102958
Date / Time Collected: 8/14/2020 7:52 AM

Customer Program Code: DS
Laboratory Sample Number: 2008159-002
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008206-003

Sample Location: 1st Draw 1412 Meridian PI NW

Customer Sample Number: 3053832

Date / Time Collected: 8/24/2020 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2008206-003

Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 1412 Meridian PI NW

Customer Sample Number: 3053832

Date / Time Collected: 8/24/2020 7:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2008206-004

Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008117-003

Sample Location: 1st Draw 1425 SWANN ST NW

Customer Sample Number: 3145234

Date / Time Collected: 8/12/2020 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2008117-003

Date / Time Received: 8/14/2020 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1425 SWANN ST NW

Customer Sample Number: 3145234

Date / Time Collected: 8/12/2020 7:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2008117-004

Date / Time Received: 8/14/2020 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008236-003

Sample Location: 1st Draw 1430 Whittier St. NW
Customer Sample Number: 3058775
Date / Time Collected: 8/22/2020 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-003
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 1430 Whittier St. NW
Customer Sample Number: 3058775
Date / Time Collected: 8/22/2020 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-004
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008050-013

Sample Location: 1st Draw 1466 BANGOR ST SE
Customer Sample Number: 3081417
Date / Time Collected: 7/31/2020 8:13 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-013
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1466 BANGOR ST SE
Customer Sample Number: 3081417
Date / Time Collected: 7/31/2020 8:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-014
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008088-011

Sample Location: 1st Draw 1508 5th St NW
Customer Sample Number: 305592
Date / Time Collected: 8/9/2020 7:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-011
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1508 5th St NW
Customer Sample Number: 305592
Date / Time Collected: 8/9/2020 7:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-012
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008107-001

Sample Location: 1st Draw 1602 D St SE
Customer Sample Number: 3075729
Date / Time Collected: 8/10/2020 8:33 AM

Customer Program Code: DS
Laboratory Sample Number: 2008107-001
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1602 D St SE
Customer Sample Number: 3075729
Date / Time Collected: 8/10/2020 8:37 AM

Customer Program Code: DS
Laboratory Sample Number: 2008107-002
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008206-005

Sample Location: 1st Draw 1610 Tuckerman St NW
Customer Sample Number: 3147512
Date / Time Collected: 8/23/2020 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-005
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 1610 Tuckerman St NW
Customer Sample Number: 3147512
Date / Time Collected: 8/23/2020 6:03 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-006
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008087-009

Sample Location: 1st Draw 1611 Shepherd St NW
Customer Sample Number: 3028900
Date / Time Collected: 8/6/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2008087-009
Date / Time Received: 8/11/2020 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1611 Shepherd St NW
Customer Sample Number: 3028900
Date / Time Collected: 8/6/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2008087-010
Date / Time Received: 8/11/2020 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008236-013

Sample Location: 1st Draw 1612 5th St. NW #1
Customer Sample Number: 3005574
Date / Time Collected: 8/28/2020 8:07 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-013
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 1612 5th St. NW #1
Customer Sample Number: 3005574
Date / Time Collected: 8/28/2020 8:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-014
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008088-005

Sample Location: 1st Draw 1633 W St SE
Customer Sample Number: 3081043
Date / Time Collected: 8/9/2020 8:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2008088-005
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1633 W St SE
Customer Sample Number: 3081043
Date / Time Collected: 8/9/2020 8:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2008088-006
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.1	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008088-001

Sample Location: 1st Draw 1701 Upsher St NW
Customer Sample Number: 3145387
Date / Time Collected: 8/9/2020 4:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-001
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1701 Upsher St NW
Customer Sample Number: 3145387
Date / Time Collected: 8/9/2020 4:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-002
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008050-007

Sample Location: 1st Draw 1708 LANIER PL NW

Customer Sample Number:

Date / Time Collected: 7/30/2020 7:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2008050-007

Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1708 LANIER PL NW

Customer Sample Number:

Date / Time Collected: 7/30/2020 7:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2008050-008

Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008236-005

Sample Location: 1st Draw 1756 Portal Dr. NW
Customer Sample Number: 3059439
Date / Time Collected: 8/25/2020 6:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-005
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 1756 Portal Dr. NW
Customer Sample Number: 3059439
Date / Time Collected: 8/25/2020 6:13 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-006
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008236-011

Sample Location: 1st Draw 1759 Lanier PI NW
Customer Sample Number: 3034790
Date / Time Collected: 8/27/2020 5:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-011
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 1759 Lanier PI NW
Customer Sample Number: 3034790
Date / Time Collected: 8/27/2020 5:52 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-012
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008050-015

Sample Location: 1st Draw 1838 INGLESIDE TER NW
Customer Sample Number: 3030995
Date / Time Collected: 8/2/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-015
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1838 INGLESIDE TER NW
Customer Sample Number: 3030995
Date / Time Collected: 8/2/2020 7:03 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-016
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008050-009

Sample Location: 1st Draw 2023 37TH ST NW
Customer Sample Number: 3009904
Date / Time Collected: 7/31/2020 9:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-009
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 2023 37TH ST NW
Customer Sample Number: 3009904
Date / Time Collected: 7/31/2020 9:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-010
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008088-003

Sample Location: 1st Draw 227 14th Place NE
Customer Sample Number: 3100392
Date / Time Collected: 8/8/2020 11:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-003
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 227 14th Place NE
Customer Sample Number: 3100392
Date / Time Collected: 8/8/2020 11:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-004
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008050-023

Sample Location: 1st Draw 2416 OTIS ST NE
Customer Sample Number: 3107030
Date / Time Collected: 8/3/2020 6:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-023
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 2416 OTIS ST NE
Customer Sample Number: 3107030
Date / Time Collected: 8/3/2020 6:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-024
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008127-003

Sample Location: 1st Draw 2510 41 ST NW
Customer Sample Number: 3013189
Date / Time Collected: 8/13/2020 5:38 AM

Customer Program Code: DS
Laboratory Sample Number: 2008127-003
Date / Time Received: 8/17/2020 8:23:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 2510 41 ST NW
Customer Sample Number: 3013189
Date / Time Collected: 8/13/2020 5:44 AM

Customer Program Code: DS
Laboratory Sample Number: 2008127-004
Date / Time Received: 8/17/2020 8:23:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008214-001

Sample Location: 1st Draw 269 56th St NE
Customer Sample Number: 3109831
Date / Time Collected: 8/18/2020 8:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2008214-001
Date / Time Received: 8/27/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 269 56th St NE
Customer Sample Number: 3109831
Date / Time Collected: 8/18/2020 8:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2008214-002
Date / Time Received: 8/27/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008221-003

Sample Location: 1st Draw 30 6th St SE
Customer Sample Number: 3072712
Date / Time Collected: 8/25/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008221-003
Date / Time Received: 8/28/2020 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 30 6th St SE
Customer Sample Number: 3072712
Date / Time Collected: 8/25/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008221-004
Date / Time Received: 8/28/2020 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008050-003

Sample Location: 1st Draw 3015 25TH STREET NE
Customer Sample Number: 3106908
Date / Time Collected: 7/3/2020 7:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-003
Date / Time Received: 8/7/2020 8:21:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/28/2020	SBrooks

Sample Location: 2nd Draw 3015 25TH STREET NE
Customer Sample Number: 3106908
Date / Time Collected: 7/3/2020 7:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-004
Date / Time Received: 8/7/2020 8:21:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008206-009

Sample Location: 1st Draw 3066 Porter St NW
Customer Sample Number: 3036320
Date / Time Collected: 8/23/2020 7:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-009
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 3066 Porter St NW
Customer Sample Number: 3036320
Date / Time Collected: 8/23/2020 7:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-010
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008214-005

Sample Location: 1st Draw 315 V St NW
Customer Sample Number: 3052260
Date / Time Collected: 8/12/2020 8:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2008214-005
Date / Time Received: 8/27/2020 8:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	9/1/2020	SBrooks

Sample Location: 2nd Draw 315 V St NW
Customer Sample Number: 3052260
Date / Time Collected: 8/12/2020 8:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2008214-006
Date / Time Received: 8/27/2020 8:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008117-001

Sample Location: 1st Draw 3200 44th Street NW
Customer Sample Number: 3044387
Date / Time Collected: 8/12/2020 6:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2008117-001
Date / Time Received: 8/14/2020 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 3200 44th Street NW
Customer Sample Number: 3044387
Date / Time Collected: 8/12/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008117-002
Date / Time Received: 8/14/2020 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008060-001

Sample Location: 1st Draw 3310 Dent Place NW

Customer Sample Number: 3009312

Date / Time Collected: 8/4/2020 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2008060-001

Date / Time Received: 8/10/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		8/27/2020	SBrooks

Sample Location: 2nd Draw 3310 Dent Place NW

Customer Sample Number: 3009312

Date / Time Collected: 8/4/2020 6:04 PM

Customer Program Code: DS

Laboratory Sample Number: 2008060-002

Date / Time Received: 8/10/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		8/27/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008087-007

Sample Location: 1st Draw 3317 Cleveland Ave NW
Customer Sample Number: 3035442
Date / Time Collected: 8/7/2020 8:41 AM

Customer Program Code: DS
Laboratory Sample Number: 2008087-007
Date / Time Received: 8/11/2020 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 3317 Cleveland Ave NW
Customer Sample Number: 3035442
Date / Time Collected: 8/7/2020 8:48 AM

Customer Program Code: DS
Laboratory Sample Number: 2008087-008
Date / Time Received: 8/11/2020 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008088-009

Sample Location: 1st Draw 3815 Veazey St NW
Customer Sample Number: 3041115
Date / Time Collected: 8/10/2020 9:27 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-009
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 3815 Veazey St NW
Customer Sample Number: 3041115
Date / Time Collected: 8/10/2020 9:29 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-010
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2007100-009

Sample Location: 1st Draw 4008 Illinois Ave NW

Customer Sample Number: 3051038

Date / Time Collected: 7/13/2020 5:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2007100-009

Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		9/3/2020	SBrooks

Sample Location: 2nd Draw 4008 Illinois Ave NW

Customer Sample Number: 3051038

Date / Time Collected: 7/13/2020 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2007100-010

Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008206-007

Sample Location: 1st Draw 4319 Ellicott St NW
Customer Sample Number: 3042238
Date / Time Collected: 8/24/2020 9:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-007
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 4319 Ellicott St NW
Customer Sample Number: 3042238
Date / Time Collected: 8/24/2020 9:31 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-008
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008107-007

Sample Location: 1st Draw 436 Kentucky Ave SE
Customer Sample Number: 3074556
Date / Time Collected: 8/11/2020 8:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2008107-007
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 436 Kentucky Ave SE
Customer Sample Number: 3074556
Date / Time Collected: 8/11/2020 8:47 AM

Customer Program Code: DS
Laboratory Sample Number: 2008107-008
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008236-007

Sample Location: 1st Draw 4409 Dexter St. NW

Customer Sample Number: 3055138

Date / Time Collected: 8/25/2020 6:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2008236-007

Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 4409 Dexter St. NW

Customer Sample Number: 3055138

Date / Time Collected: 8/25/2020 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2008236-008

Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008236-001

Sample Location: 1st Draw 449 19th St. NE
Customer Sample Number: 3101293
Date / Time Collected: 8/21/2020 6:15 PM

Customer Program Code: DS
Laboratory Sample Number: 2008236-001
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 449 19th St. NE
Customer Sample Number: 3101293
Date / Time Collected: 8/21/2020 6:21 PM

Customer Program Code: DS
Laboratory Sample Number: 2008236-002
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008088-013

Sample Location: 1st Draw 449 Luray PI NW
Customer Sample Number: 3019868
Date / Time Collected: 8/8/2020 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-013
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 449 Luray PI NW
Customer Sample Number: 3019868
Date / Time Collected: 8/8/2020 8:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2008088-014
Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008149-005

Sample Location: 1st Draw 4720 BASS PL SE

Customer Sample Number:

Date / Time Collected: 8/16/2020 9:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2008149-005

Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 4720 BASS PL SE

Customer Sample Number:

Date / Time Collected: 8/16/2020 9:56 PM

Customer Program Code: DS

Laboratory Sample Number: 2008149-006

Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008206-011

Sample Location: 1st Draw 4835 Reservoir Rd NW
Customer Sample Number: 3045143
Date / Time Collected: 8/24/2020 7:32 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-011
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 4835 Reservoir Rd NW
Customer Sample Number: 3045143
Date / Time Collected: 8/24/2020 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-012
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008149-009

Sample Location: 1st Draw 5052 12TH ST NE

Customer Sample Number:

Date / Time Collected: 8/13/2020 12:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2008149-009

Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 5052 12TH ST NE

Customer Sample Number:

Date / Time Collected: 8/13/2020 1:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2008149-010

Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008159-003

Sample Location: 1st Draw 5115 Chevy Chase Pky, NW
Customer Sample Number: 3040535
Date / Time Collected: 8/18/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008159-003
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 5115 Chevy Chase Pky, NW
Customer Sample Number: 3040535
Date / Time Collected: 8/18/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008159-004
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008107-003

Sample Location: 1st Draw 523 Quackenbos St NW
Customer Sample Number: 3026752
Date / Time Collected: 8/9/2020 4:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2008107-003
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 523 Quackenbos St NW
Customer Sample Number: 3026752
Date / Time Collected: 8/9/2020 4:05 PM

Customer Program Code: DS
Laboratory Sample Number: 2008107-004
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008236-009

Sample Location: 1st Draw 5407 2nd St. NW
Customer Sample Number: 3025637
Date / Time Collected: 8/25/2020 8:14 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-009
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 5407 2nd St. NW
Customer Sample Number: 3025637
Date / Time Collected: 8/25/2020 8:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2008236-010
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008206-001

Sample Location: 1st Draw 5411 1st St NW
Customer Sample Number: 3062343
Date / Time Collected: 8/19/2020 10:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-001
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 5411 1st St NW
Customer Sample Number: 3062343
Date / Time Collected: 8/19/2020 10:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2008206-002
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008214-003

Sample Location: 1st Draw 604 Hamilton St NW

Customer Sample Number: 3023119

Date / Time Collected: 8/24/2020 7:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2008214-003

Date / Time Received: 8/27/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 604 Hamilton St NW

Customer Sample Number: 3023119

Date / Time Collected: 8/24/2020 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2008214-004

Date / Time Received: 8/27/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008149-007

Sample Location: 1st Draw 617 FARRAGUT ST NW
Customer Sample Number:
Date / Time Collected: 8/17/2020 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2008149-007
Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 617 FARRAGUT ST NW
Customer Sample Number:
Date / Time Collected: 8/17/2020 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2008149-008
Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2008050-001

Sample Location: 1st Draw 6819 LAUREL STREET NW
Customer Sample Number: 3046510
Date / Time Collected: 7/2/2020 7:01 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-001
Date / Time Received: 8/7/2020 8:21:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	8/28/2020	SBrooks

Sample Location: 2nd Draw 6819 LAUREL STREET NW
Customer Sample Number: 3046510
Date / Time Collected: 7/2/2020 7:02 AM

Customer Program Code: DS
Laboratory Sample Number: 2008050-002
Date / Time Received: 8/7/2020 8:21:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008107-005

Sample Location: 1st Draw 729 18th St NE
Customer Sample Number: 3112011
Date / Time Collected: 8/11/2020 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2008107-005
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 729 18th St NE
Customer Sample Number: 3112011
Date / Time Collected: 8/11/2020 6:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2008107-006
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2008127-001

Sample Location: 1st Draw 909 CRITTENDEN ST NW
Customer Sample Number: 3022309
Date / Time Collected: 8/11/2020 5:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2008127-001
Date / Time Received: 8/17/2020 8:23:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 909 CRITTENDEN ST NW
Customer Sample Number: 3022309
Date / Time Collected: 8/11/2020 5:53 AM

Customer Program Code: DS
Laboratory Sample Number: 2008127-002
Date / Time Received: 8/17/2020 8:23:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009046-007

Sample Location: 1st Draw 1514 NEWTON ST NE
Customer Sample Number: 3104796
Date / Time Collected: 9/1/2020 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-007
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 1514 NEWTON ST NE
Customer Sample Number: 3104796
Date / Time Collected: 9/1/2020 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-008
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009046-001

Sample Location: 1st Draw 1535 15TH ST NW
Customer Sample Number: 3002368
Date / Time Collected: 8/30/2020 8:28 PM

Customer Program Code: DS
Laboratory Sample Number: 2009046-001
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 1535 15TH ST NW
Customer Sample Number: 3002368
Date / Time Collected: 8/30/2020 8:31 PM

Customer Program Code: DS
Laboratory Sample Number: 2009046-002
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009046-009

Sample Location: 1st Draw 1832 VARNUM ST NE
Customer Sample Number: 3105638
Date / Time Collected: 9/2/2020 6:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-009
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 1832 VARNUM ST NE
Customer Sample Number: 3105638
Date / Time Collected: 9/2/2020 6:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-010
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009046-005

Sample Location: 1st Draw 1844 PARK RD NW
Customer Sample Number: 3031510
Date / Time Collected: 9/1/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-005
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 1844 PARK RD NW
Customer Sample Number: 3031510
Date / Time Collected: 9/1/2020 6:33 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-006
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009046-013

Sample Location: 1st Draw 3901 ARGYLE TER. NW
Customer Sample Number: 3055757
Date / Time Collected: 9/2/2020 9:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-013
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.6	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 3901 ARGYLE TER. NW
Customer Sample Number: 3055757
Date / Time Collected: 9/2/2020 9:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-014
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009046-003

Sample Location: 1st Draw 4500 CHESAPEAKE ST NW
Customer Sample Number: 3043587
Date / Time Collected: 9/1/2020 6:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-003
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 4500 CHESAPEAKE ST NW
Customer Sample Number: 3043587
Date / Time Collected: 9/1/2020 6:26 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-004
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009016-001

Sample Location: 1st Draw 6155 31ST PLACE NW
Customer Sample Number: 3037947
Date / Time Collected: 8/31/2020 7:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2009016-001
Date / Time Received: 9/2/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 6155 31ST PLACE NW
Customer Sample Number: 3037947
Date / Time Collected: 8/31/2020 7:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2009016-002
Date / Time Received: 9/2/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009046-011

Sample Location: 1st Draw 714 PEABODY ST NW
Customer Sample Number: 3024512
Date / Time Collected: 9/2/2020 6:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-011
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 714 PEABODY ST NW
Customer Sample Number: 3024512
Date / Time Collected: 9/2/2020 6:37 AM

Customer Program Code: DS
Laboratory Sample Number: 2009046-012
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009132-007

Sample Location: 1st Draw 1100 CONSTITUTION AVE NE
Customer Sample Number: 3121668
Date / Time Collected: 9/12/2020 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-007
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1100 CONSTITUTION AVE NE
Customer Sample Number: 3121668
Date / Time Collected: 9/12/2020 8:01 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-008
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009078-013

Sample Location: 1st Draw 1306 34th St NW
Customer Sample Number: 3008335
Date / Time Collected: 9/8/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2009078-013
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1306 34th St NW
Customer Sample Number: 3008335
Date / Time Collected: 9/8/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2009078-014
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009092-019

Sample Location: 1st Draw 1312 S CAROLINE AVE
Customer Sample Number: 3086992
Date / Time Collected: 9/10/2020 2:33 AM

Customer Program Code: DS
Laboratory Sample Number: 2009092-019
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1312 S CAROLINE AVE
Customer Sample Number: 3086992
Date / Time Collected: 9/10/2020 2:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2009092-020
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009142-003

Sample Location: 1st Draw 1334 KALMIA RD NW

Customer Sample Number: 3047487

Date / Time Collected: 9/16/2020 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2009142-003

Date / Time Received: 9/18/2020 8:17:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1334 KALMIA RD NW

Customer Sample Number: 3047487

Date / Time Collected: 9/16/2020 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2009142-004

Date / Time Received: 9/18/2020 8:17:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009078-015

Sample Location: 1st Draw 1363 Perry PI NW

Customer Sample Number:

Date / Time Collected: 9/2/2020 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2009078-015

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1363 Perry PI NW

Customer Sample Number:

Date / Time Collected: 9/2/2020 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2009078-016

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009078-001

Sample Location: 1st Draw 1504 Taylor St NE
Customer Sample Number: 3114961
Date / Time Collected: 9/2/2020 3:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2009078-001
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1504 Taylor St NE
Customer Sample Number: 3114961
Date / Time Collected: 9/2/2020 3:34 PM

Customer Program Code: DS
Laboratory Sample Number: 2009078-002
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009078-003

Sample Location: 1st Draw 1616 Missouri Ave NW
Customer Sample Number: 3048318
Date / Time Collected: 9/3/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2009078-003
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1616 Missouri Ave NW
Customer Sample Number: 3048318
Date / Time Collected: 9/3/2020 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2009078-004
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009132-015

Sample Location: 1st Draw 1634 E STREET SE
Customer Sample Number: 3075435
Date / Time Collected: 9/14/2020 6:54 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-015
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1634 E STREET SE
Customer Sample Number: 3075435
Date / Time Collected: 9/14/2020 6:57 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-016
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009078-005

Sample Location: 1st Draw 1703 Harvard St NW

Customer Sample Number: 3034010

Date / Time Collected: 9/6/2020 12:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2009078-005

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1703 Harvard St NW

Customer Sample Number: 3034010

Date / Time Collected: 9/6/2020 12:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2009078-006

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009078-011

Sample Location: 1st Draw 1706 Kilbourne PI NW

Customer Sample Number: 3031689

Date / Time Collected: 9/7/2020 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2009078-011

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1706 Kilbourne PI NW

Customer Sample Number: 3031689

Date / Time Collected: 9/7/2020 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2009078-012

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009132-001

Sample Location: 1st Draw 1713 OTIS St NE
Customer Sample Number: 3105395
Date / Time Collected: 9/9/2020 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-001
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1713 OTIS St NE
Customer Sample Number: 3105395
Date / Time Collected: 9/9/2020 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-002
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009132-009

Sample Location: 1st Draw 2011 37TH ST NW
Customer Sample Number: 3009910
Date / Time Collected: 9/12/2020 3:08 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-009
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 2011 37TH ST NW
Customer Sample Number: 3009910
Date / Time Collected: 9/12/2020 3:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-010
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	168	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009092-007

Sample Location: 1st Draw 211 Cromwell Ter NE

Customer Sample Number: 3122079

Date / Time Collected: 9/9/2020 5:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2009092-007

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 211 Cromwell Ter NE

Customer Sample Number: 3122079

Date / Time Collected: 9/9/2020 5:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2009092-008

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009078-009

Sample Location: 1st Draw 2112 19th St NW Apt 5
Customer Sample Number: 3034456
Date / Time Collected: 9/6/2020 3:50 PM

Customer Program Code: DS
Laboratory Sample Number: 2009078-009
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 2112 19th St NW Apt 5
Customer Sample Number: 3034456
Date / Time Collected: 9/6/2020 3:51 PM

Customer Program Code: DS
Laboratory Sample Number: 2009078-010
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009132-021

Sample Location: 1st Draw 320 NICHOLSON ST NW
Customer Sample Number: 3024866
Date / Time Collected: 9/15/2020 8:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-021
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 320 NICHOLSON ST NW
Customer Sample Number: 3024866
Date / Time Collected: 9/15/2020 8:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-022
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009106-003

Sample Location: 1st Draw 432 MANOR PL NW #1

Customer Sample Number:

Date / Time Collected: 9/9/2020 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2009106-003

Date / Time Received: 9/15/2020 7:37:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 432 MANOR PL NW #1

Customer Sample Number:

Date / Time Collected: 9/9/2020 7:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2009106-004

Date / Time Received: 9/15/2020 7:37:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009092-001

Sample Location: 1st Draw 4535 NEBRASKA AVE NW
Customer Sample Number: 3055497
Date / Time Collected: 9/7/2020 9:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2009092-001
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 4535 NEBRASKA AVE NW
Customer Sample Number: 3055497
Date / Time Collected: 9/7/2020 9:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2009092-002
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009078-007

Sample Location: 1st Draw 4619 29th PI NW

Customer Sample Number:

Date / Time Collected: 9/1/2020 6:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2009078-007

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 4619 29th PI NW

Customer Sample Number:

Date / Time Collected: 9/1/2020 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2009078-008

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009132-003

Sample Location: 1st Draw 51 P ST NW
Customer Sample Number: 3006872
Date / Time Collected: 9/9/2020 8:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-003
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 51 P ST NW
Customer Sample Number: 3006872
Date / Time Collected: 9/9/2020 8:57 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-004
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009142-001

Sample Location: 1st Draw 5109 4TH ST NW
Customer Sample Number: 3023416
Date / Time Collected: 9/13/2020 10:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2009142-001
Date / Time Received: 9/18/2020 8:17:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 5109 4TH ST NW
Customer Sample Number: 3023416
Date / Time Collected: 9/13/2020 10:32 AM

Customer Program Code: DS
Laboratory Sample Number: 2009142-002
Date / Time Received: 9/18/2020 8:17:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009106-001

Sample Location: 1st Draw 5329 42ND ST NW

Customer Sample Number:

Date / Time Collected: 9/3/2020 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2009106-001

Date / Time Received: 9/15/2020 7:37:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 5329 42ND ST NW

Customer Sample Number:

Date / Time Collected: 9/3/2020 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2009106-002

Date / Time Received: 9/15/2020 7:37:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009142-007

Sample Location: 1st Draw 618 G ST SE
Customer Sample Number: 3071186
Date / Time Collected: 9/16/2020 12:43 PM

Customer Program Code: DS
Laboratory Sample Number: 2009142-007
Date / Time Received: 9/18/2020 8:17:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 618 G ST SE
Customer Sample Number: 3071186
Date / Time Collected: 9/16/2020 12:43 PM

Customer Program Code: DS
Laboratory Sample Number: 2009142-008
Date / Time Received: 9/18/2020 8:17:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009092-023

Sample Location: 1st Draw 652 G St NE
Customer Sample Number: 3127387
Date / Time Collected: 9/10/2020 12:55 PM

Customer Program Code: DS
Laboratory Sample Number: 2009092-023
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 652 G St NE
Customer Sample Number: 3127387
Date / Time Collected: 9/10/2020 1:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2009092-024
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010047-001

Sample Location: 1st Draw 100 4TH St SE
Customer Sample Number: 3071719
Date / Time Collected: 10/5/2020 12:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2010047-001
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/8/2020	SBrooks

Sample Location: 2nd Draw 100 4TH St SE
Customer Sample Number: 3071719
Date / Time Collected: 10/5/2020 12:31 PM

Customer Program Code: DS
Laboratory Sample Number: 2010047-002
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009152-001

Sample Location: 1st Draw 1018 5TH STREET NE
Customer Sample Number: 3098466
Date / Time Collected: 9/16/2020 7:21 AM

Customer Program Code: DS
Laboratory Sample Number: 2009152-001
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 1018 5TH STREET NE
Customer Sample Number: 3098466
Date / Time Collected: 9/16/2020 7:23 AM

Customer Program Code: DS
Laboratory Sample Number: 2009152-002
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010047-003

Sample Location: 1st Draw 1156 Abbey PI NE
Customer Sample Number: 3098339
Date / Time Collected: 10/5/2020 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2010047-003
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/8/2020	SBrooks

Sample Location: 2nd Draw 1156 Abbey PI NE
Customer Sample Number: 3098339
Date / Time Collected: 10/5/2020 8:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2010047-004
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2010047-005

Sample Location: 1st Draw 122 12TH St NE
Customer Sample Number: 3099497
Date / Time Collected: 10/3/2020 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010047-005
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/8/2020	SBrooks

Sample Location: 2nd Draw 122 12TH St NE
Customer Sample Number: 3099497
Date / Time Collected: 10/3/2020 6:01 AM

Customer Program Code: DS
Laboratory Sample Number: 2010047-006
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010025-011

Sample Location: 1st Draw 1222 Hamilton St NW

Customer Sample Number: 3049889

Date / Time Collected: 9/29/2020 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2010025-011

Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/8/2020	SBrooks

Sample Location: 2nd Draw 1222 Hamilton St NW

Customer Sample Number: 3049889

Date / Time Collected: 9/29/2020 6:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2010025-012

Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2010024-001

Sample Location: 1st Draw 1341 Parkwood PI NW
Customer Sample Number: 3030143
Date / Time Collected: 9/25/2020 8:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2010024-001
Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 1341 Parkwood PI NW
Customer Sample Number: 3030143
Date / Time Collected: 9/25/2020 8:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2010024-002
Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010025-001

Sample Location: 1st Draw 1351 JEFFERSON ST NW
Customer Sample Number: 3049333
Date / Time Collected: 9/30/2020 4:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2010025-001
Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/8/2020	SBrooks

Sample Location: 2nd Draw 1351 JEFFERSON ST NW
Customer Sample Number: 3049333
Date / Time Collected: 9/30/2020 4:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2010025-002
Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010024-005

Sample Location: 1st Draw 1616 Corcoran St NW

Customer Sample Number: 3001768

Date / Time Collected: 9/30/2020 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2010024-005

Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 1616 Corcoran St NW

Customer Sample Number: 3001768

Date / Time Collected: 9/30/2020 7:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2010024-006

Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009180-001

Sample Location: 1st Draw 1628 Trinidad Ave NE, Unit #1

Customer Sample Number:

Date / Time Collected: 9/21/2020 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2009180-001

Date / Time Received: 9/23/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 1628 Trinidad Ave NE, Unit #1

Customer Sample Number:

Date / Time Collected: 9/21/2020 5:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2009180-002

Date / Time Received: 9/23/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009229-003

Sample Location: 1st Draw 1831 NORTH CAPITAL ST NE
Customer Sample Number: 3125167
Date / Time Collected: 9/27/2020 5:20 PM

Customer Program Code: DS
Laboratory Sample Number: 2009229-003
Date / Time Received: 9/30/2020 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 1831 NORTH CAPITAL ST NE
Customer Sample Number: 3125167
Date / Time Collected: 9/27/2020 5:25 PM

Customer Program Code: DS
Laboratory Sample Number: 2009229-004
Date / Time Received: 9/30/2020 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2009229-005

Sample Location: 1st Draw 2058 37TH ST NW
Customer Sample Number: 3009941
Date / Time Collected: 9/28/2020 8:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2009229-005
Date / Time Received: 9/30/2020 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 2058 37TH ST NW
Customer Sample Number: 3009941
Date / Time Collected: 9/28/2020 8:13 AM

Customer Program Code: DS
Laboratory Sample Number: 2009229-006
Date / Time Received: 9/30/2020 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2010007-005

Sample Location: 1st Draw 22 R ST NE
Customer Sample Number: 3125121
Date / Time Collected: 9/29/2020 7:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2010007-005
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 22 R ST NE
Customer Sample Number: 3125121
Date / Time Collected: 9/29/2020 7:27 AM

Customer Program Code: DS
Laboratory Sample Number: 2010007-006
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009202-001

Sample Location: 1st Draw 2224 13th St NE
Customer Sample Number: 3114947
Date / Time Collected: 9/23/2020 3:48 PM

Customer Program Code: DS
Laboratory Sample Number: 2009202-001
Date / Time Received: 9/25/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 2224 13th St NE
Customer Sample Number: 3114947
Date / Time Collected: 9/23/2020 3:49 PM

Customer Program Code: DS
Laboratory Sample Number: 2009202-002
Date / Time Received: 9/25/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009221-001

Sample Location: 1st Draw 2245 5TH STREET SE

Customer Sample Number: 3071820

Date / Time Collected: 9/5/2020 7:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2009221-001

Date / Time Received: 9/29/2020 11:29:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/7/2020	SBrooks

Sample Location: 2nd Draw 2245 5TH STREET SE

Customer Sample Number: 3071820

Date / Time Collected: 9/5/2020 7:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2009221-002

Date / Time Received: 9/29/2020 11:29:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009166-001

Sample Location: 1st Draw 3224 Oliver St NW
Customer Sample Number: 3038897
Date / Time Collected: 9/18/2020 7:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2009166-001
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 3224 Oliver St NW
Customer Sample Number: 3038897
Date / Time Collected: 9/18/2020 7:29 AM

Customer Program Code: DS
Laboratory Sample Number: 2009166-002
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009180-003

Sample Location: 1st Draw 3321 McKinley St NW

Customer Sample Number: 3039478

Date / Time Collected: 9/4/2020 7:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2009180-003

Date / Time Received: 9/23/2020 8:29:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/7/2020	SBrooks

Sample Location: 2nd Draw 3321 McKinley St NW

Customer Sample Number: 3039478

Date / Time Collected: 9/4/2020 7:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2009180-004

Date / Time Received: 9/23/2020 8:29:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2009202-003

Sample Location: 1st Draw 3609 35th St. NW
Customer Sample Number: 3041810
Date / Time Collected: 9/24/2020 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2009202-003
Date / Time Received: 9/25/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 3609 35th St. NW
Customer Sample Number: 3041810
Date / Time Collected: 9/24/2020 7:32 AM

Customer Program Code: DS
Laboratory Sample Number: 2009202-004
Date / Time Received: 9/25/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009221-005

Sample Location: 1st Draw 3712 R ST NW
Customer Sample Number: 3010632
Date / Time Collected: 9/25/2020 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2009221-005
Date / Time Received: 9/29/2020 11:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 3712 R ST NW
Customer Sample Number: 3010632
Date / Time Collected: 9/25/2020 8:02 AM

Customer Program Code: DS
Laboratory Sample Number: 2009221-006
Date / Time Received: 9/29/2020 11:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2010014-001

Sample Location: 1st Draw 3817 T ST NW
Customer Sample Number: 3010775
Date / Time Collected: 9/20/2020 7:28 AM

Customer Program Code: DS
Laboratory Sample Number: 2010014-001
Date / Time Received: 10/2/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 3817 T ST NW
Customer Sample Number: 3010775
Date / Time Collected: 9/20/2020 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2010014-002
Date / Time Received: 10/2/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009229-001

Sample Location: 1st Draw 3823 VAN NESS ST NW
Customer Sample Number: 3042723
Date / Time Collected: 9/27/2020 8:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2009229-001
Date / Time Received: 9/30/2020 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 3823 VAN NESS ST NW
Customer Sample Number: 3042723
Date / Time Collected: 9/27/2020 8:29 AM

Customer Program Code: DS
Laboratory Sample Number: 2009229-002
Date / Time Received: 9/30/2020 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009221-003

Sample Location: 1st Draw 4104 20TH ST NE
Customer Sample Number: 3105533
Date / Time Collected: 9/23/2020 6:47 AM

Customer Program Code: DS
Laboratory Sample Number: 2009221-003
Date / Time Received: 9/29/2020 11:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 4104 20TH ST NE
Customer Sample Number: 3105533
Date / Time Collected: 9/23/2020 6:51 AM

Customer Program Code: DS
Laboratory Sample Number: 2009221-004
Date / Time Received: 9/29/2020 11:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2010007-001

Sample Location: 1st Draw 431 JEFFERSON ST NW
Customer Sample Number: 3024246
Date / Time Collected: 9/22/2020 7:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2010007-001
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 431 JEFFERSON ST NW
Customer Sample Number: 3024246
Date / Time Collected: 9/22/2020 7:29 AM

Customer Program Code: DS
Laboratory Sample Number: 2010007-002
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009221-009

Sample Location: 1st Draw 6824 32 ND ST NW
Customer Sample Number: 3058645
Date / Time Collected: 9/27/2020 7:32 AM

Customer Program Code: DS
Laboratory Sample Number: 2009221-009
Date / Time Received: 9/29/2020 11:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 6824 32 ND ST NW
Customer Sample Number: 3058645
Date / Time Collected: 9/27/2020 7:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2009221-010
Date / Time Received: 9/29/2020 11:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010024-003

Sample Location: 1st Draw 732 Kenyon St NW

Customer Sample Number:

Date / Time Collected: 10/1/2020 6:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2010024-003

Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 732 Kenyon St NW

Customer Sample Number:

Date / Time Collected: 10/1/2020 6:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2010024-004

Date / Time Received: 10/5/2020 8:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2009202-005

Sample Location: 1st Draw 868 HR Drive SE
Customer Sample Number: 3090599
Date / Time Collected: 9/20/2020 9:15 PM

Customer Program Code: DS
Laboratory Sample Number: 2009202-005
Date / Time Received: 9/25/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 868 HR Drive SE
Customer Sample Number: 3090599
Date / Time Collected: 9/20/2020 9:19 PM

Customer Program Code: DS
Laboratory Sample Number: 2009202-006
Date / Time Received: 9/25/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2009180-005

Sample Location: 1st Draw 901 Buchanan St NW

Customer Sample Number: 3022020

Date / Time Collected: 9/20/2020 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2009180-005

Date / Time Received: 9/23/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 901 Buchanan St NW

Customer Sample Number: 3022020

Date / Time Collected: 9/20/2020 8:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2009180-006

Date / Time Received: 9/23/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2009132-019

Sample Location: 1st Draw 1344 OAKS ST NW
Customer Sample Number: 3030063
Date / Time Collected: 9/14/2020 12:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-019
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/5/2020	SBrooks

Sample Location: 2nd Draw 1344 OAKS ST NW
Customer Sample Number: 3030063
Date / Time Collected: 9/14/2020 12:44 AM

Customer Program Code: DS
Laboratory Sample Number: 2009132-020
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010073-001

Sample Location: 1st Draw 1816 Corcoran St NE

Customer Sample Number: 3102795

Date / Time Collected: 10/6/2020 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2010073-001

Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 1816 Corcoran St NE

Customer Sample Number: 3102795

Date / Time Collected: 10/6/2020 7:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2010073-002

Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010073-003

Sample Location: 1st Draw 2210 Taylor St NE
Customer Sample Number: 3106525
Date / Time Collected: 10/7/2020 9:01 AM

Customer Program Code: DS
Laboratory Sample Number: 2010073-003
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 2210 Taylor St NE
Customer Sample Number: 3106525
Date / Time Collected: 10/7/2020 9:03 AM

Customer Program Code: DS
Laboratory Sample Number: 2010073-004
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010059-007

Sample Location: 1st Draw 3421 Porter St
Customer Sample Number: 3041801
Date / Time Collected: 10/6/2020 6:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2010059-007
Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 3421 Porter St
Customer Sample Number: 3041801
Date / Time Collected: 10/6/2020 6:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2010059-008
Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010073-005

Sample Location: 1st Draw 4116 12th St NE
Customer Sample Number: 3113466
Date / Time Collected: 10/7/2020 7:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2010073-005
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 4116 12th St NE
Customer Sample Number: 3113466
Date / Time Collected: 10/7/2020 7:18 AM

Customer Program Code: DS
Laboratory Sample Number: 2010073-006
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010059-005

Sample Location: 1st Draw 434 Kentucky Ave SE

Customer Sample Number: 3087146

Date / Time Collected: 10/6/2020 7:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2010059-005

Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 434 Kentucky Ave SE

Customer Sample Number: 3087146

Date / Time Collected: 10/6/2020 7:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2010059-006

Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010059-003

Sample Location: 1st Draw 5071 8TH St NE
Customer Sample Number: 3118283
Date / Time Collected: 10/4/2020 11:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010059-003
Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 5071 8TH St NE
Customer Sample Number: 3118283
Date / Time Collected: 10/4/2020 11:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010059-004
Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010059-001

Sample Location: 1st Draw 5107 Illinois Ave NW

Customer Sample Number: 3022732

Date / Time Collected: 10/2/2020 12:08 PM

Customer Program Code: DS

Laboratory Sample Number: 2010059-001

Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 5107 Illinois Ave NW

Customer Sample Number: 3022732

Date / Time Collected: 10/2/2020 12:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2010059-002

Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010128-009

Sample Location: 1st Draw 115 Rhode Island Ave NE
Customer Sample Number: 3125428
Date / Time Collected: 10/14/2020 5:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2010128-009
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 115 Rhode Island Ave NE
Customer Sample Number: 3125428
Date / Time Collected: 10/14/2020 5:32 AM

Customer Program Code: DS
Laboratory Sample Number: 2010128-010
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010128-001

Sample Location: 1st Draw 26 Q St NE #2
Customer Sample Number: 3102984
Date / Time Collected: 10/11/2020 6:51 AM

Customer Program Code: DS
Laboratory Sample Number: 2010128-001
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 26 Q St NE #2
Customer Sample Number: 3102984
Date / Time Collected: 10/11/2020 6:53 AM

Customer Program Code: DS
Laboratory Sample Number: 2010128-002
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010128-011

Sample Location: 1st Draw 2826 Rittenhouse St NW
Customer Sample Number: 3053306
Date / Time Collected: 10/11/2020 1:22 PM

Customer Program Code: DS
Laboratory Sample Number: 2010128-011
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 2826 Rittenhouse St NW
Customer Sample Number: 3053306
Date / Time Collected: 10/11/2020 1:22 PM

Customer Program Code: DS
Laboratory Sample Number: 2010128-012
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010128-003

Sample Location: 1st Draw 322 Seaton PI NE
Customer Sample Number: 3124834
Date / Time Collected: 10/15/2020 9:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2010128-003
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 322 Seaton PI NE
Customer Sample Number: 3124834
Date / Time Collected: 10/15/2020 9:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2010128-004
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010128-005

Sample Location: 1st Draw 3724 13th St NW
Customer Sample Number: 3028576
Date / Time Collected: 10/12/2020 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2010128-005
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 3724 13th St NW
Customer Sample Number: 3028576
Date / Time Collected: 10/12/2020 7:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2010128-006
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010128-007

Sample Location: 1st Draw 912 Perry PI NE
Customer Sample Number: 3103705
Date / Time Collected: 10/12/2020 6:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2010128-007
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 912 Perry PI NE
Customer Sample Number: 3103705
Date / Time Collected: 10/12/2020 6:05 PM

Customer Program Code: DS
Laboratory Sample Number: 2010128-008
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010187-003

Sample Location: 1st Draw 1201 KENYON ST NW APT. 4
Customer Sample Number: 3059059
Date / Time Collected: 10/16/2020 5:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2010187-003
Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 1201 KENYON ST NW APT. 4
Customer Sample Number: 3059059
Date / Time Collected: 10/16/2020 5:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2010187-004
Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2011034-007

Sample Location: 1st Draw 1422 A St SE
Customer Sample Number:
Date / Time Collected: 11/3/2020 7:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2011034-007
Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 1422 A St SE
Customer Sample Number:
Date / Time Collected: 11/3/2020 7:18 AM

Customer Program Code: DS
Laboratory Sample Number: 2011034-008
Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010167-009

Sample Location: 1st Draw 1471 Monroe St NW

Customer Sample Number: 3030611

Date / Time Collected: 10/18/2020 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2010167-009

Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 1471 Monroe St NW

Customer Sample Number: 3030611

Date / Time Collected: 10/18/2020 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2010167-010

Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2011021-007

Sample Location: 1st Draw 1715 INDEPENDENCE AVE SE

Customer Sample Number:

Date / Time Collected: 10/30/2020 8:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2011021-007

Date / Time Received: 11/3/2020 8:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 1715 INDEPENDENCE AVE SE

Customer Sample Number:

Date / Time Collected: 10/30/2020 8:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2011021-008

Date / Time Received: 11/3/2020 8:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010218-007

Sample Location: 1st Draw 1834 SHEPHERD ST NW
Customer Sample Number: 3055816
Date / Time Collected: 10/28/2020 8:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2010218-007
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 1834 SHEPHERD ST NW
Customer Sample Number: 3055816
Date / Time Collected: 10/28/2020 8:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2010218-008
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010200-001

Sample Location: 1st Draw 204 Kentucky Ave SE
Customer Sample Number: 3074412
Date / Time Collected: 10/26/2020 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010200-001
Date / Time Received: 10/28/2020 10:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 204 Kentucky Ave SE
Customer Sample Number: 3074412
Date / Time Collected: 10/26/2020 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010200-002
Date / Time Received: 10/28/2020 10:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010167-001

Sample Location: 1st Draw 207 C St SE
Customer Sample Number: 3071603
Date / Time Collected: 10/21/2020 7:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2010167-001
Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 207 C St SE
Customer Sample Number: 3071603
Date / Time Collected: 10/21/2020 7:18 AM

Customer Program Code: DS
Laboratory Sample Number: 2010167-002
Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010200-003

Sample Location: 1st Draw 207 Varnum St NW
Customer Sample Number: 3021473
Date / Time Collected: 10/26/2020 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010200-003
Date / Time Received: 10/28/2020 10:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 207 Varnum St NW
Customer Sample Number: 3021473
Date / Time Collected: 10/26/2020 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010200-004
Date / Time Received: 10/28/2020 10:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2011034-005

Sample Location: 1st Draw 2220 Hall PI NW

Customer Sample Number:

Date / Time Collected: 11/2/2020 9:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2011034-005

Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 2220 Hall PI NW

Customer Sample Number:

Date / Time Collected: 11/2/2020 9:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2011034-006

Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010218-003

Sample Location: 1st Draw 2406 LAWRENCE ST NE
Customer Sample Number: 3106965
Date / Time Collected: 10/27/2020 7:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2010218-003
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 2406 LAWRENCE ST NE
Customer Sample Number: 3106965
Date / Time Collected: 10/27/2020 7:01 PM

Customer Program Code: DS
Laboratory Sample Number: 2010218-004
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2011021-003

Sample Location: 1st Draw 3149 17TH ST NW
Customer Sample Number: 3031632
Date / Time Collected: 10/27/2020 10:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2011021-003
Date / Time Received: 11/3/2020 8:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 3149 17TH ST NW
Customer Sample Number: 3031632
Date / Time Collected: 10/27/2020 10:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2011021-004
Date / Time Received: 11/3/2020 8:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010208-003

Sample Location: 1st Draw 3334 17TH ST NW
Customer Sample Number: 3030716
Date / Time Collected: 10/27/2020 6:39 AM

Customer Program Code: DS
Laboratory Sample Number: 2010208-003
Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 3334 17TH ST NW
Customer Sample Number: 3030716
Date / Time Collected: 10/27/2020 6:42 AM

Customer Program Code: DS
Laboratory Sample Number: 2010208-004
Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.8	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010167-003

Sample Location: 1st Draw 3351 Blaine St NE
Customer Sample Number: 3115803
Date / Time Collected: 10/19/2020 10:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010167-003
Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 3351 Blaine St NE
Customer Sample Number: 3115803
Date / Time Collected: 10/19/2020 10:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010167-004
Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2011021-005

Sample Location: 1st Draw 3812 T STREET NW

Customer Sample Number:

Date / Time Collected: 10/30/2020 7:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2011021-005

Date / Time Received: 11/3/2020 8:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 3812 T STREET NW

Customer Sample Number:

Date / Time Collected: 10/30/2020 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2011021-006

Date / Time Received: 11/3/2020 8:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010187-001

Sample Location: 1st Draw 4020 17TH ST NW
Customer Sample Number: 3145421
Date / Time Collected: 10/15/2020 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2010187-001
Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 4020 17TH ST NW
Customer Sample Number: 3145421
Date / Time Collected: 10/15/2020 7:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2010187-002
Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010187-009

Sample Location: 1st Draw 4033 NEW HAMPSHIRE AVE NW
Customer Sample Number: 3051092
Date / Time Collected: 10/22/2020 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2010187-009
Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 4033 NEW HAMPSHIRE AVE NW
Customer Sample Number: 3051092
Date / Time Collected: 10/22/2020 7:31 AM

Customer Program Code: DS
Laboratory Sample Number: 2010187-010
Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010218-005

Sample Location: 1st Draw 4527 45TH STREET NW
Customer Sample Number: 3042509
Date / Time Collected: 10/28/2020 7:06 AM

Customer Program Code: DS
Laboratory Sample Number: 2010218-005
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 4527 45TH STREET NW
Customer Sample Number: 3042509
Date / Time Collected: 10/28/2020 7:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2010218-006
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010167-005

Sample Location: 1st Draw 5311 4th St NW
Customer Sample Number: 3023812
Date / Time Collected: 10/18/2020 7:44 AM

Customer Program Code: DS
Laboratory Sample Number: 2010167-005
Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 5311 4th St NW
Customer Sample Number: 3023812
Date / Time Collected: 10/18/2020 7:46 AM

Customer Program Code: DS
Laboratory Sample Number: 2010167-006
Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2011034-001

Sample Location: 1st Draw 5508 30TH PL NW

Customer Sample Number:

Date / Time Collected: 10/25/2020 7:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2011034-001

Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 5508 30TH PL NW

Customer Sample Number:

Date / Time Collected: 10/25/2020 7:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2011034-002

Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2011021-001

Sample Location: 1st Draw 609 FARRAGUT PL NE

Customer Sample Number:

Date / Time Collected: 10/26/2020 6:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2011021-001

Date / Time Received: 11/3/2020 8:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 609 FARRAGUT PL NE

Customer Sample Number:

Date / Time Collected: 10/26/2020 6:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2011021-002

Date / Time Received: 11/3/2020 8:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010208-005

Sample Location: 1st Draw 746 Kennedy St. NW
Customer Sample Number: 3119709
Date / Time Collected: 10/27/2020 10:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2010208-005
Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 746 Kennedy St. NW
Customer Sample Number: 3119709
Date / Time Collected: 10/27/2020 10:47 AM

Customer Program Code: DS
Laboratory Sample Number: 2010208-006
Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2010167-007

Sample Location: 1st Draw 802 Dahlia St NW
Customer Sample Number: 3047150
Date / Time Collected: 10/18/2020 5:48 PM

Customer Program Code: DS
Laboratory Sample Number: 2010167-007
Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 802 Dahlia St NW
Customer Sample Number: 3047150
Date / Time Collected: 10/18/2020 5:49 PM

Customer Program Code: DS
Laboratory Sample Number: 2010167-008
Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2012016-011

Sample Location: 1st Draw 1335 Maryland Ave NE
Customer Sample Number: 3143144
Date / Time Collected: 11/25/2020 7:01 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-011
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 1335 Maryland Ave NE
Customer Sample Number: 3143144
Date / Time Collected: 11/25/2020 7:02 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-012
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2012016-009

Sample Location: 1st Draw 1719 Newton St NW

Customer Sample Number: 3053878

Date / Time Collected: 11/25/2020 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2012016-009

Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 1719 Newton St NW

Customer Sample Number: 3053878

Date / Time Collected: 11/25/2020 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2012016-010

Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2012016-013

Sample Location: 1st Draw 1812 Park Rd NW
Customer Sample Number: 3031526
Date / Time Collected: 11/28/2020 5:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-013
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 1812 Park Rd NW
Customer Sample Number: 3031526
Date / Time Collected: 11/28/2020 5:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-014
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2012016-019

Sample Location: 1st Draw 2637 Patricia Roberts Harris PI NE
Customer Sample Number:
Date / Time Collected: 11/27/2020 7:11 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-019
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 2637 Patricia Roberts Harris PI NE
Customer Sample Number:
Date / Time Collected: 11/27/2020 7:13 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-020
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2012016-015

Sample Location: 1st Draw 410 16th St SE
Customer Sample Number: 3075456
Date / Time Collected: 11/24/2020 8:28 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-015
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 410 16th St SE
Customer Sample Number: 3075456
Date / Time Collected: 11/24/2020 8:29 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-016
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2012016-017

Sample Location: 1st Draw 427 Whittier St NW
Customer Sample Number: 3046323
Date / Time Collected: 11/29/2020 4:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-017
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 427 Whittier St NW
Customer Sample Number: 3046323
Date / Time Collected: 11/29/2020 4:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-018
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2012016-021

Sample Location: 1st Draw 57 Bates St NW B
Customer Sample Number: 3006849
Date / Time Collected: 11/25/2020 6:02 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-021
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 57 Bates St NW B
Customer Sample Number: 3006849
Date / Time Collected: 11/25/2020 6:03 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-022
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2012016-023

Sample Location: 1st Draw 662 Kenneth St NE
Customer Sample Number: 3159872
Date / Time Collected: 11/30/2020 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-023
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 662 Kenneth St NE
Customer Sample Number: 3159872
Date / Time Collected: 11/30/2020 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-024
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2012016-007

Sample Location: 1st Draw 706 Crittenden St NE
Customer Sample Number: 3113681
Date / Time Collected: 11/28/2020 8:53 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-007
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 706 Crittenden St NE
Customer Sample Number: 3113681
Date / Time Collected: 11/28/2020 8:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2012016-008
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2006172-001

Sample Location: 1st Draw 1862 Ontario Place NW
Customer Sample Number: 3061188
Date / Time Collected: 6/14/2020 4:01 PM

Customer Program Code: DS250
Laboratory Sample Number: 2006172-001
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 1862 Ontario Place NW
Customer Sample Number: 3061188
Date / Time Collected: 6/14/2020 4:01 PM

Customer Program Code: DS250
Laboratory Sample Number: 2006172-002
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2006213-001

Sample Location: 1st Draw 4120 14TH ST NW APT 7
Customer Sample Number: 3131576
Date / Time Collected: 6/17/2020 9:51 AM

Customer Program Code: DS250
Laboratory Sample Number: 2006213-001
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 4120 14TH ST NW APT 7
Customer Sample Number: 3131576
Date / Time Collected: 6/17/2020 9:51 AM

Customer Program Code: DS250
Laboratory Sample Number: 2006213-002
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007027-001

Sample Location: 1st Draw 1808 Connecticut Ave NW, Apt. 604
Customer Sample Number: 3060075
Date / Time Collected: 6/27/2020 8:15 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007027-001
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 1808 Connecticut Ave NW, Apt. 604
Customer Sample Number: 3060075
Date / Time Collected: 6/27/2020 8:15 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007027-002
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007013-001

Sample Location: 1st Draw 2844 Wisconsin Ave NW Apt 307
Customer Sample Number: 3061530
Date / Time Collected: 6/25/2020 1:00 PM

Customer Program Code: DS250
Laboratory Sample Number: 2007013-001
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 2844 Wisconsin Ave NW Apt 307
Customer Sample Number: 3061530
Date / Time Collected: 6/25/2020 1:00 PM

Customer Program Code: DS250
Laboratory Sample Number: 2007013-002
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007047-001

Sample Location: 1st Draw 309 4TH ST SE APT. 7
Customer Sample Number: 3071777
Date / Time Collected: 7/6/2020 5:30 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007047-001
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 309 4TH ST SE APT. 7
Customer Sample Number: 3071777
Date / Time Collected: 7/6/2020 5:30 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007047-002
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007181-007

Sample Location: 1st Draw 1001 3RD ST SW APT 305
Customer Sample Number: 3091617
Date / Time Collected: 7/22/2020 6:59 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-007
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1001 3RD ST SW APT 305
Customer Sample Number: 3091617
Date / Time Collected: 7/22/2020 6:59 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-008
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007181-005

Sample Location: 1st Draw 1200 23rd St, NW #906
Customer Sample Number: 3016590
Date / Time Collected: 7/17/2020 9:15 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-005
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1200 23rd St, NW #906
Customer Sample Number: 3016590
Date / Time Collected: 7/17/2020 9:15 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-006
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007181-001

Sample Location: 1st Draw 1875 Mintwood PI NW #42
Customer Sample Number: 3061412
Date / Time Collected: 7/15/2020 6:02 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-001
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1875 Mintwood PI NW #42
Customer Sample Number: 3061412
Date / Time Collected: 7/15/2020 6:02 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-002
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007171-002

Sample Location: 1st Draw 2219 California St NW # 54

Customer Sample Number:

Date / Time Collected: 7/19/2020 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2007171-002

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 2219 California St NW # 54

Customer Sample Number:

Date / Time Collected: 7/19/2020 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2007171-003

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007181-009

Sample Location: 1st Draw 2801 QUEBEC ST NW # 345
Customer Sample Number: 3060564
Date / Time Collected: 7/22/2020 7:45 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-009
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 2801 QUEBEC ST NW # 345
Customer Sample Number: 3060564
Date / Time Collected: 7/22/2020 7:45 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-010
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007181-003

Sample Location: 1st Draw 4000 8TH ST NE UNIT 2
Customer Sample Number: 3095402
Date / Time Collected: 7/16/2020 8:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-003
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 4000 8TH ST NE UNIT 2
Customer Sample Number: 3095402
Date / Time Collected: 7/16/2020 8:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007181-004
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/7/2020

Report Number: L-DC-DS250- 2007171-006

Sample Location: 1st Draw 4105 WISCONSIN AVE APT 504
Customer Sample Number:
Date / Time Collected: 7/21/2020 6:53 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007171-006
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 4105 WISCONSIN AVE APT 504
Customer Sample Number:
Date / Time Collected: 7/21/2020 6:53 AM

Customer Program Code: DS250
Laboratory Sample Number: 2007171-007
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager **Report**

Report Date: 8/12/2020 *Report revised on 8/12/2020 by mc.
For Lab Sample Numbers: 2007171-004 & 2007171-005, the
address was changed from 6321 to 1321 KENYON ST NW
APT 408 as recorded on the bottles and chain-of-custody form.*

Number: L-DC-DS250- 2007171-004b

Sample Location: 1st Draw 1321 KENYON ST NW APT 408	Customer Program Code: DS250
Customer Sample Number:	Laboratory Sample Number: 2007171-004
Date / Time Collected: 7/20/2020 7:15 AM	Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1321 KENYON ST NW APT 408	Customer Program Code: DS250
Customer Sample Number:	Laboratory Sample Number: 2007171-005
Date / Time Collected: 7/20/2020 7:15 AM	Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2007171-001

Sample Location: 1st Draw 645 46TH ST SE # 33

Customer Sample Number:

Date / Time Collected: 7/16/2020 12:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2007171-001

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2008009-003

Sample Location: 1st Draw 1117 NEW HAMPSHIRE AVE NW APT 4

Customer Sample Number:

Date / Time Collected: 7/29/2020 10:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008009-003

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1117 NEW HAMPSHIRE AVE NW APT 4

Customer Sample Number:

Date / Time Collected: 7/29/2020 10:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008009-004

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2008009-001

Sample Location: 1st Draw 555 MASSACHUSETTS AVE NW UNIT 815

Customer Sample Number:

Date / Time Collected: 7/28/2020 12:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2008009-001

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 555 MASSACHUSETTS AVE NW UNIT 815

Customer Sample Number:

Date / Time Collected: 7/28/2020 12:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2008009-002

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2008089-003

Sample Location: 1st Draw 1623 Lanier PI NW Apt 202

Customer Sample Number:

Date / Time Collected: 8/10/2020 5:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008089-003

Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1623 Lanier PI NW Apt 202

Customer Sample Number:

Date / Time Collected: 8/10/2020 5:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008089-004

Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2008089-001

Sample Location: 1st Draw 201 I St NE Apt 703

Customer Sample Number:

Date / Time Collected: 8/9/2020 6:15 PM

Customer Program Code: DS250

Laboratory Sample Number: 2008089-001

Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 201 I St NE Apt 703

Customer Sample Number:

Date / Time Collected: 8/9/2020 6:15 PM

Customer Program Code: DS250

Laboratory Sample Number: 2008089-002

Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/9/2020

Report Number: L-DC-DS250- 2008220-001

Sample Location: 1st Draw 2320 Wisconsin Ave NW #203

Customer Sample Number:

Date / Time Collected: 8/26/2020 11:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008220-001

Date / Time Received: 8/28/2020 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 2320 Wisconsin Ave NW #203

Customer Sample Number:

Date / Time Collected: 8/26/2020 11:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008220-002

Date / Time Received: 8/28/2020 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2008234-001

Sample Location: 1st Draw 2516 Q St. NW, #201Q

Customer Sample Number:

Date / Time Collected: 8/26/2020 7:15 PM

Customer Program Code: DS250

Laboratory Sample Number: 2008234-001

Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 2516 Q St. NW, #201Q

Customer Sample Number:

Date / Time Collected: 8/26/2020 7:15 PM

Customer Program Code: DS250

Laboratory Sample Number: 2008234-002

Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2008089-005

Sample Location: 1st Draw 3541 11th St NW Apt 2

Customer Sample Number:

Date / Time Collected: 8/9/2020 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008089-005

Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 3541 11th St NW Apt 2

Customer Sample Number:

Date / Time Collected: 8/9/2020 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008089-006

Date / Time Received: 8/12/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2008205-001

Sample Location: 1st Draw 4316 14th St NW Apt 2

Customer Sample Number:

Date / Time Collected: 8/20/2020 6:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008205-001

Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 4316 14th St NW Apt 2

Customer Sample Number:

Date / Time Collected: 8/20/2020 6:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008205-002

Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2008047-003

Sample Location: 1st Draw 5819 3RD PL NW

Customer Sample Number:

Date / Time Collected: 8/2/2020 6:47 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008047-003

Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 5819 3RD PL NW

Customer Sample Number:

Date / Time Collected: 8/2/2020 6:47 AM

Customer Program Code: DS250

Laboratory Sample Number: 2008047-004

Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2008047-001

Sample Location: 1st Draw APT. 811, 2020 7TH ST NW
Customer Sample Number:
Date / Time Collected: 8/6/2020 6:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2008047-001
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw APT. 811, 2020 7TH ST NW
Customer Sample Number:
Date / Time Collected: 8/6/2020 6:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2008047-002
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2009045-001

Sample Location: 1st Draw 4601 CONN AVE NW # 616

Customer Sample Number:

Date / Time Collected: 8/28/2020 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2009045-001

Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 4601 CONN AVE NW # 616

Customer Sample Number:

Date / Time Collected: 8/28/2020 7:02 AM

Customer Program Code: DS250

Laboratory Sample Number: 2009045-002

Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2009073-001

Sample Location: 1st Draw 1435 4th St SW B-609

Customer Sample Number:

Date / Time Collected: 9/5/2020 9:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2009073-001

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2n Draw 1435 4th St SW B-609

Customer Sample Number:

Date / Time Collected: 9/5/2020 9:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2009073-002

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2009077-001

Sample Location: 1st Draw 1726 17th St NW #403
Customer Sample Number: 3015128
Date / Time Collected: 9/5/2020 8:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2009077-001
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1726 17th St NW #403
Customer Sample Number: 3015128
Date / Time Collected: 9/5/2020 8:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2009077-002
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2009133-003

Sample Location: 1st Draw 350 G St SW, N317

Customer Sample Number: 3142367

Date / Time Collected: 9/12/2020 5:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2009133-003

Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 350 G St SW, N317

Customer Sample Number: 3142367

Date / Time Collected: 9/12/2020 5:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2009133-004

Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2009133-005

Sample Location: 1st Draw 3821 NEWARK ST NW E 443
Customer Sample Number:
Date / Time Collected: 9/14/2020 6:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2009133-005
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 3821 NEWARK ST NW E 443
Customer Sample Number:
Date / Time Collected: 9/14/2020 6:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2009133-006
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2009133-001

Sample Location: 1st Draw 907 6TH ST SW APT 912C
Customer Sample Number: 3091646
Date / Time Collected: 9/9/2020 6:10 AM

Customer Program Code: DS250
Laboratory Sample Number: 2009133-001
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 907 6TH ST SW APT 912C
Customer Sample Number: 3091646
Date / Time Collected: 9/9/2020 6:10 AM

Customer Program Code: DS250
Laboratory Sample Number: 2009133-002
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2010046-001

Sample Location: 1st Draw 1615 Q St NW Apt 1114
Customer Sample Number: 3018230
Date / Time Collected: 10/5/2020 10:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010046-001
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/8/2020	SBrooks

Sample Location: 2nd Draw 1615 Q St NW Apt 1114
Customer Sample Number: 3018230
Date / Time Collected: 10/5/2020 10:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010046-002
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2010046-003

Sample Location: 1st Draw 3801 Connecticut Ave NW, P37
Customer Sample Number: 3060562
Date / Time Collected: 10/4/2020 9:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010046-003
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/8/2020	SBrooks

Sample Location: 2nd Draw 3801 Connecticut Ave NW, P37
Customer Sample Number: 3060562
Date / Time Collected: 10/4/2020 9:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010046-004
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2020

Report Number: L-DC-DS250- 2009212-001

Sample Location: 1st Draw 4545 Connecticut Ave, NW #110

Customer Sample Number:

Date / Time Collected: 9/24/2020 5:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2009212-001

Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 4545 Connecticut Ave, NW #110

Customer Sample Number:

Date / Time Collected: 9/24/2020 5:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2009212-002

Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2010070-005

Sample Location: 1st Draw 1397 Congress St #2

Customer Sample Number: 3068381

Date / Time Collected: 9/22/2020 6:32 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010070-005

Date / Time Received: 10/9/2020 8:11:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	10/29/2020	SBrooks

Sample Location: 2nd Draw 1397 Congress St #2

Customer Sample Number: 3068381

Date / Time Collected: 9/22/2020 6:32 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010070-006

Date / Time Received: 10/9/2020 8:11:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/5/2020

Report Number: L-DC-DS250- 2010070-007

Sample Location: 1st Draw 1397 Congress St Apt 6
Customer Sample Number: 3068381
Date / Time Collected: 9/21/2020 8:00 AM
Customer Program Code: DS250
Laboratory Sample Number: 2010070-007
Date / Time Received: 10/9/2020 8:11:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	10/29/2020	SBrooks

Sample Location: 2nd Draw 1397 Congress St Apt 6
Customer Sample Number: 3068381
Date / Time Collected: 9/21/2020 8:00 AM
Customer Program Code: DS250
Laboratory Sample Number: 2010070-008
Date / Time Received: 10/9/2020 8:11:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2010070-001

Sample Location: 1st Draw 4545 Conn Ave NW Apt. 734
Customer Sample Number: 3061965
Date / Time Collected: 10/7/2020 5:50 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010070-001
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 4545 Conn Ave NW Apt. 734
Customer Sample Number: 3061965
Date / Time Collected: 10/7/2020 5:50 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010070-002
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2010070-003

Sample Location: 1st Draw 4912 New Hampshire Ave NW Apt. 203
Customer Sample Number: 3062266
Date / Time Collected: 10/4/2020 9:05 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010070-003
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 4912 New Hampshire Ave NW Apt. 203
Customer Sample Number: 3062266
Date / Time Collected: 10/4/2020 9:05 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010070-004
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2010058-001

Sample Location: 1st Draw 736 Kenyon St, NW #2
Customer Sample Number: 3032356
Date / Time Collected: 10/2/2020 4:09 AM
Customer Program Code: DS250
Laboratory Sample Number: 2010058-001
Date / Time Received: 10/8/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 736 Kenyon St, NW #2
Customer Sample Number: 3032356
Date / Time Collected: 10/2/2020 4:09 AM
Customer Program Code: DS250
Laboratory Sample Number: 2010058-002
Date / Time Received: 10/8/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/18/2020

Report Number: L-DC-DS250- 2010129-001

Sample Location: 1st Draw 2425 L St NW Apt. 516
Customer Sample Number: 3015789
Date / Time Collected: 10/14/2020 8:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010129-001
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 2425 L St NW Apt. 516
Customer Sample Number: 3015789
Date / Time Collected: 10/14/2020 8:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2010129-001
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2010129-003

Sample Location: 1st Draw 4545 Connecticut Ave NW #326

Customer Sample Number:

Date / Time Collected: 10/13/2020 6:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010129-003

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 4545 Connecticut Ave NW #326

Customer Sample Number:

Date / Time Collected: 10/13/2020 6:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010129-004

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 11/18/2020

Report Number: L-DC-DS250- 2010129-005

Sample Location: 1st Draw 777 7th St NW Apt 926

Customer Sample Number:

Date / Time Collected: 10/12/2020 7:19 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010129-005

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 777 7th St NW Apt 926

Customer Sample Number:

Date / Time Collected: 10/12/2020 7:19 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010129-006

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2010215-001

Sample Location: 1st Draw 1324 EUCLID ST NW # 104

Customer Sample Number:

Date / Time Collected: 10/28/2020 5:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010215-001

Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 1324 EUCLID ST NW # 104

Customer Sample Number:

Date / Time Collected: 10/28/2020 5:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010215-002

Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2011036-001

Sample Location: 1st Draw 1435 4th St SW B-108

Customer Sample Number:

Date / Time Collected: 11/1/2020 9:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2011036-001

Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 1435 4th St SW B-108

Customer Sample Number:

Date / Time Collected: 11/1/2020 9:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2011036-002

Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2010199-001

Sample Location: 1st Draw 1523 Park Rd NW #102

Customer Sample Number: 3012585

Date / Time Collected: 10/21/2020 9:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010199-001

Date / Time Received: 10/28/2020 10:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 1523 Park Rd NW #102

Customer Sample Number: 3012585

Date / Time Collected: 10/21/2020 9:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2010199-002

Date / Time Received: 10/28/2020 10:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Customer Collected Filtered Samples

DC Water operates a program where customers request a lead sampling kit to test their in-line point-of-use filtered water. The test kit comes with a 1-L bottle and instructions on how to take a sample. Customers collect their own sample and contact DC Water to deliver the bottle to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 2006173-001

Sample Location: 1st Draw 3211 Oliver St NW
Customer Sample Number: 3038909
Date / Time Collected: 6/17/2020 8:03 AM

Customer Program Code: CUSTFILT
Laboratory Sample Number: 2006173-001
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 2008204-001

Sample Location: 1st Draw 1650 29th St, NW
Customer Sample Number: 3007821
Date / Time Collected: 8/19/2020 6:45 AM

Customer Program Code: CUSTFILT
Laboratory Sample Number: 2008204-001
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/15/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS- 2011143-001

Sample Location: 1st Draw 1320 CORBIN PL NE

Customer Sample Number:

Date / Time Collected: 11/4/2020 8:20 AM

Customer Program Code: U&F

Laboratory Sample Number: 2011143-001

Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 1320 CORBIN PL NE

Customer Sample Number:

Date / Time Collected: 11/4/2020 8:20 AM

Customer Program Code: U&F

Laboratory Sample Number: 2011143-002

Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off approximately 4 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-037

Sample Location: 1st Draw 106 R Street NE
Customer Sample Number: 3124960
Date / Time Collected: 6/23/2020 6:58 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-037
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 106 R Street NE
Customer Sample Number: 3124960
Date / Time Collected: 6/23/2020 7:04 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-038
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-025

Sample Location: 1st Draw 1114 FAIRMONT ST NW
Customer Sample Number: 3033105
Date / Time Collected: 6/22/2020 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-025
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 1114 FAIRMONT ST NW
Customer Sample Number: 3033105
Date / Time Collected: 6/22/2020 6:01 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-026
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-027

Sample Location: 1st Draw 1167 Abbey PI NE
Customer Sample Number: 3128225
Date / Time Collected: 6/23/2020 7:06 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-027
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 1167 Abbey PI NE
Customer Sample Number: 3128225
Date / Time Collected: 6/23/2020 7:09 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-028
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006223-007

Sample Location: 1st Draw 12 S Street NW
Customer Sample Number: 3017939
Date / Time Collected: 6/24/2020 7:40 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006223-007
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 12 S Street NW
Customer Sample Number: 3017939
Date / Time Collected: 6/24/2020 7:40 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006223-008
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-013

Sample Location: 1st Draw 1208 WALTER ST SE
Customer Sample Number: 3073799
Date / Time Collected: 6/21/2020 6:40 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-013
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 1208 WALTER ST SE
Customer Sample Number: 3073799
Date / Time Collected: 6/21/2020 6:42 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-014
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006174-005

Sample Location: 1st Draw 127 Rhode Island Ave NE
Customer Sample Number: 3125418
Date / Time Collected: 6/14/2020 10:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-005
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 127 Rhode Island Ave NE
Customer Sample Number: 3125418
Date / Time Collected: 6/14/2020 10:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-006
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006174-009

Sample Location: 1st Draw 1405 LAWRENCE ST NE
Customer Sample Number: 3104876
Date / Time Collected: 6/15/2020 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-009
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 1405 LAWRENCE ST NE
Customer Sample Number: 3104876
Date / Time Collected: 6/15/2020 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-010
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006174-011

Sample Location: 1st Draw 1416 Buchanan St NW

Customer Sample Number: 3027868

Date / Time Collected: 6/15/2020 8:47 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2006174-011

Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-041

Sample Location: 1st Draw 1512 KEARNY ST NE
Customer Sample Number: 3104852
Date / Time Collected: 6/23/2020 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-041
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 1512 KEARNY ST NE
Customer Sample Number: 3104852
Date / Time Collected: 6/23/2020 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-042
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006223-015

Sample Location: 1st Draw 1712 Taylor Steet NW
Customer Sample Number: 3028796
Date / Time Collected: 6/18/2020 7:12 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006223-015
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 1712 Taylor Steet NW
Customer Sample Number: 3028796
Date / Time Collected: 6/18/2020 7:14 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006223-016
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006174-003

Sample Location: 1st Draw 1726 Jackson St. NE
Customer Sample Number: 3105281
Date / Time Collected: 6/14/2020 5:57 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-003
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 1726 Jackson St. NE
Customer Sample Number: 3105281
Date / Time Collected: 6/14/2020 6:01 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-004
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-031

Sample Location: 1st Draw 20 S ST NW
Customer Sample Number: 3017935
Date / Time Collected: 6/23/2020 6:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-031
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 20 S ST NW
Customer Sample Number: 3017935
Date / Time Collected: 6/23/2020 6:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-032
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-001

Sample Location: 1st Draw 2014 EVARTS ST NE
Customer Sample Number: 3123581
Date / Time Collected: 6/14/2020 6:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-001
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 2014 EVARTS ST NE
Customer Sample Number: 3123581
Date / Time Collected: 6/14/2020 6:14 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-002
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-039

Sample Location: 1st Draw 219 RITTENHOUSE ST NW
Customer Sample Number: 3026008
Date / Time Collected: 6/23/2020 8:08 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-039
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 219 RITTENHOUSE ST NW
Customer Sample Number: 3026008
Date / Time Collected: 6/23/2020 8:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-040
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006223-013

Sample Location: 1st Draw 2232 Cathedral Ave NW
Customer Sample Number: 3052993
Date / Time Collected: 6/22/2020 12:05 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006223-013
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 2232 Cathedral Ave NW
Customer Sample Number: 3052993
Date / Time Collected: 6/22/2020 12:06 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006223-014
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-003

Sample Location: 1st Draw 2915 ORDWAY ST NW
Customer Sample Number: 3036351
Date / Time Collected: 6/17/2020 6:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-003
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 2915 ORDWAY ST NW
Customer Sample Number: 3036351
Date / Time Collected: 6/17/2020 6:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-004
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-005

Sample Location: 1st Draw 2925 ORDWAY ST NW
Customer Sample Number: 3036347
Date / Time Collected: 6/20/2020 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-005
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 2925 ORDWAY ST NW
Customer Sample Number: 3036347
Date / Time Collected: 6/20/2020 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-006
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-029

Sample Location: 1st Draw 3315 Morrison St. NW
Customer Sample Number: 3039490
Date / Time Collected: 6/23/2020 6:18 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-029
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 3315 Morrison St. NW
Customer Sample Number: 3039490
Date / Time Collected: 6/23/2020 6:24 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-030
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006174-012

Sample Location: 1st Draw 3403 O St NW
Customer Sample Number: 3008371
Date / Time Collected: 6/16/2020 5:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-012
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 3403 O St NW
Customer Sample Number: 3008371
Date / Time Collected: 6/16/2020 5:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-013
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-019

Sample Location: 1st Draw 3439 MT. PLEASANT ST NW
Customer Sample Number: 3030930
Date / Time Collected: 6/22/2020 5:38 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-019
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 3439 MT. PLEASANT ST NW
Customer Sample Number: 3030930
Date / Time Collected: 6/22/2020 5:41 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-020
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006185-001

Sample Location: 1st Draw 3509 35TH ST NW

Customer Sample Number: 3041845

Date / Time Collected: 5/26/2020 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2006185-001

Date / Time Received: 6/23/2020 10:11:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/1/2020	SBrooks

Sample Location: 2nd Draw 3509 35TH ST NW

Customer Sample Number: 3041845

Date / Time Collected: 5/26/2020 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2006185-002

Date / Time Received: 6/23/2020 10:11:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-015

Sample Location: 1st Draw 3515 LEGATION ST NW
Customer Sample Number: 3039515
Date / Time Collected: 6/21/2020 6:55 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-015
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 3515 LEGATION ST NW
Customer Sample Number: 3039515
Date / Time Collected: 6/21/2020 6:59 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-016
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006185-004

Sample Location: 1st Draw 3520 QUESADA ST NW
Customer Sample Number: 3038784
Date / Time Collected: 6/20/2020 5:50 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006185-004
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 3520 QUESADA ST NW
Customer Sample Number: 3038784
Date / Time Collected: 6/20/2020 5:55 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006185-005
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006174-014

Sample Location: 1st Draw 3634 Van Ness St NW
Customer Sample Number: 3041514
Date / Time Collected: 6/16/2020 7:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-014
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	174	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 3634 Van Ness St NW
Customer Sample Number: 3041514
Date / Time Collected: 6/16/2020 7:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-015
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.5	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006174-007

Sample Location: 1st Draw 3723 R Street NW
Customer Sample Number: 3010644
Date / Time Collected: 6/15/2020 4:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-007
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Sample Location: 2nd Draw 3723 R Street NW
Customer Sample Number: 3010644
Date / Time Collected: 6/15/2020 4:19 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006174-008
Date / Time Received: 6/19/2020 3:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-023

Sample Location: 1st Draw 3840 FULTON ST NW
Customer Sample Number: 3035043
Date / Time Collected: 6/22/2020 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-023
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 3840 FULTON ST NW
Customer Sample Number: 3035043
Date / Time Collected: 6/22/2020 6:06 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-024
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-033

Sample Location: 1st Draw 4509 ELLICOT ST
Customer Sample Number: 3043197
Date / Time Collected: 6/23/2020 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-033
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 4509 ELLICOT ST
Customer Sample Number: 3043197
Date / Time Collected: 6/23/2020 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-034
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006223-017

Sample Location: 1st Draw 521 9th St NE
Customer Sample Number: 3099074
Date / Time Collected: 6/24/2020 6:16 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006223-017
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 521 9th St NE
Customer Sample Number: 3099074
Date / Time Collected: 6/24/2020 6:18 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006223-018
Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006212-009

Sample Location: 1st Draw 600 E. CAPITOL ST NE
Customer Sample Number: 3121219
Date / Time Collected: 6/21/2020 7:43 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-009
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 600 E. CAPITOL ST NE
Customer Sample Number: 3121219
Date / Time Collected: 6/21/2020 7:47 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2006212-010
Date / Time Received: 6/26/2020 9:44:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006223-009

Sample Location: 1st Draw 632 Edgewood St. NE

Customer Sample Number: 3128309

Date / Time Collected: 6/20/2020 2:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2006223-009

Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 632 Edgewood St. NE

Customer Sample Number: 3128309

Date / Time Collected: 6/20/2020 2:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2006223-010

Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2006223-011

Sample Location: 1st Draw 635 Emerson St NW

Customer Sample Number: 3022683

Date / Time Collected: 6/24/2020 5:14 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2006223-011

Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks

Sample Location: 2nd Draw 635 Emerson St NW

Customer Sample Number: 3022683

Date / Time Collected: 6/24/2020 5:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2006223-012

Date / Time Received: 6/29/2020 8:52:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007014-019

Sample Location: 1st Draw 1219 F St NE
Customer Sample Number: 3099345
Date / Time Collected: 6/26/2020 6:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007014-019
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 1219 F St NE
Customer Sample Number: 3099345
Date / Time Collected: 6/26/2020 6:19 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007014-020
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007026-019

Sample Location: 1st Draw 1302 LONGFELLOW ST NW
Customer Sample Number: 3049401
Date / Time Collected: 6/28/2020 6:05 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-019
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 1302 LONGFELLOW ST NW
Customer Sample Number: 3049401
Date / Time Collected: 6/28/2020 6:08 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-020
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007026-029

Sample Location: 1st Draw 1636 MONROE ST NW
Customer Sample Number: 3030673
Date / Time Collected: 6/29/2020 6:29 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-029
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 1636 MONROE ST NW
Customer Sample Number: 3030673
Date / Time Collected: 6/29/2020 6:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-030
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007014-011

Sample Location: 1st Draw 28 15th Street SE

Customer Sample Number:

Date / Time Collected: 6/17/2020 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007014-011

Date / Time Received: 7/2/2020 8:43:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	7/9/2020	SBrooks

Sample Location: 2nd Draw 28 15th Street SE

Customer Sample Number:

Date / Time Collected: 6/17/2020 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007014-012

Date / Time Received: 7/2/2020 8:43:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007014-009

Sample Location: 1st Draw 3121 33rd Place NW

Customer Sample Number:

Date / Time Collected: 6/17/2020 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007014-009

Date / Time Received: 7/2/2020 8:43:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	7/9/2020	SBrooks

Sample Location: 2nd Draw 3121 33rd Place NW

Customer Sample Number:

Date / Time Collected: 6/17/2020 6:47 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007014-010

Date / Time Received: 7/2/2020 8:43:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007026-025

Sample Location: 1st Draw 3314 N ST NW
Customer Sample Number: 3012075
Date / Time Collected: 6/29/2020 8:53 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-025
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 3314 N ST NW
Customer Sample Number: 3012075
Date / Time Collected: 6/29/2020 8:54 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-026
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007014-017

Sample Location: 1st Draw 3715 Ingomar St NW
Customer Sample Number: 3040509
Date / Time Collected: 6/26/2020 11:56 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007014-017
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 3715 Ingomar St NW
Customer Sample Number: 3040509
Date / Time Collected: 6/26/2020 12:00 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007014-018
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007026-003

Sample Location: 1st Draw 4102 5TH ST NW
Customer Sample Number: 3051123
Date / Time Collected: 6/27/2020 8:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-003
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 4102 5TH ST NW
Customer Sample Number: 3051123
Date / Time Collected: 6/27/2020 8:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-004
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007014-013

Sample Location: 1st Draw 437 KENYON ST NW

Customer Sample Number: 3019812

Date / Time Collected: 6/18/2020 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007014-013

Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 437 KENYON ST NW

Customer Sample Number: 3019812

Date / Time Collected: 6/18/2020 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007014-014

Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007026-033

Sample Location: 1st Draw 4608 4th St NW
Customer Sample Number: 3021806
Date / Time Collected: 6/29/2020 6:19 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-033
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 4608 4th St NW
Customer Sample Number: 3021806
Date / Time Collected: 6/29/2020 6:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-034
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007014-015

Sample Location: 1st Draw 4941 Blaine St NE
Customer Sample Number: 3109525
Date / Time Collected: 6/20/2020 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007014-015
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 4941 Blaine St NE
Customer Sample Number: 3109525
Date / Time Collected: 6/20/2020 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007014-016
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007014-021

Sample Location: 1st Draw 803 Aspen St NW
Customer Sample Number: 3047129
Date / Time Collected: 6/26/2020 5:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007014-021
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 803 Aspen St NW
Customer Sample Number: 3047129
Date / Time Collected: 6/26/2020 5:03 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007014-022
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007026-031

Sample Location: 1st Draw 931 FARAGUT ST NW
Customer Sample Number: 3022802
Date / Time Collected: 6/29/2020 5:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-031
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2nd Draw 931 FARAGUT ST NW
Customer Sample Number: 3022802
Date / Time Collected: 6/29/2020 5:16 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007026-032
Date / Time Received: 7/6/2020 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007046-007

Sample Location: 1st Draw 1371 EMERALD ST NE
Customer Sample Number: 3127728
Date / Time Collected: 7/1/2020 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007046-007
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 1371 EMERALD ST NE
Customer Sample Number: 3127728
Date / Time Collected: 7/1/2020 7:05 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007046-008
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007046-001

Sample Location: 1st Draw 21 RANDOLPH PL NW

Customer Sample Number: 3017881

Date / Time Collected: 6/2/2020 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007046-001

Date / Time Received: 7/8/2020 10:48:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	7/16/2020	SBrooks

Sample Location: 2nd Draw 21 RANDOLPH PL NW

Customer Sample Number: 3017881

Date / Time Collected: 6/2/2020 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007046-002

Date / Time Received: 7/8/2020 10:48:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007084-005

Sample Location: 1st Draw 418 Elm St. NW
Customer Sample Number: 3019101
Date / Time Collected: 7/3/2020 10:22 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007084-005
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 418 Elm St. NW
Customer Sample Number: 3019101
Date / Time Collected: 7/3/2020 10:26 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007084-006
Date / Time Received: 7/13/2020 1:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007046-025

Sample Location: 1st Draw 5627 KANSAS AVE NW
Customer Sample Number: 3051741
Date / Time Collected: 7/5/2020 8:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007046-025
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 5627 KANSAS AVE NW
Customer Sample Number: 3051741
Date / Time Collected: 7/5/2020 8:17 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007046-026
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/21/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007046-011

Sample Location: 1st Draw 924 UPSHUR ST NE
Customer Sample Number: 3113544
Date / Time Collected: 7/2/2020 6:36 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007046-011
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2020	SBrooks

Sample Location: 2nd Draw 924 UPSHUR ST NE
Customer Sample Number: 3113544
Date / Time Collected: 7/2/2020 6:38 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007046-012
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007129-001

Sample Location: 1st Draw 1007 LAMONT ST NW
Customer Sample Number: 3059150
Date / Time Collected: 7/10/2020 8:45 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007129-001
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1007 LAMONT ST NW
Customer Sample Number: 3059150
Date / Time Collected: 7/10/2020 9:00 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007129-002
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007182-013

Sample Location: 1st Draw 1239 34TH ST NW
Customer Sample Number: 3012089
Date / Time Collected: 7/20/2020 12:05 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007182-013
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 1239 34TH ST NW
Customer Sample Number: 3012089
Date / Time Collected: 7/20/2020 12:08 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007182-014
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007182-011

Sample Location: 1st Draw 207 49TH ST NE
Customer Sample Number: 3109543
Date / Time Collected: 7/19/2020 7:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007182-011
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 207 49TH ST NE
Customer Sample Number: 3109543
Date / Time Collected: 7/19/2020 7:19 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007182-012
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007170-003

Sample Location: 1st Draw 234 Kentucky Ave. SE

Customer Sample Number:

Date / Time Collected: 7/18/2020 4:22 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007170-003

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 234 Kentucky Ave. SE

Customer Sample Number:

Date / Time Collected: 7/18/2020 4:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007170-004

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007100-019

Sample Location: 1st Draw 3605 Patterson St. NW
Customer Sample Number: 3039695
Date / Time Collected: 7/13/2020 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007100-019
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 3605 Patterson St. NW
Customer Sample Number: 3039695
Date / Time Collected: 7/13/2020 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007100-020
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007170-005

Sample Location: 1st Draw 3726 LIVINGSTON ST NW

Customer Sample Number:

Date / Time Collected: 7/20/2020 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007170-005

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 3726 LIVINGSTON ST NW

Customer Sample Number:

Date / Time Collected: 7/20/2020 6:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007170-006

Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007182-021

Sample Location: 1st Draw 41 Franklin St NE
Customer Sample Number: 3125580
Date / Time Collected: 7/23/2020 6:09 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007182-021
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 41 Franklin St NE
Customer Sample Number: 3125580
Date / Time Collected: 7/23/2020 6:09 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007182-022
Date / Time Received: 7/24/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/7/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007170-019

Sample Location: 1st Draw 601 3RD ST NE
Customer Sample Number:
Date / Time Collected: 7/21/2020 7:21 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007170-019
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2nd Draw 601 3RD ST NE
Customer Sample Number:
Date / Time Collected: 7/21/2020 7:24 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2007170-020
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008011-009

Sample Location: 1st Draw 1515 MASSACHUSETTS SE

Customer Sample Number:

Date / Time Collected: 7/27/2020 7:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008011-009

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 1515 MASSACHUSETTS SE

Customer Sample Number:

Date / Time Collected: 7/27/2020 7:47 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008011-010

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008011-001

Sample Location: 1st Draw 2412 N CAPITOL STREET NW

Customer Sample Number:

Date / Time Collected: 7/18/2020 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008011-001

Date / Time Received: 8/3/2020 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/6/2020	SBrooks

Sample Location: 2nd Draw 2412 N CAPITOL STREET NW

Customer Sample Number:

Date / Time Collected: 7/18/2020 7:37 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008011-002

Date / Time Received: 8/3/2020 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008011-017

Sample Location: 1st Draw 3035 Sherman Ave NW

Customer Sample Number:

Date / Time Collected: 7/28/2020 11:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008011-017

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 3035 Sherman Ave NW

Customer Sample Number:

Date / Time Collected: 7/28/2020 11:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008011-018

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2007209-023

Sample Location: 1st Draw 3907 Harrison St. NW

Customer Sample Number:

Date / Time Collected: 7/23/2020 8:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007209-023

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/6/2020	SBrooks

Sample Location: 2nd draw 3907 Harrison St. NW

Customer Sample Number:

Date / Time Collected: 7/23/2020 8:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2007209-024

Date / Time Received: 7/29/2020 10:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/11/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008011-005

Sample Location: 1st Draw 713 14TH ST SE

Customer Sample Number:

Date / Time Collected: 7/25/2020 10:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008011-005

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2nd Draw 713 14TH ST SE

Customer Sample Number:

Date / Time Collected: 7/25/2020 10:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008011-006

Date / Time Received: 8/3/2020 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008050-021

Sample Location: 1st Draw 1127 Maryland Ave. NE
Customer Sample Number: 3099331
Date / Time Collected: 8/3/2020 6:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008050-021
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1127 Maryland Ave. NE
Customer Sample Number: 3099331
Date / Time Collected: 8/3/2020 6:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008050-022
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008221-005

Sample Location: 1st Draw 1341 Ridge PI SE

Customer Sample Number:

Date / Time Collected: 8/23/2020 8:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008221-005

Date / Time Received: 8/28/2020 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 1341 Ridge PI SE

Customer Sample Number:

Date / Time Collected: 8/23/2020 8:23 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008221-006

Date / Time Received: 8/28/2020 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008206-017

Sample Location: 1st Draw 153 V St NE
Customer Sample Number: 3125360
Date / Time Collected: 8/23/2020 7:35 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008206-017
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 153 V St NE
Customer Sample Number: 3125360
Date / Time Collected: 8/23/2020 7:35 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008206-018
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008050-011

Sample Location: 1st Draw 1631 MONROE ST NW
Customer Sample Number: 3030687
Date / Time Collected: 7/31/2020 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008050-011
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 1631 MONROE ST NW
Customer Sample Number: 3030687
Date / Time Collected: 7/31/2020 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008050-012
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008149-001

Sample Location: 1st Draw 2927 ORDWAY ST NW

Customer Sample Number:

Date / Time Collected: 8/14/2020 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008149-001

Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 2927 ORDWAY ST NW

Customer Sample Number:

Date / Time Collected: 8/14/2020 7:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008149-002

Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008087-003

Sample Location: 1st Draw 4108 Garrison St NW

Customer Sample Number: 3147524

Date / Time Collected: 8/7/2020 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008087-003

Date / Time Received: 8/11/2020 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 4108 Garrison St NW

Customer Sample Number: 3147524

Date / Time Collected: 8/7/2020 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008087-004

Date / Time Received: 8/11/2020 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008087-005

Sample Location: 1st Draw 4210 3rd St NW

Customer Sample Number:

Date / Time Collected: 8/3/2020 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008087-005

Date / Time Received: 8/11/2020 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 4210 3rd St NW

Customer Sample Number:

Date / Time Collected: 8/3/2020 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008087-006

Date / Time Received: 8/11/2020 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008206-013

Sample Location: 1st Draw 4304 Brandywine St NW
Customer Sample Number:
Date / Time Collected: 8/21/2020 8:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008206-013
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 4304 Brandywine St NW
Customer Sample Number:
Date / Time Collected: 8/21/2020 8:25 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008206-014
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008149-003

Sample Location: 1st Draw 47 U ST NW
Customer Sample Number:
Date / Time Collected: 8/14/2020 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008149-003
Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 47 U ST NW
Customer Sample Number:
Date / Time Collected: 8/14/2020 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008149-004
Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008087-001

Sample Location: 1st Draw 4915 41st St NW

Customer Sample Number:

Date / Time Collected: 7/6/2020 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008087-001

Date / Time Received: 8/11/2020 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	8/28/2020	SBrooks

Sample Location: 2nd Draw 4915 41st St NW

Customer Sample Number:

Date / Time Collected: 7/6/2020 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008087-002

Date / Time Received: 8/11/2020 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008214-007

Sample Location: 1st Draw 4917 43rd St. NW

Customer Sample Number:

Date / Time Collected: 8/18/2020 6:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008214-007

Date / Time Received: 8/27/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 4917 43rd St. NW

Customer Sample Number:

Date / Time Collected: 8/18/2020 6:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008214-008

Date / Time Received: 8/27/2020 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008050-017

Sample Location: 1st Draw 4926 Hillbrook LN NW

Customer Sample Number:

Date / Time Collected: 8/2/2020 2:28 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008050-017

Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 4926 Hillbrook LN NW

Customer Sample Number:

Date / Time Collected: 8/2/2020 2:31 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008050-018

Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008050-029

Sample Location: 1st Draw 5502 8TH St NW
Customer Sample Number: 3056784
Date / Time Collected: 8/3/2020 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008050-029
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	17.1	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 5502 8TH St NW
Customer Sample Number: 3056784
Date / Time Collected: 8/3/2020 8:04 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008050-030
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	13.0	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008050-027

Sample Location: 1st Draw 637 MORTON PL NE
Customer Sample Number: 3127168
Date / Time Collected: 8/3/2020 7:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008050-027
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/28/2020	SBrooks

Sample Location: 2nd Draw 637 MORTON PL NE
Customer Sample Number: 3127168
Date / Time Collected: 8/3/2020 7:22 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2008050-028
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/9/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2008206-015

Sample Location: 1st Draw 640 Massachusetts Ave NE

Customer Sample Number:

Date / Time Collected: 8/21/2020 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008206-015

Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 2nd Draw 640 Massachusetts Ave NE

Customer Sample Number:

Date / Time Collected: 8/21/2020 6:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2008206-016

Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009016-003

Sample Location: 1st Draw 3926 Illinois Ave NW
Customer Sample Number: 3051045
Date / Time Collected: 8/31/2020 9:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009016-003
Date / Time Received: 9/2/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/15/2020	SBrooks

Sample Location: 2nd Draw 3926 Illinois Ave NW
Customer Sample Number: 3051045
Date / Time Collected: 8/31/2020 9:05 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009016-004
Date / Time Received: 9/2/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009132-013

Sample Location: 1st Draw 1122 Staples St. NE
Customer Sample Number: 3102135
Date / Time Collected: 9/13/2020 10:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-013
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1122 Staples St. NE
Customer Sample Number: 3102135
Date / Time Collected: 9/13/2020 10:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-014
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009092-005

Sample Location: 1st Draw 1815 Monroe St NW

Customer Sample Number:

Date / Time Collected: 9/8/2020 9:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-005

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 1815 Monroe St NW

Customer Sample Number:

Date / Time Collected: 9/8/2020 9:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-006

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009092-009

Sample Location: 1st Draw 207 S St NE
Customer Sample Number:
Date / Time Collected: 9/9/2020 5:25 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009092-009
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 207 S St NE
Customer Sample Number:
Date / Time Collected: 9/9/2020 5:27 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009092-010
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009092-017

Sample Location: 1st Draw 2617 24TH STREET NE

Customer Sample Number:

Date / Time Collected: 9/9/2020 7:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-017

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 2617 24TH STREET NE

Customer Sample Number:

Date / Time Collected: 9/9/2020 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-018

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009142-005

Sample Location: 1st Draw 3211 Oliver St NW

Customer Sample Number:

Date / Time Collected: 9/16/2020 7:49 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009142-005

Date / Time Received: 9/18/2020 8:17:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 3211 Oliver St NW

Customer Sample Number:

Date / Time Collected: 9/16/2020 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009142-006

Date / Time Received: 9/18/2020 8:17:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009092-011

Sample Location: 1st Draw 3750 JOCELYN ST NW

Customer Sample Number:

Date / Time Collected: 9/9/2020 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-011

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 3750 JOCELYN ST NW

Customer Sample Number:

Date / Time Collected: 9/9/2020 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-012

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009092-003

Sample Location: 1st Draw 3901 Alton PI NW

Customer Sample Number:

Date / Time Collected: 9/8/2020 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-003

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 3901 Alton PI NW

Customer Sample Number:

Date / Time Collected: 9/8/2020 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-004

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009092-015

Sample Location: 1st Draw 4441 FARADAY PL NW

Customer Sample Number:

Date / Time Collected: 9/9/2020 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-015

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 4441 FARADAY PL NW

Customer Sample Number:

Date / Time Collected: 9/9/2020 7:14 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-016

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009132-005

Sample Location: 1st Draw 512 Missouri Ave NW
Customer Sample Number: 3024190
Date / Time Collected: 9/11/2020 6:33 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-005
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 512 Missouri Ave NW
Customer Sample Number: 3024190
Date / Time Collected: 9/11/2020 6:35 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-006
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009092-013

Sample Location: 1st Draw 521 ROCK CREEK CHURCH RD NW

Customer Sample Number:

Date / Time Collected: 9/9/2020 6:34 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-013

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 521 ROCK CREEK CHURCH RD NW

Customer Sample Number:

Date / Time Collected: 9/9/2020 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009092-014

Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009092-021

Sample Location: 1st Draw 6609 1st St NW
Customer Sample Number:
Date / Time Collected: 9/10/2020 6:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009092-021
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 6609 1st St NW
Customer Sample Number:
Date / Time Collected: 9/10/2020 6:31 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009092-022
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009132-017

Sample Location: 1st Draw 829 MARIETTA PL NW
Customer Sample Number: 3024446
Date / Time Collected: 9/14/2020 7:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-017
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 829 MARIETTA PL NW
Customer Sample Number: 3024446
Date / Time Collected: 9/14/2020 7:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-018
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/6/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009132-023

Sample Location: 1st Draw 912 Evarts St NE
Customer Sample Number: 3120550
Date / Time Collected: 9/16/2020 8:09 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-023
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/22/2020	SBrooks

Sample Location: 2nd Draw 912 Evarts St NE
Customer Sample Number: 3120550
Date / Time Collected: 9/16/2020 8:12 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-024
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009213-001

Sample Location: 1st Draw 1107 Alabama Ave, SE

Customer Sample Number:

Date / Time Collected: 9/24/2020 7:47 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009213-001

Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 1107 Alabama Ave, SE

Customer Sample Number:

Date / Time Collected: 9/24/2020 7:51 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009213-002

Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009180-007

Sample Location: 1st Draw 4006 12th St NE
Customer Sample Number: 3113424
Date / Time Collected: 9/20/2020 2:00 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009180-007
Date / Time Received: 9/23/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 4006 12th St NE
Customer Sample Number: 3113424
Date / Time Collected: 9/20/2020 2:00 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009180-008
Date / Time Received: 9/23/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010047-007

Sample Location: 1st Draw 4200 New Hampshire Ave NW
Customer Sample Number: 3056998
Date / Time Collected: 10/5/2020 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010047-007
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/8/2020	SBrooks

Sample Location: 2nd Draw 4200 New Hampshire Ave NW
Customer Sample Number: 3056998
Date / Time Collected: 10/5/2020 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010047-008
Date / Time Received: 10/7/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009221-007

Sample Location: 1st Draw 4622 4TH ST NW

Customer Sample Number:

Date / Time Collected: 9/27/2020 7:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009221-007

Date / Time Received: 9/29/2020 11:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 4622 4TH ST NW

Customer Sample Number:

Date / Time Collected: 9/27/2020 7:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2009221-008

Date / Time Received: 9/29/2020 11:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/19/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010007-003

Sample Location: 1st Draw 58 S ST NW
Customer Sample Number:
Date / Time Collected: 9/28/2020 6:53 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010007-003
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2nd Draw 58 S ST NW
Customer Sample Number:
Date / Time Collected: 9/28/2020 6:56 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010007-004
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2009132-011

Sample Location: 1st Draw 1530 Locust Rd NW
Customer Sample Number: 3047687
Date / Time Collected: 9/13/2020 10:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-011
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		10/5/2020	SBrooks

Sample Location: 2nd Draw 1530 Locust Rd NW
Customer Sample Number: 3047687
Date / Time Collected: 9/13/2020 10:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2009132-012
Date / Time Received: 9/17/2020 8:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010059-009

Sample Location: 1st Draw 1417 Taylor St NW
Customer Sample Number: 3028388
Date / Time Collected: 10/3/2020 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010059-009
Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 1417 Taylor St NW
Customer Sample Number: 3028388
Date / Time Collected: 10/3/2020 8:02 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010059-010
Date / Time Received: 10/8/2020 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/5/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010073-007

Sample Location: 1st Draw 6500 16TH St NW
Customer Sample Number: 3048764
Date / Time Collected: 10/7/2020 7:49 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010073-007
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 6500 16TH St NW
Customer Sample Number: 3048764
Date / Time Collected: 10/7/2020 7:49 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010073-008
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010128-015

Sample Location: 1st Draw 1017 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 10/14/2020 7:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010128-015

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 1017 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 10/14/2020 7:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010128-016

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010128-023

Sample Location: 1st Draw 1804 Irving St NW

Customer Sample Number:

Date / Time Collected: 10/12/2020 7:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010128-023

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 1804 Irving St NW

Customer Sample Number:

Date / Time Collected: 10/12/2020 7:58 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010128-024

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010128-019

Sample Location: 1st Draw 3429 Ordway St NW
Customer Sample Number: 3041844
Date / Time Collected: 10/7/2020 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010128-019
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 3429 Ordway St NW
Customer Sample Number: 3041844
Date / Time Collected: 10/7/2020 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010128-020
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010128-013

Sample Location: 1st Draw 3816 Military Rd NW

Customer Sample Number:

Date / Time Collected: 10/12/2020 6:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010128-013

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 3816 Military Rd NW

Customer Sample Number:

Date / Time Collected: 10/12/2020 6:01 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010128-014

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010128-017

Sample Location: 1st Draw 435 10th St NE
Customer Sample Number: 3099185
Date / Time Collected: 10/5/2020 5:33 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010128-017
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 435 10th St NE
Customer Sample Number: 3099185
Date / Time Collected: 10/5/2020 5:36 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010128-018
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010128-021

Sample Location: 1st Draw 4628 48th St NW

Customer Sample Number:

Date / Time Collected: 10/6/2020 10:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010128-021

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 4628 48th St NW

Customer Sample Number:

Date / Time Collected: 10/6/2020 10:35 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010128-022

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010128-025

Sample Location: 1st Draw 7529 Morningside Drive NW
Customer Sample Number:
Date / Time Collected: 10/10/2020 7:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010128-025
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 7529 Morningside Drive NW
Customer Sample Number:
Date / Time Collected: 10/10/2020 7:18 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010128-026
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010167-015

Sample Location: 1st Draw 1026 Quebec PI NW

Customer Sample Number:

Date / Time Collected: 10/20/2020 6:04 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010167-015

Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 1026 Quebec PI NW

Customer Sample Number:

Date / Time Collected: 10/20/2020 6:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010167-016

Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2011034-003

Sample Location: 1st Draw 1223 MASSACHUSETTS AVE SE
Customer Sample Number:
Date / Time Collected: 10/27/2020 7:18 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2011034-003
Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 1223 MASSACHUSETTS AVE SE
Customer Sample Number:
Date / Time Collected: 10/27/2020 7:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2011034-004
Date / Time Received: 11/4/2020 8:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010187-005

Sample Location: 1st Draw 225 14TH ST NE

Customer Sample Number:

Date / Time Collected: 10/17/2020 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010187-005

Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 225 14TH ST NE

Customer Sample Number:

Date / Time Collected: 10/17/2020 7:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010187-006

Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010167-013

Sample Location: 1st Draw 2921 10TH ST NE

Customer Sample Number:

Date / Time Collected: 10/9/2020 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010167-013

Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 2921 10TH ST NE

Customer Sample Number:

Date / Time Collected: 10/9/2020 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010167-014

Date / Time Received: 10/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010200-005

Sample Location: 1st Draw 3554 Albemarle St NW
Customer Sample Number: 3036613
Date / Time Collected: 10/26/2020 9:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010200-005
Date / Time Received: 10/28/2020 10:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 3554 Albemarle St NW
Customer Sample Number: 3036613
Date / Time Collected: 10/26/2020 9:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010200-006
Date / Time Received: 10/28/2020 10:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010218-001

Sample Location: 1st Draw 3636 13th St NW

Customer Sample Number:

Date / Time Collected: 10/21/2020 8:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010218-001

Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 3636 13th St NW

Customer Sample Number:

Date / Time Collected: 10/21/2020 8:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010218-002

Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010187-007

Sample Location: 1st Draw 3721 WINDOM PLACE NW
Customer Sample Number: 3053577
Date / Time Collected: 10/19/2020 6:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010187-007
Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/29/2020	SBrooks

Sample Location: 2nd Draw 3721 WINDOM PLACE NW
Customer Sample Number: 3053577
Date / Time Collected: 10/19/2020 6:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2010187-008
Date / Time Received: 10/27/2020 8:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010208-001

Sample Location: 1st Draw 3900 YUMA ST NW

Customer Sample Number:

Date / Time Collected: 10/26/2020 5:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010208-001

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2020	SBrooks

Sample Location: 2nd Draw 3900 YUMA ST NW

Customer Sample Number:

Date / Time Collected: 10/26/2020 5:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010208-002

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2010167-011

Sample Location: 1st Draw 919 L St NE

Customer Sample Number:

Date / Time Collected: 9/18/2020 9:09 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010167-011

Date / Time Received: 10/23/2020 9:42:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/29/2020	SBrooks

Sample Location: 2nd Draw 919 L St NE

Customer Sample Number:

Date / Time Collected: 9/18/2020 9:10 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2010167-012

Date / Time Received: 10/23/2020 9:42:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2012016-001

Sample Location: 1st Draw 1243 34th St NW
Customer Sample Number: 3012087
Date / Time Collected: 11/28/2020 7:41 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2012016-001
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 1243 34th St NW
Customer Sample Number: 3012087
Date / Time Collected: 11/28/2020 7:45 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2012016-002
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2012016-005

Sample Location: 1st Draw 5004 13th St NW
Customer Sample Number: 3049763
Date / Time Collected: 11/30/2020 6:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2012016-005
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 5004 13th St NW
Customer Sample Number: 3049763
Date / Time Collected: 11/30/2020 6:13 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2012016-006
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2012016-003

Sample Location: 1st Draw 610 FARRAGUT ST NW
Customer Sample Number: 3022644
Date / Time Collected: 11/29/2020 6:35 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2012016-003
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2nd Draw 610 FARRAGUT ST NW
Customer Sample Number: 3022644
Date / Time Collected: 11/29/2020 6:35 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2012016-004
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Customer Collected Profiles

DC Water operates a program when customers request a lead sampling kit without knowledge of their service line material. The profile kit comes with ten bottles and instructions on how to collect samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/10/2020

Report Number: LT-DC-CCPF- 2006186

Sample Location: 1 905 5TH ST NE
Date Collected: 6/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2006186-001
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks
Tin	EPA 200.8		0.2	4.3	ug/L		7/1/2020	SBrooks

Sample Location: 2 905 5TH ST NE
Date Collected: 6/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2006186-002
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 3 905 5TH ST NE
Date Collected: 6/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2006186-003
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 4 905 5TH ST NE
Date Collected: 6/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2006186-004
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 905 5TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/13/2020						Laboratory Sample Number: 2006186-005			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Sample Location: 6 905 5TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/13/2020						Laboratory Sample Number: 2006186-006			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.7	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Sample Location: 7 905 5TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/13/2020						Laboratory Sample Number: 2006186-007			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.4	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Sample Location: 8 905 5TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/13/2020						Laboratory Sample Number: 2006186-008			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Sample Location: 9 905 5TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/13/2020						Laboratory Sample Number: 2006186-009			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Sample Location: 10 905 5TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/13/2020						Laboratory Sample Number: 2006186-010			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/10/2020

Report Number: LT-DC-CCPF- 2006187

Sample Location: 1 3028 CLINTON ST NE
Date Collected: 6/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2006187-001
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		7/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 2 3028 CLINTON ST NE
Date Collected: 6/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2006187-002
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		7/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 3 3028 CLINTON ST NE
Date Collected: 6/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2006187-003
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		7/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 4 3028 CLINTON ST NE
Date Collected: 6/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2006187-004
Date / Time Received: 6/23/2020 10:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		7/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 3028 CLINTON ST NE						Customer Program Code: CCPF			
Date Collected: 6/20/2020						Laboratory Sample Number: 2006187-005			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Sample Location: 6 3028 CLINTON ST NE						Customer Program Code: CCPF			
Date Collected: 6/20/2020						Laboratory Sample Number: 2006187-006			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/6/2020	SBrooks	

Sample Location: 7 3028 CLINTON ST NE						Customer Program Code: CCPF			
Date Collected: 6/20/2020						Laboratory Sample Number: 2006187-007			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	1.8	ug/L		7/1/2020	SBrooks	

Sample Location: 8 3028 CLINTON ST NE						Customer Program Code: CCPF			
Date Collected: 6/20/2020						Laboratory Sample Number: 2006187-008			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.1	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Sample Location: 9 3028 CLINTON ST NE						Customer Program Code: CCPF			
Date Collected: 6/20/2020						Laboratory Sample Number: 2006187-009			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Sample Location: 10 3028 CLINTON ST NE						Customer Program Code: CCPF			
Date Collected: 6/20/2020						Laboratory Sample Number: 2006187-010			
						Date / Time Received: 6/23/2020 10:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/1/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/14/2020

Report Number: LT-DC-CCPF- 2007012

Sample Location: 1 1681 32ND St NW
Date Collected: 6/25/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007012-001
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 2 1681 32ND St NW
Date Collected: 6/25/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007012-002
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/9/2020	SBrooks

Sample Location: 3 1681 32ND St NW
Date Collected: 6/25/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007012-003
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/9/2020	SBrooks
Tin	EPA 200.8		0.2	1.3	ug/L		7/9/2020	SBrooks

Sample Location: 4 1681 32ND St NW
Date Collected: 6/25/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007012-004
Date / Time Received: 7/2/2020 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/9/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 1681 32ND St NW						Customer Program Code: CCPF			
Date Collected: 6/25/2020						Laboratory Sample Number: 2007012-005			
						Date / Time Received: 7/2/2020 8:43:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/9/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/9/2020	SBrooks	

Sample Location: 6 1681 32ND St NW						Customer Program Code: CCPF			
Date Collected: 6/25/2020						Laboratory Sample Number: 2007012-006			
						Date / Time Received: 7/2/2020 8:43:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.3	ug/L		7/9/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/9/2020	SBrooks	

Sample Location: 7 1681 32ND St NW						Customer Program Code: CCPF			
Date Collected: 6/25/2020						Laboratory Sample Number: 2007012-007			
						Date / Time Received: 7/2/2020 8:43:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/9/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/9/2020	SBrooks	

Sample Location: 8 1681 32ND St NW						Customer Program Code: CCPF			
Date Collected: 6/25/2020						Laboratory Sample Number: 2007012-008			
						Date / Time Received: 7/2/2020 8:43:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/9/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/9/2020	SBrooks	

Sample Location: 9 1681 32ND St NW						Customer Program Code: CCPF			
Date Collected: 6/25/2020						Laboratory Sample Number: 2007012-009			
						Date / Time Received: 7/2/2020 8:43:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/9/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/9/2020	SBrooks	

Sample Location: 10 1681 32ND St NW						Customer Program Code: CCPF			
Date Collected: 6/25/2020						Laboratory Sample Number: 2007012-010			
						Date / Time Received: 7/2/2020 8:43:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/9/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/9/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 7/21/2020

Report Number: LT-DC-CCPF- 2007048

Sample Location: 1 5 TERRACE CT NE
Date Collected: 6/28/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007048-001
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2 5 TERRACE CT NE
Date Collected: 6/28/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007048-002
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/16/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 3 5 TERRACE CT NE
Date Collected: 6/28/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007048-003
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 4 5 TERRACE CT NE
Date Collected: 6/28/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007048-004
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 5 TERRACE CT NE						Customer Program Code: CCPF			
Date Collected: 6/28/2020						Laboratory Sample Number: 2007048-005			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 6 5 TERRACE CT NE						Customer Program Code: CCPF			
Date Collected: 6/28/2020						Laboratory Sample Number: 2007048-006			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 7 5 TERRACE CT NE						Customer Program Code: CCPF			
Date Collected: 6/28/2020						Laboratory Sample Number: 2007048-007			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 8 5 TERRACE CT NE						Customer Program Code: CCPF			
Date Collected: 6/28/2020						Laboratory Sample Number: 2007048-008			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 9 5 TERRACE CT NE						Customer Program Code: CCPF			
Date Collected: 6/28/2020						Laboratory Sample Number: 2007048-009			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 10 5 TERRACE CT NE						Customer Program Code: CCPF			
Date Collected: 6/28/2020						Laboratory Sample Number: 2007048-010			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 7/21/2020

Report Number: LT-DC-CCPF- 2007049

Sample Location: 1 2905 25TH ST NE
Date Collected: 6/29/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007049-001
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/16/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 2 2905 25TH ST NE
Date Collected: 6/29/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007049-002
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/16/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 3 2905 25TH ST NE
Date Collected: 6/29/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007049-003
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/16/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 4 2905 25TH ST NE
Date Collected: 6/29/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007049-004
Date / Time Received: 7/8/2020 10:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		7/16/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 2905 25TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/29/2020						Laboratory Sample Number: 2007049-005			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.5	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 6 2905 25TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/29/2020						Laboratory Sample Number: 2007049-006			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.3	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 7 2905 25TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/29/2020						Laboratory Sample Number: 2007049-007			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 8 2905 25TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/29/2020						Laboratory Sample Number: 2007049-008			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 9 2905 25TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/29/2020						Laboratory Sample Number: 2007049-009			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Sample Location: 10 2905 25TH ST NE						Customer Program Code: CCPF			
Date Collected: 6/29/2020						Laboratory Sample Number: 2007049-010			
						Date / Time Received: 7/8/2020 10:48:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/16/2020	SBrooks	

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/7/2020

Report Number: LT-DC-CCPF- 2007101

Sample Location: 1 314 14th PI NE
Date Collected: 7/6/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007101-001
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2 314 14th PI NE
Date Collected: 7/6/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007101-002
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 3 314 14th PI NE
Date Collected: 7/6/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007101-003
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 4 314 14th PI NE
Date Collected: 7/6/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007101-004
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 314 14th PI NE						Customer Program Code: CCPF			
Date Collected: 7/6/2020						Laboratory Sample Number: 2007101-005			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	3.1	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	
Sample Location: 6 314 14th PI NE						Customer Program Code: CCPF			
Date Collected: 7/6/2020						Laboratory Sample Number: 2007101-006			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.6	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	
Sample Location: 7 314 14th PI NE						Customer Program Code: CCPF			
Date Collected: 7/6/2020						Laboratory Sample Number: 2007101-007			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	
Sample Location: 8 314 14th PI NE						Customer Program Code: CCPF			
Date Collected: 7/6/2020						Laboratory Sample Number: 2007101-008			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.6	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	
Sample Location: 9 314 14th PI NE						Customer Program Code: CCPF			
Date Collected: 7/6/2020						Laboratory Sample Number: 2007101-009			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	
Sample Location: 10 314 14th PI NE						Customer Program Code: CCPF			
Date Collected: 7/6/2020						Laboratory Sample Number: 2007101-010			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/7/2020

Report Number: LT-DC-CCPF- 2007102

Sample Location: 1 7121 9th ST NW
Date Collected: 7/11/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007102-001
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2 7121 9th ST NW
Date Collected: 7/11/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007102-002
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 3 7121 9th ST NW
Date Collected: 7/11/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007102-003
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 4 7121 9th ST NW
Date Collected: 7/11/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007102-004
Date / Time Received: 7/15/2020 10:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 7121 9th ST NW						Customer Program Code: CCPF			
Date Collected: 7/11/2020						Laboratory Sample Number: 2007102-005			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 6 7121 9th ST NW						Customer Program Code: CCPF			
Date Collected: 7/11/2020						Laboratory Sample Number: 2007102-006			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 7 7121 9th ST NW						Customer Program Code: CCPF			
Date Collected: 7/11/2020						Laboratory Sample Number: 2007102-007			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 8 7121 9th ST NW						Customer Program Code: CCPF			
Date Collected: 7/11/2020						Laboratory Sample Number: 2007102-008			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 9 7121 9th ST NW						Customer Program Code: CCPF			
Date Collected: 7/11/2020						Laboratory Sample Number: 2007102-009			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 10 7121 9th ST NW						Customer Program Code: CCPF			
Date Collected: 7/11/2020						Laboratory Sample Number: 2007102-010			
						Date / Time Received: 7/15/2020 10:33:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/7/2020

Report Number: LT-DC-CCPF- 2007128

Sample Location: 1 2225 13TH ST NW
Date Collected: 7/11/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007128-001
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2 2225 13TH ST NW
Date Collected: 7/11/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007128-002
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 3 2225 13TH ST NW
Date Collected: 7/11/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007128-003
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 4 2225 13TH ST NW
Date Collected: 7/11/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007128-004
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 2225 13TH ST NW **Customer Program Code:** CCPF
Date Collected: 7/11/2020 **Laboratory Sample Number:** 2007128-005
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 6 2225 13TH ST NW **Customer Program Code:** CCPF
Date Collected: 7/11/2020 **Laboratory Sample Number:** 2007128-006
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 7 2225 13TH ST NW **Customer Program Code:** CCPF
Date Collected: 7/11/2020 **Laboratory Sample Number:** 2007128-007
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 8 2225 13TH ST NW **Customer Program Code:** CCPF
Date Collected: 7/11/2020 **Laboratory Sample Number:** 2007128-008
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 9 2225 13TH ST NW **Customer Program Code:** CCPF
Date Collected: 7/11/2020 **Laboratory Sample Number:** 2007128-009
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 10 2225 13TH ST NW **Customer Program Code:** CCPF
Date Collected: 7/11/2020 **Laboratory Sample Number:** 2007128-010
Date / Time Received: 7/17/2020 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/7/2020

Report Number: LT-DC-CCPF- 2007172

Sample Location: 1 3300 13TH ST NE
Date Collected: 7/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007172-001
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2 3300 13TH ST NE
Date Collected: 7/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007172-002
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 3 3300 13TH ST NE
Date Collected: 7/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007172-003
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 4 3300 13TH ST NE
Date Collected: 7/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007172-004
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 3300 13TH ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007172-005			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 6 3300 13TH ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007172-006			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 7 3300 13TH ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007172-007			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 8 3300 13TH ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007172-008			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 9 3300 13TH ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007172-009			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 10 3300 13TH ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007172-010			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/7/2020

Report Number: LT-DC-CCPF- 2007173

Sample Location: 1 3172 UPLAND TER NW
Date Collected: 7/19/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007173-001
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 2 3172 UPLAND TER NW
Date Collected: 7/19/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007173-002
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 3 3172 UPLAND TER NW
Date Collected: 7/19/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007173-003
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Sample Location: 4 3172 UPLAND TER NW
Date Collected: 7/19/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007173-004
Date / Time Received: 7/23/2020 9:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 3172 UPLAND TER NW						Customer Program Code: CCPF			
Date Collected: 7/19/2020						Laboratory Sample Number: 2007173-005			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 6 3172 UPLAND TER NW						Customer Program Code: CCPF			
Date Collected: 7/19/2020						Laboratory Sample Number: 2007173-006			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 7 3172 UPLAND TER NW						Customer Program Code: CCPF			
Date Collected: 7/19/2020						Laboratory Sample Number: 2007173-007			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 8 3172 UPLAND TER NW						Customer Program Code: CCPF			
Date Collected: 7/19/2020						Laboratory Sample Number: 2007173-008			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 9 3172 UPLAND TER NW						Customer Program Code: CCPF			
Date Collected: 7/19/2020						Laboratory Sample Number: 2007173-009			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Sample Location: 10 3172 UPLAND TER NW						Customer Program Code: CCPF			
Date Collected: 7/19/2020						Laboratory Sample Number: 2007173-010			
						Date / Time Received: 7/23/2020 9:42:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		7/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		7/29/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/11/2020

Report Number: LT-DC-CCPF- 2007217

Sample Location: 1 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-001

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Sample Location: 2 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-002

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Sample Location: 3 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-003

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Sample Location: 4 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-004

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-005

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Sample Location: 6 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-006

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Sample Location: 7 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-007

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Sample Location: 8 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-008

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Sample Location: 9 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-009

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Sample Location: 10 113 MADISON ST NW

Date Collected: 7/11/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2007217-010

Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/11/2020

Report Number: LT-DC-CCPF- 2007218

Sample Location: 1 335 K ST NE
Date Collected: 7/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007218-001
Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2 335 K ST NE
Date Collected: 7/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007218-002
Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 3 335 K ST NE
Date Collected: 7/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007218-003
Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 4 335 K ST NE
Date Collected: 7/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007218-004
Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 335 K ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007218-005			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	

Sample Location: 6 335 K ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007218-006			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	

Sample Location: 7 335 K ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007218-007			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	

Sample Location: 8 335 K ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007218-008			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	

Sample Location: 9 335 K ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007218-009			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	

Sample Location: 10 335 K ST NE						Customer Program Code: CCPF			
Date Collected: 7/17/2020						Laboratory Sample Number: 2007218-010			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/11/2020

Report Number: LT-DC-CCPF- 2007219

Sample Location: 1 1103 S ST NW
Date Collected: 7/25/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007219-001
Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 2 1103 S ST NW
Date Collected: 7/25/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007219-002
Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 3 1103 S ST NW
Date Collected: 7/25/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007219-003
Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks

Sample Location: 4 1103 S ST NW
Date Collected: 7/25/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2007219-004
Date / Time Received: 7/30/2020 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 1103 S ST NW						Customer Program Code: CCPF			
Date Collected: 7/25/2020						Laboratory Sample Number: 2007219-005			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	
Sample Location: 6 1103 S ST NW						Customer Program Code: CCPF			
Date Collected: 7/25/2020						Laboratory Sample Number: 2007219-006			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	
Sample Location: 7 1103 S ST NW						Customer Program Code: CCPF			
Date Collected: 7/25/2020						Laboratory Sample Number: 2007219-007			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	
Sample Location: 8 1103 S ST NW						Customer Program Code: CCPF			
Date Collected: 7/25/2020						Laboratory Sample Number: 2007219-008			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.6	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	
Sample Location: 9 1103 S ST NW						Customer Program Code: CCPF			
Date Collected: 7/25/2020						Laboratory Sample Number: 2007219-009			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	
Sample Location: 10 1103 S ST NW						Customer Program Code: CCPF			
Date Collected: 7/25/2020						Laboratory Sample Number: 2007219-010			
						Date / Time Received: 7/30/2020 8:34:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/6/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/9/2020

Report Number: LT-DC-CCPF- 2008048

Sample Location: 1 3288 N ST NW
Date Collected: 7/27/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008048-001
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2 3288 N ST NW
Date Collected: 7/27/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008048-002
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 3 3288 N ST NW
Date Collected: 7/27/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008048-003
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 4 3288 N ST NW
Date Collected: 7/27/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008048-004
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 3288 N ST NW						Customer Program Code: CCPF			
Date Collected: 7/27/2020						Laboratory Sample Number: 2008048-005			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	
Sample Location: 6 3288 N ST NW						Customer Program Code: CCPF			
Date Collected: 7/27/2020						Laboratory Sample Number: 2008048-006			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	
Sample Location: 7 3288 N ST NW						Customer Program Code: CCPF			
Date Collected: 7/27/2020						Laboratory Sample Number: 2008048-007			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	
Sample Location: 8 3288 N ST NW						Customer Program Code: CCPF			
Date Collected: 7/27/2020						Laboratory Sample Number: 2008048-008			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.6	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	
Sample Location: 9 3288 N ST NW						Customer Program Code: CCPF			
Date Collected: 7/27/2020						Laboratory Sample Number: 2008048-009			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	
Sample Location: 10 3288 N ST NW						Customer Program Code: CCPF			
Date Collected: 7/27/2020						Laboratory Sample Number: 2008048-010			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/9/2020

Report Number: LT-DC-CCPF- 2008049

Sample Location: 1 4112 Fessenden St, NW
Date Collected: 8/3/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008049-001
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2 4112 Fessenden St, NW
Date Collected: 8/3/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008049-002
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 3 4112 Fessenden St, NW
Date Collected: 8/3/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008049-003
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 4 4112 Fessenden St, NW
Date Collected: 8/3/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008049-004
Date / Time Received: 8/7/2020 8:21:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5		4112 Fessenden St, NW				Customer Program Code: CCPF			
Date Collected: 8/3/2020						Laboratory Sample Number: 2008049-005			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 6		4112 Fessenden St, NW				Customer Program Code: CCPF			
Date Collected: 8/3/2020						Laboratory Sample Number: 2008049-006			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 7		4112 Fessenden St, NW				Customer Program Code: CCPF			
Date Collected: 8/3/2020						Laboratory Sample Number: 2008049-007			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 8		4112 Fessenden St, NW				Customer Program Code: CCPF			
Date Collected: 8/3/2020						Laboratory Sample Number: 2008049-008			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 9		4112 Fessenden St, NW				Customer Program Code: CCPF			
Date Collected: 8/3/2020						Laboratory Sample Number: 2008049-009			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 10		4112 Fessenden St, NW				Customer Program Code: CCPF			
Date Collected: 8/3/2020						Laboratory Sample Number: 2008049-010			
						Date / Time Received: 8/7/2020 8:21:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/9/2020

Report Number: LT-DC-CCPF- 2008148

Sample Location: 1 3717 Fordham Rd NW
Date Collected: 8/14/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008148-001
Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2 3717 Fordham Rd NW
Date Collected: 8/14/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008148-002
Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 3 3717 Fordham Rd NW
Date Collected: 8/14/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008148-003
Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 4 3717 Fordham Rd NW
Date Collected: 8/14/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008148-004
Date / Time Received: 8/19/2020 9:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 3717 Fordham Rd NW						Customer Program Code: CCPF			
Date Collected: 8/14/2020						Laboratory Sample Number: 2008148-005			
						Date / Time Received: 8/19/2020 9:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 6 3717 Fordham Rd NW						Customer Program Code: CCPF			
Date Collected: 8/14/2020						Laboratory Sample Number: 2008148-006			
						Date / Time Received: 8/19/2020 9:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 7 3717 Fordham Rd NW						Customer Program Code: CCPF			
Date Collected: 8/14/2020						Laboratory Sample Number: 2008148-007			
						Date / Time Received: 8/19/2020 9:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 8 3717 Fordham Rd NW						Customer Program Code: CCPF			
Date Collected: 8/14/2020						Laboratory Sample Number: 2008148-008			
						Date / Time Received: 8/19/2020 9:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 9 3717 Fordham Rd NW						Customer Program Code: CCPF			
Date Collected: 8/14/2020						Laboratory Sample Number: 2008148-009			
						Date / Time Received: 8/19/2020 9:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 10 3717 Fordham Rd NW						Customer Program Code: CCPF			
Date Collected: 8/14/2020						Laboratory Sample Number: 2008148-010			
						Date / Time Received: 8/19/2020 9:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/9/2020

Report Number: LT-DC-CCPF- 2008158

Sample Location: 1 4928 46th St NW
Date Collected: 8/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008158-001
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2 4928 46th St NW
Date Collected: 8/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008158-002
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 3 4928 46th St NW
Date Collected: 8/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008158-003
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 4 4928 46th St NW
Date Collected: 8/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008158-004
Date / Time Received: 8/20/2020 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 4928 46th St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008158-005			
						Date / Time Received: 8/20/2020 8:30:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 6 4928 46th St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008158-006			
						Date / Time Received: 8/20/2020 8:30:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 7 4928 46th St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008158-007			
						Date / Time Received: 8/20/2020 8:30:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 8 4928 46th St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008158-008			
						Date / Time Received: 8/20/2020 8:30:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 9 4928 46th St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008158-009			
						Date / Time Received: 8/20/2020 8:30:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Sample Location: 10 4928 46th St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008158-010			
						Date / Time Received: 8/20/2020 8:30:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/9/2020

Report Number: LT-DC-CCPF- 2008202

Sample Location: 1 1336 28TH St NW
Date Collected: 8/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008202-001
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		8/28/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 2 1336 28TH St NW
Date Collected: 8/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008202-002
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		9/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 3 1336 28TH St NW
Date Collected: 8/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008202-003
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		9/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 4 1336 28TH St NW
Date Collected: 8/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2008202-004
Date / Time Received: 8/26/2020 7:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		9/1/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 1336 28TH St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008202-005			
						Date / Time Received: 8/26/2020 7:51:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/1/2020	SBrooks	

Sample Location: 6 1336 28TH St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008202-006			
						Date / Time Received: 8/26/2020 7:51:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.9	ug/L		9/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/1/2020	SBrooks	

Sample Location: 7 1336 28TH St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008202-007			
						Date / Time Received: 8/26/2020 7:51:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/1/2020	SBrooks	

Sample Location: 8 1336 28TH St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008202-008			
						Date / Time Received: 8/26/2020 7:51:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/1/2020	SBrooks	

Sample Location: 9 1336 28TH St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008202-009			
						Date / Time Received: 8/26/2020 7:51:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/1/2020	SBrooks	

Sample Location: 10 1336 28TH St NW						Customer Program Code: CCPF			
Date Collected: 8/13/2020						Laboratory Sample Number: 2008202-010			
						Date / Time Received: 8/26/2020 7:51:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/1/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/1/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2020

Report Number: LT-DC-CCPF- 2009014

Sample Location: 1 1327 V St NW
Date Collected: 8/30/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009014-001
Date / Time Received: 9/2/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		9/15/2020	SBrooks
Tin	EPA 200.8		0.2	0.2	ug/L		9/15/2020	SBrooks

Sample Location: 2 1327 V St NW
Date Collected: 8/30/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009014-002
Date / Time Received: 9/2/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		9/15/2020	SBrooks
Tin	EPA 200.8		0.2	0.2	ug/L		9/15/2020	SBrooks

Sample Location: 3 1327 V St NW
Date Collected: 8/30/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009014-003
Date / Time Received: 9/2/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		9/15/2020	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		9/15/2020	SBrooks

Sample Location: 4 1327 V St NW
Date Collected: 8/30/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009014-004
Date / Time Received: 9/2/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		9/15/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 1327 V St NW						Customer Program Code: CCPF			
Date Collected: 8/30/2020						Laboratory Sample Number: 2009014-005			
						Date / Time Received: 9/2/2020 10:20:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	5.2	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	
Sample Location: 6 1327 V St NW						Customer Program Code: CCPF			
Date Collected: 8/30/2020						Laboratory Sample Number: 2009014-006			
						Date / Time Received: 9/2/2020 10:20:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	5.1	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	
Sample Location: 7 1327 V St NW						Customer Program Code: CCPF			
Date Collected: 8/30/2020						Laboratory Sample Number: 2009014-007			
						Date / Time Received: 9/2/2020 10:20:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	4.7	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	
Sample Location: 8 1327 V St NW						Customer Program Code: CCPF			
Date Collected: 8/30/2020						Laboratory Sample Number: 2009014-008			
						Date / Time Received: 9/2/2020 10:20:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	3.6	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	
Sample Location: 9 1327 V St NW						Customer Program Code: CCPF			
Date Collected: 8/30/2020						Laboratory Sample Number: 2009014-009			
						Date / Time Received: 9/2/2020 10:20:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	
Sample Location: 10 1327 V St NW						Customer Program Code: CCPF			
Date Collected: 8/30/2020						Laboratory Sample Number: 2009014-010			
						Date / Time Received: 9/2/2020 10:20:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	4.5	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2020

Report Number: LT-DC-CCPF- 2009044

Sample Location: 1 814 UNDERWOOD ST NW
Date Collected: 9/3/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009044-001
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks

Sample Location: 2 814 UNDERWOOD ST NW
Date Collected: 9/3/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009044-002
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks

Sample Location: 3 814 UNDERWOOD ST NW
Date Collected: 9/3/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009044-003
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks

Sample Location: 4 814 UNDERWOOD ST NW
Date Collected: 9/3/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009044-004
Date / Time Received: 9/8/2020 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 814 UNDERWOOD ST NW						Customer Program Code: CCPF			
Date Collected: 9/3/2020						Laboratory Sample Number: 2009044-005			
						Date / Time Received: 9/8/2020 9:24:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	

Sample Location: 6 814 UNDERWOOD ST NW						Customer Program Code: CCPF			
Date Collected: 9/3/2020						Laboratory Sample Number: 2009044-006			
						Date / Time Received: 9/8/2020 9:24:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	

Sample Location: 7 814 UNDERWOOD ST NW						Customer Program Code: CCPF			
Date Collected: 9/3/2020						Laboratory Sample Number: 2009044-007			
						Date / Time Received: 9/8/2020 9:24:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	

Sample Location: 8 814 UNDERWOOD ST NW						Customer Program Code: CCPF			
Date Collected: 9/3/2020						Laboratory Sample Number: 2009044-008			
						Date / Time Received: 9/8/2020 9:24:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	

Sample Location: 9 814 UNDERWOOD ST NW						Customer Program Code: CCPF			
Date Collected: 9/3/2020						Laboratory Sample Number: 2009044-009			
						Date / Time Received: 9/8/2020 9:24:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	

Sample Location: 10 814 UNDERWOOD ST NW						Customer Program Code: CCPF			
Date Collected: 9/3/2020						Laboratory Sample Number: 2009044-010			
						Date / Time Received: 9/8/2020 9:24:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	ND	ug/L		9/15/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/15/2020	SBrooks	

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 10/6/2020

Report Number: LT-DC-CCPF- 2009074

Sample Location: 1 35 Hamilton St NW
Date Collected: 9/4/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009074-001
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	17.6	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	1.7	ug/L		9/22/2020	SBrooks

Sample Location: 2 35 Hamilton St NW
Date Collected: 9/4/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009074-002
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	0.6	ug/L		9/22/2020	SBrooks

Sample Location: 3 35 Hamilton St NW
Date Collected: 9/4/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009074-003
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 4 35 Hamilton St NW
Date Collected: 9/4/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009074-004
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	0.5	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 35 Hamilton St NW						Customer Program Code: CCPF			
Date Collected: 9/4/2020						Laboratory Sample Number: 2009074-005			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	
Sample Location: 6 35 Hamilton St NW						Customer Program Code: CCPF			
Date Collected: 9/4/2020						Laboratory Sample Number: 2009074-006			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	
Sample Location: 7 35 Hamilton St NW						Customer Program Code: CCPF			
Date Collected: 9/4/2020						Laboratory Sample Number: 2009074-007			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	0.2	ug/L		9/22/2020	SBrooks	
Sample Location: 8 35 Hamilton St NW						Customer Program Code: CCPF			
Date Collected: 9/4/2020						Laboratory Sample Number: 2009074-008			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	
Sample Location: 9 35 Hamilton St NW						Customer Program Code: CCPF			
Date Collected: 9/4/2020						Laboratory Sample Number: 2009074-009			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	0.5	ug/L		9/22/2020	SBrooks	
Sample Location: 10 35 Hamilton St NW						Customer Program Code: CCPF			
Date Collected: 9/4/2020						Laboratory Sample Number: 2009074-010			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 10/6/2020

Report Number: LT-DC-CCPF- 2009075

Sample Location: 1 416 10th St SE
Date Collected: 8/29/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009075-001
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2 416 10th St SE
Date Collected: 8/29/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009075-002
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 3 416 10th St SE
Date Collected: 8/29/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009075-003
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 4 416 10th St SE
Date Collected: 8/29/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009075-004
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 416 10th St SE						Customer Program Code: CCPF			
Date Collected: 8/29/2020						Laboratory Sample Number: 2009075-005			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	

Sample Location: 6 416 10th St SE						Customer Program Code: CCPF			
Date Collected: 8/29/2020						Laboratory Sample Number: 2009075-006			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	

Sample Location: 7 416 10th St SE						Customer Program Code: CCPF			
Date Collected: 8/29/2020						Laboratory Sample Number: 2009075-007			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	

Sample Location: 8 416 10th St SE						Customer Program Code: CCPF			
Date Collected: 8/29/2020						Laboratory Sample Number: 2009075-008			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	

Sample Location: 9 416 10th St SE						Customer Program Code: CCPF			
Date Collected: 8/29/2020						Laboratory Sample Number: 2009075-009			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	

Sample Location: 10 416 10th St SE						Customer Program Code: CCPF			
Date Collected: 8/29/2020						Laboratory Sample Number: 2009075-010			
						Date / Time Received: 9/11/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 10/6/2020

Report Number: LT-DC-CCPF- 2009076

Sample Location: 1518 New Jersey Ave NW

Date Collected: 8/25/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2009076-001

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Sample Location: 1518 New Jersey Ave NW

Date Collected: 8/25/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2009076-002

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Sample Location: 1518 New Jersey Ave NW

Date Collected: 8/25/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2009076-003

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Sample Location: 1518 New Jersey Ave NW

Date Collected: 8/25/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2009076-004

Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 1518 New Jersey Ave NW
Date Collected: 8/25/2020
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF
Laboratory Sample Number: 2009076-005
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	29.4	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Sample Location: 1518 New Jersey Ave NW
Date Collected: 8/25/2020
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF
Laboratory Sample Number: 2009076-006
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Sample Location: 1518 New Jersey Ave NW
Date Collected: 8/25/2020
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF
Laboratory Sample Number: 2009076-007
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Sample Location: 1518 New Jersey Ave NW
Date Collected: 8/25/2020
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF
Laboratory Sample Number: 2009076-008
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Sample Location: 1518 New Jersey Ave NW
Date Collected: 8/25/2020
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF
Laboratory Sample Number: 2009076-009
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Sample Location: 1518 New Jersey Ave NW
Date Collected: 8/25/2020
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF
Laboratory Sample Number: 2009076-010
Date / Time Received: 9/11/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L	H	9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/22/2020	SBrooks

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/6/2020

Report Number: LT-DC-CCPF- 2009090

Sample Location: 1 3507 10TH ST NE
Date Collected: 9/6/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009090-001
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 2 3507 10TH ST NE
Date Collected: 9/6/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009090-002
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 3 3507 10TH ST NE
Date Collected: 9/6/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009090-003
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks

Sample Location: 4 3507 10TH ST NE
Date Collected: 9/6/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009090-004
Date / Time Received: 9/14/2020 10:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		9/22/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 3507 10TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/6/2020						Laboratory Sample Number: 2009090-005			
						Date / Time Received: 9/14/2020 10:08:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.0	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	
Sample Location: 6 3507 10TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/6/2020						Laboratory Sample Number: 2009090-006			
						Date / Time Received: 9/14/2020 10:08:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.9	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	
Sample Location: 7 3507 10TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/6/2020						Laboratory Sample Number: 2009090-007			
						Date / Time Received: 9/14/2020 10:08:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.2	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	
Sample Location: 8 3507 10TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/6/2020						Laboratory Sample Number: 2009090-008			
						Date / Time Received: 9/14/2020 10:08:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.6	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	
Sample Location: 9 3507 10TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/6/2020						Laboratory Sample Number: 2009090-009			
						Date / Time Received: 9/14/2020 10:08:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	
Sample Location: 10 3507 10TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/6/2020						Laboratory Sample Number: 2009090-010			
						Date / Time Received: 9/14/2020 10:08:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.6	ug/L		9/22/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2020

Report Number: LT-DC-CCPF- 2009153

Sample Location: 1 2242 Hall Place NW
Date Collected: 9/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009153-001
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		10/7/2020	SBrooks

Sample Location: 2 2242 Hall Place NW
Date Collected: 9/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009153-002
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 3 2242 Hall Place NW
Date Collected: 9/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009153-003
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 4 2242 Hall Place NW
Date Collected: 9/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009153-004
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 2242 Hall Place NW						Customer Program Code: CCPF			
Date Collected: 9/17/2020						Laboratory Sample Number: 2009153-005			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	6.7	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 6 2242 Hall Place NW						Customer Program Code: CCPF			
Date Collected: 9/17/2020						Laboratory Sample Number: 2009153-006			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	3.8	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 7 2242 Hall Place NW						Customer Program Code: CCPF			
Date Collected: 9/17/2020						Laboratory Sample Number: 2009153-007			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	3.1	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 8 2242 Hall Place NW						Customer Program Code: CCPF			
Date Collected: 9/17/2020						Laboratory Sample Number: 2009153-008			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.8	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 9 2242 Hall Place NW						Customer Program Code: CCPF			
Date Collected: 9/17/2020						Laboratory Sample Number: 2009153-009			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 10 2242 Hall Place NW						Customer Program Code: CCPF			
Date Collected: 9/17/2020						Laboratory Sample Number: 2009153-010			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2020

Report Number: LT-DC-CCPF- 2009154

Sample Location: 1 705 Otis Place NW
Date Collected: 9/15/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009154-001
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2 705 Otis Place NW
Date Collected: 9/15/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009154-002
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 3 705 Otis Place NW
Date Collected: 9/15/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009154-003
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 4 705 Otis Place NW
Date Collected: 9/15/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009154-004
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 705 Otis Place NW						Customer Program Code: CCPF			
Date Collected: 9/15/2020						Laboratory Sample Number: 2009154-005			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 6 705 Otis Place NW						Customer Program Code: CCPF			
Date Collected: 9/15/2020						Laboratory Sample Number: 2009154-006			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.7	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 7 705 Otis Place NW						Customer Program Code: CCPF			
Date Collected: 9/15/2020						Laboratory Sample Number: 2009154-007			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	3.3	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 8 705 Otis Place NW						Customer Program Code: CCPF			
Date Collected: 9/15/2020						Laboratory Sample Number: 2009154-008			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	3.6	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 9 705 Otis Place NW						Customer Program Code: CCPF			
Date Collected: 9/15/2020						Laboratory Sample Number: 2009154-009			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	4.0	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 10 705 Otis Place NW						Customer Program Code: CCPF			
Date Collected: 9/15/2020						Laboratory Sample Number: 2009154-010			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	3.7	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2020

Report Number: LT-DC-CCPF- 2009155

Sample Location: 1 708 19TH ST NE
Date Collected: 9/10/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009155-001
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	0.4	ug/L		10/7/2020	SBrooks

Sample Location: 2 708 19TH ST NE
Date Collected: 9/10/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009155-002
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 3 708 19TH ST NE
Date Collected: 9/10/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009155-003
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 4 708 19TH ST NE
Date Collected: 9/10/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009155-004
Date / Time Received: 9/21/2020 9:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 708 19TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/10/2020						Laboratory Sample Number: 2009155-005			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.7	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 6 708 19TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/10/2020						Laboratory Sample Number: 2009155-006			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	5.7	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 7 708 19TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/10/2020						Laboratory Sample Number: 2009155-007			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	6.7	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 8 708 19TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/10/2020						Laboratory Sample Number: 2009155-008			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.5	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 9 708 19TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/10/2020						Laboratory Sample Number: 2009155-009			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 10 708 19TH ST NE						Customer Program Code: CCPF			
Date Collected: 9/10/2020						Laboratory Sample Number: 2009155-010			
						Date / Time Received: 9/21/2020 9:54:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2020

Report Number: LT-DC-CCPF- 2009167

Sample Location: 3 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-003
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	82.6	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	3.4	ug/L		10/7/2020	SBrooks

Sample Location: 4 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-004
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	32.1	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	9.2	ug/L		10/7/2020	SBrooks

Sample Location: 5 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-005
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	174	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	4.2	ug/L		10/7/2020	SBrooks

Sample Location: 6 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-006
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	83.0	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	4.3	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 7 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-007
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	28.3	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	1.6	ug/L		10/7/2020	SBrooks

Sample Location: 8 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-008
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	291	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	4.4	ug/L		10/7/2020	SBrooks

Sample Location: 9 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-009
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	52.0	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	1.8	ug/L		10/7/2020	SBrooks

Sample Location: 10 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-010
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	54.8	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	1.3	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2020

Report Number: LT-DC-CCPF- 2010005

Sample Location: 1 6218 30 ST NW
Date Collected: 9/26/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010005-001
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 2 6218 30 ST NW
Date Collected: 9/26/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010005-002
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 3 6218 30 ST NW
Date Collected: 9/26/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010005-003
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 4 6218 30 ST NW
Date Collected: 9/26/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010005-004
Date / Time Received: 10/1/2020 7:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 6218 30 ST NW						Customer Program Code: CCPF			
Date Collected: 9/26/2020						Laboratory Sample Number: 2010005-005			
						Date / Time Received: 10/1/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 6 6218 30 ST NW						Customer Program Code: CCPF			
Date Collected: 9/26/2020						Laboratory Sample Number: 2010005-006			
						Date / Time Received: 10/1/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 7 6218 30 ST NW						Customer Program Code: CCPF			
Date Collected: 9/26/2020						Laboratory Sample Number: 2010005-007			
						Date / Time Received: 10/1/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.4	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 8 6218 30 ST NW						Customer Program Code: CCPF			
Date Collected: 9/26/2020						Laboratory Sample Number: 2010005-008			
						Date / Time Received: 10/1/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.2	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 9 6218 30 ST NW						Customer Program Code: CCPF			
Date Collected: 9/26/2020						Laboratory Sample Number: 2010005-009			
						Date / Time Received: 10/1/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.7	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Sample Location: 10 6218 30 ST NW						Customer Program Code: CCPF			
Date Collected: 9/26/2020						Laboratory Sample Number: 2010005-010			
						Date / Time Received: 10/1/2020 7:58:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.9	ug/L		10/7/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/7/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2020

Report Number: LT-DC-CCPF- 2009167

Sample Location: 1 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-001
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	207	ug/L		10/5/2020	SBrooks
Tin	EPA 200.8		0.2	49.5	ug/L		10/5/2020	SBrooks

Sample Location: 2 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-002
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.4	522	ug/L		10/22/2020	SBrooks
Tin	EPA 200.8		0.2	36.1	ug/L		10/5/2020	SBrooks

Sample Location: 3 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-003
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	82.6	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	3.4	ug/L		10/7/2020	SBrooks

Sample Location: 4 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-004
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	32.1	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	9.2	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-005
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	174	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	4.2	ug/L		10/7/2020	SBrooks

Sample Location: 6 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-006
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	83.0	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	4.3	ug/L		10/7/2020	SBrooks

Sample Location: 7 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-007
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	28.3	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	1.6	ug/L		10/7/2020	SBrooks

Sample Location: 8 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-008
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	291	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	4.4	ug/L		10/7/2020	SBrooks

Sample Location: 9 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-009
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	52.0	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	1.8	ug/L		10/7/2020	SBrooks

Sample Location: 10 314 East Capital St NE Apt 207
Date Collected: 9/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2009167-010
Date / Time Received: 9/22/2020 10:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	54.8	ug/L		10/7/2020	SBrooks
Tin	EPA 200.8		0.2	1.3	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 11/19/2020

Report Number: LT-DC-CCPF- 2010072

Sample Location: 1 218 17TH PL NE
Date Collected: 10/5/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010072-001
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 2 218 17TH PL NE
Date Collected: 10/5/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010072-002
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 3 218 17TH PL NE
Date Collected: 10/5/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010072-003
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		10/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks

Sample Location: 4 218 17TH PL NE
Date Collected: 10/5/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010072-004
Date / Time Received: 10/9/2020 8:11:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		10/29/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 218 17TH PL NE						Customer Program Code: CCPF			
Date Collected: 10/5/2020						Laboratory Sample Number: 2010072-005			
						Date / Time Received: 10/9/2020 8:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	4.8	ug/L		10/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks	

Sample Location: 6 218 17TH PL NE						Customer Program Code: CCPF			
Date Collected: 10/5/2020						Laboratory Sample Number: 2010072-006			
						Date / Time Received: 10/9/2020 8:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.5	ug/L		10/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks	

Sample Location: 7 218 17TH PL NE						Customer Program Code: CCPF			
Date Collected: 10/5/2020						Laboratory Sample Number: 2010072-007			
						Date / Time Received: 10/9/2020 8:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	3.8	ug/L		10/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks	

Sample Location: 8 218 17TH PL NE						Customer Program Code: CCPF			
Date Collected: 10/5/2020						Laboratory Sample Number: 2010072-008			
						Date / Time Received: 10/9/2020 8:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	4.7	ug/L		10/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks	

Sample Location: 9 218 17TH PL NE						Customer Program Code: CCPF			
Date Collected: 10/5/2020						Laboratory Sample Number: 2010072-009			
						Date / Time Received: 10/9/2020 8:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks	

Sample Location: 10 218 17TH PL NE						Customer Program Code: CCPF			
Date Collected: 10/5/2020						Laboratory Sample Number: 2010072-010			
						Date / Time Received: 10/9/2020 8:11:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/29/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		10/29/2020	SBrooks	

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 12/3/2020

Report Number: LT-DC-CCPF- 2010207

Sample Location: 1 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-001

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L	H	11/10/2020	SBrooks

Sample Location: 2 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-002

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	11/10/2020	SBrooks

Sample Location: 3 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-003

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	11/10/2020	SBrooks

Sample Location: 4 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-004

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-005

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	11/10/2020	SBrooks

Sample Location: 6 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-006

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	11/10/2020	SBrooks

Sample Location: 7 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-007

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	11/10/2020	SBrooks

Sample Location: 8 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-008

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	11/10/2020	SBrooks

Sample Location: 9 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-009

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	11/10/2020	SBrooks

Sample Location: 10 5716 8TH ST NW

Date Collected: 9/16/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2010207-010

Date / Time Received: 10/29/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 12/3/2020

Report Number: LT-DC-CCPF- 2010217

Sample Location: 1 1664 BEEKMAN PL NW
Date Collected: 10/27/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010217-001
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 2 1664 BEEKMAN PL NW
Date Collected: 10/27/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010217-002
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 3 1664 BEEKMAN PL NW
Date Collected: 10/27/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010217-003
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 4 1664 BEEKMAN PL NW
Date Collected: 10/27/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2010217-004
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 1664 BEEKMAN PL NW **Customer Program Code:** CCPF
Date Collected: 10/27/2020 **Laboratory Sample Number:** 2010217-005
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 6 1664 BEEKMAN PL NW **Customer Program Code:** CCPF
Date Collected: 10/27/2020 **Laboratory Sample Number:** 2010217-006
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 7 1664 BEEKMAN PL NW **Customer Program Code:** CCPF
Date Collected: 10/27/2020 **Laboratory Sample Number:** 2010217-007
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 8 1664 BEEKMAN PL NW **Customer Program Code:** CCPF
Date Collected: 10/27/2020 **Laboratory Sample Number:** 2010217-008
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 9 1664 BEEKMAN PL NW **Customer Program Code:** CCPF
Date Collected: 10/27/2020 **Laboratory Sample Number:** 2010217-009
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Sample Location: 10 1664 BEEKMAN PL NW **Customer Program Code:** CCPF
Date Collected: 10/27/2020 **Laboratory Sample Number:** 2010217-010
Date / Time Received: 10/30/2020 8:06:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2020

Report Number: LT-DC-CCPF- 2011105

Sample Location: 1 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-001

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Sample Location: 2 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-002

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Sample Location: 3 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-003

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Sample Location: 4 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-004

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 5 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-005

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Sample Location: 6 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-006

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Sample Location: 7 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-007

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Sample Location: 8 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-008

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Sample Location: 9 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-009

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Sample Location: 10 224 R St NE

Date Collected: 10/24/2020

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2011105-010

Date / Time Received: 11/12/2020 1:31:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2020

Report Number: LT-DC-CCPF- 2011140

Sample Location: 1 1306 C St NE
Date Collected: 11/10/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011140-001
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2 1306 C St NE
Date Collected: 11/10/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011140-002
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 3 1306 C St NE
Date Collected: 11/10/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011140-003
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 4 1306 C St NE
Date Collected: 11/10/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011140-004
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 1306 C St NE **Customer Program Code:** CCPF
Date Collected: 11/10/2020 **Laboratory Sample Number:** 2011140-005
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 6 1306 C St NE **Customer Program Code:** CCPF
Date Collected: 11/10/2020 **Laboratory Sample Number:** 2011140-006
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 7 1306 C St NE **Customer Program Code:** CCPF
Date Collected: 11/10/2020 **Laboratory Sample Number:** 2011140-007
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 8 1306 C St NE **Customer Program Code:** CCPF
Date Collected: 11/10/2020 **Laboratory Sample Number:** 2011140-008
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 9 1306 C St NE **Customer Program Code:** CCPF
Date Collected: 11/10/2020 **Laboratory Sample Number:** 2011140-009
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 10 1306 C St NE **Customer Program Code:** CCPF
Date Collected: 11/10/2020 **Laboratory Sample Number:** 2011140-010
Date / Time Received: 11/17/2020 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2020

Report Number: LT-DC-CCPF- 2011205

Sample Location: 1 35 Hamilton St NW
Date Collected: 11/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011205-001
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2 35 Hamilton St NW
Date Collected: 11/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011205-002
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 3 35 Hamilton St NW
Date Collected: 11/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011205-003
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 4 35 Hamilton St NW
Date Collected: 11/13/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011205-004
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 35 Hamilton St NW **Customer Program Code:** CCPF
Date Collected: 11/13/2020 **Laboratory Sample Number:** 2011205-005
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 6 35 Hamilton St NW **Customer Program Code:** CCPF
Date Collected: 11/13/2020 **Laboratory Sample Number:** 2011205-006
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 7 35 Hamilton St NW **Customer Program Code:** CCPF
Date Collected: 11/13/2020 **Laboratory Sample Number:** 2011205-007
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 8 35 Hamilton St NW **Customer Program Code:** CCPF
Date Collected: 11/13/2020 **Laboratory Sample Number:** 2011205-008
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 9 35 Hamilton St NW **Customer Program Code:** CCPF
Date Collected: 11/13/2020 **Laboratory Sample Number:** 2011205-009
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 10 35 Hamilton St NW **Customer Program Code:** CCPF
Date Collected: 11/13/2020 **Laboratory Sample Number:** 2011205-010
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/5/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/5/2020	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2020

Report Number: LT-DC-CCPF- 2011206

Sample Location: 1 429 5th St. NE
Date Collected: 11/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011206-001
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		12/4/2020	SBrooks

Sample Location: 2 429 5th St. NE
Date Collected: 11/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011206-002
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.4	ug/L		12/4/2020	SBrooks

Sample Location: 3 429 5th St. NE
Date Collected: 11/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011206-003
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 4 429 5th St. NE
Date Collected: 11/16/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011206-004
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 429 5th St. NE **Customer Program Code:** CCPF
Date Collected: 11/16/2020 **Laboratory Sample Number:** 2011206-005
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 6 429 5th St. NE **Customer Program Code:** CCPF
Date Collected: 11/16/2020 **Laboratory Sample Number:** 2011206-006
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 7 429 5th St. NE **Customer Program Code:** CCPF
Date Collected: 11/16/2020 **Laboratory Sample Number:** 2011206-007
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 8 429 5th St. NE **Customer Program Code:** CCPF
Date Collected: 11/16/2020 **Laboratory Sample Number:** 2011206-008
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 9 429 5th St. NE **Customer Program Code:** CCPF
Date Collected: 11/16/2020 **Laboratory Sample Number:** 2011206-009
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		12/4/2020	SBrooks

Sample Location: 10 429 5th St. NE **Customer Program Code:** CCPF
Date Collected: 11/16/2020 **Laboratory Sample Number:** 2011206-010
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2020

Report Number: LT-DC-CCPF- 2011207

Sample Location: 1 3515 W PL NW
Date Collected: 11/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011207-001
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	11.7	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.7	ug/L		12/4/2020	SBrooks

Sample Location: 2 3515 W PL NW
Date Collected: 11/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011207-002
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		12/4/2020	SBrooks

Sample Location: 3 3515 W PL NW
Date Collected: 11/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011207-003
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 4 3515 W PL NW
Date Collected: 11/17/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011207-004
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 3515 W PL NW						Customer Program Code: CCPF			
Date Collected: 11/17/2020						Laboratory Sample Number: 2011207-005			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.1	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks	

Sample Location: 6 3515 W PL NW						Customer Program Code: CCPF			
Date Collected: 11/17/2020						Laboratory Sample Number: 2011207-006			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	0.4	ug/L		12/4/2020	SBrooks	

Sample Location: 7 3515 W PL NW						Customer Program Code: CCPF			
Date Collected: 11/17/2020						Laboratory Sample Number: 2011207-007			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks	

Sample Location: 8 3515 W PL NW						Customer Program Code: CCPF			
Date Collected: 11/17/2020						Laboratory Sample Number: 2011207-008			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.9	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks	

Sample Location: 9 3515 W PL NW						Customer Program Code: CCPF			
Date Collected: 11/17/2020						Laboratory Sample Number: 2011207-009			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.8	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	1.1	ug/L		12/4/2020	SBrooks	

Sample Location: 10 3515 W PL NW						Customer Program Code: CCPF			
Date Collected: 11/17/2020						Laboratory Sample Number: 2011207-010			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	0.3	ug/L		12/4/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2020

Report Number: LT-DC-CCPF- 2011208

Sample Location: 1 2011 37TH ST NW
Date Collected: 11/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011208-001
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 2 2011 37TH ST NW
Date Collected: 11/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011208-002
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 3 2011 37TH ST NW
Date Collected: 11/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011208-003
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 4 2011 37TH ST NW
Date Collected: 11/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011208-004
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 2011 37TH ST NW						Customer Program Code: CCPF			
Date Collected: 11/20/2020						Laboratory Sample Number: 2011208-005			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	5.6	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks	

Sample Location: 6 2011 37TH ST NW						Customer Program Code: CCPF			
Date Collected: 11/20/2020						Laboratory Sample Number: 2011208-006			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	5.2	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks	

Sample Location: 7 2011 37TH ST NW						Customer Program Code: CCPF			
Date Collected: 11/20/2020						Laboratory Sample Number: 2011208-007			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	5.0	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks	

Sample Location: 8 2011 37TH ST NW						Customer Program Code: CCPF			
Date Collected: 11/20/2020						Laboratory Sample Number: 2011208-008			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	3.4	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks	

Sample Location: 9 2011 37TH ST NW						Customer Program Code: CCPF			
Date Collected: 11/20/2020						Laboratory Sample Number: 2011208-009			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks	

Sample Location: 10 2011 37TH ST NW						Customer Program Code: CCPF			
Date Collected: 11/20/2020						Laboratory Sample Number: 2011208-010			
						Date / Time Received: 11/24/2020 7:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/4/2020	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead and Tin Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2020

Report Number: LT-DC-CCPF- 2011209

Sample Location: 1 220 Q ST NW
Date Collected: 11/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011209-001
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	35.9	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	10.3	ug/L		12/4/2020	SBrooks

Sample Location: 2 220 Q ST NW
Date Collected: 11/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011209-002
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	20.1	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	3.8	ug/L		12/4/2020	SBrooks

Sample Location: 3 220 Q ST NW
Date Collected: 11/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011209-003
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	1.0	ug/L		12/4/2020	SBrooks

Sample Location: 4 220 Q ST NW
Date Collected: 11/20/2020

Customer Program Code: CCPF
Laboratory Sample Number: 2011209-004
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.6	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 5 220 Q ST NW **Customer Program Code:** CCPF
Date Collected: 11/20/2020 **Laboratory Sample Number:** 2011209-005
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		12/4/2020	SBrooks

Sample Location: 6 220 Q ST NW **Customer Program Code:** CCPF
Date Collected: 11/20/2020 **Laboratory Sample Number:** 2011209-006
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		12/4/2020	SBrooks

Sample Location: 7 220 Q ST NW **Customer Program Code:** CCPF
Date Collected: 11/20/2020 **Laboratory Sample Number:** 2011209-007
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Sample Location: 8 220 Q ST NW **Customer Program Code:** CCPF
Date Collected: 11/20/2020 **Laboratory Sample Number:** 2011209-008
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.2	ug/L		12/4/2020	SBrooks

Sample Location: 9 220 Q ST NW **Customer Program Code:** CCPF
Date Collected: 11/20/2020 **Laboratory Sample Number:** 2011209-009
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	0.2	ug/L		12/4/2020	SBrooks

Sample Location: 10 220 Q ST NW **Customer Program Code:** CCPF
Date Collected: 11/20/2020 **Laboratory Sample Number:** 2011209-010
Date / Time Received: 11/24/2020 7:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/4/2020	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Pipe Loop Research

DC Water collected stagnated samples from lead pipe loops to simulate lead levels released in the distribution system. The Washington Aqueduct laboratory analyzed the samples for lead.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/10/2020

Report Number: L-DC-LLP- 10072020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006178-001
Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		6/23/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006178-002
Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.9	ug/L		6/23/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006178-003
Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		6/23/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006178-004
Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		6/23/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006178-005
Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 7/10/2020

Report Number: L-DC-LLP- 10072020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006178-006

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.5	ug/L		6/23/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006178-007

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		6/23/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006178-008

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		6/23/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006178-009

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		6/23/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 6/11/2020 2:15 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006178-010

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		6/23/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-001

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		6/23/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-002

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L		6/23/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-003

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 7/10/2020

Report Number: L-DC-LLP- 10072020

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-004

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		6/23/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-005

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		6/23/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-006

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		6/23/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-007

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		6/23/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-008

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		6/23/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-009

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		6/23/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 6/16/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006179-010

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		6/23/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006180-001

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 7/10/2020

Report Number: L-DC-LLP- 10072020

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006180-002

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		6/23/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006180-003

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		6/23/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006180-004

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		6/23/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006180-005

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		6/23/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006180-006

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		6/23/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006180-007

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		6/23/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006180-008

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		6/23/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006180-009

Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		6/23/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 7/10/2020

Report Number: L-DC-LLP- 10072020

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 6/22/2020 2:30 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006180-010
Date / Time Received: 6/22/2020 3:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		6/23/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: HB
Date / Time Collected: 5/27/2020 9:55 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-001
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	7/1/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: HB
Date / Time Collected: 5/27/2020 9:55 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-002
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L	H	7/1/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 5/27/2020 8:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-003
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/1/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: MC
Date / Time Collected: 6/2/2020 10:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-004
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.9	ug/L	H	7/1/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: MC
Date / Time Collected: 6/2/2020 10:42 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-005
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L	H	7/1/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 6/5/2020 10:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-006
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/1/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 7/10/2020

Report Number: L-DC-LLP- 10072020

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: AAI
Date / Time Collected: 6/10/2020 1:30 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-007
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		7/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: AAI
Date / Time Collected: 6/10/2020 1:30 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-008
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: HB
Date / Time Collected: 6/12/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-009
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.2	ug/L		7/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: HB
Date / Time Collected: 6/12/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-010
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 6/12/2020 11:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-011
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: MC
Date / Time Collected: 6/18/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-012
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		7/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: MC
Date / Time Collected: 6/18/2020 9:02 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-013
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		7/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: AAI
Date / Time Collected: 6/19/2020 2:45 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-014
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minumum Reporting Limit

Report Date: 7/10/2020

Report Number: L-DC-LLP- 10072020

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: AAI
Date / Time Collected: 6/19/2020 2:45 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-015
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		7/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: MC
Date / Time Collected: 6/23/2020 9:05 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-016
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		7/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: MC
Date / Time Collected: 6/23/2020 9:07 AM

Customer Program Code: LLP
Laboratory Sample Number: 2006202-017
Date / Time Received: 6/24/2020 2:05:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		7/1/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006214-001
Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		7/1/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006214-002
Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.3	ug/L		7/1/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006214-003
Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		7/1/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006214-004
Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		7/1/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP
Laboratory Sample Number: 2006214-005
Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minumum Reporting Limit

Report Date: 7/10/2020

Report Number: L-DC-LLP- 10072020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006214-006

Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		7/1/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006214-007

Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		7/1/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006214-008

Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		7/1/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006214-009

Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		7/1/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 6/26/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2006214-010

Date / Time Received: 6/26/2020 2:48:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		7/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/14/2020

Report Number: L-DC-LLP- 14072020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007006-001
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		7/9/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007006-002
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		7/9/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007006-003
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		7/9/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007006-004
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		7/9/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007006-005
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 7/14/2020

Report Number: L-DC-LLP- 14072020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007006-006

Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		7/9/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007006-007

Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		7/9/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007006-008

Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		7/9/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007006-009

Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		7/9/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 7/1/2020 1:55 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007006-010

Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/9/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007007-001

Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		7/9/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007007-002

Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		7/9/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007007-003

Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 7/14/2020

Report Number: L-DC-LLP- 14072020

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007007-004
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		7/9/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007007-005
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		7/9/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007007-006
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		7/9/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007007-007
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		7/9/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007007-008
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		7/9/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007007-009
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		7/9/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 6/30/2020 2:15 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007007-010
Date / Time Received: 7/1/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/9/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 7/7/2020 1:45 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007041-001
Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 7/14/2020

Report Number: L-DC-LLP- 14072020

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 7/7/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007041-002

Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.8	ug/L		7/9/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 7/7/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007041-003

Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		7/9/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 7/7/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007041-004

Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		7/9/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 7/7/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007041-005

Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		7/9/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 7/7/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007041-006

Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.7	ug/L		7/9/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 7/7/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007041-007

Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		7/9/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 7/7/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007041-008

Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		7/9/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 7/7/2020 1:45 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007041-009

Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 7/14/2020

Report Number: L-DC-LLP- 14072020

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2007041-010

Date / Time Collected: 7/7/2020 1:45 PM

Date / Time Received: 7/7/2020 2:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		7/9/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

*Washington Aqueduct
Laboratory*

*5900 MacArthur Blvd, NW
Washington, DC 20016*

*Phone (202) 345-5928
Fax (202) 587-9446*



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 7/21/2020

Report Number: L-DC-LLP- 21072020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007086-001
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		7/16/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007086-002
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.5	ug/L		7/16/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007086-003
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		7/16/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007086-004
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		7/16/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007086-005
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 7/21/2020

Report Number: L-DC-LLP- 21072020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007086-006

Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		7/16/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007086-007

Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		7/16/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007086-008

Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/16/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007086-009

Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/16/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 7/10/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007086-010

Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		7/16/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007087-001

Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		7/16/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007087-002

Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.2	ug/L		7/16/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007087-003

Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 7/21/2020

Report Number: L-DC-LLP- 21072020

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007087-004
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		7/16/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007087-005
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.8	ug/L		7/16/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: DM
Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007087-006
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.6	ug/L		7/16/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: DM
Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007087-007
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.1	ug/L		7/16/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: DM
Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007087-008
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		7/16/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: DM
Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007087-009
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		7/16/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: DM
Date / Time Collected: 7/13/2020 2:20 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007087-010
Date / Time Received: 7/13/2020 4:08:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		7/16/2020	SBrooks

Sample Location: 3900 Donaldson Pl NW (Pipeloop 1)
Sample Collected By: MC
Date / Time Collected: 6/24/2020 9:46 AM

Customer Program Code: LLP
Laboratory Sample Number: 2007113-001
Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L	H	7/16/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 7/21/2020

Report Number: L-DC-LLP- 21072020

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: MC
Date / Time Collected: 6/24/2020 9:48 AM

Customer Program Code: LLP
Laboratory Sample Number: 2007113-002
Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L	H	7/16/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: HB
Date / Time Collected: 6/30/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2007113-003
Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L	H	7/16/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: HB
Date / Time Collected: 6/30/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2007113-004
Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L	H	7/16/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 6/30/2020 10:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2007113-005
Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/16/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: AAI
Date / Time Collected: 7/2/2020 1:00 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007113-006
Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		7/16/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: AAI
Date / Time Collected: 7/2/2020 1:01 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007113-007
Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		7/16/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: AAI
Date / Time Collected: 7/7/2020 1:00 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007113-008
Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 7/21/2020

Report Number: L-DC-LLP- 21072020

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: AAI

Date / Time Collected: 7/7/2020 1:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007113-009

Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		7/16/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: HB

Date / Time Collected: 7/10/2020 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2007113-010

Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		7/16/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 7/10/2020 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2007113-011

Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		7/16/2020	SBrooks

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 7/10/2020 11:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2007113-012

Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: HB

Date / Time Collected: 7/14/2020 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2007113-013

Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		7/16/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 7/14/2020 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2007113-014

Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		7/16/2020	SBrooks

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 7/14/2020 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2007113-015

Date / Time Received: 7/15/2020 3:42:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 8/11/2020

Report Number: L-DC-LLP- 11082020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007211-001
Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		8/6/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007211-002
Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.9	ug/L		8/6/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007211-003
Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		8/6/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007211-004
Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L		8/6/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP
Laboratory Sample Number: 2007211-005
Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	11.0	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 8/11/2020

Report Number: L-DC-LLP- 11082020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007211-006

Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.2	ug/L		8/6/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007211-007

Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		8/6/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007211-008

Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/6/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007211-009

Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/6/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 7/16/2020 2:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007211-010

Date / Time Received: 7/29/2020 2:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		8/6/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-001

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		8/6/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-002

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		8/6/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-003

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 8/11/2020

Report Number: L-DC-LLP- 11082020

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-004

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		8/6/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-005

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.8	ug/L		8/6/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-006

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		8/6/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-007

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		8/6/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-008

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		8/6/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-009

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		8/6/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 7/29/2020 2:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007212-010

Date / Time Received: 7/29/2020 2:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		8/6/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-001

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.6	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 8/11/2020

Report Number: L-DC-LLP- 11082020

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-002

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	11.5	ug/L		8/6/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-003

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.1	ug/L		8/6/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-004

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.6	ug/L		8/6/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-005

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	12.4	ug/L		8/6/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-006

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	14.7	ug/L		8/6/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-007

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	11.1	ug/L		8/6/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-008

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.7	ug/L		8/6/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-009

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 8/11/2020

Report Number: L-DC-LLP- 11082020

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 7/21/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2007226-010

Date / Time Received: 7/31/2020 3:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.3	ug/L		8/6/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-001

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		8/6/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-002

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.9	ug/L		8/6/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-003

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		8/6/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-004

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		8/6/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-005

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		8/6/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-006

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		8/6/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-007

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 8/11/2020

Report Number: L-DC-LLP- 11082020

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-008

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		8/6/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-009

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/6/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 8/3/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008018-010

Date / Time Received: 8/3/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		8/6/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-001
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		8/28/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-002
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		8/28/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-003
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		8/28/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-004
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		8/28/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-005
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.8	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-006
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.0	ug/L		8/28/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-007
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		8/28/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-008
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		8/28/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-009
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/28/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 8/5/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008070-010
Date / Time Received: 8/10/2020 3:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		8/28/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-001
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.4	ug/L		8/28/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-002
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	13.6	ug/L		8/28/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-003
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.1	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-004
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.1	ug/L		8/28/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-005
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	12.9	ug/L		8/28/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-006
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	15.9	ug/L		8/28/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-007
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	11.2	ug/L		8/28/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-008
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.5	ug/L		8/28/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-009
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.0	ug/L		8/28/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: DM
Date / Time Collected: 8/10/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008071-010
Date / Time Received: 8/10/2020 3:34:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.2	ug/L		8/28/2020	SBrooks

Sample Location: 3900 Donaldson Pl NW (Pipeloo 1)
Sample Collected By: YT
Date / Time Collected: 7/16/2020 11:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-001
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L	H	8/28/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: YT
Date / Time Collected: 7/16/2020 11:02 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-002
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L	H	8/28/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: MC
Date / Time Collected: 7/21/2020 10:58 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-003
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L	H	8/28/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: MC
Date / Time Collected: 7/21/2020 10:58 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-004
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L	H	8/28/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: HB
Date / Time Collected: 7/28/2020 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-005
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L	H	8/28/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: HB
Date / Time Collected: 7/28/2020 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-006
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L	H	8/28/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 7/28/2020 10:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-007
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/28/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: HB
Date / Time Collected: 8/5/2020 8:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-008
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.6	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minumum Reporting Limit

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: HB
Date / Time Collected: 8/5/2020 8:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-009
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		8/28/2020	SBrooks

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 8/7/2020 11:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-010
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/28/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: HB
Date / Time Collected: 8/12/2020 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-011
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		8/28/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: HB
Date / Time Collected: 8/12/2020 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008106-012
Date / Time Received: 8/13/2020 8:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		8/28/2020	SBrooks

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-001
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		8/28/2020	SBrooks

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-002
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		8/28/2020	SBrooks

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-003
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/28/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-004
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minumum Reporting Limit

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-005
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		9/1/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-006
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.1	ug/L		8/28/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-007
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		8/28/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-008
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		8/28/2020	SBrooks

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-009
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		8/28/2020	SBrooks

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 8/12/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008170-010
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		8/28/2020	SBrooks

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008171-001
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/28/2020	SBrooks

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008171-002
Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008171-003

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/28/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008171-004

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		8/28/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008171-005

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		8/28/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008171-006

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L		8/28/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008171-007

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		8/28/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008171-008

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		8/28/2020	SBrooks

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008171-009

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		8/28/2020	SBrooks

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 8/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008171-010

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-001

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		8/28/2020	SBrooks

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-002

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		8/28/2020	SBrooks

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-003

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		8/28/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-004

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		8/28/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-005

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		8/28/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-006

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		8/28/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-007

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		8/28/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-008

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		8/28/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-009

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		8/28/2020	SBrooks

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 8/21/2020 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008172-010

Date / Time Received: 8/21/2020 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/28/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-001

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		9/1/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-002

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		9/1/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-003

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		9/1/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-004

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		9/1/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-005

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		9/1/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-006

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.9	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-007

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		9/1/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-008

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		9/1/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-009

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		9/1/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 8/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2008219-010

Date / Time Received: 8/28/2020 9:02:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: HB

Date / Time Collected: 8/14/2020 12:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2008233-001

Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L	H	9/1/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 8/14/2020 12:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2008233-002

Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L	H	9/1/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 8/14/2020 1:30 PM

Customer Program Code: LLP

Laboratory Sample Number: 2008233-003

Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/1/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: MC
Date / Time Collected: 8/18/2020 9:53 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008233-004
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		9/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: MC
Date / Time Collected: 8/18/2020 9:54 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008233-005
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		9/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: HB
Date / Time Collected: 8/21/2020 10:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008233-006
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		9/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: HB
Date / Time Collected: 8/21/2020 10:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008233-007
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 8/21/2020 11:12 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008233-008
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: MC
Date / Time Collected: 8/25/2020 11:07 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008233-009
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		9/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: MC
Date / Time Collected: 8/25/2020 11:08 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008233-010
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		9/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: HB
Date / Time Collected: 8/27/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2008233-011
Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minumum Reporting Limit

Report Date: 9/9/2020

Report Number: L-DC-LLP- 09092020

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Customer Program Code: LLP

Sample Collected By: HB

Laboratory Sample Number: 2008233-012

Date / Time Collected: 8/27/2020 9:30 AM

Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		9/1/2020	SBrooks

Sample Location: 3900 Donaldson PI NW Baseline

Customer Program Code: LLP

Sample Collected By: HB

Laboratory Sample Number: 2008233-013

Date / Time Collected: 8/27/2020 11:00 AM

Date / Time Received: 8/31/2020 1:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

*Washington Aqueduct
Laboratory*

*5900 MacArthur Blvd, NW
Washington, DC 20016*

*Phone (202) 345-5928
Fax (202) 587-9446*



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 10/6/2020

Report Number: L-DC-LLP- 06102020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009079-001
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		9/22/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009079-002
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		9/22/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009079-003
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		9/22/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009079-004
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		9/22/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009079-005
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/6/2020

Report Number: L-DC-LLP- 06102020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009079-006

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.9	ug/L		9/22/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009079-007

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		9/22/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009079-008

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		9/22/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009079-009

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		9/22/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 9/1/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009079-010

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		9/22/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 8/28/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009080-001

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		9/22/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 8/28/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009080-002

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		9/22/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 8/28/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009080-003

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 10/6/2020

Report Number: L-DC-LLP- 06102020

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 8/28/2020 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009080-004
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		9/22/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 8/28/2020 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009080-005
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		9/22/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 8/28/2020 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009080-006
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		9/22/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 8/28/2020 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009080-007
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		9/22/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 8/28/2020 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009080-008
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		9/22/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 8/28/2020 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009080-009
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		9/22/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 8/28/2020 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009080-010
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		9/22/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By:
Date / Time Collected: 9/11/2020 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009081-001
Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 10/6/2020

Report Number: L-DC-LLP- 06102020

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By:

Date / Time Collected: 9/11/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009081-002

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		9/22/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By:

Date / Time Collected: 9/11/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009081-003

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		9/22/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By:

Date / Time Collected: 9/11/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009081-004

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		9/22/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By:

Date / Time Collected: 9/11/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009081-005

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		9/22/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By:

Date / Time Collected: 9/11/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009081-006

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		9/22/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By:

Date / Time Collected: 9/11/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009081-007

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		9/22/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By:

Date / Time Collected: 9/11/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009081-008

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/22/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By:

Date / Time Collected: 9/11/2020 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009081-009

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/6/2020

Report Number: L-DC-LLP- 06102020

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By:

Laboratory Sample Number: 2009081-010

Date / Time Collected: 9/11/2020 9:15 AM

Date / Time Received: 9/11/2020 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		9/22/2020	SBrooks

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-001

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		9/22/2020	SBrooks

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-002

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		9/22/2020	SBrooks

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-003

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.1	ug/L		9/22/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-004

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		9/22/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-005

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		9/22/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-006

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		9/22/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-007

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Report Date: 10/6/2020

Report Number: L-DC-LLP- 06102020

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-008

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		9/22/2020	SBrooks

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-009

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/22/2020	SBrooks

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2009107-010

Date / Time Collected: 9/15/2020 9:00 AM

Date / Time Received: 9/15/2020 10:41:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		9/22/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009188-001
Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		10/7/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009188-002
Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		10/7/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009188-003
Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		10/7/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009188-004
Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		10/7/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009188-005
Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009188-006

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		10/7/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009188-007

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		10/7/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009188-008

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		10/7/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009188-009

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		10/7/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 9/16/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009188-010

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		10/7/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-001

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		10/7/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-002

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		10/7/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-003

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-004

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		10/7/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-005

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		10/7/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-006

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		10/7/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-007

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		10/7/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-008

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		10/7/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-009

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		10/7/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 9/23/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009189-010

Date / Time Received: 9/23/2020 3:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		10/7/2020	SBrooks

Sample Location: 3900 donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 9/1/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009211-001

Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L	H	10/7/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 3900 donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 9/1/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-002
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L	H	10/7/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 donaldson PI NW Pipeloop 1
Sample Collected By: MC
Date / Time Collected: 9/9/2020 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-003
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L	H	10/7/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 donaldson PI NW Pipeloop 3
Sample Collected By: MC
Date / Time Collected: 9/9/2020 9:46 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-004
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L	H	10/7/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 donaldson PI NW Pipeloop 1
Sample Collected By: HB
Date / Time Collected: 9/11/2020 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-005
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L	H	10/7/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 9/11/2020 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-006
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L	H	10/7/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 9/11/2020 11:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-007
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/7/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 donaldson PI NW Pipeloop 1
Sample Collected By: MC
Date / Time Collected: 9/15/2020 9:13 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-008
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 3900 donaldson PI NW Pipeloop 3
Sample Collected By: MC
Date / Time Collected: 9/15/2020 9:14 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-009
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		10/7/2020	SBrooks

Sample Location: 3900 donaldson PI NW Pipeloop 1
Sample Collected By: MC
Date / Time Collected: 9/23/2020 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-010
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		10/7/2020	SBrooks

Sample Location: 3900 donaldson PI NW Pipeloop 3
Sample Collected By: MC
Date / Time Collected: 9/23/2020 9:46 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-011
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		10/7/2020	SBrooks

Sample Location: 3900 donaldson PI NW Pipeloop 1
Sample Collected By: HB
Date / Time Collected: 9/25/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-012
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		10/7/2020	SBrooks

Sample Location: 3900 donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 9/25/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-013
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		10/7/2020	SBrooks

Sample Location: 3900 donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 9/25/2020 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009211-014
Date / Time Received: 9/28/2020 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/7/2020	SBrooks

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009227-001
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		10/7/2020	SBrooks

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009227-002
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009227-003

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		10/7/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009227-004

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		10/7/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009227-005

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/7/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009227-006

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.8	ug/L		10/7/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009227-007

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		10/7/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009227-008

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		10/7/2020	SBrooks

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009227-009

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		10/7/2020	SBrooks

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 9/29/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009227-010

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009228-001
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.8	ug/L		10/7/2020	SBrooks

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009228-002
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.9	ug/L		10/7/2020	SBrooks

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009228-003
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.2	ug/L		10/7/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009228-004
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.5	ug/L		10/7/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009228-005
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.4	ug/L		10/7/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009228-006
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	11.3	ug/L		10/7/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009228-007
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.8	ug/L		10/7/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2009228-008
Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.2	ug/L		10/7/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009228-009

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.0	ug/L		10/7/2020	SBrooks

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 9/25/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2009228-010

Date / Time Received: 9/30/2020 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.4	ug/L		10/7/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010052-001

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		10/8/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010052-002

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		10/8/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010052-003

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		10/8/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010052-004

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		10/8/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010052-005

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		10/8/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010052-006

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010052-007
Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		10/8/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010052-008
Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		10/8/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010052-009
Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		10/8/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 9/30/2020 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010052-010
Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		10/8/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010053-001
Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		10/8/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010053-002
Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		10/8/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010053-003
Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		10/8/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010053-004
Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 10/19/2020

Report Number: L-DC-LLP- 19102020

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010053-005

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		10/8/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010053-006

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		10/8/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010053-007

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		10/8/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010053-008

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		10/8/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010053-009

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		10/8/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 10/6/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010053-010

Date / Time Received: 10/7/2020 3:18:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		10/8/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 11/18/2020

Report Number: L-DC-LLP- 18112020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010091-001
Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		10/29/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010091-002
Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		10/29/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010091-003
Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		10/29/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010091-004
Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		10/29/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010091-005
Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 11/18/2020

Report Number: L-DC-LLP- 18112020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010091-006

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		10/29/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010091-007

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		10/29/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010091-008

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		10/29/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010091-009

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		10/29/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 10/13/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010091-010

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		10/29/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-001

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		10/29/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-002

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		10/29/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-003

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 11/18/2020

Report Number: L-DC-LLP- 18112020

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-004

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		10/29/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-005

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		10/29/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-006

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.8	ug/L		10/29/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-007

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		10/29/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-008

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		10/29/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-009

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		10/29/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 10/9/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010092-010

Date / Time Received: 10/13/2020 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		10/29/2020	SBrooks

Sample Location: 3900 Donaldson Pl NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 9/29/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010130-001

Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L	H	10/29/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 11/18/2020

Report Number: L-DC-LLP- 18112020

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 9/29/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010130-002
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L	H	10/29/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 9/29/2020 10:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010130-003
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/29/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: HB
Date / Time Collected: 10/2/2020 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010130-004
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	10/29/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 10/2/2020 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010130-005
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L	H	10/29/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 10/2/2020 12:00 PM

Customer Program Code: LLP
Laboratory Sample Number: 2010130-006
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/29/2020	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: HB
Date / Time Collected: 10/6/2020 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010130-007
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		10/29/2020	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 10/6/2020 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010130-008
Date / Time Received: 10/19/2020 9:09:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 11/18/2020

Report Number: L-DC-LLP- 18112020

Sample Location: 3900 Donaldson PI NW Pipeloop 1						Customer Program Code: LLP		
Sample Collected By: HB						Laboratory Sample Number: 2010130-009		
Date / Time Collected: 10/9/2020 10:00 AM						Date / Time Received: 10/19/2020 9:09:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		10/29/2020	SBrooks
Sample Location: 3900 Donaldson PI NW Pipeloop 3						Customer Program Code: LLP		
Sample Collected By: HB						Laboratory Sample Number: 2010130-010		
Date / Time Collected: 10/9/2020 10:00 AM						Date / Time Received: 10/19/2020 9:09:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		10/29/2020	SBrooks
Sample Location: 3900 Donaldson PI NW Baseline						Customer Program Code: LLP		
Sample Collected By: HB						Laboratory Sample Number: 2010130-011		
Date / Time Collected: 10/9/2020 11:30 AM						Date / Time Received: 10/19/2020 9:09:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks
Sample Location: 3900 Donaldson PI NW Pipeloop 1						Customer Program Code: LLP		
Sample Collected By: MC						Laboratory Sample Number: 2010130-012		
Date / Time Collected: 10/14/2020 10:17 AM						Date / Time Received: 10/19/2020 9:09:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		10/29/2020	SBrooks
Sample Location: 3900 Donaldson PI NW Pipeloop 3						Customer Program Code: LLP		
Sample Collected By: MC						Laboratory Sample Number: 2010130-013		
Date / Time Collected: 10/14/2020 10:18 AM						Date / Time Received: 10/19/2020 9:09:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		10/29/2020	SBrooks
Sample Location: 3900 Donaldson PI NW Pipeloop 1						Customer Program Code: LLP		
Sample Collected By: HB						Laboratory Sample Number: 2010130-014		
Date / Time Collected: 10/16/2020 10:30 AM						Date / Time Received: 10/19/2020 9:09:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		10/29/2020	SBrooks
Sample Location: 3900 Donaldson PI NW Pipeloop 3						Customer Program Code: LLP		
Sample Collected By: HB						Laboratory Sample Number: 2010130-015		
Date / Time Collected: 10/16/2020 10:30 AM						Date / Time Received: 10/19/2020 9:09:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		10/29/2020	SBrooks
Sample Location: 3900 Donaldson PI NW Baseline						Customer Program Code: LLP		
Sample Collected By: HB						Laboratory Sample Number: 2010130-016		
Date / Time Collected: 10/16/2020 12:00 PM						Date / Time Received: 10/19/2020 9:09:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 11/18/2020

Report Number: L-DC-LLP- 18112020

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-001

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		10/29/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-002

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		10/29/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-003

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		10/29/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-004

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		10/29/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-005

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		10/29/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-006

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.0	ug/L		10/29/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-007

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		10/29/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-008

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 11/18/2020

Report Number: L-DC-LLP- 18112020

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-009

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		10/29/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 10/20/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010166-010

Date / Time Received: 10/23/2020 9:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		10/29/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

*Washington Aqueduct
Laboratory*

*5900 MacArthur Blvd, NW
Washington, DC 20016*

*Phone (202) 345-5928
Fax (202) 587-9446*



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 12/3/2020

Report Number: L-DC-LLP- 03122020

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010219-001
Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		11/10/2020	SBrooks

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010219-002
Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		11/10/2020	SBrooks

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010219-003
Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		11/10/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010219-004
Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		11/10/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2010219-005
Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/3/2020

Report Number: L-DC-LLP- 03122020

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010219-006

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.5	ug/L		11/10/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010219-007

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		11/10/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010219-008

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		11/10/2020	SBrooks

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010219-009

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		11/10/2020	SBrooks

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 10/16/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010219-010

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		11/10/2020	SBrooks

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-001

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		11/10/2020	SBrooks

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-002

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		11/10/2020	SBrooks

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-003

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/3/2020

Report Number: L-DC-LLP- 03122020

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-004

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		11/10/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-005

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		11/10/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-006

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		11/10/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-007

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		11/10/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-008

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		11/10/2020	SBrooks

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-009

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		11/10/2020	SBrooks

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 10/22/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010220-010

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		11/10/2020	SBrooks

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 10/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010221-001

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/3/2020

Report Number: L-DC-LLP- 03122020

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 10/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010221-002

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/10/2020	SBrooks

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 10/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010221-003

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/10/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 10/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010221-004

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		11/10/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 10/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010221-005

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		11/10/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 10/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010221-006

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		11/10/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 10/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010221-007

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		11/10/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 10/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010221-008

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		11/10/2020	SBrooks

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 10/30/2020 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2010221-009

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/3/2020

Report Number: L-DC-LLP- 03122020

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2010221-010

Date / Time Collected: 10/30/2020 9:20 AM

Date / Time Received: 10/30/2020 10:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/10/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Customer Program Code: LLP

Sample Collected By: MC

Laboratory Sample Number: 2011029-001

Date / Time Collected: 10/21/2020 9:45 AM

Date / Time Received: 11/3/2020 2:26:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		11/10/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Customer Program Code: LLP

Sample Collected By: MC

Laboratory Sample Number: 2011029-002

Date / Time Collected: 10/21/2020 9:46 AM

Date / Time Received: 11/3/2020 2:26:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		11/10/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Customer Program Code: LLP

Sample Collected By: MC

Laboratory Sample Number: 2011029-003

Date / Time Collected: 10/27/2020 9:30 AM

Date / Time Received: 11/3/2020 2:26:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		11/10/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Customer Program Code: LLP

Sample Collected By: MC

Laboratory Sample Number: 2011029-004

Date / Time Collected: 10/27/2020 9:31 AM

Date / Time Received: 11/3/2020 2:26:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		11/10/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Customer Program Code: LLP

Sample Collected By: MC

Laboratory Sample Number: 2011029-005

Date / Time Collected: 11/3/2020 9:51 AM

Date / Time Received: 11/3/2020 2:26:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		11/10/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2011029-006

Date / Time Collected: 11/3/2020 9:51 AM

Date / Time Received: 11/3/2020 2:26:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		11/10/2020	SBrooks

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2011037-001

Date / Time Collected: 11/4/2020 9:05 AM

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Report Date: 12/3/2020

Report Number: L-DC-LLP- 03122020

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 11/4/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011037-002

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		11/10/2020	SBrooks

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 11/4/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011037-003

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		11/10/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 11/4/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011037-004

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		11/10/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 11/4/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011037-005

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		11/10/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 11/4/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011037-006

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		11/10/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 11/4/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011037-007

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		11/10/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 11/4/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011037-008

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		11/10/2020	SBrooks

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 11/4/2020 9:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011037-009

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/3/2020

Report Number: L-DC-LLP- 03122020

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2011037-010

Date / Time Collected: 11/4/2020 9:05 AM

Date / Time Received: 11/4/2020 10:19:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		11/10/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

*Washington Aqueduct
Laboratory*

*5900 MacArthur Blvd, NW
Washington, DC 20016*

*Phone (202) 345-5928
Fax (202) 587-9446*



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2020

Report Number: L-DC-LLP- 14122020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011077-001
Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		12/4/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011077-002
Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		12/4/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011077-003
Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/4/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011077-004
Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		12/4/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011077-005
Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/14/2020

Report Number: L-DC-LLP- 14122020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011077-006

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		12/4/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011077-007

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		12/4/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011077-008

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		12/4/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011077-009

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		12/4/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 11/6/2020 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011077-010

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		12/4/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-001

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		12/4/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-002

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		12/4/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-003

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 12/14/2020

Report Number: L-DC-LLP- 14122020

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-004

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		12/4/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-005

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		12/4/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-006

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		12/4/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-007

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		12/4/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-008

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		12/4/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-009

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		12/4/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 11/10/2020 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011078-010

Date / Time Received: 11/10/2020 11:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/4/2020	SBrooks

Sample Location: 3900 Donaldson Pl NW (Pipeloop 1)

Sample Collected By: HB

Date / Time Collected: 11/15/2020 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011170-001

Date / Time Received: 11/19/2020 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 12/14/2020

Report Number: L-DC-LLP- 14122020

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: HB
Date / Time Collected: 11/15/2020 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011170-002
Date / Time Received: 11/19/2020 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/4/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: DM
Date / Time Collected: 11/17/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011170-003
Date / Time Received: 11/19/2020 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		12/4/2020	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: DM
Date / Time Collected: 11/17/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011170-004
Date / Time Received: 11/19/2020 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		12/4/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-001
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		12/4/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-002
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		12/4/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-003
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		12/4/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-004
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/4/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-005
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minumum Reporting Limit

Report Date: 12/14/2020

Report Number: L-DC-LLP- 14122020

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-006
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		12/4/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-007
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		12/4/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-008
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		12/4/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-009
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		12/4/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 11/13/2020 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011223-010
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/4/2020	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011224-001
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		12/4/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011224-002
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/4/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2011224-003
Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 12/14/2020

Report Number: L-DC-LLP- 14122020

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011224-004

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		12/4/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011224-005

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		12/4/2020	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011224-006

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		12/4/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011224-007

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		12/4/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011224-008

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		12/4/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011224-009

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		12/4/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 11/20/2020 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011224-010

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		12/4/2020	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 11/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011225-001

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 12/14/2020

Report Number: L-DC-LLP- 14122020

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 11/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011225-002

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		12/4/2020	SBrooks

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 11/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011225-003

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/4/2020	SBrooks

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 11/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011225-004

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		12/4/2020	SBrooks

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 11/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011225-005

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		12/4/2020	SBrooks

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 11/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011225-006

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		12/4/2020	SBrooks

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 11/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011225-007

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	12.6	ug/L		12/4/2020	SBrooks

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 11/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011225-008

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		12/4/2020	SBrooks

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 11/27/2020 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2011225-009

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/14/2020

Report Number: L-DC-LLP- 14122020

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2011225-010

Date / Time Collected: 11/27/2020 8:50 AM

Date / Time Received: 11/27/2020 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

*Washington Aqueduct
Laboratory*

*5900 MacArthur Blvd, NW
Washington, DC 20016*

*Phone (202) 345-5928
Fax (202) 587-9446*



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
 5900 MacArthur Blvd, NW
 Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 12/18/2020

Report Number: L-DC-LLP- 18122020

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2012015-001
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		12/4/2020	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2012015-002
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/4/2020	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2012015-003
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		12/4/2020	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2012015-004
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		12/4/2020	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2012015-005
Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

**Washington Aqueduct
 Laboratory**

**5900 MacArthur Blvd, NW
 Washington, DC 20016**

**Phone (202) 345-5928
 Fax (202) 587-9446**

Report Date: 12/18/2020

Report Number: L-DC-LLP- 18122020

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2012015-006

Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		12/4/2020	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2012015-007

Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/4/2020	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2012015-008

Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/4/2020	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2012015-009

Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		12/4/2020	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 12/1/2020 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2012015-010

Date / Time Received: 12/2/2020 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		12/4/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit