

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306015-023

Sample Location: 1st Draw 1207 Queen St. NE

Customer Sample Number:

Date / Time Collected: 5/29/2023 6:22 PM

Customer Program Code: DS

Laboratory Sample Number: 2306015-023

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1207 Queen St. NE

Customer Sample Number:

Date / Time Collected: 5/29/2023 6:23 PM

Customer Program Code: DS

Laboratory Sample Number: 2306015-024

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-019

Sample Location: 1st Draw 1316 Leegate Rd. NW

Customer Sample Number:

Date / Time Collected: 6/8/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-019

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1316 Leegate Rd. NW

Customer Sample Number:

Date / Time Collected: 6/8/2023 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-020

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306015-019

Sample Location: 1st Draw 1316 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 8:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2306015-019

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1316 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2306015-020

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305212-015

Sample Location: 1st Draw 1334 Taylor St. NE

Customer Sample Number:

Date / Time Collected: 5/23/2023 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-015

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1334 Taylor St. NE

Customer Sample Number:

Date / Time Collected: 5/23/2023 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-016

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-033

Sample Location: 1st Draw 1501 Channing St. NE

Customer Sample Number:

Date / Time Collected: 6/6/2023 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-033

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1501 Channing St. NE

Customer Sample Number:

Date / Time Collected: 6/6/2023 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-034

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306015-013

Sample Location: 1st Draw 1503 19th St. SE

Customer Sample Number:

Date / Time Collected: 5/26/2023 6:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2306015-013

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1503 19th St. SE

Customer Sample Number:

Date / Time Collected: 5/26/2023 6:22 PM

Customer Program Code: DS

Laboratory Sample Number: 2306015-014

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305188-017

Sample Location: 1st Draw 1520 Taylor St. NE

Customer Sample Number:

Date / Time Collected: 5/21/2023 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-017

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1520 Taylor St. NE

Customer Sample Number:

Date / Time Collected: 5/21/2023 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-018

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305188-001

Sample Location: 1st Draw 1627 Newton St. NW

Customer Sample Number:

Date / Time Collected: 4/18/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-001

Date / Time Received: 5/25/2023 10:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	6/22/2023	SBrooks

Sample Location: 2nd Draw 1627 Newton St. NW

Customer Sample Number:

Date / Time Collected: 4/18/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-002

Date / Time Received: 5/25/2023 10:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-023

Sample Location: 1st Draw 1674 Beekman PL Unit D

Customer Sample Number:

Date / Time Collected: 6/9/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-023

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1674 Beekman PL Unit D

Customer Sample Number:

Date / Time Collected: 6/9/2023 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-024

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-031

Sample Location: 1st Draw 1721 Hobart St. NW

Customer Sample Number:

Date / Time Collected: 6/6/2023 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-031

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1721 Hobart St. NW

Customer Sample Number:

Date / Time Collected: 6/6/2023 7:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-032

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306015-015

Sample Location: 1st Draw 1836 Irving St. NW

Customer Sample Number:

Date / Time Collected: 5/28/2023 10:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2306015-015

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1836 Irving St. NW

Customer Sample Number:

Date / Time Collected: 5/28/2023 10:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2306015-016

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-037

Sample Location: 1st Draw 1853 Vernon St. NW

Customer Sample Number:

Date / Time Collected: 6/7/2023 10:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-037

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1853 Vernon St. NW

Customer Sample Number:

Date / Time Collected: 6/7/2023 10:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-038

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305188-005

Sample Location: 1st Draw 1918 S St. NW
Customer Sample Number:
Date / Time Collected: 5/14/2023 10:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2305188-005
Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1918 S St. NW
Customer Sample Number:
Date / Time Collected: 5/14/2023 10:37 AM

Customer Program Code: DS
Laboratory Sample Number: 2305188-006
Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-021

Sample Location: 1st Draw 211 Quackenbos St. NW

Customer Sample Number:

Date / Time Collected: 6/9/2023 4:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-021

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 211 Quackenbos St. NW

Customer Sample Number:

Date / Time Collected: 6/9/2023 4:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-022

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305188-015

Sample Location: 1st Draw 2113 2nd St. NW

Customer Sample Number:

Date / Time Collected: 5/20/2023 5:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-015

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 2113 2nd St. NW

Customer Sample Number:

Date / Time Collected: 5/20/2023 5:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-016

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305188-019

Sample Location: 1st Draw 229 Jefferson St. NW

Customer Sample Number:

Date / Time Collected: 5/22/2023 8:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-019

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 229 Jefferson St. NW

Customer Sample Number:

Date / Time Collected: 5/22/2023 8:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-020

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-015

Sample Location: 1st Draw 2355 Ashmead PL NW

Customer Sample Number:

Date / Time Collected: 5/28/2023 5:33 PM

Customer Program Code: DS

Laboratory Sample Number: 2306108-015

Date / Time Received: 6/15/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/22/2023	SBrooks

Sample Location: 2nd Draw 2355 Ashmead PL NW

Customer Sample Number:

Date / Time Collected: 5/28/2023 5:34 PM

Customer Program Code: DS

Laboratory Sample Number: 2306108-016

Date / Time Received: 6/15/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-017

Sample Location: 1st Draw 250 10th St. NE

Customer Sample Number:

Date / Time Collected: 6/7/2023 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2306108-017

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 250 10th St. NE

Customer Sample Number:

Date / Time Collected: 6/7/2023 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2306108-018

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-039

Sample Location: 1st Draw 2601 Newton St. NE

Customer Sample Number:

Date / Time Collected: 6/8/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-039

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 2601 Newton St. NE

Customer Sample Number:

Date / Time Collected: 6/8/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-040

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305212-011

Sample Location: 1st Draw 2712 27th St. NW

Customer Sample Number:

Date / Time Collected: 5/20/2023 5:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-011

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 2712 27th St. NW

Customer Sample Number:

Date / Time Collected: 5/20/2023 5:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-012

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305188-013

Sample Location: 1st Draw 3051 N St. NW
Customer Sample Number:
Date / Time Collected: 5/19/2023 5:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2305188-013
Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 3051 N St. NW
Customer Sample Number:
Date / Time Collected: 5/19/2023 5:33 AM

Customer Program Code: DS
Laboratory Sample Number: 2305188-014
Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305212-013

Sample Location: 1st Draw 308 Longfellow St. NW

Customer Sample Number:

Date / Time Collected: 5/22/2023 3:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2305212-013

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 308 Longfellow St. NW

Customer Sample Number:

Date / Time Collected: 5/22/2023 3:03 PM

Customer Program Code: DS

Laboratory Sample Number: 2305212-014

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305212-017

Sample Location: 1st Draw 3225 Garfield St. NW

Customer Sample Number:

Date / Time Collected: 5/23/2023 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-017

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 3225 Garfield St. NW

Customer Sample Number:

Date / Time Collected: 5/23/2023 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-018

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-029

Sample Location: 1st Draw 327 63rd St. NE
Customer Sample Number:
Date / Time Collected: 6/1/2023 9:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2306108-029
Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 327 63rd St. NE
Customer Sample Number:
Date / Time Collected: 6/1/2023 10:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2306108-030
Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305212-021

Sample Location: 1st Draw 3303 Prospect St. NW

Customer Sample Number:

Date / Time Collected: 5/24/2023 10:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-021

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	22.0	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 3303 Prospect St. NW

Customer Sample Number:

Date / Time Collected: 5/24/2023 10:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-022

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305188-009

Sample Location: 1st Draw 3361 18th St. NW

Customer Sample Number:

Date / Time Collected: 5/17/2023 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-009

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 3361 18th St. NW

Customer Sample Number:

Date / Time Collected: 5/17/2023 7:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-010

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306015-021

Sample Location: 1st Draw 3443 24th St. SE
Customer Sample Number:
Date / Time Collected: 5/29/2023 10:49 AM

Customer Program Code: DS
Laboratory Sample Number: 2306015-021
Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 3443 24th St. SE
Customer Sample Number:
Date / Time Collected: 5/29/2023 10:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2306015-022
Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/13/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2305188-003

Sample Location: 1st Draw 4110 3rd St. NW

Customer Sample Number:

Date / Time Collected: 5/18/2023 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-003

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 4110 3rd St. NW

Customer Sample Number:

Date / Time Collected: 5/18/2023 7:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-004

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306015-011

Sample Location: 1st Draw 4508 Chesapeake St. NW

Customer Sample Number:

Date / Time Collected: 5/24/2023 6:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2306015-011

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 4508 Chesapeake St. NW

Customer Sample Number:

Date / Time Collected: 5/24/2023 6:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2306015-012

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305212-019

Sample Location: 1st Draw 4526 29th St. NW

Customer Sample Number:

Date / Time Collected: 5/23/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-019

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 4526 29th St. NW

Customer Sample Number:

Date / Time Collected: 5/23/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2305212-020

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305188-011

Sample Location: 1st Draw 4613 15th St. NW #A

Customer Sample Number:

Date / Time Collected: 5/17/2023 11:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-011

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 4613 15th St. NW #A

Customer Sample Number:

Date / Time Collected: 5/17/2023 11:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-012

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-035

Sample Location: 1st Draw 626 3rd St. NE
Customer Sample Number:
Date / Time Collected: 6/7/2023 8:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2306108-035
Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 626 3rd St. NE
Customer Sample Number:
Date / Time Collected: 6/7/2023 8:14 AM

Customer Program Code: DS
Laboratory Sample Number: 2306108-036
Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2305188-007

Sample Location: 1st Draw 636 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 5/17/2023 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-007

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 636 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 5/17/2023 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2305188-008

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-013

Sample Location: 1st Draw 719 N. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 5/28/2023 2:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2306108-013

Date / Time Received: 6/15/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/22/2023	SBrooks

Sample Location: 2nd Draw 719 N. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 5/28/2023 2:06 PM

Customer Program Code: DS

Laboratory Sample Number: 2306108-014

Date / Time Received: 6/15/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306015-017

Sample Location: 1st Draw 728 Rock Creek Church Rd. NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 9:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2306015-017

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 728 Rock Creek Church Rd. NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 9:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2306015-018

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS-2306108-027

Sample Location: 1st Draw 7530 13th St. NW

Customer Sample Number:

Date / Time Collected: 6/1/2023 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-027

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 7530 13th St. NW

Customer Sample Number:

Date / Time Collected: 6/1/2023 6:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2306108-028

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS250- 2306109-005

Sample Location: 1st Draw 1330 New Hampshire Ave

Customer Sample Number:

Date / Time Collected: 6/7/2023 9:04 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306109-005

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1330 New Hampshire Ave

Customer Sample Number:

Date / Time Collected: 6/7/2023 9:04 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306109-006

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS250- 2306016-001

Sample Location: 1st Draw 1500 Pennsylvania Ave. SE Apt. 202

Customer Sample Number:

Date / Time Collected: 5/30/2023 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306016-001

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1500 Pennsylvania Ave. SE Apt. 202

Customer Sample Number:

Date / Time Collected: 5/30/2023 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306016-002

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS250- 2306109-003

Sample Location: 1st Draw 221 Constitution Ave. NE

Customer Sample Number:

Date / Time Collected: 6/6/2023 5:05 PM

Customer Program Code: DS250

Laboratory Sample Number: 2306109-003

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 221 Constitution Ave. NE

Customer Sample Number:

Date / Time Collected: 6/6/2023 5:05 PM

Customer Program Code: DS250

Laboratory Sample Number: 2306109-004

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS250- 2305189-001

Sample Location: 1st Draw 3 Tingey Sq. SE #703

Customer Sample Number:

Date / Time Collected: 5/17/2023 9:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2305189-001

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 3 Tingey Sq. SE #703

Customer Sample Number:

Date / Time Collected: 5/17/2023 9:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2305189-002

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS250- 2305216-001

Sample Location: 1st Draw 300 Morse St. NE #914

Customer Sample Number:

Date / Time Collected: 5/23/2023 9:48 AM

Customer Program Code: DS250

Laboratory Sample Number: 2305216-001

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 300 Morse St. NE #914

Customer Sample Number:

Date / Time Collected: 5/23/2023 9:48 AM

Customer Program Code: DS250

Laboratory Sample Number: 2305216-002

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-DS250- 2306109-001

Sample Location: 1st Draw 4201 Massachusetts Ave. NW (4023)

Customer Sample Number:

Date / Time Collected: 5/31/2023 4:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2306109-001

Date / Time Received: 6/15/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/22/2023	SBrooks

Sample Location: 2nd Draw 4201 Massachusetts Ave. NW (4023)

Customer Sample Number:

Date / Time Collected: 5/31/2023 4:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2306109-002

Date / Time Received: 6/15/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-005

Sample Location: 1st Draw 1028 D St. NE
Customer Sample Number:
Date / Time Collected: 6/19/2023 1:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2307001-005
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 1028 D St. NE
Customer Sample Number:
Date / Time Collected: 6/19/2023 1:33 PM

Customer Program Code: DS
Laboratory Sample Number: 2307001-006
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-027

Sample Location: 1st Draw 1117 1/2 6th Street NE

Customer Sample Number:

Date / Time Collected: 6/14/2023 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-027

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 1117 1/2 6th Street NE

Customer Sample Number:

Date / Time Collected: 6/14/2023 7:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-028

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-013

Sample Location: 1st Draw 1219 Duncan PL NE

Customer Sample Number:

Date / Time Collected: 6/13/2023 5:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-013

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 1219 Duncan PL NE

Customer Sample Number:

Date / Time Collected: 6/13/2023 5:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-014

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-021

Sample Location: 1st Draw 1412 Newton St. NW

Customer Sample Number:

Date / Time Collected: 6/13/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-021

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 1412 Newton St. NW

Customer Sample Number:

Date / Time Collected: 6/13/2023 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-022

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-029

Sample Location: 1st Draw 1437 Parkwood PL NW

Customer Sample Number:

Date / Time Collected: 6/14/2023 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-029

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 1437 Parkwood PL NW

Customer Sample Number:

Date / Time Collected: 6/14/2023 10:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-030

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-051

Sample Location: 1st Draw 1627 Gales St. NE

Customer Sample Number:

Date / Time Collected: 6/25/2023 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-051

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 1627 Gales St. NE

Customer Sample Number:

Date / Time Collected: 6/25/2023 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-052

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-015

Sample Location: 1st Draw 1829 Kilbourne PL NW

Customer Sample Number:

Date / Time Collected: 6/13/2023 7:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-015

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 1829 Kilbourne PL NW

Customer Sample Number:

Date / Time Collected: 6/13/2023 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-016

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-053

Sample Location: 1st Draw 214 N St. NW
Customer Sample Number:
Date / Time Collected: 6/25/2023 3:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2307001-053
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 214 N St. NW
Customer Sample Number:
Date / Time Collected: 6/25/2023 3:10 PM

Customer Program Code: DS
Laboratory Sample Number: 2307001-054
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-023

Sample Location: 1st Draw 2331 14th PL SE

Customer Sample Number:

Date / Time Collected: 6/13/2023 9:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-023

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 2331 14th PL SE

Customer Sample Number:

Date / Time Collected: 6/13/2023 9:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-024

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-003

Sample Location: 1st Draw 3417 Baker St. NE

Customer Sample Number:

Date / Time Collected: 6/18/2023 7:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-003

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 3417 Baker St. NE

Customer Sample Number:

Date / Time Collected: 6/18/2023 7:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-004

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-049

Sample Location: 1st Draw 3538 Alton PL NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-049

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 3538 Alton PL NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-050

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-007

Sample Location: 1st Draw 3915 13th St. NW

Customer Sample Number:

Date / Time Collected: 6/20/2023 3:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-007

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 3915 13th St. NW

Customer Sample Number:

Date / Time Collected: 6/20/2023 3:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-008

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-007

Sample Location: 1st Draw 4107 18th St. NW

Customer Sample Number:

Date / Time Collected: 6/5/2023 5:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-007

Date / Time Received: 6/26/2023 10:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/11/2023	SBrooks

Sample Location: 2nd Draw 4107 18th St. NW

Customer Sample Number:

Date / Time Collected: 6/5/2023 5:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-008

Date / Time Received: 6/26/2023 10:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-069

Sample Location: 1st Draw 4427 Iowa Ave. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-069

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 4427 Iowa Ave. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-070

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-019

Sample Location: 1st Draw 512 6th St. NE
Customer Sample Number:
Date / Time Collected: 6/13/2023 7:23 AM

Customer Program Code: DS
Laboratory Sample Number: 2306182-019
Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 512 6th St. NE
Customer Sample Number:
Date / Time Collected: 6/13/2023 7:27 AM

Customer Program Code: DS
Laboratory Sample Number: 2306182-020
Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-025

Sample Location: 1st Draw 528 Edgewood St. NE

Customer Sample Number:

Date / Time Collected: 6/14/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-025

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 528 Edgewood St. NE

Customer Sample Number:

Date / Time Collected: 6/14/2023 7:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-026

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-011

Sample Location: 1st Draw 5710 Nevada Ave. NW

Customer Sample Number:

Date / Time Collected: 6/12/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-011

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 5710 Nevada Ave. NW

Customer Sample Number:

Date / Time Collected: 6/12/2023 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-012

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-001

Sample Location: 1st Draw 6018 3rd St. NW

Customer Sample Number:

Date / Time Collected: 6/16/2023 3:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2307001-001

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 6018 3rd St. NW

Customer Sample Number:

Date / Time Collected: 6/16/2023 3:27 PM

Customer Program Code: DS

Laboratory Sample Number: 2307001-002

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-017

Sample Location: 1st Draw 604 Columbia Rd. NW #2

Customer Sample Number:

Date / Time Collected: 6/13/2023 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-017

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 604 Columbia Rd. NW #2

Customer Sample Number:

Date / Time Collected: 6/13/2023 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-018

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2306182-009

Sample Location: 1st Draw 632 Webster St. NW

Customer Sample Number:

Date / Time Collected: 6/8/2023 7:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-009

Date / Time Received: 6/26/2023 10:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	7/11/2023	SBrooks

Sample Location: 2nd Draw 632 Webster St. NW

Customer Sample Number:

Date / Time Collected: 6/8/2023 7:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2306182-010

Date / Time Received: 6/26/2023 10:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.2	ug/L	H	7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-057

Sample Location: 1st Draw 6713 2nd St. NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 9:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2307001-057

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 6713 2nd St. NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 9:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2307001-058

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS-2307001-061

Sample Location: 1st Draw 7001 31st St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-061

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 7001 31st St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2307001-062

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS250- 2306183-007

Sample Location: 1st Draw 1349 Kenyon St NW Apt 26
Customer Sample Number:
Date / Time Collected: 6/13/2023 6:58 AM

Customer Program Code: DS250
Laboratory Sample Number: 2306183-007
Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 1349 Kenyon St NW Apt 26
Customer Sample Number:
Date / Time Collected: 6/13/2023 6:58 AM

Customer Program Code: DS250
Laboratory Sample Number: 2306183-008
Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS250- 2306183-005

Sample Location: 1st Draw 1545 18th St NW #703

Customer Sample Number:

Date / Time Collected: 6/12/2023 9:02 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306183-005

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 1545 18th St NW #703

Customer Sample Number:

Date / Time Collected: 6/12/2023 9:02 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306183-006

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS250- 2306183-001

Sample Location: 1st Draw 2131 Florida Ave NW #32

Customer Sample Number:

Date / Time Collected: 6/5/2023 12:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2306183-001

Date / Time Received: 6/26/2023 10:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/11/2023	SBrooks

Sample Location: 2nd Draw 2131 Florida Ave NW #32

Customer Sample Number:

Date / Time Collected: 6/5/2023 12:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2306183-002

Date / Time Received: 6/26/2023 10:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS250- 2307002-001

Sample Location: 1st Draw 2251 12th St. NW Unit 5

Customer Sample Number:

Date / Time Collected: 6/20/2023 7:42 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307002-001

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 2251 12th St. NW Unit 5

Customer Sample Number:

Date / Time Collected: 6/20/2023 7:42 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307002-002

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS250- 2306183-003

Sample Location: 1st Draw 3541 11th St NW #203

Customer Sample Number:

Date / Time Collected: 6/12/2023 8:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306183-003

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 3541 11th St NW #203

Customer Sample Number:

Date / Time Collected: 6/12/2023 8:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306183-004

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-DS250- 2306183-009

Sample Location: 1st Draw 809 Otis PI NW Apt 2

Customer Sample Number:

Date / Time Collected: 6/14/2023 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306183-009

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 809 Otis PI NW Apt 2

Customer Sample Number:

Date / Time Collected: 6/14/2023 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2306183-010

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/19/2023

Report Number: L-DC-DS-2306108-025

Sample Location: 1st Draw 122 Seaton PL NW

Customer Sample Number:

Date / Time Collected: 5/30/2023 10:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2306108-025

Date / Time Received: 6/15/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2	87.1	ug/L	H	6/29/2023	SBrooks

Sample Location: 2nd Draw 122 Seaton PL NW

Customer Sample Number:

Date / Time Collected: 5/30/2023 10:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2306108-026

Date / Time Received: 6/15/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2	9.8	ug/L	H	6/29/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-053

Sample Location: 1st Draw 1205 Trinidad Ave. NE

Customer Sample Number:

Date / Time Collected: 7/13/2023 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-053

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 1205 Trinidad Ave. NE

Customer Sample Number:

Date / Time Collected: 7/13/2023 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-054

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-009

Sample Location: 1st Draw 1217 Owen PL NE

Customer Sample Number:

Date / Time Collected: 6/28/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-009

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1217 Owen PL NE

Customer Sample Number:

Date / Time Collected: 6/28/2023 7:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-010

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-001

Sample Location: 1st Draw 1320 Randolph St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-001

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	7/17/2023	Bprakash

Sample Location: 2nd Draw 1320 Randolph St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2023 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-002

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-039

Sample Location: 1st Draw 1329 F St. NE
Customer Sample Number:
Date / Time Collected: 7/9/2023 7:09 PM

Customer Program Code: DS
Laboratory Sample Number: 2307112-039
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 1329 F St. NE
Customer Sample Number:
Date / Time Collected: 7/9/2023 7:09 PM

Customer Program Code: DS
Laboratory Sample Number: 2307112-040
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-047

Sample Location: 1st Draw 1334 Hemlock St. NW

Customer Sample Number:

Date / Time Collected: 7/11/2023 5:22 PM

Customer Program Code: DS

Laboratory Sample Number: 2307112-047

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 1334 Hemlock St. NW

Customer Sample Number:

Date / Time Collected: 7/11/2023 5:26 PM

Customer Program Code: DS

Laboratory Sample Number: 2307112-048

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-027

Sample Location: 1st Draw 1347 Quincy St. NW Unit 1
Customer Sample Number:
Date / Time Collected: 7/6/2023 5:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2307112-027
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 1347 Quincy St. NW Unit 1
Customer Sample Number:
Date / Time Collected: 7/6/2023 5:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2307112-028
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-043

Sample Location: 1st Draw 1415 K St. SE
Customer Sample Number:
Date / Time Collected: 7/10/2023 4:37 AM

Customer Program Code: DS
Laboratory Sample Number: 2307112-043
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 1415 K St. SE
Customer Sample Number:
Date / Time Collected: 7/10/2023 4:37 AM

Customer Program Code: DS
Laboratory Sample Number: 2307112-044
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	13.3	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307098-005

Sample Location: 1st Draw 1526 Manor St. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 6:07 PM

Customer Program Code: DS

Laboratory Sample Number: 2307098-005

Date / Time Received: 7/13/2023 11:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	7/20/2023	Bprakash

Sample Location: 2nd Draw 1526 Manor St. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 6:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2307098-006

Date / Time Received: 7/13/2023 11:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/20/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307098-007

Sample Location: 1st Draw 1672 Kalorama Rd. NW
Customer Sample Number:
Date / Time Collected: 6/8/2023 7:29 AM
Customer Program Code: DS
Laboratory Sample Number: 2307098-007
Date / Time Received: 7/13/2023 11:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	7/20/2023	Bprakash

Sample Location: 2nd Draw 1672 Kalorama Rd. NW
Customer Sample Number:
Date / Time Collected: 6/8/2023 7:31 AM
Customer Program Code: DS
Laboratory Sample Number: 2307098-008
Date / Time Received: 7/13/2023 11:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.5	ug/L	H	7/20/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-021

Sample Location: 1st Draw 1728 Independence Ave SE
Customer Sample Number:
Date / Time Collected: 7/18/2023 5:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2307154-021
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 1728 Independence Ave SE
Customer Sample Number:
Date / Time Collected: 7/18/2023 5:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2307154-022
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-007

Sample Location: 1st Draw 208 Randolph PI NE

Customer Sample Number:

Date / Time Collected: 7/12/2023 4:31 PM

Customer Program Code: DS

Laboratory Sample Number: 2307154-007

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 208 Randolph PI NE

Customer Sample Number:

Date / Time Collected: 7/12/2023 4:34 PM

Customer Program Code: DS

Laboratory Sample Number: 2307154-008

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-011

Sample Location: 1st Draw 2220 Tunlaw Rd. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 8:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-011

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 2220 Tunlaw Rd. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 8:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-012

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-041

Sample Location: 1st Draw 241 Rock Creek Church Rd. NW

Customer Sample Number:

Date / Time Collected: 7/9/2023 11:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2307112-041

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 241 Rock Creek Church Rd. NW

Customer Sample Number:

Date / Time Collected: 7/9/2023 11:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2307112-042

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/2/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2307112-051

Sample Location: 1st Draw 2520 17th St. NE

Customer Sample Number:

Date / Time Collected: 7/13/2023 6:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-051

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 2520 17th St. NE

Customer Sample Number:

Date / Time Collected: 7/13/2023 6:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-052

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-019

Sample Location: 1st Draw 2537 Queen Annes Ln NW

Customer Sample Number:

Date / Time Collected: 7/17/2023 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-019

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 2537 Queen Annes Ln NW

Customer Sample Number:

Date / Time Collected: 7/17/2023 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-020

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-049

Sample Location: 1st Draw 2739 Woodley PL NW

Customer Sample Number:

Date / Time Collected: 7/12/2023 7:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-049

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 2739 Woodley PL NW

Customer Sample Number:

Date / Time Collected: 7/12/2023 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-050

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-017

Sample Location: 1st Draw 2946 Carlton Ave NE

Customer Sample Number:

Date / Time Collected: 7/17/2023 7:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-017

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 2946 Carlton Ave NE

Customer Sample Number:

Date / Time Collected: 7/17/2023 7:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-018

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-015

Sample Location: 1st Draw 310 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 7/1/2023 9:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-015

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 310 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 7/1/2023 9:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-016

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-015

Sample Location: 1st Draw 313 Adams St NE

Customer Sample Number:

Date / Time Collected: 7/17/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-015

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 313 Adams St NE

Customer Sample Number:

Date / Time Collected: 7/17/2023 6:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-016

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-021

Sample Location: 1st Draw 3412 Rittenhouse St. NW

Customer Sample Number:

Date / Time Collected: 7/4/2023 3:24 PM

Customer Program Code: DS

Laboratory Sample Number: 2307049-021

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 3412 Rittenhouse St. NW

Customer Sample Number:

Date / Time Collected: 7/4/2023 3:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2307049-022

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-017

Sample Location: 1st Draw 3423 Oakwood Ter. NW
Customer Sample Number:
Date / Time Collected: 7/3/2023 9:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2307049-017
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 3423 Oakwood Ter. NW
Customer Sample Number:
Date / Time Collected: 7/3/2023 9:31 AM

Customer Program Code: DS
Laboratory Sample Number: 2307049-018
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-037

Sample Location: 1st Draw 3606 Rock Creek Church Rd. NW, #305

Customer Sample Number:

Date / Time Collected: 7/9/2023 6:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2307112-037

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 3606 Rock Creek Church Rd. NW, #305

Customer Sample Number:

Date / Time Collected: 7/9/2023 6:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2307112-038

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-031

Sample Location: 1st Draw 3650 Upton St. NW

Customer Sample Number:

Date / Time Collected: 7/6/2023 1:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2307112-031

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 3650 Upton St. NW

Customer Sample Number:

Date / Time Collected: 7/6/2023 1:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2307112-032

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-003

Sample Location: 1st Draw 3816 Van Ness St NW

Customer Sample Number:

Date / Time Collected: 7/10/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-003

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 3816 Van Ness St NW

Customer Sample Number:

Date / Time Collected: 7/10/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-004

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-005

Sample Location: 1st Draw 3905 Alton PI NW

Customer Sample Number:

Date / Time Collected: 7/18/2023 3:43 PM

Customer Program Code: DS

Laboratory Sample Number: 2307154-005

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 3905 Alton PI NW

Customer Sample Number:

Date / Time Collected: 7/18/2023 3:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2307154-006

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-023

Sample Location: 1st Draw 405 12th St SE
Customer Sample Number:
Date / Time Collected: 7/18/2023 8:45 PM

Customer Program Code: DS
Laboratory Sample Number: 2307154-023
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 405 12th St SE
Customer Sample Number:
Date / Time Collected: 7/18/2023 8:49 PM

Customer Program Code: DS
Laboratory Sample Number: 2307154-024
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-013

Sample Location: 1st Draw 410 4th St SE
Customer Sample Number:
Date / Time Collected: 7/17/2023 5:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2307154-013
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 410 4th St SE
Customer Sample Number:
Date / Time Collected: 7/17/2023 5:31 AM

Customer Program Code: DS
Laboratory Sample Number: 2307154-014
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/2/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2307154-011

Sample Location: 1st Draw 4108 4th St NW
Customer Sample Number:
Date / Time Collected: 7/15/2023 7:39 AM

Customer Program Code: DS
Laboratory Sample Number: 2307154-011
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 4108 4th St NW
Customer Sample Number:
Date / Time Collected: 7/15/2023 7:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2307154-012
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-045

Sample Location: 1st Draw 424 Oneida PL NW

Customer Sample Number:

Date / Time Collected: 7/10/2023 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-045

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 424 Oneida PL NW

Customer Sample Number:

Date / Time Collected: 7/10/2023 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-046

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-003

Sample Location: 1st Draw 434 Kentucky Ave. SE

Customer Sample Number:

Date / Time Collected: 6/24/2023 5:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-003

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 434 Kentucky Ave. SE

Customer Sample Number:

Date / Time Collected: 6/24/2023 5:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-004

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-019

Sample Location: 1st Draw 4416 Windom PL NW

Customer Sample Number:

Date / Time Collected: 7/4/2023 6:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-019

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 4416 Windom PL NW

Customer Sample Number:

Date / Time Collected: 7/4/2023 6:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-020

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/2/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2307112-025

Sample Location: 1st Draw 4508 Argyle Ter. NW

Customer Sample Number:

Date / Time Collected: 7/5/2023 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-025

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 4508 Argyle Ter. NW

Customer Sample Number:

Date / Time Collected: 7/5/2023 6:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-026

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-005

Sample Location: 1st Draw 4621 5th St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 7:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-005

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 4621 5th St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 7:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-006

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-035

Sample Location: 1st Draw 4830 Blagden Ave. NW

Customer Sample Number:

Date / Time Collected: 7/8/2023 11:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-035

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.8	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 4830 Blagden Ave. NW

Customer Sample Number:

Date / Time Collected: 7/8/2023 11:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-036

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-013

Sample Location: 1st Draw 5019 7th Place NW

Customer Sample Number:

Date / Time Collected: 6/30/2023 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-013

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 5019 7th Place NW

Customer Sample Number:

Date / Time Collected: 6/30/2023 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2307049-014

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-009

Sample Location: 1st Draw 5108 Macomb St NW

Customer Sample Number:

Date / Time Collected: 7/15/2023 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-009

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 5108 Macomb St NW

Customer Sample Number:

Date / Time Collected: 7/15/2023 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-010

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307154-001

Sample Location: 1st Draw 5204 13th St NW

Customer Sample Number:

Date / Time Collected: 3/22/2023 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-001

Date / Time Received: 7/21/2023 9:16:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. Results are considered biased low.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	7/27/2023	Bprakash

Sample Location: 2nd Draw 5204 13th St NW

Customer Sample Number:

Date / Time Collected: 3/22/2023 7:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2307154-002

Date / Time Received: 7/21/2023 9:16:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. Results are considered biased low.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-029

Sample Location: 1st Draw 5338 32nd St. NW

Customer Sample Number:

Date / Time Collected: 7/6/2023 6:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-029

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 5338 32nd St. NW

Customer Sample Number:

Date / Time Collected: 7/6/2023 6:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2307112-030

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307049-007

Sample Location: 1st Draw 6428 8th St. NW
Customer Sample Number:
Date / Time Collected: 6/27/2023 10:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2307049-007
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 6428 8th St. NW
Customer Sample Number:
Date / Time Collected: 6/27/2023 10:33 AM

Customer Program Code: DS
Laboratory Sample Number: 2307049-008
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS-2307112-033

Sample Location: 1st Draw 901 11th St. NE
Customer Sample Number:
Date / Time Collected: 7/7/2023 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2307112-033
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 901 11th St. NE
Customer Sample Number:
Date / Time Collected: 7/7/2023 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2307112-034
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307066-003

Sample Location: 1st Draw 1025 1st SE, # 406

Customer Sample Number:

Date / Time Collected: 7/3/2023 10:08 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-003

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	Bprakash

Sample Location: 2nd Draw 1025 1st SE, # 406

Customer Sample Number:

Date / Time Collected: 7/3/2023 10:08 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-004

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307155-001

Sample Location: 1st Draw 1390 Kenyon St NW (518)

Customer Sample Number:

Date / Time Collected: 7/13/2023 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307155-001

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 1390 Kenyon St NW (518)

Customer Sample Number:

Date / Time Collected: 7/13/2023 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307155-002

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307048-005

Sample Location: 1st Draw 1415 Rhode Island Ave. NW, Apt. 313

Customer Sample Number:

Date / Time Collected: 6/27/2023 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-005

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1415 Rhode Island Ave. NW, Apt. 313

Customer Sample Number:

Date / Time Collected: 6/27/2023 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-006

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307155-003

Sample Location: 1st Draw 1420 Clifton St NW #304

Customer Sample Number:

Date / Time Collected: 7/17/2023 6:50 PM

Customer Program Code: DS250

Laboratory Sample Number: 2307155-003

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 1420 Clifton St NW #304

Customer Sample Number:

Date / Time Collected: 7/17/2023 6:50 PM

Customer Program Code: DS250

Laboratory Sample Number: 2307155-004

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307048-003

Sample Location: 1st Draw 1423 R St. NW, #105

Customer Sample Number:

Date / Time Collected: 6/27/2023 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-003

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1423 R St. NW, #105

Customer Sample Number:

Date / Time Collected: 6/27/2023 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-004

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307048-009

Sample Location: 1st Draw 1818 Kalorama Rd. NW, Apt.40

Customer Sample Number:

Date / Time Collected: 6/28/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-009

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1818 Kalorama Rd. NW, Apt.40

Customer Sample Number:

Date / Time Collected: 6/28/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-010

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307066-007

Sample Location: 1st Draw 1824 Belmont Rd. NW, #33

Customer Sample Number:

Date / Time Collected: 7/7/2023 8:48 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-007

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/20/2023	Bprakash

Sample Location: 2nd Draw 1824 Belmont Rd. NW, #33

Customer Sample Number:

Date / Time Collected: 7/7/2023 8:49 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-008

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307066-001

Sample Location: 1st Draw 1929 Calvert St. NW, #3

Customer Sample Number:

Date / Time Collected: 7/2/2023 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-001

Date / Time Received: 7/17/2023 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/20/2023	BPrakash

Sample Location: 2nd Draw 1929 Calvert St. NW, #3

Customer Sample Number:

Date / Time Collected: 7/2/2023 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-002

Date / Time Received: 7/17/2023 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307048-001

Sample Location: 1st Draw 3000 Connecticut Ave. NW, #125

Customer Sample Number:

Date / Time Collected: 6/26/2023 5:03 PM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-001

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 3000 Connecticut Ave. NW, #125

Customer Sample Number:

Date / Time Collected: 6/26/2023 5:03 PM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-002

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307066-005

Sample Location: 1st Draw 3020 Dent Place NW, Apt. 46W

Customer Sample Number:

Date / Time Collected: 7/8/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-005

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	Bprakash

Sample Location: 2nd Draw 3020 Dent Place NW, Apt. 46W

Customer Sample Number:

Date / Time Collected: 7/8/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-006

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307155-005

Sample Location: 1st Draw 3460 14th St NW, Apt 31

Customer Sample Number:

Date / Time Collected: 7/18/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307155-005

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 3460 14th St NW, Apt 31

Customer Sample Number:

Date / Time Collected: 7/18/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307155-006

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307097-001

Sample Location: 1st Draw 3810 39th St NW, #F126

Customer Sample Number:

Date / Time Collected: 6/28/2023 5:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2307097-001

Date / Time Received: 7/13/2023 11:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	7/20/2023	BPrakash

Sample Location: 2nd Draw 3810 39th St NW, #F126

Customer Sample Number:

Date / Time Collected: 6/28/2023 5:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2307097-002

Date / Time Received: 7/13/2023 11:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307066-009

Sample Location: 1st Draw 3900 Watson PL NW, #B-4E

Customer Sample Number:

Date / Time Collected: 7/11/2023 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-009

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	Bprakash

Sample Location: 2nd Draw 3900 Watson PL NW, #B-4E

Customer Sample Number:

Date / Time Collected: 7/11/2023 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307066-010

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/20/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-DS250- 2307048-007

Sample Location: 1st Draw 5406 Connecticut Ave. NW, 704

Customer Sample Number:

Date / Time Collected: 6/27/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-007

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 5406 Connecticut Ave. NW, 704

Customer Sample Number:

Date / Time Collected: 6/27/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2307048-008

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/9/2023

Report Number: L-DC-DS-2307193-001

Sample Location: 1st Draw 1822 Calvert St. NW, #1
Customer Sample Number:
Date / Time Collected: 7/16/2023 6:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2307193-001
Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/2/2023	LGallimore

Sample Location: 2nd Draw 1822 Calvert St. NW, #1
Customer Sample Number:
Date / Time Collected: 7/16/2023 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2307193-002
Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/2/2023	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/9/2023

Report Number: L-DC-DS-2307193-007

Sample Location: 1st Draw 3125 12th St. NE

Customer Sample Number:

Date / Time Collected: 7/20/2023 7:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2307193-007

Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/2/2023	LGallimore

Sample Location: 2nd Draw 3125 12th St. NE

Customer Sample Number:

Date / Time Collected: 7/20/2023 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2307193-008

Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/2/2023	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/9/2023

Report Number: L-DC-DS-2307193-009

Sample Location: 1st Draw 3213 Adams Mill Rd. NW

Customer Sample Number:

Date / Time Collected: 7/20/2023 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2307193-009

Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/2/2023	LGallimore

Sample Location: 2nd Draw 3213 Adams Mill Rd. NW

Customer Sample Number:

Date / Time Collected: 7/20/2023 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2307193-010

Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/2/2023	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/9/2023

Report Number: L-DC-DS-2307193-011

Sample Location: 1st Draw 331 W St. NE
Customer Sample Number:
Date / Time Collected: 7/20/2023 5:11 PM

Customer Program Code: DS
Laboratory Sample Number: 2307193-011
Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		8/2/2023	LGallimore

Sample Location: 2nd Draw 331 W St. NE
Customer Sample Number:
Date / Time Collected: 7/20/2023 5:12 PM

Customer Program Code: DS
Laboratory Sample Number: 2307193-012
Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		8/2/2023	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308039-017

Sample Location: 1st Draw 1011 Hamlin St. NE

Customer Sample Number:

Date / Time Collected: 7/31/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308039-017

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1011 Hamlin St. NE

Customer Sample Number:

Date / Time Collected: 7/31/2023 8:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2308039-018

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2308038-005

Sample Location: 1st Draw 116 Bryant St. NW

Customer Sample Number:

Date / Time Collected: 7/28/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2308038-005

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 116 Bryant St. NW

Customer Sample Number:

Date / Time Collected: 7/28/2023 6:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2308038-006

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-039

Sample Location: 1st Draw 1325 Sheridan St. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-039

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1325 Sheridan St. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-040

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-019

Sample Location: 1st Draw 1344 Vermont Ave. NW

Customer Sample Number:

Date / Time Collected: 7/25/2023 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-019

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1344 Vermont Ave. NW

Customer Sample Number:

Date / Time Collected: 7/25/2023 6:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-020

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-035

Sample Location: 1st Draw 1810 Riggs PL NW, #1

Customer Sample Number:

Date / Time Collected: 7/27/2023 5:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-035

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1810 Riggs PL NW, #1

Customer Sample Number:

Date / Time Collected: 7/27/2023 5:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-036

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-013

Sample Location: 1st Draw 1827 6th St. NW, #4

Customer Sample Number:

Date / Time Collected: 7/24/2023 4:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2308062-013

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Sample Location: 2nd Draw 1827 6th St. NW, #4

Customer Sample Number:

Date / Time Collected: 7/24/2023 4:06 PM

Customer Program Code: DS

Laboratory Sample Number: 2308062-014

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-045

Sample Location: 1st Draw 1933 First St. NE

Customer Sample Number:

Date / Time Collected: 7/27/2023 11:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2308062-045

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1933 First St. NE

Customer Sample Number:

Date / Time Collected: 7/27/2023 11:23 PM

Customer Program Code: DS

Laboratory Sample Number: 2308062-046

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-003

Sample Location: 1st Draw 218 Morgan St. NW Unit 2 (or Apt B)

Customer Sample Number:

Date / Time Collected: 7/22/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-003

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Sample Location: 2nd Draw 218 Morgan St. NW Unit 2 (or Apt B)

Customer Sample Number:

Date / Time Collected: 7/22/2023 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-004

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-041

Sample Location: 1st Draw 2905 N St. NW
Customer Sample Number:
Date / Time Collected: 7/27/2023 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2308062-041
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 2905 N St. NW
Customer Sample Number:
Date / Time Collected: 7/27/2023 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2308062-042
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-009

Sample Location: 1st Draw 3318 19th St. NW

Customer Sample Number:

Date / Time Collected: 7/24/2023 5:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-009

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Sample Location: 2nd Draw 3318 19th St. NW

Customer Sample Number:

Date / Time Collected: 7/24/2023 5:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-010

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-027

Sample Location: 1st Draw 3621 Ordway St. NW

Customer Sample Number:

Date / Time Collected: 7/21/2023 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-027

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	8/10/2023	Lgallimore

Sample Location: 2nd Draw 3621 Ordway St. NW

Customer Sample Number:

Date / Time Collected: 7/21/2023 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-028

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308039-003

Sample Location: 1st Draw 3712 35th St. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2308039-003

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 3712 35th St. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 7:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2308039-004

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308039-009

Sample Location: 1st Draw 3724 Benton St. NW

Customer Sample Number:

Date / Time Collected: 7/28/2023 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2308039-009

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 3724 Benton St. NW

Customer Sample Number:

Date / Time Collected: 7/28/2023 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2308039-010

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308038-017

Sample Location: 1st Draw 3751 W St. NW
Customer Sample Number:
Date / Time Collected: 8/1/2023 6:46 AM

Customer Program Code: DS
Laboratory Sample Number: 2308038-017
Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 3751 W St. NW
Customer Sample Number:
Date / Time Collected: 8/1/2023 6:48 AM

Customer Program Code: DS
Laboratory Sample Number: 2308038-018
Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-049

Sample Location: 1st Draw 3922 13th St. NE

Customer Sample Number:

Date / Time Collected: 7/28/2023 7:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-049

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 3922 13th St. NE

Customer Sample Number:

Date / Time Collected: 7/28/2023 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-050

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-001

Sample Location: 1st Draw 4116 10th St. NE

Customer Sample Number:

Date / Time Collected: 7/21/2023 6:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2308062-001

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Sample Location: 2nd Draw 4116 10th St. NE

Customer Sample Number:

Date / Time Collected: 7/21/2023 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-002

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-053

Sample Location: 1st Draw 422 20th St. NE
Customer Sample Number:
Date / Time Collected: 7/31/2023 2:37 PM

Customer Program Code: DS
Laboratory Sample Number: 2308062-053
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 422 20th St. NE
Customer Sample Number:
Date / Time Collected: 7/31/2023 2:41 PM

Customer Program Code: DS
Laboratory Sample Number: 2308062-054
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-005

Sample Location: 1st Draw 4407 Foote St. NE

Customer Sample Number:

Date / Time Collected: 7/22/2023 9:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-005

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Sample Location: 2nd Draw 4407 Foote St. NE

Customer Sample Number:

Date / Time Collected: 7/22/2023 9:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-006

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-007

Sample Location: 1st Draw 4611 44th St. NW

Customer Sample Number:

Date / Time Collected: 7/22/2023 9:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-007

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	8/10/2023	Lgallimore

Sample Location: 2nd Draw 4611 44th St. NW

Customer Sample Number:

Date / Time Collected: 7/22/2023 9:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-008

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-025

Sample Location: 1st Draw 4818 Nebraska Ave

Customer Sample Number:

Date / Time Collected: 7/26/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-025

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 4818 Nebraska Ave

Customer Sample Number:

Date / Time Collected: 7/26/2023 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-026

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-021

Sample Location: 1st Draw 5115 Cathedral Ave. NW
Customer Sample Number:
Date / Time Collected: 7/25/2023 7:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2308062-021
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 5115 Cathedral Ave. NW
Customer Sample Number:
Date / Time Collected: 7/25/2023 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2308062-022
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308062-055

Sample Location: 1st Draw 5166 Tilden St. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-055

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 5166 Tilden St. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308062-055

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308038-009

Sample Location: 1st Draw 636 Webster St. NW

Customer Sample Number:

Date / Time Collected: 7/29/2023 7:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2308038-009

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 636 Webster St. NW

Customer Sample Number:

Date / Time Collected: 7/29/2023 7:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2308038-010

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2308039-007

Sample Location: 1st Draw 87 V St. NW
Customer Sample Number:
Date / Time Collected: 7/28/2023 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2308039-007
Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 87 V St. NW
Customer Sample Number:
Date / Time Collected: 7/28/2023 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2308039-008
Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS-2308039-021

Sample Location: 1st Draw 935 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2308039-021

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 935 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 7:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2308039-022

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS250- 2308061-003

Sample Location: 1st Draw 1001 4th St. SW, Apt. 828

Customer Sample Number:

Date / Time Collected: 8/2/2023 7:57 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308061-003

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1001 4th St. SW, Apt. 828

Customer Sample Number:

Date / Time Collected: 8/2/2023 7:57 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308061-004

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS250- 2308061-001

Sample Location: 1st Draw 1725 T St. NW, #21

Customer Sample Number:

Date / Time Collected: 7/24/2023 5:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308061-001

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/10/2023	Lgallimore

Sample Location: 2nd Draw 1725 T St. NW, #21

Customer Sample Number:

Date / Time Collected: 7/24/2023 5:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308061-002

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS250- 2308040-001

Sample Location: 1st Draw 2500 Wisconsin Ave. NW Apt.318

Customer Sample Number:

Date / Time Collected: 7/31/2023 6:12 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308040-001

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 2500 Wisconsin Ave. NW Apt.318

Customer Sample Number:

Date / Time Collected: 7/31/2023 6:12 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308040-002

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-DS250- 2308040-003

Sample Location: 1st Draw 255 Carroll St. NW, Z-464

Customer Sample Number:

Date / Time Collected: 8/2/2023 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308040-003

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 255 Carroll St. NW, Z-464

Customer Sample Number:

Date / Time Collected: 8/2/2023 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308040-004

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/23/2023

Report Number: L-DC-DS-2308094-003

Sample Location: 1st Draw 1218 Constitution Ave. NE

Customer Sample Number:

Date / Time Collected: 8/2/2023 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308094-003

Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/16/2023	SBrooks

Sample Location: 2nd Draw 1218 Constitution Ave. NE

Customer Sample Number:

Date / Time Collected: 8/2/2023 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308094-004

Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/16/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/23/2023

Report Number: L-DC-DS-2308094-001

Sample Location: 1st Draw 1677 Fort Dupont St. SE

Customer Sample Number:

Date / Time Collected: 7/25/2023 11:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2308094-001

Date / Time Received: 8/11/2023 9:48:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/16/2023	SBrooks

Sample Location: 2nd Draw 1677 Fort Dupont St. SE

Customer Sample Number:

Date / Time Collected: 7/25/2023 11:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2308094-002

Date / Time Received: 8/11/2023 9:48:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/16/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/23/2023

Report Number: L-DC-DS-2308094-011

Sample Location: 1st Draw 1751 Kilbourne PL NW

Customer Sample Number:

Date / Time Collected: 7/28/2023 7:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2308094-011

Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/16/2023	SBrooks

Sample Location: 2nd Draw 1751 Kilbourne PL NW

Customer Sample Number:

Date / Time Collected: 7/28/2023 7:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2308094-012

Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/16/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/23/2023

Report Number: L-DC-DS-2308094-009

Sample Location: 1st Draw 339 35th St. NE

Customer Sample Number:

Date / Time Collected: 7/28/2023 10:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2308094-009

Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/16/2023	SBrooks

Sample Location: 2nd Draw 339 35th St. NE

Customer Sample Number:

Date / Time Collected: 7/28/2023 10:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2308094-010

Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/16/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/23/2023

Report Number: L-DC-DS250- 2308095-001

Sample Location: 1st Draw 1111 11th St. NW, #907

Customer Sample Number:

Date / Time Collected: 7/27/2023 6:04 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308095-001

Date / Time Received: 8/11/2023 9:48:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/16/2023	SBrooks

Sample Location: 2nd Draw 1111 11th St. NW, #907

Customer Sample Number:

Date / Time Collected: 7/27/2023 6:04 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308095-002

Date / Time Received: 8/11/2023 9:48:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/16/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/23/2023

Report Number: L-DC-DS250- 2308095-003

Sample Location: 1st Draw 1745 N St. NW, Unit 313

Customer Sample Number:

Date / Time Collected: 7/30/2023 10:25 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308095-003

Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/16/2023	SBrooks

Sample Location: 2nd Draw 1745 N St. NW, Unit 313

Customer Sample Number:

Date / Time Collected: 7/30/2023 10:25 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308095-004

Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/16/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-019

Sample Location: 1st Draw 1307 B Fairmont St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-019

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 1307 B Fairmont St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2023 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-020

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-005

Sample Location: 1st Draw 1376 Underwood St. NW

Customer Sample Number:

Date / Time Collected: 8/3/2023 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-005

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 1376 Underwood St. NW

Customer Sample Number:

Date / Time Collected: 8/3/2023 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-006

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-027

Sample Location: 1st Draw 1662 Irving St. NW

Customer Sample Number:

Date / Time Collected: 8/16/2023 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-027

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 1662 Irving St. NW

Customer Sample Number:

Date / Time Collected: 8/16/2023 7:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-028

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-023

Sample Location: 1st Draw 1742 Kilbourne PL NW

Customer Sample Number:

Date / Time Collected: 8/10/2023 2:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2308147-023

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 1742 Kilbourne PL NW

Customer Sample Number:

Date / Time Collected: 8/10/2023 2:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2308147-024

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-021

Sample Location: 1st Draw 1841 Irving St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2023 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-021

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 1841 Irving St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2023 6:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-022

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-015

Sample Location: 1st Draw 1948 Bennett PL NE

Customer Sample Number:

Date / Time Collected: 8/7/2023 6:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-015

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 1948 Bennett PL NE

Customer Sample Number:

Date / Time Collected: 8/7/2023 6:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-016

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-013

Sample Location: 1st Draw 2903 7th St. NE

Customer Sample Number:

Date / Time Collected: 8/6/2023 8:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-013

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 2903 7th St. NE

Customer Sample Number:

Date / Time Collected: 8/6/2023 8:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-014

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-003

Sample Location: 1st Draw 3101 34th St. NW

Customer Sample Number:

Date / Time Collected: 8/2/2023 7:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-003

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 3101 34th St. NW

Customer Sample Number:

Date / Time Collected: 8/2/2023 7:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-004

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308132-013

Sample Location: 1st Draw 3914 New Hampshire Ave. NW

Customer Sample Number:

Date / Time Collected: 8/13/2023 9:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2308132-013

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 3914 New Hampshire Ave. NW

Customer Sample Number:

Date / Time Collected: 8/13/2023 9:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2308132-014

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308132-001

Sample Location: 1st Draw 422 17th St. SE
Customer Sample Number:
Date / Time Collected: 8/3/2023 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2308132-001
Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 422 17th St. SE
Customer Sample Number:
Date / Time Collected: 8/3/2023 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2308132-002
Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-017

Sample Location: 1st Draw 430 Oneida PL NW

Customer Sample Number:

Date / Time Collected: 8/7/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-017

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 430 Oneida PL NW

Customer Sample Number:

Date / Time Collected: 8/7/2023 7:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-018

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308132-017

Sample Location: 1st Draw 5000 Lowell St. NW

Customer Sample Number:

Date / Time Collected: 8/10/2023 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2308132-017

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 5000 Lowell St. NW

Customer Sample Number:

Date / Time Collected: 8/10/2023 7:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2308132-018

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-009

Sample Location: 1st Draw 5331 43rd St. NW

Customer Sample Number:

Date / Time Collected: 8/4/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-009

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 5331 43rd St. NW

Customer Sample Number:

Date / Time Collected: 8/4/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-010

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-011

Sample Location: 1st Draw 5608 39th St. NW

Customer Sample Number:

Date / Time Collected: 8/5/2023 10:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2308147-011

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 5608 39th St. NW

Customer Sample Number:

Date / Time Collected: 8/5/2023 10:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2308147-012

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-001

Sample Location: 1st Draw 5922 Broad Branch Rd. NW

Customer Sample Number:

Date / Time Collected: 8/2/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-001

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 5922 Broad Branch Rd. NW

Customer Sample Number:

Date / Time Collected: 8/2/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-002

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-007

Sample Location: 1st Draw 606 Keefer PL NW

Customer Sample Number:

Date / Time Collected: 8/3/2023 6:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-007

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	96.3	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 606 Keefer PL NW

Customer Sample Number:

Date / Time Collected: 8/3/2023 6:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-008

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	147	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-025

Sample Location: 1st Draw 640 Orleans PL NE

Customer Sample Number:

Date / Time Collected: 8/15/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-025

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 640 Orleans PL NE

Customer Sample Number:

Date / Time Collected: 8/15/2023 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-026

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-031

Sample Location: 1st Draw 6939 33rd St. NW

Customer Sample Number:

Date / Time Collected: 8/16/2023 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-031

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 6939 33rd St. NW

Customer Sample Number:

Date / Time Collected: 8/16/2023 9:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-032

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS-2308147-029

Sample Location: 1st Draw 94 Darrington St. SW

Customer Sample Number:

Date / Time Collected: 8/16/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-029

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 94 Darrington St. SW

Customer Sample Number:

Date / Time Collected: 8/16/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2308147-030

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS250- 2308133-005

Sample Location: 1st Draw 1349 G St. SE

Customer Sample Number:

Date / Time Collected: 8/1/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308133-005

Date / Time Received: 8/17/2023 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 1349 G St. SE

Customer Sample Number:

Date / Time Collected: 8/1/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308133-006

Date / Time Received: 8/17/2023 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS250- 2308146-005

Sample Location: 1st Draw 3005 Bladensburg Rd. NE, #613

Customer Sample Number:

Date / Time Collected: 8/16/2023 12:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2308146-005

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 3005 Bladensburg Rd. NE, #613

Customer Sample Number:

Date / Time Collected: 8/16/2023 12:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2308146-006

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS250- 2308146-001

Sample Location: 1st Draw 3020 Dent Place NW # 32 W

Customer Sample Number:

Date / Time Collected: 8/7/2023 6:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308146-001

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 3020 Dent Place NW # 32 W

Customer Sample Number:

Date / Time Collected: 8/7/2023 6:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308146-002

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS250- 2308133-001

Sample Location: 1st Draw 4740 Connecticut Ave NW, Apt 518

Customer Sample Number:

Date / Time Collected: 8/3/2023 6:53 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308133-001

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 4740 Connecticut Ave NW, Apt 518

Customer Sample Number:

Date / Time Collected: 8/3/2023 6:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308133-002

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS250- 2308133-003

Sample Location: 1st Draw 680 Rhode Island Ave NE, #458

Customer Sample Number:

Date / Time Collected: 8/14/2023 10:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308133-003

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 680 Rhode Island Ave NE, #458

Customer Sample Number:

Date / Time Collected: 8/14/2023 10:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308133-004

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-DS250- 2308146-003

Sample Location: 1st Draw 901 W St. NW, Apt. 415

Customer Sample Number:

Date / Time Collected: 8/14/2023 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308146-003

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 901 W St. NW, Apt. 415

Customer Sample Number:

Date / Time Collected: 8/14/2023 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308146-004

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-009

Sample Location: 1st Draw 1242 D St. NE
Customer Sample Number:
Date / Time Collected: 8/19/2023 3:49 PM

Customer Program Code: DS
Laboratory Sample Number: 2308227-009
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 1242 D St. NE
Customer Sample Number:
Date / Time Collected: 8/19/2023 3:50 PM

Customer Program Code: DS
Laboratory Sample Number: 2308227-010
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-011

Sample Location: 1st Draw 1515 Massachusetts Ave. SE

Customer Sample Number:

Date / Time Collected: 8/20/2023 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-011

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 1515 Massachusetts Ave. SE

Customer Sample Number:

Date / Time Collected: 8/20/2023 6:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-012

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-025

Sample Location: 1st Draw 1832 9th st. NW, Apt. A

Customer Sample Number:

Date / Time Collected: 8/24/2023 6:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-025

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 1832 9th st. NW, Apt. A

Customer Sample Number:

Date / Time Collected: 8/24/2023 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-026

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-019

Sample Location: 1st Draw 2057 34th St. SE

Customer Sample Number:

Date / Time Collected: 8/22/2023 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2308227-019

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 2057 34th St. SE

Customer Sample Number:

Date / Time Collected: 8/22/2023 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2308227-020

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308184-007

Sample Location: 1st Draw 217 Walnut St. NW

Customer Sample Number:

Date / Time Collected: 8/11/2023 6:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2308184-007

Date / Time Received: 8/24/2023 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 217 Walnut St. NW

Customer Sample Number:

Date / Time Collected: 8/11/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308184-008

Date / Time Received: 8/24/2023 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308184-001

Sample Location: 1st Draw 32 U St. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 7:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2308184-001

Date / Time Received: 8/24/2023 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	9/12/2023	Rlamsal

Sample Location: 2nd Draw 32 U St. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 7:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2308184-002

Date / Time Received: 8/24/2023 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-017

Sample Location: 1st Draw 3415 Sherman Ave. NW, #2
Customer Sample Number:
Date / Time Collected: 8/22/2023 6:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2308227-017
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 3415 Sherman Ave. NW, #2
Customer Sample Number:
Date / Time Collected: 8/22/2023 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2308227-018
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-007

Sample Location: 1st Draw 400 9th St. NE
Customer Sample Number:
Date / Time Collected: 8/19/2023 12:25 PM

Customer Program Code: DS
Laboratory Sample Number: 2308227-007
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 400 9th St. NE
Customer Sample Number:
Date / Time Collected: 8/19/2023 12:27 PM

Customer Program Code: DS
Laboratory Sample Number: 2308227-008
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-013

Sample Location: 1st Draw 4623 Davenport St. NW	Customer Program Code: DS
Customer Sample Number:	Laboratory Sample Number: 2308227-013
Date / Time Collected: 8/21/2023 8:37 AM	Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 4623 Davenport St. NW	Customer Program Code: DS
Customer Sample Number:	Laboratory Sample Number: 2308227-014
Date / Time Collected: 8/21/2023 8:39 AM	Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-003

Sample Location: 1st Draw 5808 16th St. NW

Customer Sample Number:

Date / Time Collected: 8/17/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-003

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 5808 16th St. NW

Customer Sample Number:

Date / Time Collected: 8/17/2023 6:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-004

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-021

Sample Location: 1st Draw 616 Irving St. NW
Customer Sample Number:
Date / Time Collected: 8/22/2023 6:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2308227-021
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 616 Irving St. NW
Customer Sample Number:
Date / Time Collected: 8/22/2023 6:35 PM

Customer Program Code: DS
Laboratory Sample Number: 2308227-022
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-023

Sample Location: 1st Draw 725 Rock Creek Church Rd. NW

Customer Sample Number:

Date / Time Collected: 8/23/2023 8:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-023

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 725 Rock Creek Church Rd. NW

Customer Sample Number:

Date / Time Collected: 8/23/2023 8:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-024

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS-2308227-015

Sample Location: 1st Draw 919 46th St. NE

Customer Sample Number:

Date / Time Collected: 8/22/2023 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-015

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 919 46th St. NE

Customer Sample Number:

Date / Time Collected: 8/22/2023 5:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2308227-016

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS250- 2308183-001

Sample Location: 1st Draw 1220 D St SE, Apt. 2

Customer Sample Number:

Date / Time Collected: 7/24/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308183-001

Date / Time Received: 8/24/2023 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Sample Location: 2nd Draw 1220 D St SE, Apt. 2

Customer Sample Number:

Date / Time Collected: 7/24/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308183-002

Date / Time Received: 8/24/2023 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS250- 2308226-001

Sample Location: 1st Draw 1230 23rd St. NW Apt. 907

Customer Sample Number:

Date / Time Collected: 8/14/2023 7:50 PM

Customer Program Code: DS250

Laboratory Sample Number: 2308226-001

Date / Time Received: 8/31/2023 11:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Sample Location: 2nd Draw 1230 23rd St. NW Apt. 907

Customer Sample Number:

Date / Time Collected: 8/14/2023 7:50 PM

Customer Program Code: DS250

Laboratory Sample Number: 2308226-002

Date / Time Received: 8/31/2023 11:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS250- 2308226-003

Sample Location: 1st Draw 1930 18TH ST NW #42

Customer Sample Number:

Date / Time Collected: 8/16/2023 8:37 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308226-003

Date / Time Received: 8/31/2023 11:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Sample Location: 2nd Draw 1930 18TH ST NW #42

Customer Sample Number:

Date / Time Collected: 8/16/2023 8:37 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308226-004

Date / Time Received: 8/31/2023 11:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-DS250- 2308226-005

Sample Location: 1st Draw 2101 N St. NW T4

Customer Sample Number:

Date / Time Collected: 8/22/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308226-005

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 2101 N St. NW T4

Customer Sample Number:

Date / Time Collected: 8/22/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2308226-006

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-007

Sample Location: 1st Draw 1014 D St. SE
Customer Sample Number:
Date / Time Collected: 8/28/2023 6:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-007
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 1014 D St. SE
Customer Sample Number:
Date / Time Collected: 8/28/2023 6:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-008
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-017

Sample Location: 1st Draw 1281 Simms Place, Unit 1

Customer Sample Number:

Date / Time Collected: 8/29/2023 11:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-017

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 1281 Simms Place, Unit 1

Customer Sample Number:

Date / Time Collected: 8/29/2023 11:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-018

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-009

Sample Location: 1st Draw 1309 North Carolina Ave. NE

Customer Sample Number:

Date / Time Collected: 8/28/2023 6:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-009

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 1309 North Carolina Ave. NE

Customer Sample Number:

Date / Time Collected: 8/28/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-010

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-003

Sample Location: 1st Draw 1903 Kalorama Rd. Apt #4

Customer Sample Number:

Date / Time Collected: 8/25/2023 4:52 PM

Customer Program Code: DS

Laboratory Sample Number: 2309071-003

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 1903 Kalorama Rd. Apt #4

Customer Sample Number:

Date / Time Collected: 8/25/2023 4:54 PM

Customer Program Code: DS

Laboratory Sample Number: 2309071-004

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-015

Sample Location: 1st Draw 1917 D St. NE
Customer Sample Number:
Date / Time Collected: 8/29/2023 6:51 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-015
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 1917 D St. NE
Customer Sample Number:
Date / Time Collected: 8/29/2023 6:53 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-016
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-001

Sample Location: 1st Draw 2237 Hall PL NW

Customer Sample Number:

Date / Time Collected: 8/24/2023 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-001

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	9/19/2023	BPrakash

Sample Location: 2nd Draw 2237 Hall PL NW

Customer Sample Number:

Date / Time Collected: 8/24/2023 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-002

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-011

Sample Location: 1st Draw 3003 P St. NW
Customer Sample Number:
Date / Time Collected: 8/28/2023 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-011
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 3003 P St. NW
Customer Sample Number:
Date / Time Collected: 8/28/2023 7:31 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-012
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309052-005

Sample Location: 1st Draw 301 C St. SE
Customer Sample Number:
Date / Time Collected: 9/5/2023 7:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2309052-005
Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 301 C St. SE
Customer Sample Number:
Date / Time Collected: 9/5/2023 7:48 AM

Customer Program Code: DS
Laboratory Sample Number: 2309052-006
Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-013

Sample Location: 1st Draw 3234 Walbridge PL NW	Customer Program Code: DS
Customer Sample Number:	Laboratory Sample Number: 2309071-013
Date / Time Collected: 8/29/2023 6:00 AM	Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 3234 Walbridge PL NW	Customer Program Code: DS
Customer Sample Number:	Laboratory Sample Number: 2309071-014
Date / Time Collected: 8/29/2023 6:00 AM	Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309052-007

Sample Location: 1st Draw 3549 Quesada St. NW

Customer Sample Number:

Date / Time Collected: 9/6/2023 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2309052-007

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 3549 Quesada St. NW

Customer Sample Number:

Date / Time Collected: 9/6/2023 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2309052-008

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309052-001

Sample Location: 1st Draw 3619 Fessenden St. NW

Customer Sample Number:

Date / Time Collected: 7/28/2023 4:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2309052-001

Date / Time Received: 9/8/2023 12:30:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 3619 Fessenden St. NW

Customer Sample Number:

Date / Time Collected: 7/28/2023 4:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2309052-002

Date / Time Received: 9/8/2023 12:30:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309052-003

Sample Location: 1st Draw 3734 Southern Ave. SE

Customer Sample Number:

Date / Time Collected: 9/5/2023 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2309052-003

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 3734 Southern Ave. SE

Customer Sample Number:

Date / Time Collected: 9/5/2023 6:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2309052-004

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-019

Sample Location: 1st Draw 3834 McKinley St. NW

Customer Sample Number:

Date / Time Collected: 8/31/2023 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-019

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 3834 McKinley St. NW

Customer Sample Number:

Date / Time Collected: 8/31/2023 7:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-020

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-025

Sample Location: 1st Draw 4620 Q St. NW
Customer Sample Number:
Date / Time Collected: 9/4/2023 5:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-025
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 4620 Q St. NW
Customer Sample Number:
Date / Time Collected: 9/4/2023 5:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-026
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-021

Sample Location: 1st Draw 518 Groff CT NE

Customer Sample Number:

Date / Time Collected: 9/1/2023 8:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-021

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 518 Groff CT NE

Customer Sample Number:

Date / Time Collected: 9/1/2023 8:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-022

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-005

Sample Location: 1st Draw 5343 32nd St. NW

Customer Sample Number:

Date / Time Collected: 8/28/2023 5:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-005

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 5343 32nd St. NW

Customer Sample Number:

Date / Time Collected: 8/28/2023 5:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2309071-006

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS-2309071-023

Sample Location: 1st Draw 614 Tewkesbury PL NW
Customer Sample Number:
Date / Time Collected: 9/3/2023 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-023
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 614 Tewkesbury PL NW
Customer Sample Number:
Date / Time Collected: 9/3/2023 6:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2309071-024
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.4	1.0	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS250- 2309070-001

Sample Location: 1st Draw 1305 10th St. NW, # 104

Customer Sample Number:

Date / Time Collected: 8/27/2023 8:38 PM

Customer Program Code: DS250

Laboratory Sample Number: 2309070-001

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 1305 10th St. NW, # 104

Customer Sample Number:

Date / Time Collected: 8/27/2023 8:38 PM

Customer Program Code: DS250

Laboratory Sample Number: 2309070-002

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-DS250- 2309070-003

Sample Location: 1st Draw 2418 Lenfant Sq. SE, Unit 8

Customer Sample Number:

Date / Time Collected: 8/28/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309070-003

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 2418 Lenfant Sq. SE, Unit 8

Customer Sample Number:

Date / Time Collected: 8/28/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309070-004

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309129-001

Sample Location: 1st Draw 1281 Simms PL NE, Apt. 9

Customer Sample Number:

Date / Time Collected: 9/11/2023 11:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2309129-001

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1281 Simms PL NE, Apt. 9

Customer Sample Number:

Date / Time Collected: 9/11/2023 11:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2309129-002

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309114-005

Sample Location: 1st Draw 1335 Emerald St. NE

Customer Sample Number:

Date / Time Collected: 9/7/2023 5:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2309114-005

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1335 Emerald St. NE

Customer Sample Number:

Date / Time Collected: 9/7/2023 5:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2309114-006

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309114-007

Sample Location: 1st Draw 1347 V St. NW
Customer Sample Number:
Date / Time Collected: 9/10/2023 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2309114-007
Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1347 V St. NW
Customer Sample Number:
Date / Time Collected: 9/10/2023 7:38 AM

Customer Program Code: DS
Laboratory Sample Number: 2309114-008
Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309106-009

Sample Location: 1st Draw 1518 Ridge PL SE

Customer Sample Number:

Date / Time Collected: 9/12/2023 8:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2309106-009

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1518 Ridge PL SE

Customer Sample Number:

Date / Time Collected: 9/12/2023 8:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2309106-010

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309145-005

Sample Location: 1st Draw 1630 4th St. NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2309145-005

Date / Time Received: 9/20/2023 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1630 4th St. NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 4:03 PM

Customer Program Code: DS

Laboratory Sample Number: 2309145-006

Date / Time Received: 9/20/2023 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309145-003

Sample Location: 1st Draw 198 F St. SE
Customer Sample Number:
Date / Time Collected: 9/9/2023 7:11 AM

Customer Program Code: DS
Laboratory Sample Number: 2309145-003
Date / Time Received: 9/20/2023 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	1.3	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 198 F St. SE
Customer Sample Number:
Date / Time Collected: 9/9/2023 7:13 AM

Customer Program Code: DS
Laboratory Sample Number: 2309145-004
Date / Time Received: 9/20/2023 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309106-003

Sample Location: 1st Draw 2214 Tunlaw Rd. NW

Customer Sample Number:

Date / Time Collected: 9/8/2023 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2309106-003

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	2.0	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 2214 Tunlaw Rd. NW

Customer Sample Number:

Date / Time Collected: 9/8/2023 7:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2309106-004

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	2.6	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309106-007

Sample Location: 1st Draw 2816 38th St. NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 4:34 PM

Customer Program Code: DS

Laboratory Sample Number: 2309106-007

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 2816 38th St. NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 4:36 PM

Customer Program Code: DS

Laboratory Sample Number: 2309106-008

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309114-011

Sample Location: 1st Draw 2938 McKinley St. NW

Customer Sample Number:

Date / Time Collected: 9/10/2023 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2309114-011

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 2938 McKinley St. NW

Customer Sample Number:

Date / Time Collected: 9/10/2023 8:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2309114-012

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309114-009

Sample Location: 1st Draw 3427 Quebec St. NW

Customer Sample Number:

Date / Time Collected: 9/10/2023 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2309114-009

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	0.6	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 3427 Quebec St. NW

Customer Sample Number:

Date / Time Collected: 9/10/2023 7:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2309114-010

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	2.5	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309166-001

Sample Location: 1st Draw 3445 17th St. NW

Customer Sample Number:

Date / Time Collected: 9/20/2023 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2309166-001

Date / Time Received: 9/22/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 3445 17th St. NW

Customer Sample Number:

Date / Time Collected: 9/20/2023 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2309166-002

Date / Time Received: 9/22/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309114-013

Sample Location: 1st Draw 3740 W St. NW
Customer Sample Number:
Date / Time Collected: 9/11/2023 7:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2309114-013
Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 3740 W St. NW
Customer Sample Number:
Date / Time Collected: 9/11/2023 7:14 AM

Customer Program Code: DS
Laboratory Sample Number: 2309114-014
Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309106-005

Sample Location: 1st Draw 3807 Benton St. NW

Customer Sample Number:

Date / Time Collected: 9/9/2023 8:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2309106-005

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 3807 Benton St. NW

Customer Sample Number:

Date / Time Collected: 9/9/2023 8:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2309106-006

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309129-007

Sample Location: 1st Draw 4723 4th St. NW

Customer Sample Number:

Date / Time Collected: 9/15/2023 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2309129-007

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 4723 4th St. NW

Customer Sample Number:

Date / Time Collected: 9/15/2023 6:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2309129-008

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309129-005

Sample Location: 1st Draw 5318 Manning Pl

Customer Sample Number:

Date / Time Collected: 9/14/2023 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2309129-005

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 5318 Manning Pl

Customer Sample Number:

Date / Time Collected: 9/14/2023 8:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2309129-006

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS-2309114-015

Sample Location: 1st Draw 54 S St. NW
Customer Sample Number:
Date / Time Collected: 9/12/2023 8:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2309114-015
Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	1.4	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 54 S St. NW
Customer Sample Number:
Date / Time Collected: 9/12/2023 8:51 AM

Customer Program Code: DS
Laboratory Sample Number: 2309114-016
Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/5/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2309129-003

Sample Location: 1st Draw 628 E St. NE
Customer Sample Number:
Date / Time Collected: 9/13/2023 6:59 PM

Customer Program Code: DS
Laboratory Sample Number: 2309129-003
Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 628 E St. NE
Customer Sample Number:
Date / Time Collected: 9/13/2023 7:02 PM

Customer Program Code: DS
Laboratory Sample Number: 2309129-004
Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS250-2309160-001

Sample Location: 1st Draw 1858 California St. NW #23

Customer Sample Number:

Date / Time Collected: 9/15/2023 6:53 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309160-001

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1858 California St. NW #23

Customer Sample Number:

Date / Time Collected: 9/15/2023 6:53 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309160-002

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS250-2309113-001

Sample Location: 1st Draw 2915 Connecticut Ave NW, #209

Customer Sample Number:

Date / Time Collected: 9/12/2023 6:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2309113-001

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	BPrakash

Sample Location: 2nd Draw 2915 Connecticut Ave NW, #209

Customer Sample Number:

Date / Time Collected: 9/12/2023 6:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2309113-002

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-DS250-2309160-003

Sample Location: 1st Draw 4411 Connecticut Ave. NW Apt T508

Customer Sample Number:

Date / Time Collected: 9/16/2023 12:19 PM

Customer Program Code: DS250

Laboratory Sample Number: 2309160-003

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 4411 Connecticut Ave. NW Apt T508

Customer Sample Number:

Date / Time Collected: 9/16/2023 12:19 PM

Customer Program Code: DS250

Laboratory Sample Number: 2309160-004

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/10/2023

Report Number: L-DC-DS-2308227-001

Sample Location: 1st Draw 1506 Queen St. NE

Customer Sample Number:

Date / Time Collected: 8/14/2023 7:26 PM

Customer Program Code: DS

Laboratory Sample Number: 2308227-001

Date / Time Received: 8/31/2023 11:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	1.0	5.4	ug/L	H	9/28/2023	SBrooks

Sample Location: 2nd Draw 1506 Queen St. NE

Customer Sample Number:

Date / Time Collected: 8/14/2023 7:28 PM

Customer Program Code: DS

Laboratory Sample Number: 2308227-002

Date / Time Received: 8/31/2023 11:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/10/2023

Report Number: L-DC-DS-2308227-005

Sample Location: 1st Draw 3282 Aberfoyle PL NW

Customer Sample Number:

Date / Time Collected: 8/17/2023 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2308227-005

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	1.0	3.4	ug/L		9/28/2023	SBrooks

Sample Location: 2nd Draw 3282 Aberfoyle PL NW

Customer Sample Number:

Date / Time Collected: 8/17/2023 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2308227-006

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/12/2023	RIamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/10/2023

Report Number: L-DC-DS-2309106-001

Sample Location: 1st Draw 708 Mississippi Ave. SE
Customer Sample Number:
Date / Time Collected: 9/5/2023 6:18 AM

Customer Program Code: DS
Laboratory Sample Number: 2309106-001
Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	1.0	319	ug/L		9/28/2023	SBrooks

Sample Location: 2nd Draw 708 Mississippi Ave. SE
Customer Sample Number:
Date / Time Collected: 9/5/2023 6:22 AM

Customer Program Code: DS
Laboratory Sample Number: 2309106-002
Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	258	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS-2309161-003

Sample Location: 1st Draw 1135 Harvard St. NW, Unit #1
Customer Sample Number:
Date / Time Collected: 9/16/2023 10:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2309161-003
Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1135 Harvard St. NW, Unit #1
Customer Sample Number:
Date / Time Collected: 9/16/2023 10:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2309161-004
Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS-2309161-005

Sample Location: 1st Draw 122 Bates St. NW, Unit #1

Customer Sample Number:

Date / Time Collected: 9/16/2023 10:29 PM

Customer Program Code: DS

Laboratory Sample Number: 2309161-005

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 122 Bates St. NW, Unit #1

Customer Sample Number:

Date / Time Collected: 9/16/2023 10:31 PM

Customer Program Code: DS

Laboratory Sample Number: 2309161-006

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS-2309161-007

Sample Location: 1st Draw 1231 Talbert St. SE

Customer Sample Number:

Date / Time Collected: 9/17/2023 4:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2309161-007

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1231 Talbert St. SE

Customer Sample Number:

Date / Time Collected: 9/17/2023 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2309161-008

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS-2309161-001

Sample Location: 1st Draw 4912 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 9/16/2023 7:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2309161-001

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 4912 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 9/16/2023 7:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2309161-002

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS-2309161-011

Sample Location: 1st Draw 5266 Loughboro Rd. NW
Customer Sample Number:
Date / Time Collected: 9/18/2023 6:52 AM

Customer Program Code: DS
Laboratory Sample Number: 2309161-011
Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 5266 Loughboro Rd. NW
Customer Sample Number:
Date / Time Collected: 9/18/2023 6:54 AM

Customer Program Code: DS
Laboratory Sample Number: 2309161-012
Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS-2309161-009

Sample Location: 1st Draw 644 9th St. NE
Customer Sample Number:
Date / Time Collected: 9/18/2023 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2309161-009
Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 644 9th St. NE
Customer Sample Number:
Date / Time Collected: 9/18/2023 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2309161-010
Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS250- 2309206-005

Sample Location: 1st Draw 1511 22nd St. NW, #51
Customer Sample Number:
Date / Time Collected: 9/21/2023 7:07 AM

Customer Program Code: DS250
Laboratory Sample Number: 2309206-005
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1511 22nd St. NW, #51
Customer Sample Number:
Date / Time Collected: 9/21/2023 7:07 AM

Customer Program Code: DS250
Laboratory Sample Number: 2309206-006
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS250- 2309206-003

Sample Location: 1st Draw 1511 22nd St. NW, Apt. 34

Customer Sample Number:

Date / Time Collected: 9/20/2023 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309206-003

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1511 22nd St. NW, Apt. 34

Customer Sample Number:

Date / Time Collected: 9/20/2023 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309206-004

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS250- 2309206-001

Sample Location: 1st Draw 3100 Connecticut Ave NW, #200

Customer Sample Number:

Date / Time Collected: 9/19/2023 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309206-001

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 3100 Connecticut Ave NW, #200

Customer Sample Number:

Date / Time Collected: 9/19/2023 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309206-002

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS250- 2309206-007

Sample Location: 1st Draw 3800 39th St. NW, Apt. E131

Customer Sample Number:

Date / Time Collected: 9/21/2023 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309206-007

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 3800 39th St. NW, Apt. E131

Customer Sample Number:

Date / Time Collected: 9/21/2023 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309206-008

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-DS250- 2309206-009

Sample Location: 1st Draw 3900 16th St. NW, Apt. 622

Customer Sample Number:

Date / Time Collected: 9/25/2023 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309206-009

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 3900 16th St. NW, Apt. 622

Customer Sample Number:

Date / Time Collected: 9/25/2023 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2309206-010

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-017

Sample Location: 1st Draw 1113 3rd St. NE

Customer Sample Number:

Date / Time Collected: 9/21/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-017

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1113 3rd St. NE

Customer Sample Number:

Date / Time Collected: 9/21/2023 7:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-018

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310016-023

Sample Location: 1st Draw 119 7th St. SE
Customer Sample Number:
Date / Time Collected: 9/28/2023 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2310016-023
Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 119 7th St. SE
Customer Sample Number:
Date / Time Collected: 9/28/2023 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2310016-024
Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-005

Sample Location: 1st Draw 1349 Talbert Terr SE

Customer Sample Number:

Date / Time Collected: 9/16/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-005

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1349 Talbert Terr SE

Customer Sample Number:

Date / Time Collected: 9/16/2023 7:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-006

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-021

Sample Location: 1st Draw 1616 D St. NE
Customer Sample Number:
Date / Time Collected: 9/24/2023 7:02 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-021
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1616 D St. NE
Customer Sample Number:
Date / Time Collected: 9/24/2023 7:04 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-022
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-027

Sample Location: 1st Draw 1736 Lyman PL NE

Customer Sample Number:

Date / Time Collected: 9/24/2023 10:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-027

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1736 Lyman PL NE

Customer Sample Number:

Date / Time Collected: 9/24/2023 10:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-028

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-015

Sample Location: 1st Draw 219 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 9/21/2023 5:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-015

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 219 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 9/21/2023 5:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-016

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310016-011

Sample Location: 1st Draw 227 Upshur St. NW, Apt. A

Customer Sample Number:

Date / Time Collected: 9/25/2023 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-011

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 227 Upshur St. NW, Apt. A

Customer Sample Number:

Date / Time Collected: 9/25/2023 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-012

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310039-001

Sample Location: 1st Draw 25 Seaton PL NE

Customer Sample Number:

Date / Time Collected: 9/23/2023 4:09 PM

Customer Program Code: DS

Laboratory Sample Number: 2310039-001

Date / Time Received: 10/4/2023 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 25 Seaton PL NE

Customer Sample Number:

Date / Time Collected: 9/23/2023 4:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2310039-002

Date / Time Received: 10/4/2023 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310016-015

Sample Location: 1st Draw 2515 32nd St. SE

Customer Sample Number:

Date / Time Collected: 9/26/2023 5:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2310016-015

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 2515 32nd St. SE

Customer Sample Number:

Date / Time Collected: 9/26/2023 5:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2310016-016

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-009

Sample Location: 1st Draw 2715 36th PL NW

Customer Sample Number:

Date / Time Collected: 9/19/2023 8:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-009

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 2715 36th PL NW

Customer Sample Number:

Date / Time Collected: 9/19/2023 8:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-010

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-031

Sample Location: 1st Draw 318 14 th St. NE
Customer Sample Number:
Date / Time Collected: 9/25/2023 9:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-031
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 318 14 th St. NE
Customer Sample Number:
Date / Time Collected: 9/25/2023 9:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-032
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310016-025

Sample Location: 1st Draw 3526 Edmunds ST. NW

Customer Sample Number:

Date / Time Collected: 9/28/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-025

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 3526 Edmunds ST. NW

Customer Sample Number:

Date / Time Collected: 9/28/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-026

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-029

Sample Location: 1st Draw 3760 W St. NW
Customer Sample Number:
Date / Time Collected: 9/25/2023 7:33 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-029
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 3760 W St. NW
Customer Sample Number:
Date / Time Collected: 9/25/2023 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-030
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310016-021

Sample Location: 1st Draw 3819 Kansas Ave. NW

Customer Sample Number:

Date / Time Collected: 9/27/2023 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-021

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 3819 Kansas Ave. NW

Customer Sample Number:

Date / Time Collected: 9/27/2023 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-022

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-007

Sample Location: 1st Draw 3926 Morrison St. NW

Customer Sample Number:

Date / Time Collected: 9/19/2023 4:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-007

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 3926 Morrison St. NW

Customer Sample Number:

Date / Time Collected: 9/19/2023 4:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-008

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-019

Sample Location: 1st Draw 407 D St. SE
Customer Sample Number:
Date / Time Collected: 9/22/2023 6:49 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-019
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 407 D St. SE
Customer Sample Number:
Date / Time Collected: 9/22/2023 6:53 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-020
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-035

Sample Location: 1st Draw 4204 Arkansas Ave. NW

Customer Sample Number:

Date / Time Collected: 9/26/2023 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-035

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 4204 Arkansas Ave. NW

Customer Sample Number:

Date / Time Collected: 9/26/2023 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-036

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-037

Sample Location: 1st Draw 4343 Harrison St. NW, #2

Customer Sample Number:

Date / Time Collected: 9/26/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-037

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 4343 Harrison St. NW, #2

Customer Sample Number:

Date / Time Collected: 9/26/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-038

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310039-003

Sample Location: 1st Draw 4406 VOLTA PL NW

Customer Sample Number:

Date / Time Collected: 9/29/2023 6:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2310039-003

Date / Time Received: 10/4/2023 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 4406 VOLTA PL NW

Customer Sample Number:

Date / Time Collected: 9/29/2023 6:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2310039-004

Date / Time Received: 10/4/2023 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-023

Sample Location: 1st Draw 4703 7th St. NE

Customer Sample Number:

Date / Time Collected: 9/24/2023 8:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-023

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 4703 7th St. NE

Customer Sample Number:

Date / Time Collected: 9/24/2023 8:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-024

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-013

Sample Location: 1st Draw 501 Oneida PL NW

Customer Sample Number:

Date / Time Collected: 9/20/2023 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-013

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 501 Oneida PL NW

Customer Sample Number:

Date / Time Collected: 9/20/2023 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-014

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310016-017

Sample Location: 1st Draw 506 Kenyon St. NW

Customer Sample Number:

Date / Time Collected: 9/27/2023 6:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-017

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 506 Kenyon St. NW

Customer Sample Number:

Date / Time Collected: 9/27/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-018

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309216-001

Sample Location: 1st Draw 5338 43rd St. NW

Customer Sample Number:

Date / Time Collected: 9/22/2023 6:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2309216-001

Date / Time Received: 9/28/2023 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 5338 43rd St. NW

Customer Sample Number:

Date / Time Collected: 9/22/2023 6:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2309216-002

Date / Time Received: 9/28/2023 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-033

Sample Location: 1st Draw 5464 30th PL NW

Customer Sample Number:

Date / Time Collected: 9/25/2023 2:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2309207-033

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 5464 30th PL NW

Customer Sample Number:

Date / Time Collected: 9/25/2023 2:46 PM

Customer Program Code: DS

Laboratory Sample Number: 2309207-034

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-025

Sample Location: 1st Draw 5543 Chillum PL NE

Customer Sample Number:

Date / Time Collected: 9/24/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-025

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 5543 Chillum PL NE

Customer Sample Number:

Date / Time Collected: 9/24/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-026

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310016-019

Sample Location: 1st Draw 5700 Chevy Chase Pkwy NW

Customer Sample Number:

Date / Time Collected: 9/27/2023 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-019

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 5700 Chevy Chase Pkwy NW

Customer Sample Number:

Date / Time Collected: 9/27/2023 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-020

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-003

Sample Location: 1st Draw 606 14th PL NE
Customer Sample Number:
Date / Time Collected: 9/16/2023 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-003
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 606 14th PL NE
Customer Sample Number:
Date / Time Collected: 9/16/2023 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-004
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-001

Sample Location: 1st Draw 654 F St. NE
Customer Sample Number:
Date / Time Collected: 9/15/2023 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-001
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 654 F St. NE
Customer Sample Number:
Date / Time Collected: 9/15/2023 7:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2309207-002
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310016-027

Sample Location: 1st Draw 68 V St. NW, #1

Customer Sample Number:

Date / Time Collected: 9/28/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-027

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 68 V St. NW, #1

Customer Sample Number:

Date / Time Collected: 9/28/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-028

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2309207-011

Sample Location: 1st Draw 920 25th St. NW

Customer Sample Number:

Date / Time Collected: 9/20/2023 6:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-011

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 920 25th St. NW

Customer Sample Number:

Date / Time Collected: 9/20/2023 6:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2309207-012

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-DS-2310016-013

Sample Location: 1st Draw 935 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2023 7:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-013

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 935 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2023 7:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2310016-014

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310075-021

Sample Location: 1st Draw 1246 Columbia Rd. NW, Apt. 1

Customer Sample Number:

Date / Time Collected: 10/2/2023 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-021

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 1246 Columbia Rd. NW, Apt. 1

Customer Sample Number:

Date / Time Collected: 10/2/2023 8:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-022

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310104-021

Sample Location: 1st Draw 1309 Park Rd. NW, Apt. 101

Customer Sample Number:

Date / Time Collected: 10/3/2023 6:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-021

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 1309 Park Rd. NW, Apt. 101

Customer Sample Number:

Date / Time Collected: 10/3/2023 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-022

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310144-007

Sample Location: 1st Draw 1418 Orren St. NE

Customer Sample Number:

Date / Time Collected: 10/17/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310144-007

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 1418 Orren St. NE

Customer Sample Number:

Date / Time Collected: 10/17/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310144-008

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310180-005

Sample Location: 1st Draw 1420 T St. NW, #2

Customer Sample Number:

Date / Time Collected: 10/17/2023 7:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2310180-005

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 1420 T St. NW, #2

Customer Sample Number:

Date / Time Collected: 10/17/2023 7:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2310180-006

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310104-019

Sample Location: 1st Draw 1433 B Chanute Place SW

Customer Sample Number:

Date / Time Collected: 10/2/2023 2:27 PM

Customer Program Code: DS

Laboratory Sample Number: 2310104-019

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 1433 B Chanute Place SW

Customer Sample Number:

Date / Time Collected: 10/2/2023 2:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2310104-020

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310104-029

Sample Location: 1st Draw 1634 6th St. NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 6:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-029

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 1634 6th St. NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 6:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-030

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310075-017

Sample Location: 1st Draw 165 U St. NW
Customer Sample Number:
Date / Time Collected: 10/2/2023 5:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2310075-017
Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 165 U St. NW
Customer Sample Number:
Date / Time Collected: 10/2/2023 5:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2310075-018
Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310180-001

Sample Location: 1st Draw 1704 P St. NW
Customer Sample Number:
Date / Time Collected: 10/17/2023 6:52 AM

Customer Program Code: DS
Laboratory Sample Number: 2310180-001
Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 1704 P St. NW
Customer Sample Number:
Date / Time Collected: 10/17/2023 6:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2310180-002
Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310104-013

Sample Location: 1st Draw 1720 Euclid St. NW

Customer Sample Number:

Date / Time Collected: 9/30/2023 7:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-013

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 1720 Euclid St. NW

Customer Sample Number:

Date / Time Collected: 9/30/2023 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-014

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/8/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2310174-015

Sample Location: 1st Draw 1848 8th St. NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 10:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-015

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 1848 8th St. NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 10:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-016

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-021

Sample Location: 1st Draw 2200 Tunlaw Rd. NW

Customer Sample Number:

Date / Time Collected: 10/9/2023 9:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-021

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L	H	10/31/2023	SBrooks

Sample Location: 2nd Draw 2200 Tunlaw Rd. NW

Customer Sample Number:

Date / Time Collected: 10/9/2023 9:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-022

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L	H	10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310075-023

Sample Location: 1st Draw 2300 Foxhill Rd. NW

Customer Sample Number:

Date / Time Collected: 10/5/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-023

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 2300 Foxhill Rd. NW

Customer Sample Number:

Date / Time Collected: 10/5/2023 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-024

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310075-019

Sample Location: 1st Draw 2312 20th St. NW

Customer Sample Number:

Date / Time Collected: 10/2/2023 6:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-019

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 2312 20th St. NW

Customer Sample Number:

Date / Time Collected: 10/2/2023 6:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-020

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310144-005

Sample Location: 1st Draw 2333 Ashmead Place NW

Customer Sample Number:

Date / Time Collected: 10/15/2023 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2310144-005

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 2333 Ashmead Place NW

Customer Sample Number:

Date / Time Collected: 10/15/2023 7:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2310144-006

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310075-027

Sample Location: 1st Draw 236 P St. NW
Customer Sample Number:
Date / Time Collected: 10/7/2023 3:36 PM

Customer Program Code: DS
Laboratory Sample Number: 2310075-027
Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 236 P St. NW
Customer Sample Number:
Date / Time Collected: 10/7/2023 3:39 PM

Customer Program Code: DS
Laboratory Sample Number: 2310075-028
Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310104-015

Sample Location: 1st Draw 245 9th St. NE
Customer Sample Number:
Date / Time Collected: 10/1/2023 7:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2310104-015
Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 245 9th St. NE
Customer Sample Number:
Date / Time Collected: 10/1/2023 7:07 AM

Customer Program Code: DS
Laboratory Sample Number: 2310104-016
Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-019

Sample Location: 1st Draw 2631 Otis St. NE

Customer Sample Number:

Date / Time Collected: 10/9/2023 11:07 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-019

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	SBrooks

Sample Location: 2nd Draw 2631 Otis St. NE

Customer Sample Number:

Date / Time Collected: 10/9/2023 11:08 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-020

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-023

Sample Location: 1st Draw 2753 Woodley PL NW

Customer Sample Number:

Date / Time Collected: 10/17/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-023

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 2753 Woodley PL NW

Customer Sample Number:

Date / Time Collected: 10/17/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-024

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310104-025

Sample Location: 1st Draw 2909 5th St. SE
Customer Sample Number:
Date / Time Collected: 10/5/2023 8:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2310104-025
Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 2909 5th St. SE
Customer Sample Number:
Date / Time Collected: 10/5/2023 8:03 PM

Customer Program Code: DS
Laboratory Sample Number: 2310104-026
Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-003

Sample Location: 1st Draw 3060 Thayer St. NE

Customer Sample Number:

Date / Time Collected: 10/15/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-003

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 3060 Thayer St. NE

Customer Sample Number:

Date / Time Collected: 10/15/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-004

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310180-007

Sample Location: 1st Draw 31 Milmarson PI NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 5:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2310180-007

Date / Time Received: 10/25/2023 10:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/1/2023	SBrooks

Sample Location: 2nd Draw 31 Milmarson PI NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 5:27 PM

Customer Program Code: DS

Laboratory Sample Number: 2310180-008

Date / Time Received: 10/25/2023 10:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-025

Sample Location: 1st Draw 3543 S St. NW
Customer Sample Number:
Date / Time Collected: 10/10/2023 7:08 AM

Customer Program Code: DS
Laboratory Sample Number: 2310174-025
Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 3543 S St. NW
Customer Sample Number:
Date / Time Collected: 10/10/2023 7:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2310174-026
Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310180-009

Sample Location: 1st Draw 3629 10th St. NW

Customer Sample Number:

Date / Time Collected: 10/10/2023 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310180-009

Date / Time Received: 10/25/2023 10:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/1/2023	SBrooks

Sample Location: 2nd Draw 3629 10th St. NW

Customer Sample Number:

Date / Time Collected: 10/10/2023 5:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2310180-010

Date / Time Received: 10/25/2023 10:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310075-013

Sample Location: 1st Draw 3921 Benton St. NW

Customer Sample Number:

Date / Time Collected: 7/31/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-013

Date / Time Received: 10/11/2023 12:45:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2023	SBrooks

Sample Location: 2nd Draw 3921 Benton St. NW

Customer Sample Number:

Date / Time Collected: 7/31/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-014

Date / Time Received: 10/11/2023 12:45:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-029

Sample Location: 1st Draw 4 Longfellow St. NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 4:46 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-029

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	10/31/2023	SBrooks

Sample Location: 2nd Draw 4 Longfellow St. NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 4:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-030

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-005

Sample Location: 1st Draw 4114 Garrison St. NW

Customer Sample Number:

Date / Time Collected: 10/14/2023 10:18 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-005

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 4114 Garrison St. NW

Customer Sample Number:

Date / Time Collected: 10/14/2023 10:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-006

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310180-011

Sample Location: 1st Draw 4211 43rd St. NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 6:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2310180-011

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 4211 43rd St. NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2310180-012

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310144-009

Sample Location: 1st Draw 425 Newton PL NW, Unit B

Customer Sample Number:

Date / Time Collected: 10/15/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310144-009

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 425 Newton PL NW, Unit B

Customer Sample Number:

Date / Time Collected: 10/15/2023 9:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2310144-010

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-017

Sample Location: 1st Draw 426 Ridge St. NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 1:56 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-017

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 426 Ridge St. NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 2:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-018

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310104-023

Sample Location: 1st Draw 4431 46th St. NW

Customer Sample Number:

Date / Time Collected: 10/3/2023 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-023

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 4431 46th St. NW

Customer Sample Number:

Date / Time Collected: 10/3/2023 7:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-024

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-009

Sample Location: 1st Draw 4826 Blagden Ave. NW

Customer Sample Number:

Date / Time Collected: 10/8/2023 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-009

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	SBrooks

Sample Location: 2nd Draw 4826 Blagden Ave. NW

Customer Sample Number:

Date / Time Collected: 10/8/2023 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-010

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310075-015

Sample Location: 1st Draw 5149 8th St. NE

Customer Sample Number:

Date / Time Collected: 9/25/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-015

Date / Time Received: 10/11/2023 12:45:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2023	SBrooks

Sample Location: 2nd Draw 5149 8th St. NE

Customer Sample Number:

Date / Time Collected: 9/25/2023 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-016

Date / Time Received: 10/11/2023 12:45:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310075-025

Sample Location: 1st Draw 518 V St. NW
Customer Sample Number:
Date / Time Collected: 10/6/2023 7:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2310075-025
Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 518 V St. NW
Customer Sample Number:
Date / Time Collected: 10/6/2023 7:13 AM

Customer Program Code: DS
Laboratory Sample Number: 2310075-026
Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/8/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2310180-003

Sample Location: 1st Draw 5203 5th St NW

Customer Sample Number:

Date / Time Collected: 10/17/2023 5:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2310180-003

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 5203 5th St NW

Customer Sample Number:

Date / Time Collected: 10/17/2023 5:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2310180-004

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310104-017

Sample Location: 1st Draw 5302 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 10/2/2023 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-017

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 5302 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 10/2/2023 5:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-018

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-011

Sample Location: 1st Draw 5438 4th St. NW, Unit #1
Customer Sample Number:
Date / Time Collected: 10/10/2023 8:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2310174-011
Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 5438 4th St. NW, Unit #1
Customer Sample Number:
Date / Time Collected: 10/10/2023 8:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2310174-012
Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310144-003

Sample Location: 1st Draw 55th St. SE, #53

Customer Sample Number:

Date / Time Collected: 10/14/2023 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2310144-003

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 55th St. SE, #53

Customer Sample Number:

Date / Time Collected: 10/14/2023 6:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2310144-004

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-027

Sample Location: 1st Draw 5734 1st St. NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 4:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-027

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	SBrooks

Sample Location: 2nd Draw 5734 1st St. NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 4:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2310174-028

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310104-027

Sample Location: 1st Draw 600 Brandywine St. SE

Customer Sample Number:

Date / Time Collected: 10/6/2023 5:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-027

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 600 Brandywine St. SE

Customer Sample Number:

Date / Time Collected: 10/6/2023 5:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2310104-028

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-001

Sample Location: 1st Draw 6278 Brandywine St. SE
Customer Sample Number:
Date / Time Collected: 10/10/2023 7:35 PM

Customer Program Code: DS
Laboratory Sample Number: 2310174-001
Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 6278 Brandywine St. SE
Customer Sample Number:
Date / Time Collected: 10/10/2023 7:37 PM

Customer Program Code: DS
Laboratory Sample Number: 2310174-002
Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-007

Sample Location: 1st Draw 632 1/2 Morton PL NE

Customer Sample Number:

Date / Time Collected: 10/9/2023 7:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-007

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	10/31/2023	SBrooks

Sample Location: 2nd Draw 632 1/2 Morton PL NE

Customer Sample Number:

Date / Time Collected: 10/9/2023 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-008

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L	H	10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310075-029

Sample Location: 1st Draw 65 Underwood St. NW

Customer Sample Number:

Date / Time Collected: 10/9/2023 8:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-029

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 65 Underwood St. NW

Customer Sample Number:

Date / Time Collected: 10/9/2023 8:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2310075-030

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS-2310174-013

Sample Location: 1st Draw 905 G St. SE

Customer Sample Number:

Date / Time Collected: 10/9/2023 6:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-013

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	SBrooks

Sample Location: 2nd Draw 905 G St. SE

Customer Sample Number:

Date / Time Collected: 10/9/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310174-014

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310089-001

Sample Location: 1st Draw 1001 26th St. NW, #508
Customer Sample Number:
Date / Time Collected: 10/4/2023 7:30 AM

Customer Program Code: DS250
Laboratory Sample Number: 2310089-001
Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 1001 26th St. NW, #508
Customer Sample Number:
Date / Time Collected: 10/4/2023 7:30 AM

Customer Program Code: DS250
Laboratory Sample Number: 2310089-002
Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310076-009

Sample Location: 1st Draw 1010 25th St. NW, Apt. 504

Customer Sample Number:

Date / Time Collected: 10/3/2023 7:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-009

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 1010 25th St. NW, Apt. 504

Customer Sample Number:

Date / Time Collected: 10/3/2023 7:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-010

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250-2310076-001

Sample Location: 1st Draw 1222 28th St. NW

Customer Sample Number:

Date / Time Collected: 10/1/2023 2:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-001

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	8	9.7	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1222 28th St. NW

Customer Sample Number:

Date / Time Collected: 10/1/2023 2:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-002

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2	5.9	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310076-007

Sample Location: 1st Draw 1236 Raum St. NE #PH 1

Customer Sample Number:

Date / Time Collected: 10/3/2023 6:02 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-007

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 1236 Raum St. NE #PH 1

Customer Sample Number:

Date / Time Collected: 10/3/2023 6:02 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-008

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310076-003

Sample Location: 1st Draw 1613 Harvard St. NW, # 115

Customer Sample Number:

Date / Time Collected: 10/1/2023 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-003

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 1613 Harvard St. NW, # 115

Customer Sample Number:

Date / Time Collected: 10/1/2023 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-004

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310191-005

Sample Location: 1st Draw 1842 Ingleside Terr., Apt. B

Customer Sample Number:

Date / Time Collected: 10/20/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310191-005

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1842 Ingleside Terr., Apt. B

Customer Sample Number:

Date / Time Collected: 10/20/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310191-006

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310170-001

Sample Location: 1st Draw 2022 Columbia Rd NW, Apt. 410/510

Customer Sample Number:

Date / Time Collected: 10/5/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310170-001

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	Sbrooks

Sample Location: 2nd Draw 2022 Columbia Rd NW, Apt. 410/510

Customer Sample Number:

Date / Time Collected: 10/5/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310170-002

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310191-001

Sample Location: 1st Draw 2125 14th St. NW, Unit 516

Customer Sample Number:

Date / Time Collected: 10/16/2023 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310191-001

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 2125 14th St. NW, Unit 516

Customer Sample Number:

Date / Time Collected: 10/16/2023 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310191-002

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310191-003

Sample Location: 1st Draw 2501 Porter St NW, #809

Customer Sample Number:

Date / Time Collected: 10/18/2023 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310191-003

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 2501 Porter St NW, #809

Customer Sample Number:

Date / Time Collected: 10/18/2023 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310191-004

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310076-005

Sample Location: 1st Draw 3001 Veazey Terrace NW

Customer Sample Number:

Date / Time Collected: 10/2/2023 5:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-005

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 3001 Veazey Terrace NW

Customer Sample Number:

Date / Time Collected: 10/2/2023 5:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-006

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310170-003

Sample Location: 1st Draw 350 9th St. SE, #26

Customer Sample Number:

Date / Time Collected: 10/6/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310170-003

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	Sbrooks

Sample Location: 2nd Draw 350 9th St. SE, #26

Customer Sample Number:

Date / Time Collected: 10/6/2023 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310170-004

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310076-011

Sample Location: 1st Draw 3750 39th St. NW, F150

Customer Sample Number:

Date / Time Collected: 10/4/2023 7:25 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-011

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 3750 39th St. NW, F150

Customer Sample Number:

Date / Time Collected: 10/4/2023 7:25 AM

Customer Program Code: DS250

Laboratory Sample Number: 2310076-012

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310170-005

Sample Location: 1st Draw 424 Q St. NW, Apt. D

Customer Sample Number:

Date / Time Collected: 10/9/2023 11:28 PM

Customer Program Code: DS250

Laboratory Sample Number: 2310170-005

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2024	Sbrooks

Sample Location: 2nd Draw 424 Q St. NW, Apt. D

Customer Sample Number:

Date / Time Collected: 10/9/2023 11:28 PM

Customer Program Code: DS250

Laboratory Sample Number: 2310170-006

Date / Time Received: 10/24/2023 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/31/2024	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310170-007

Sample Location: 1st Draw 916 Penn. Ave. SE

Customer Sample Number:

Date / Time Collected: 10/11/2023 1:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2310170-007

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/31/2024	Sbrooks

Sample Location: 2nd Draw 916 Penn. Ave. SE

Customer Sample Number:

Date / Time Collected: 10/11/2023 1:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2310170-008

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2024	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-DS250- 2310191-007

Sample Location: 1st Draw 922 Madison St. NW, #202

Customer Sample Number:

Date / Time Collected: 10/29/2023 10:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2310191-007

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 922 Madison St. NW, #202

Customer Sample Number:

Date / Time Collected: 10/29/2023 10:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2310191-008

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-005

Sample Location: 1st Draw 1103 Park Street NE

Customer Sample Number:

Date / Time Collected: 10/18/2023 6:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2310193-005

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1103 Park Street NE

Customer Sample Number:

Date / Time Collected: 10/18/2023 6:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2310193-006

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-007

Sample Location: 1st Draw 1281 Owen Place NE

Customer Sample Number:

Date / Time Collected: 10/18/2023 7:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-007

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1281 Owen Place NE

Customer Sample Number:

Date / Time Collected: 10/18/2023 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-008

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-017

Sample Location: 1st Draw 1404 G St. SE
Customer Sample Number:
Date / Time Collected: 10/21/2023 9:18 AM

Customer Program Code: DS
Laboratory Sample Number: 2310193-017
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1404 G St. SE
Customer Sample Number:
Date / Time Collected: 10/21/2023 9:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2310193-018
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-021

Sample Location: 1st Draw 1417 Trinidad Ave. NE

Customer Sample Number:

Date / Time Collected: 10/22/2023 10:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-021

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1417 Trinidad Ave. NE

Customer Sample Number:

Date / Time Collected: 10/22/2023 10:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-022

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-013

Sample Location: 1st Draw 1439 Taylor St NW

Customer Sample Number:

Date / Time Collected: 10/20/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-013

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1439 Taylor St NW

Customer Sample Number:

Date / Time Collected: 10/20/2023 8:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-014

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-003

Sample Location: 1st Draw 1517 1st St. NW

Customer Sample Number:

Date / Time Collected: 10/18/2023 5:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-003

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1517 1st St. NW

Customer Sample Number:

Date / Time Collected: 10/18/2023 5:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-004

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-019

Sample Location: 1st Draw 1674 Irving St. NW, Apt. 3

Customer Sample Number:

Date / Time Collected: 10/22/2023 9:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-019

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1674 Irving St. NW, Apt. 3

Customer Sample Number:

Date / Time Collected: 10/22/2023 9:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-020

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-011

Sample Location: 1st Draw 1936 4th St. NW

Customer Sample Number:

Date / Time Collected: 10/19/2023 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-011

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1936 4th St. NW

Customer Sample Number:

Date / Time Collected: 10/19/2023 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-012

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-023

Sample Location: 1st Draw 245 16th St SE
Customer Sample Number:
Date / Time Collected: 10/22/2023 7:02 PM

Customer Program Code: DS
Laboratory Sample Number: 2310193-023
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 245 16th St SE
Customer Sample Number:
Date / Time Collected: 10/22/2023 7:04 PM

Customer Program Code: DS
Laboratory Sample Number: 2310193-024
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-027

Sample Location: 1st Draw 3135 Ellicott St. NW

Customer Sample Number:

Date / Time Collected: 10/25/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-027

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 3135 Ellicott St. NW

Customer Sample Number:

Date / Time Collected: 10/25/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-028

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-009

Sample Location: 1st Draw 315 Adams St. NE

Customer Sample Number:

Date / Time Collected: 10/19/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-009

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.5	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 315 Adams St. NE

Customer Sample Number:

Date / Time Collected: 10/19/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-010

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-025

Sample Location: 1st Draw 4411 5th St. NW
Customer Sample Number:
Date / Time Collected: 10/23/2023 10:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2310193-025
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	188	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 4411 5th St. NW
Customer Sample Number:
Date / Time Collected: 10/23/2023 10:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2310193-026
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	22.8	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-015

Sample Location: 1st Draw 5300 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 10/20/2023 8:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-015

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 5300 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 10/20/2023 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2310193-016

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-DS-2310193-001

Sample Location: 1st Draw 929 7th St. NE
Customer Sample Number:
Date / Time Collected: 10/17/2023 2:31 PM

Customer Program Code: DS
Laboratory Sample Number: 2310193-001
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 929 7th St. NE
Customer Sample Number:
Date / Time Collected: 10/17/2023 2:38 PM

Customer Program Code: DS
Laboratory Sample Number: 2310193-002
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-017

Sample Location: 1st Draw 1107 Savannah St. SE

Customer Sample Number:

Date / Time Collected: 11/12/2023 10:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-017

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 1107 Savannah St. SE

Customer Sample Number:

Date / Time Collected: 11/12/2023 10:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-018

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-009

Sample Location: 1st Draw 1122 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 11/11/2023 1:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2311128-009

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 1122 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 11/11/2023 1:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2311128-010

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-025

Sample Location: 1st Draw 1224 Emerson St. NE

Customer Sample Number:

Date / Time Collected: 11/15/2023 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-025

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 1224 Emerson St. NE

Customer Sample Number:

Date / Time Collected: 11/15/2023 10:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-026

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-003

Sample Location: 1st Draw 127 N. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 10/22/2023 10:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-003

Date / Time Received: 11/8/2023 12:35:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/15/2023	Rlamsal

Sample Location: 2nd Draw 127 N. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 10/22/2023 10:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-004

Date / Time Received: 11/8/2023 12:35:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-027

Sample Location: 1st Draw 1305 G St. NE
Customer Sample Number:
Date / Time Collected: 11/13/2023 2:50 PM

Customer Program Code: DS
Laboratory Sample Number: 2311123-027
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 1305 G St. NE
Customer Sample Number:
Date / Time Collected: 11/13/2023 2:50 PM

Customer Program Code: DS
Laboratory Sample Number: 2311123-028
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-035

Sample Location: 1st Draw 133 D St. SE
Customer Sample Number:
Date / Time Collected: 11/14/2023 7:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-036
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 133 D St. SE
Customer Sample Number:
Date / Time Collected: 11/14/2023 7:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-036
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-003

Sample Location: 1st Draw 1334 Rittenhouse St. NW

Customer Sample Number:

Date / Time Collected: 11/6/2023 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-003

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 1334 Rittenhouse St. NW

Customer Sample Number:

Date / Time Collected: 11/6/2023 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-004

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-031

Sample Location: 1st Draw 134 10th St. NE

Customer Sample Number:

Date / Time Collected: 11/14/2023 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-031

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 134 10th St. NE

Customer Sample Number:

Date / Time Collected: 11/14/2023 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-032

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-019

Sample Location: 1st Draw 1378 C St. NE
Customer Sample Number:
Date / Time Collected: 11/6/2023 7:53 AM

Customer Program Code: DS
Laboratory Sample Number: 2311066-019
Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 1378 C St. NE
Customer Sample Number:
Date / Time Collected: 11/6/2023 7:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2311066-020
Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-009

Sample Location: 1st Draw 1415 Monroe St. NW

Customer Sample Number:

Date / Time Collected: 11/9/2023 7:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2311123-009

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 1415 Monroe St. NW

Customer Sample Number:

Date / Time Collected: 11/9/2023 7:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2311123-010

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-029

Sample Location: 1st Draw 1418 Varnum St. NW

Customer Sample Number:

Date / Time Collected: 11/14/2023 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-029

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 1418 Varnum St. NW

Customer Sample Number:

Date / Time Collected: 11/14/2023 5:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-030

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-007

Sample Location: 1st Draw 1421 E Street NE
Customer Sample Number:
Date / Time Collected: 10/25/2023 4:50 PM

Customer Program Code: DS
Laboratory Sample Number: 2311028-007
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	29.4	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 1421 E Street NE
Customer Sample Number:
Date / Time Collected: 10/25/2023 4:51 PM

Customer Program Code: DS
Laboratory Sample Number: 2311028-008
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	12.9	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-015

Sample Location: 1st Draw 150 12th St. NE

Customer Sample Number:

Date / Time Collected: 11/6/2023 4:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-015

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 150 12th St. NE

Customer Sample Number:

Date / Time Collected: 11/6/2023 4:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-016

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-005

Sample Location: 1st Draw 1521 Caroline St. NW

Customer Sample Number:

Date / Time Collected: 10/29/2023 7:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2311066-005

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 1521 Caroline St. NW

Customer Sample Number:

Date / Time Collected: 10/29/2023 7:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2311066-006

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-023

Sample Location: 1st Draw 161 Elmira St. SW

Customer Sample Number:

Date / Time Collected: 10/29/2023 9:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-023

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 161 Elmira St. SW

Customer Sample Number:

Date / Time Collected: 10/29/2023 9:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-024

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311076-001

Sample Location: 1st Draw 1644 35th St. NW

Customer Sample Number:

Date / Time Collected: 11/4/2023 6:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2311076-001

Date / Time Received: 11/9/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 1644 35th St. NW

Customer Sample Number:

Date / Time Collected: 11/4/2023 6:28 PM

Customer Program Code: DS

Laboratory Sample Number: 2311076-002

Date / Time Received: 11/9/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-009

Sample Location: 1st Draw 1834 Potomac Ave. SE

Customer Sample Number:

Date / Time Collected: 10/26/2023 5:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-009

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 1834 Potomac Ave. SE

Customer Sample Number:

Date / Time Collected: 10/26/2023 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-010

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-021

Sample Location: 1st Draw 1835 Burke St. SE

Customer Sample Number:

Date / Time Collected: 11/15/2023 6:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-021

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 1835 Burke St. SE

Customer Sample Number:

Date / Time Collected: 11/15/2023 6:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-022

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-007

Sample Location: 1st Draw 2034 4th St. NW

Customer Sample Number:

Date / Time Collected: 10/30/2023 10:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2311066-007

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 2034 4th St. NW

Customer Sample Number:

Date / Time Collected: 10/30/2023 10:22 PM

Customer Program Code: DS

Laboratory Sample Number: 2311066-008

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-019

Sample Location: 1st Draw 211 INGRAHAM ST NW
Customer Sample Number:
Date / Time Collected: 11/15/2023 6:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2311128-019
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 211 INGRAHAM ST NW
Customer Sample Number:
Date / Time Collected: 11/15/2023 6:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2311128-020
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-009

Sample Location: 1st Draw 2115 11th St. NW

Customer Sample Number:

Date / Time Collected: 11/2/2023 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-009

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 2115 11th St. NW

Customer Sample Number:

Date / Time Collected: 11/2/2023 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-010

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-017

Sample Location: 1st Draw 2130 BANCROFT PL NW

Customer Sample Number:

Date / Time Collected: 11/13/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-017

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 2130 BANCROFT PL NW

Customer Sample Number:

Date / Time Collected: 11/13/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-018

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-023

Sample Location: 1st Draw 221 Longfellow St. NW

Customer Sample Number:

Date / Time Collected: 11/15/2023 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-023

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 221 Longfellow St. NW

Customer Sample Number:

Date / Time Collected: 11/15/2023 7:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-024

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-001

Sample Location: 1st Draw 2310 Huidekoper PI NW

Customer Sample Number:

Date / Time Collected: 9/7/2023 6:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-001

Date / Time Received: 11/8/2023 12:35:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/15/2023	Rlamsal

Sample Location: 2nd Draw 2310 Huidekoper PI NW

Customer Sample Number:

Date / Time Collected: 9/7/2023 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-002

Date / Time Received: 11/8/2023 12:35:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-025

Sample Location: 1st Draw 250 9th St. SE
Customer Sample Number:
Date / Time Collected: 11/13/2023 7:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-025
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 250 9th St. SE
Customer Sample Number:
Date / Time Collected: 11/13/2023 7:23 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-026
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-013

Sample Location: 1st Draw 2504 Branch Ave SE

Customer Sample Number:

Date / Time Collected: 10/27/2023 6:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-013

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 2504 Branch Ave SE

Customer Sample Number:

Date / Time Collected: 10/27/2023 6:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-014

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-015

Sample Location: 1st Draw 306 7th St. NE
Customer Sample Number:
Date / Time Collected: 10/27/2023 8:19 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-015
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 306 7th St. NE
Customer Sample Number:
Date / Time Collected: 10/27/2023 8:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-016
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-007

Sample Location: 1st Draw 320 Independence Ave SE

Customer Sample Number:

Date / Time Collected: 11/11/2023 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-007

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 320 Independence Ave SE

Customer Sample Number:

Date / Time Collected: 11/11/2023 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-008

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-017

Sample Location: 1st Draw 3225 Woodley Rd NW

Customer Sample Number:

Date / Time Collected: 11/6/2023 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-017

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 3225 Woodley Rd NW

Customer Sample Number:

Date / Time Collected: 11/6/2023 5:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-018

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-001

Sample Location: 1st Draw 3315 12th ST SE

Customer Sample Number:

Date / Time Collected: 11/5/2023 5:12 PM

Customer Program Code: DS

Laboratory Sample Number: 2311123-001

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 3315 12th ST SE

Customer Sample Number:

Date / Time Collected: 11/5/2023 5:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2311123-002

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-021

Sample Location: 1st Draw 3523 Albemarle St. NW	Customer Program Code: DS
Customer Sample Number:	Laboratory Sample Number: 2311123-021
Date / Time Collected: 11/13/2023 6:00 AM	Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 3523 Albemarle St. NW	Customer Program Code: DS
Customer Sample Number:	Laboratory Sample Number: 2311123-022
Date / Time Collected: 11/13/2023 6:00 AM	Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-025

Sample Location: 1st Draw 3714 Garfield St. NW

Customer Sample Number:

Date / Time Collected: 10/31/2023 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-025

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 3714 Garfield St. NW

Customer Sample Number:

Date / Time Collected: 10/31/2023 5:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-026

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-021

Sample Location: 1st Draw 4000 14th St. NW, #1

Customer Sample Number:

Date / Time Collected: 10/29/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-021

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 4000 14th St. NW, #1

Customer Sample Number:

Date / Time Collected: 10/29/2023 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-022

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-015

Sample Location: 1st Draw 44 V St. NW
Customer Sample Number:
Date / Time Collected: 11/10/2023 7:57 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-015
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 44 V St. NW
Customer Sample Number:
Date / Time Collected: 11/10/2023 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-016
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-003

Sample Location: 1st Draw 4805 Irving St. NW

Customer Sample Number:

Date / Time Collected: 11/9/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-003

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 4805 Irving St. NW

Customer Sample Number:

Date / Time Collected: 11/9/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2311128-004

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-011

Sample Location: 1st Draw 4811 Brandywine St. NW

Customer Sample Number:

Date / Time Collected: 11/10/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-011

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 4811 Brandywine St. NW

Customer Sample Number:

Date / Time Collected: 11/10/2023 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2311123-012

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-005

Sample Location: 1st Draw 503 G St SE
Customer Sample Number:
Date / Time Collected: 11/11/2023 7:39 AM

Customer Program Code: DS
Laboratory Sample Number: 2311128-005
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 503 G St SE
Customer Sample Number:
Date / Time Collected: 11/11/2023 7:41 AM

Customer Program Code: DS
Laboratory Sample Number: 2311128-006
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-013

Sample Location: 1st Draw 516 T St. NW
Customer Sample Number:
Date / Time Collected: 11/2/2023 7:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2311066-013
Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 516 T St. NW
Customer Sample Number:
Date / Time Collected: 11/2/2023 7:28 AM

Customer Program Code: DS
Laboratory Sample Number: 2311066-014
Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-013

Sample Location: 1st Draw 526 9th St. SE
Customer Sample Number:
Date / Time Collected: 11/12/2023 6:53 AM

Customer Program Code: DS
Laboratory Sample Number: 2311128-013
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 526 9th St. SE
Customer Sample Number:
Date / Time Collected: 11/12/2023 6:56 AM

Customer Program Code: DS
Laboratory Sample Number: 2311128-014
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-005

Sample Location: 1st Draw 5351 28th St. NW

Customer Sample Number:

Date / Time Collected: 10/25/2023 3:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2311028-005

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 5351 28th St. NW

Customer Sample Number:

Date / Time Collected: 10/25/2023 3:58 PM

Customer Program Code: DS

Laboratory Sample Number: 2311028-006

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-007

Sample Location: 1st Draw 5911 4th St. NW

Customer Sample Number:

Date / Time Collected: 11/8/2023 4:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2311123-007

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 5911 4th St. NW

Customer Sample Number:

Date / Time Collected: 11/8/2023 4:51 PM

Customer Program Code: DS

Laboratory Sample Number: 2311123-008

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-013

Sample Location: 1st Draw 615 E St. SE
Customer Sample Number:
Date / Time Collected: 11/10/2023 7:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-013
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 615 E St. SE
Customer Sample Number:
Date / Time Collected: 11/10/2023 7:16 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-014
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-011

Sample Location: 1st Draw 617 E St. SE
Customer Sample Number:
Date / Time Collected: 10/26/2023 8:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-011
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 617 E St. SE
Customer Sample Number:
Date / Time Collected: 10/26/2023 8:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-012
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311021-001

Sample Location: 1st Draw 618 Harvard St. NW

Customer Sample Number:

Date / Time Collected: 10/9/2023 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2311021-001

Date / Time Received: 11/2/2023 11:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L	H	11/15/2023	Rlamsal

Sample Location: 2nd Draw 618 Harvard St. NW

Customer Sample Number:

Date / Time Collected: 10/9/2023 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2311021-002

Date / Time Received: 11/2/2023 11:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L	H	11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-017

Sample Location: 1st Draw 634 E St SE
Customer Sample Number:
Date / Time Collected: 10/28/2023 5:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-017
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 634 E St SE
Customer Sample Number:
Date / Time Collected: 10/28/2023 5:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-018
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-019

Sample Location: 1st Draw 636 E St. SE
Customer Sample Number:
Date / Time Collected: 10/28/2023 8:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-019
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 636 E St. SE
Customer Sample Number:
Date / Time Collected: 10/28/2023 8:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-020
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-019

Sample Location: 1st Draw 637 E St. SE
Customer Sample Number:
Date / Time Collected: 11/12/2023 4:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2311123-019
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 637 E St. SE
Customer Sample Number:
Date / Time Collected: 11/12/2023 4:35 PM

Customer Program Code: DS
Laboratory Sample Number: 2311123-020
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-001

Sample Location: 1st Draw 6951 33rd St. NW

Customer Sample Number:

Date / Time Collected: 10/20/2023 5:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-001

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 6951 33rd St. NW

Customer Sample Number:

Date / Time Collected: 10/20/2023 5:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-002

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311128-001

Sample Location: 1st Draw 719 15th St. SE
Customer Sample Number:
Date / Time Collected: 11/7/2023 1:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2311128-001
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 719 15th St. SE
Customer Sample Number:
Date / Time Collected: 11/7/2023 1:05 PM

Customer Program Code: DS
Laboratory Sample Number: 2311128-002
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311123-033

Sample Location: 1st Draw 741 10th St. SE
Customer Sample Number:
Date / Time Collected: 11/14/2023 6:49 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-033
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 741 10th St. SE
Customer Sample Number:
Date / Time Collected: 11/14/2023 6:51 AM

Customer Program Code: DS
Laboratory Sample Number: 2311123-034
Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-027

Sample Location: 1st Draw 817 S ST. NW, #301

Customer Sample Number:

Date / Time Collected: 10/31/2023 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-027

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 817 S ST. NW, #301

Customer Sample Number:

Date / Time Collected: 10/31/2023 7:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-028

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-003

Sample Location: 1st Draw 821 11th St. NE
Customer Sample Number:
Date / Time Collected: 10/25/2023 2:46 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-003
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 821 11th St. NE
Customer Sample Number:
Date / Time Collected: 10/25/2023 2:47 AM

Customer Program Code: DS
Laboratory Sample Number: 2311028-004
Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311066-011

Sample Location: 1st Draw 912 Westminster St. NW

Customer Sample Number:

Date / Time Collected: 11/2/2023 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-011

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.5	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 912 Westminster St. NW

Customer Sample Number:

Date / Time Collected: 11/2/2023 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2311066-012

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS-2311028-029

Sample Location: 1st Draw 918 N. Carolina Ave SE

Customer Sample Number:

Date / Time Collected: 11/1/2023 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-029

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 918 N. Carolina Ave SE

Customer Sample Number:

Date / Time Collected: 11/1/2023 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2311028-030

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS250- 2311130-001

Sample Location: 1st Draw 100 K St. NE, Apt. 317

Customer Sample Number:

Date / Time Collected: 11/10/2023 8:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311130-001

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 100 K St. NE, Apt. 317

Customer Sample Number:

Date / Time Collected: 11/10/2023 8:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311130-002

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS250- 2311065-003

Sample Location: 1st Draw 1245 4th St. SW, Apt. E707

Customer Sample Number:

Date / Time Collected: 11/3/2023 9:54 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311065-003

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 1245 4th St. SW, Apt. E707

Customer Sample Number:

Date / Time Collected: 11/3/2023 9:54 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311065-004

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS250- 2311130-003

Sample Location: 1st Draw 2032 Belmont Rd NW, Apt. 324

Customer Sample Number:

Date / Time Collected: 11/12/2023 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311130-003

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 2032 Belmont Rd NW, Apt. 324

Customer Sample Number:

Date / Time Collected: 11/12/2023 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311130-004

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS250- 2311021-005

Sample Location: 1st Draw 3524 International Ct. NW, #303

Customer Sample Number:

Date / Time Collected: 10/19/2023 5:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311021-005

Date / Time Received: 11/2/2023 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 3524 International Ct. NW, #303

Customer Sample Number:

Date / Time Collected: 10/19/2023 5:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311021-006

Date / Time Received: 11/2/2023 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS250- 2311027-001

Sample Location: 1st Draw 3624 Connecticut Ave. NW, #24

Customer Sample Number:

Date / Time Collected: 10/28/2023 10:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2311027-001

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 3624 Connecticut Ave. NW, #24

Customer Sample Number:

Date / Time Collected: 10/28/2023 10:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2311027-002

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-DS250- 2311130-005

Sample Location: 1st Draw 4840 MacArthur Blvd NW, Unit 308

Customer Sample Number:

Date / Time Collected: 11/13/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311130-005

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 4840 MacArthur Blvd NW, Unit 308

Customer Sample Number:

Date / Time Collected: 11/13/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311130-006

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/8/2023

Report Number: L-DC-DS250- 2311065-001

Sample Location: 1st Draw 1026 16th St. NW, #304

Customer Sample Number:

Date / Time Collected: 10/18/2023 8:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311065-001

Date / Time Received: 11/8/2023 12:35:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	22.6	ug/L	H	12/1/2023	SBrooks

Sample Location: 2nd Draw 1026 16th St. NW, #304

Customer Sample Number:

Date / Time Collected: 10/18/2023 8:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2311065-002

Date / Time Received: 11/8/2023 12:35:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-DS-2311158-005

Sample Location: 1st Draw 1935 38th St NW

Customer Sample Number:

Date / Time Collected: 11/16/2023 12:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2311158-005

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/4/2023	Bprakash

Sample Location: 2nd Draw 1935 38th St NW

Customer Sample Number:

Date / Time Collected: 11/16/2023 12:11 PM

Customer Program Code: DS

Laboratory Sample Number: 2311158-006

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-DS-2311158-007

Sample Location: 1st Draw 229 6th St NE
Customer Sample Number:
Date / Time Collected: 11/17/2023 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2311158-007
Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2023	Bprakash

Sample Location: 2nd Draw 229 6th St NE
Customer Sample Number:
Date / Time Collected: 11/17/2023 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2311158-008
Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-DS-2311158-011

Sample Location: 1st Draw 5109 34th St NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2311158-011

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2023	Bprakash

Sample Location: 2nd Draw 5109 34th St NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2311158-012

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-DS-2311158-009

Sample Location: 1st Draw 638 E. St SE
Customer Sample Number:
Date / Time Collected: 11/17/2023 6:41 AM

Customer Program Code: DS
Laboratory Sample Number: 2311158-009
Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/4/2023	Bprakash

Sample Location: 2nd Draw 638 E. St SE
Customer Sample Number:
Date / Time Collected: 11/17/2023 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2311158-010
Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-DS-2311158-001

Sample Location: 1st Draw 927 Westminster St. NW
Customer Sample Number:
Date / Time Collected: 11/15/2023 6:23 AM

Customer Program Code: DS
Laboratory Sample Number: 2311158-001
Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2023	Bprakash

Sample Location: 2nd Draw 927 Westminster St. NW
Customer Sample Number:
Date / Time Collected: 11/15/2023 6:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2311158-002
Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-023

Sample Location: 1st Draw 1100 Queen St. NE

Customer Sample Number:

Date / Time Collected: 11/25/2023 10:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-023

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 1100 Queen St. NE

Customer Sample Number:

Date / Time Collected: 11/25/2023 10:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-024

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-013

Sample Location: 1st Draw 1143 5th St. NW, #2

Customer Sample Number:

Date / Time Collected: 11/20/2023 6:03 PM

Customer Program Code: DS

Laboratory Sample Number: 2312005-013

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 1143 5th St. NW, #2

Customer Sample Number:

Date / Time Collected: 11/20/2023 6:06 PM

Customer Program Code: DS

Laboratory Sample Number: 2312005-014

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-017

Sample Location: 1st Draw 118 S St. NW
Customer Sample Number:
Date / Time Collected: 11/24/2023 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2312005-017
Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 118 S St. NW
Customer Sample Number:
Date / Time Collected: 11/24/2023 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2312005-018
Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-043

Sample Location: 1st Draw 1331 Park Rd. NW

Customer Sample Number:

Date / Time Collected: 11/29/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-043

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 1331 Park Rd. NW

Customer Sample Number:

Date / Time Collected: 11/29/2023 7:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-044

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-021

Sample Location: 1st Draw 1503 C St. SE
Customer Sample Number:
Date / Time Collected: 11/25/2023 6:38 AM

Customer Program Code: DS
Laboratory Sample Number: 2312005-021
Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 1503 C St. SE
Customer Sample Number:
Date / Time Collected: 11/25/2023 6:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2312005-022
Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-019

Sample Location: 1st Draw 1849 IRVING ST NW

Customer Sample Number:

Date / Time Collected: 11/24/2023 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-019

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 1849 IRVING ST NW

Customer Sample Number:

Date / Time Collected: 11/24/2023 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-020

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-003

Sample Location: 1st Draw 2126 1st St. NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-003

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 2126 1st St. NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 6:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-004

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-039

Sample Location: 1st Draw 225 E Street SE

Customer Sample Number:

Date / Time Collected: 11/28/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-039

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 225 E Street SE

Customer Sample Number:

Date / Time Collected: 11/28/2023 11:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312005-040

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-035

Sample Location: 1st Draw 3212 12th St. SE
Customer Sample Number:
Date / Time Collected: 11/28/2023 4:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2312005-035
Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 3212 12th St. SE
Customer Sample Number:
Date / Time Collected: 11/28/2023 4:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2312005-036
Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-011

Sample Location: 1st Draw 3308 12th St. SE
Customer Sample Number:
Date / Time Collected: 11/19/2023 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2312005-011
Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 3308 12th St. SE
Customer Sample Number:
Date / Time Collected: 11/19/2023 8:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2312005-012
Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS-2312005-033

Sample Location: 1st Draw 4412 Reservoir Rd. NW

Customer Sample Number:

Date / Time Collected: 11/27/2023 2:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2312005-033

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 4412 Reservoir Rd. NW

Customer Sample Number:

Date / Time Collected: 11/27/2023 2:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2312005-034

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS250- 2312006-005

Sample Location: 1st Draw 3315 16th St. NW, Apt.D

Customer Sample Number:

Date / Time Collected: 11/27/2023 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312006-005

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 3315 16th St. NW, Apt.D

Customer Sample Number:

Date / Time Collected: 11/27/2023 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312006-006

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS250- 2312006-003

Sample Location: 1st Draw 4009 8th St. NE, Unit 2

Customer Sample Number:

Date / Time Collected: 11/27/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312006-003

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 4009 8th St. NE, Unit 2

Customer Sample Number:

Date / Time Collected: 11/27/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312006-004

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/14/2023

Report Number: L-DC-DS250- 2312006-001

Sample Location: 1st Draw 534 Taylor St. NW, Apt. B

Customer Sample Number:

Date / Time Collected: 11/20/2023 4:24 PM

Customer Program Code: DS250

Laboratory Sample Number: 2312006-001

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Sample Location: 2nd Draw 534 Taylor St. NW, Apt. B

Customer Sample Number:

Date / Time Collected: 11/20/2023 4:24 PM

Customer Program Code: DS250

Laboratory Sample Number: 2312006-002

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off approximately 4 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-027

Sample Location: 1st Draw 1117 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 5/19/2023 11:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-027

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1117 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 5/19/2023 11:51 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-028

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306108-009

Sample Location: 1st Draw 1214 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 6/8/2023 1:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306108-009

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1214 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 6/8/2023 1:21 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306108-010

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-025

Sample Location: 1st Draw 1232 C St. NE
Customer Sample Number:
Date / Time Collected: 5/19/2023 6:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2305188-025
Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1232 C St. NE
Customer Sample Number:
Date / Time Collected: 5/19/2023 6:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2305188-026
Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306015-001

Sample Location: 1st Draw 1327 Massachusetts Ave. SE

Customer Sample Number:

Date / Time Collected: 5/26/2023 6:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-001

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	14.6	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1327 Massachusetts Ave. SE

Customer Sample Number:

Date / Time Collected: 5/26/2023 6:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-002

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306015-009

Sample Location: 1st Draw 1352 Parkwood PL NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 6:10 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-009

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1352 Parkwood PL NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 6:14 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-010

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305212-007

Sample Location: 1st Draw 1413 Trinidad Ave. NE

Customer Sample Number:

Date / Time Collected: 5/24/2023 5:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-007

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1413 Trinidad Ave. NE

Customer Sample Number:

Date / Time Collected: 5/24/2023 5:57 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-008

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305212-001

Sample Location: 1st Draw 1513 Foxhall Rd. NW

Customer Sample Number:

Date / Time Collected: 5/14/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-001

Date / Time Received: 5/31/2023 7:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/22/2023	SBrooks

Sample Location: 2nd Draw 1513 Foxhall Rd. NW

Customer Sample Number:

Date / Time Collected: 5/14/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-002

Date / Time Received: 5/31/2023 7:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-023

Sample Location: 1st Draw 1702 Kalmia Rd. NW

Customer Sample Number:

Date / Time Collected: 5/17/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-023

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1702 Kalmia Rd. NW

Customer Sample Number:

Date / Time Collected: 5/17/2023 7:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-024

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-021

Sample Location: 1st Draw 1840 Ontario PL NW

Customer Sample Number:

Date / Time Collected: 5/16/2023 7:35 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-021

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 1840 Ontario PL NW

Customer Sample Number:

Date / Time Collected: 5/16/2023 7:40 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-022

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306057-001

Sample Location: 1st Draw 217 Seaton PL NE

Customer Sample Number:

Date / Time Collected: 5/24/2023 7:01 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306057-001

Date / Time Received: 6/8/2023 12:30:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	6/22/2023	SBrooks

Sample Location: 2nd Draw 217 Seaton PL NE

Customer Sample Number:

Date / Time Collected: 5/24/2023 7:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306057-002

Date / Time Received: 6/8/2023 12:30:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305212-003

Sample Location: 1st Draw 3034 Alabama Ave. SE

Customer Sample Number:

Date / Time Collected: 5/22/2023 3:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-003

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 3034 Alabama Ave. SE

Customer Sample Number:

Date / Time Collected: 5/22/2023 3:17 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-004

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306108-007

Sample Location: 1st Draw 322 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 6/6/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306108-007

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 322 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 6/6/2023 8:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306108-008

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306108-005

Sample Location: 1st Draw 3725 R St. NW
Customer Sample Number:
Date / Time Collected: 6/1/2023 6:37 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2306108-005
Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 3725 R St. NW
Customer Sample Number:
Date / Time Collected: 6/1/2023 6:39 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2306108-006
Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306108-001

Sample Location: 1st Draw 3867 Beecher St. NW

Customer Sample Number:

Date / Time Collected: 6/8/2023 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306108-001

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 3867 Beecher St. NW

Customer Sample Number:

Date / Time Collected: 6/8/2023 6:22 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306108-002

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/13/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2306015-005

Sample Location: 1st Draw 4207 16th St. NW

Customer Sample Number:

Date / Time Collected: 5/28/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-005

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 4207 16th St. NW

Customer Sample Number:

Date / Time Collected: 5/28/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-006

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306015-003

Sample Location: 1st Draw 4215 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 5/27/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-003

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 4215 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 5/27/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-004

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306015-007

Sample Location: 1st Draw 434 Newton PL NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 8:37 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-007

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 434 Newton PL NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 8:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306015-008

Date / Time Received: 6/2/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306108-011

Sample Location: 1st Draw 459 Luray PL NW
Customer Sample Number:
Date / Time Collected: 6/9/2023 8:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2306108-011
Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 459 Luray PL NW
Customer Sample Number:
Date / Time Collected: 6/9/2023 8:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2306108-012
Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-031

Sample Location: 1st Draw 4611 44th St. NW

Customer Sample Number:

Date / Time Collected: 5/21/2023 8:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-031

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	26.7	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 4611 44th St. NW

Customer Sample Number:

Date / Time Collected: 5/21/2023 8:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-032

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2306108-003

Sample Location: 1st Draw 4810 Quebec St. NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306108-003

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 4810 Quebec St. NW

Customer Sample Number:

Date / Time Collected: 5/29/2023 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306108-004

Date / Time Received: 6/15/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-039

Sample Location: 1st Draw 4921 Quebec St. NW

Customer Sample Number:

Date / Time Collected: 5/17/2023 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-039

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 4921 Quebec St. NW

Customer Sample Number:

Date / Time Collected: 5/17/2023 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-040

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305149-068

Sample Location: 1st Draw 5115 Cathedral Ave. NW
Customer Sample Number:
Date / Time Collected: 5/15/2023 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2305149-068
Date / Time Received: 5/19/2023 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	113	ug/L		6/29/2023	SBrooks

Sample Location: 2nd Draw 5115 Cathedral Ave. NW
Customer Sample Number:
Date / Time Collected: 5/15/2023 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2305149-069
Date / Time Received: 5/19/2023 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	23.3	ug/L		6/1/2023	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305212-009

Sample Location: 1st Draw 5877 Nebraska Ave

Customer Sample Number:

Date / Time Collected: 5/24/2023 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-009

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 5877 Nebraska Ave

Customer Sample Number:

Date / Time Collected: 5/24/2023 9:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-010

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-029

Sample Location: 1st Draw 621 Quackenbos St. NW

Customer Sample Number:

Date / Time Collected: 5/20/2023 8:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-029

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 621 Quackenbos St. NW

Customer Sample Number:

Date / Time Collected: 5/20/2023 8:33 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-030

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305212-005

Sample Location: 1st Draw 6606 2nd St. NW

Customer Sample Number:

Date / Time Collected: 5/23/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-005

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 6606 2nd St. NW

Customer Sample Number:

Date / Time Collected: 5/23/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305212-006

Date / Time Received: 5/31/2023 7:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-035

Sample Location: 1st Draw 814 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 5/21/2023 7:44 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-035

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 814 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 5/21/2023 7:47 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-036

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-033

Sample Location: 1st Draw 916 15th St. SE
Customer Sample Number:
Date / Time Collected: 5/21/2023 11:26 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2305188-033
Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 916 15th St. SE
Customer Sample Number:
Date / Time Collected: 5/21/2023 11:29 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2305188-034
Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/13/2023

Report Number: L-DC-Post-LSR- 2305188-037

Sample Location: 1st Draw 944 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 5/22/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-037

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		6/22/2023	SBrooks

Sample Location: 2nd Draw 944 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 5/22/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2305188-038

Date / Time Received: 5/25/2023 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		6/22/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-063

Sample Location: 1st Draw 102 14th St. NE
Customer Sample Number:
Date / Time Collected: 6/26/2023 6:36 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307001-063
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 102 14th St. NE
Customer Sample Number:
Date / Time Collected: 6/26/2023 6:38 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307001-064
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-021

Sample Location: 1st Draw 1036 Evarts St. NE

Customer Sample Number:

Date / Time Collected: 6/21/2023 6:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-021

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 1036 Evarts St. NE

Customer Sample Number:

Date / Time Collected: 6/21/2023 6:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-022

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-029

Sample Location: 1st Draw 1318 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 6/22/2023 7:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-029

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 1318 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 6/22/2023 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-030

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-027

Sample Location: 1st Draw 146 Randolph PL NW

Customer Sample Number:

Date / Time Collected: 6/22/2023 6:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-027

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 146 Randolph PL NW

Customer Sample Number:

Date / Time Collected: 6/22/2023 6:49 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-028

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-019

Sample Location: 1st Draw 149 Uhland Ter NE

Customer Sample Number:

Date / Time Collected: 6/21/2023 6:29 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-019

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 149 Uhland Ter NE

Customer Sample Number:

Date / Time Collected: 6/21/2023 6:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-020

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-023

Sample Location: 1st Draw 3009 Central Ave. NE

Customer Sample Number:

Date / Time Collected: 6/21/2023 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-023

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 3009 Central Ave. NE

Customer Sample Number:

Date / Time Collected: 6/21/2023 6:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-024

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-009

Sample Location: 1st Draw 307 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 6/20/2023 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-009

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 307 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 6/20/2023 7:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-010

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-031

Sample Location: 1st Draw 311 4th St. SE #3
Customer Sample Number:
Date / Time Collected: 6/22/2023 7:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307001-031
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 311 4th St. SE #3
Customer Sample Number:
Date / Time Collected: 6/22/2023 7:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307001-032
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-013

Sample Location: 1st Draw 3221 6th St. NW

Customer Sample Number:

Date / Time Collected: 6/20/2023 7:01 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-013

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 3221 6th St. NW

Customer Sample Number:

Date / Time Collected: 6/20/2023 7:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-014

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2306182-001

Sample Location: 1st Draw 3304 Alabama Ave. SE

Customer Sample Number:

Date / Time Collected: 6/7/2023 5:32 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306182-001

Date / Time Received: 6/26/2023 10:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/11/2023	SBrooks

Sample Location: 2nd Draw 3304 Alabama Ave. SE

Customer Sample Number:

Date / Time Collected: 6/7/2023 5:33 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306182-002

Date / Time Received: 6/26/2023 10:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-025

Sample Location: 1st Draw 3525 MLK Jr. Ave SE

Customer Sample Number:

Date / Time Collected: 6/21/2023 7:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-025

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 3525 MLK Jr. Ave SE

Customer Sample Number:

Date / Time Collected: 6/21/2023 7:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-026

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-035

Sample Location: 1st Draw 412 Oglethorpe St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2023 5:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-035

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 412 Oglethorpe St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2023 5:50 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-036

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-039

Sample Location: 1st Draw 4406 New Hampshire Ave. NW

Customer Sample Number:

Date / Time Collected: 6/23/2023 5:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-039

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 4406 New Hampshire Ave. NW

Customer Sample Number:

Date / Time Collected: 6/23/2023 5:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-040

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-043

Sample Location: 1st Draw 4419 17th St. NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 5:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-043

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 4419 17th St. NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 5:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-044

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-033

Sample Location: 1st Draw 4419 N. H. Ave. NW

Customer Sample Number:

Date / Time Collected: 6/22/2023 7:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-033

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	11.5	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 4419 N. H. Ave. NW

Customer Sample Number:

Date / Time Collected: 6/22/2023 7:59 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-034

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-015

Sample Location: 1st Draw 4428 New Hampshire Ave. NW

Customer Sample Number:

Date / Time Collected: 6/21/2023 5:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-015

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 4428 New Hampshire Ave. NW

Customer Sample Number:

Date / Time Collected: 6/21/2023 5:22 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-016

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-037

Sample Location: 1st Draw 46 R St. NE
Customer Sample Number:
Date / Time Collected: 6/22/2023 11:00 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307001-037
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 46 R St. NE
Customer Sample Number:
Date / Time Collected: 6/22/2023 11:04 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307001-038
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-067

Sample Location: 1st Draw 514 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-067

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 514 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-068

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-055

Sample Location: 1st Draw 523 Tuckerman St NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 7:42 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-055

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 523 Tuckerman St NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 7:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-056

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-065

Sample Location: 1st Draw 527 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-065

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 527 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-066

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-045

Sample Location: 1st Draw 53 R St. NE Unit 1

Customer Sample Number:

Date / Time Collected: 6/25/2023 6:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-045

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 53 R St. NE Unit 1

Customer Sample Number:

Date / Time Collected: 6/25/2023 6:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-046

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2306182-005

Sample Location: 1st Draw 54 S St. NW
Customer Sample Number:
Date / Time Collected: 6/14/2023 6:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2306182-005
Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.7	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 54 S St. NW
Customer Sample Number:
Date / Time Collected: 6/14/2023 6:16 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2306182-006
Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-041

Sample Location: 1st Draw 612 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/24/2023 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-041

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 612 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/24/2023 6:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-042

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-011

Sample Location: 1st Draw 622 Otis Place NW

Customer Sample Number:

Date / Time Collected: 6/20/2023 5:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-011

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 622 Otis Place NW

Customer Sample Number:

Date / Time Collected: 6/20/2023 5:50 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-012

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2306182-003

Sample Location: 1st Draw 637 Quebec Place NW

Customer Sample Number:

Date / Time Collected: 6/12/2023 3:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306182-003

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/11/2023	SBrooks

Sample Location: 2nd Draw 637 Quebec Place NW

Customer Sample Number:

Date / Time Collected: 6/12/2023 3:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2306182-004

Date / Time Received: 6/26/2023 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/11/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-073

Sample Location: 1st Draw 6423 8th St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-073

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 6423 8th St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-074

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-017

Sample Location: 1st Draw 6505 3rd St. NW

Customer Sample Number:

Date / Time Collected: 6/21/2023 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-017

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 6505 3rd St. NW

Customer Sample Number:

Date / Time Collected: 6/21/2023 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-018

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-071

Sample Location: 1st Draw 652 G St. NE
Customer Sample Number:
Date / Time Collected: 6/26/2023 7:25 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307001-071
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 652 G St. NE
Customer Sample Number:
Date / Time Collected: 6/26/2023 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307001-072
Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-059

Sample Location: 1st Draw 830 Otis PL NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 5:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-059

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 830 Otis PL NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 5:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-060

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/18/2023

Report Number: L-DC-Post-LSR- 2307001-047

Sample Location: 1st Draw 924 Spring Rd. NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-047

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Sample Location: 2nd Draw 924 Spring Rd. NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 7:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307001-048

Date / Time Received: 6/29/2023 7:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/11/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-077

Sample Location: 1st Draw 1003 S. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 7/3/2023 9:03 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-077

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1003 S. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 7/3/2023 9:10 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-078

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/2/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2307049-035

Sample Location: 1st Draw 114 Bryant St. NW

Customer Sample Number:

Date / Time Collected: 6/24/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-035

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 114 Bryant St. NW

Customer Sample Number:

Date / Time Collected: 6/24/2023 8:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-036

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-069

Sample Location: 1st Draw 124 Bryant St. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 9:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-069

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 124 Bryant St. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 9:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-070

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-057

Sample Location: 1st Draw 1283 Oates St. NE

Customer Sample Number:

Date / Time Collected: 6/27/2023 7:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-057

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1283 Oates St. NE

Customer Sample Number:

Date / Time Collected: 6/27/2023 7:22 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-058

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-023

Sample Location: 1st Draw 13 R St. NE, Apt. #2

Customer Sample Number:

Date / Time Collected: 6/20/2023 6:56 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-023

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/17/2023	Bprakash

Sample Location: 2nd Draw 13 R St. NE, Apt. #2

Customer Sample Number:

Date / Time Collected: 6/20/2023 7:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-024

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-005

Sample Location: 1st Draw 1332 Locust Rd. NW

Customer Sample Number:

Date / Time Collected: 7/3/2023 7:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-005

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 1332 Locust Rd. NW

Customer Sample Number:

Date / Time Collected: 7/3/2023 7:39 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-006

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-053

Sample Location: 1st Draw 1335 Lawrence St. NE

Customer Sample Number:

Date / Time Collected: 6/27/2023 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-053

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1335 Lawrence St. NE

Customer Sample Number:

Date / Time Collected: 6/27/2023 6:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-054

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307098-001

Sample Location: 1st Draw 1358 Locust Rd NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307098-001

Date / Time Received: 7/13/2023 11:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/20/2023	Bprakash

Sample Location: 2nd Draw 1358 Locust Rd NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 6:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307098-002

Date / Time Received: 7/13/2023 11:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/20/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-009

Sample Location: 1st Draw 1501 Constitution Ave. NE

Customer Sample Number:

Date / Time Collected: 7/8/2023 12:22 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-009

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 1501 Constitution Ave. NE

Customer Sample Number:

Date / Time Collected: 7/8/2023 12:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-010

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/2/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2307049-071

Sample Location: 1st Draw 1503 Constitution Ave. NE

Customer Sample Number:

Date / Time Collected: 6/29/2023 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-071

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1503 Constitution Ave. NE

Customer Sample Number:

Date / Time Collected: 6/29/2023 8:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-072

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-007

Sample Location: 1st Draw 1528 Spring PL NW

Customer Sample Number:

Date / Time Collected: 7/6/2023 6:04 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-007

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 1528 Spring PL NW

Customer Sample Number:

Date / Time Collected: 7/6/2023 6:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-008

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-015

Sample Location: 1st Draw 1533 Pennsylvania Ave. SE

Customer Sample Number:

Date / Time Collected: 7/9/2023 6:39 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-015

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 1533 Pennsylvania Ave. SE

Customer Sample Number:

Date / Time Collected: 7/9/2023 6:44 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-016

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-043

Sample Location: 1st Draw 1601 28th St. SE

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-043

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1601 28th St. SE

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:02 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-044

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-031

Sample Location: 1st Draw 1638 G St. SE

Customer Sample Number:

Date / Time Collected: 6/22/2023 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-031

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	7/17/2023	Bprakash

Sample Location: 2nd Draw 1638 G St. SE

Customer Sample Number:

Date / Time Collected: 6/22/2023 7:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-032

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-067

Sample Location: 1st Draw 1829 Columbia Rd. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 9:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-067

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 1829 Columbia Rd. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 9:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-068

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307154-031

Sample Location: 1st Draw 1841 Newton St NW

Customer Sample Number:

Date / Time Collected: 7/17/2023 8:11 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307154-031

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 1841 Newton St NW

Customer Sample Number:

Date / Time Collected: 7/17/2023 8:13 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307154-032

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307154-033

Sample Location: 1st Draw 2216 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 7/17/2023 2:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307154-033

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 2216 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 7/17/2023 2:32 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307154-034

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-029

Sample Location: 1st Draw 225 Quackenbos St. NW

Customer Sample Number:

Date / Time Collected: 6/21/2023 4:02 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-029

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	7/17/2023	Bprakash

Sample Location: 2nd Draw 225 Quackenbos St. NW

Customer Sample Number:

Date / Time Collected: 6/21/2023 4:09 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-030

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-045

Sample Location: 1st Draw 2413 I St. NW
Customer Sample Number:
Date / Time Collected: 6/26/2023 8:08 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-045
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 2413 I St. NW
Customer Sample Number:
Date / Time Collected: 6/26/2023 8:10 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-046
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-017

Sample Location: 1st Draw 309 4th St. SE #4
Customer Sample Number:
Date / Time Collected: 7/10/2023 5:22 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307112-017
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 309 4th St. SE #4
Customer Sample Number:
Date / Time Collected: 7/10/2023 5:24 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307112-018
Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-001

Sample Location: 1st Draw 310 No. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 7/2/2023 1:40 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-001

Date / Time Received: 7/17/2023 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	7/20/2023	BPrakash

Sample Location: 2nd Draw 310 No. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 7/2/2023 1:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-002

Date / Time Received: 7/17/2023 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-041

Sample Location: 1st Draw 311 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-041

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 311 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2023 6:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-042

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-049

Sample Location: 1st Draw 3206 18th St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 4:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-049

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 3206 18th St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 4:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-050

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-081

Sample Location: 1st Draw 322 North Carolina Ave. SE
Customer Sample Number:
Date / Time Collected: 7/4/2023 9:26 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-081
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 322 North Carolina Ave. SE
Customer Sample Number:
Date / Time Collected: 7/4/2023 9:28 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-082
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307154-027

Sample Location: 1st Draw 3248 Q St NW
Customer Sample Number:
Date / Time Collected: 7/14/2023 6:33 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307154-027
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 3248 Q St NW
Customer Sample Number:
Date / Time Collected: 7/14/2023 6:35 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307154-028
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-013

Sample Location: 1st Draw 325 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 7/9/2023 2:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-013

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 325 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 7/9/2023 2:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-014

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-037

Sample Location: 1st Draw 3502 McKinley St. NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-037

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 3502 McKinley St. NW

Customer Sample Number:

Date / Time Collected: 6/25/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-038

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-063

Sample Location: 1st Draw 3526 Edmunds St. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-063

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 3526 Edmunds St. NW

Customer Sample Number:

Date / Time Collected: 6/28/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-064

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/2/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2307049-065

Sample Location: 1st Draw 4011 13th St. NE

Customer Sample Number:

Date / Time Collected: 6/28/2023 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-065

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 4011 13th St. NE

Customer Sample Number:

Date / Time Collected: 6/28/2023 7:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-066

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-027

Sample Location: 1st Draw 413 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 6/21/2023 6:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-027

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	7/17/2023	Bprakash

Sample Location: 2nd Draw 413 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 6/21/2023 6:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-028

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-039

Sample Location: 1st Draw 437 15th St. SE
Customer Sample Number:
Date / Time Collected: 6/25/2023 8:45 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-039
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 437 15th St. SE
Customer Sample Number:
Date / Time Collected: 6/25/2023 8:48 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-040
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-075

Sample Location: 1st Draw 510 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/30/2023 6:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-075

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 510 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/30/2023 6:34 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-076

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-003

Sample Location: 1st Draw 512 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 7/2/2023 6:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-003

Date / Time Received: 7/17/2023 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/20/2023	BPrakash

Sample Location: 2nd Draw 512 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 7/2/2023 6:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-004

Date / Time Received: 7/17/2023 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-051

Sample Location: 1st Draw 520 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 5:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-051

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 520 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 5:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-052

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-021

Sample Location: 1st Draw 522 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 7/11/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-021

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 522 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 7/11/2023 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-022

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-025

Sample Location: 1st Draw 56 R Street NE

Customer Sample Number:

Date / Time Collected: 6/20/2023 9:02 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-025

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/17/2023	Bprakash

Sample Location: 2nd Draw 56 R Street NE

Customer Sample Number:

Date / Time Collected: 6/20/2023 9:04 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-026

Date / Time Received: 7/7/2023 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-055

Sample Location: 1st Draw 5618 Nevada Ave. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-055

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 5618 Nevada Ave. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 7:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-056

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307154-035

Sample Location: 1st Draw 6 14th St. NE
Customer Sample Number:
Date / Time Collected: 7/18/2023 5:30 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307154-035
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 6 14th St. NE
Customer Sample Number:
Date / Time Collected: 7/18/2023 5:30 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307154-036
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/2/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2307112-019

Sample Location: 1st Draw 6007 5th St. NW

Customer Sample Number:

Date / Time Collected: 7/11/2023 5:59 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-019

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 6007 5th St. NW

Customer Sample Number:

Date / Time Collected: 7/11/2023 6:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-020

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-033

Sample Location: 1st Draw 605 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/23/2023 11:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-033

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 605 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/23/2023 11:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-034

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307154-029

Sample Location: 1st Draw 612 Hamilton St NW

Customer Sample Number:

Date / Time Collected: 7/16/2023 8:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307154-029

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 612 Hamilton St NW

Customer Sample Number:

Date / Time Collected: 7/16/2023 8:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307154-030

Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/2/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2307112-011

Sample Location: 1st Draw 612 M St. NW Apt. A

Customer Sample Number:

Date / Time Collected: 7/8/2023 8:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-011

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 612 M St. NW Apt. A

Customer Sample Number:

Date / Time Collected: 7/8/2023 8:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-012

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-079

Sample Location: 1st Draw 617 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 7/4/2023 7:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-079

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 617 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 7/4/2023 7:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-080

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-083

Sample Location: 1st Draw 617 Varnum St. NW

Customer Sample Number:

Date / Time Collected: 7/5/2023 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-083

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 617 Varnum St. NW

Customer Sample Number:

Date / Time Collected: 7/5/2023 7:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-084

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-047

Sample Location: 1st Draw 618 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 4:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-047

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 618 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 4:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-048

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-061

Sample Location: 1st Draw 6427 8th St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 5:21 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-061

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 6427 8th St. NW

Customer Sample Number:

Date / Time Collected: 6/27/2023 5:24 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307049-062

Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307098-003

Sample Location: 1st Draw 6513 3rd St. NW

Customer Sample Number:

Date / Time Collected: 7/2/2023 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307098-003

Date / Time Received: 7/13/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	Bprakash

Sample Location: 2nd Draw 6513 3rd St. NW

Customer Sample Number:

Date / Time Collected: 7/2/2023 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307098-004

Date / Time Received: 7/13/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/20/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-059

Sample Location: 1st Draw 653 A St. NE
Customer Sample Number:
Date / Time Collected: 6/27/2023 4:35 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-059
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 653 A St. NE
Customer Sample Number:
Date / Time Collected: 6/27/2023 4:38 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-060
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307049-073

Sample Location: 1st Draw 66 Bryant St. NW Apt. A
Customer Sample Number:
Date / Time Collected: 6/29/2023 9:28 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-073
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/17/2023	Bprakash

Sample Location: 2nd Draw 66 Bryant St. NW Apt. A
Customer Sample Number:
Date / Time Collected: 6/29/2023 9:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307049-074
Date / Time Received: 7/7/2023 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/17/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307154-025

Sample Location: 1st Draw 70 S St NW
Customer Sample Number:
Date / Time Collected: 7/13/2023 6:05 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307154-025
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/27/2023	Bprakash

Sample Location: 2nd Draw 70 S St NW
Customer Sample Number:
Date / Time Collected: 7/13/2023 6:10 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307154-026
Date / Time Received: 7/21/2023 9:16:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/27/2023	Bprakash

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/2/2023

Report Number: L-DC-Post-LSR- 2307112-023

Sample Location: 1st Draw 72 S Street, NW

Customer Sample Number:

Date / Time Collected: 7/12/2023 8:39 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-023

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/20/2023	BPrakash

Sample Location: 2nd Draw 72 S Street, NW

Customer Sample Number:

Date / Time Collected: 7/12/2023 8:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2307112-024

Date / Time Received: 7/17/2023 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/20/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/9/2023

Report Number: L-DC-Post-LSR- 2307193-005

Sample Location: 1st Draw 23 R St. NE
Customer Sample Number:
Date / Time Collected: 7/16/2023 8:54 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307193-005
Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/2/2023	LGallimore

Sample Location: 2nd Draw 23 R St. NE
Customer Sample Number:
Date / Time Collected: 7/16/2023 8:55 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307193-006
Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/2/2023	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/9/2023

Report Number: L-DC-Post-LSR- 2307193-003

Sample Location: 1st Draw 3822 Albermarle St. NW
Customer Sample Number:
Date / Time Collected: 7/27/2023 6:56 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307193-003
Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/2/2023	LGallimore

Sample Location: 2nd Draw 3822 Albermarle St. NW
Customer Sample Number:
Date / Time Collected: 7/27/2023 6:58 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2307193-004
Date / Time Received: 7/28/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/2/2023	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308039-011

Sample Location: 1st Draw 1022 S. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 7/29/2023 5:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-011

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1022 S. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 7/29/2023 5:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-012

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-017

Sample Location: 1st Draw 115 4th St. NE
Customer Sample Number:
Date / Time Collected: 7/25/2023 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308062-017
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 115 4th St. NE
Customer Sample Number:
Date / Time Collected: 7/25/2023 6:05 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308062-018
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-043

Sample Location: 1st Draw 1304 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 7:51 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-043

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1304 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 7:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-044

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-029

Sample Location: 1st Draw 1520 28th St. SE

Customer Sample Number:

Date / Time Collected: 7/26/2023 9:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-029

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1520 28th St. SE

Customer Sample Number:

Date / Time Collected: 7/26/2023 9:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-030

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.0	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-015

Sample Location: 1st Draw 1608 A St. NE
Customer Sample Number:
Date / Time Collected: 7/25/2023 4:27 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308062-015
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1608 A St. NE
Customer Sample Number:
Date / Time Collected: 7/25/2023 4:34 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308062-016
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-023

Sample Location: 1st Draw 1716 21th St. NW

Customer Sample Number:

Date / Time Collected: 7/25/2023 6:55 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-023

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	101	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1716 21th St. NW

Customer Sample Number:

Date / Time Collected: 7/25/2023 6:58 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-024

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308039-013

Sample Location: 1st Draw 1717 Newton St. NW

Customer Sample Number:

Date / Time Collected: 7/30/2023 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-013

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 1717 Newton St. NW

Customer Sample Number:

Date / Time Collected: 7/30/2023 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-014

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-037

Sample Location: 1st Draw 22 R St. NE
Customer Sample Number:
Date / Time Collected: 7/27/2023 6:24 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308062-037
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 22 R St. NE
Customer Sample Number:
Date / Time Collected: 7/27/2023 6:27 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308062-038
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308039-005

Sample Location: 1st Draw 2620 Rhode Island Ave. NE

Customer Sample Number:

Date / Time Collected: 7/28/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-005

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 2620 Rhode Island Ave. NE

Customer Sample Number:

Date / Time Collected: 7/28/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-006

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-033

Sample Location: 1st Draw 30 14th St. NE
Customer Sample Number:
Date / Time Collected: 7/26/2023 10:50 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308062-033
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 30 14th St. NE
Customer Sample Number:
Date / Time Collected: 7/26/2023 10:53 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308062-034
Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308038-003

Sample Location: 1st Draw 306 N. Carolina Ave. SE
Customer Sample Number:
Date / Time Collected: 7/27/2023 9:47 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308038-003
Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 306 N. Carolina Ave. SE
Customer Sample Number:
Date / Time Collected: 7/27/2023 9:50 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308038-004
Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308038-001

Sample Location: 1st Draw 318 14th PL NE
Customer Sample Number:
Date / Time Collected: 7/27/2023 7:40 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308038-001
Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 318 14th PL NE
Customer Sample Number:
Date / Time Collected: 7/27/2023 7:41 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308038-002
Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308038-007

Sample Location: 1st Draw 3450 24th St. SE

Customer Sample Number:

Date / Time Collected: 7/28/2023 9:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308038-007

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 3450 24th St. SE

Customer Sample Number:

Date / Time Collected: 7/28/2023 9:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308038-008

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-047

Sample Location: 1st Draw 3608 17th St. NE

Customer Sample Number:

Date / Time Collected: 7/28/2023 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-047

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 3608 17th St. NE

Customer Sample Number:

Date / Time Collected: 7/28/2023 6:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-048

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308038-011

Sample Location: 1st Draw 415 Aspen St. NW

Customer Sample Number:

Date / Time Collected: 7/31/2023 8:14 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308038-011

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	20.0	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 415 Aspen St. NW

Customer Sample Number:

Date / Time Collected: 7/31/2023 8:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308038-012

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308039-023

Sample Location: 1st Draw 4213 16th St. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 5:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-023

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 4213 16th St. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 5:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-024

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-011

Sample Location: 1st Draw 427 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 7/24/2023 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-011

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	8/10/2023	Lgallimore

Sample Location: 2nd Draw 427 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 7/24/2023 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-012

Date / Time Received: 8/8/2023 7:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-031

Sample Location: 1st Draw 4312 2nd St. NW

Customer Sample Number:

Date / Time Collected: 7/26/2023 7:13 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-031

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 4312 2nd St. NW

Customer Sample Number:

Date / Time Collected: 7/26/2023 7:19 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-032

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308039-015

Sample Location: 1st Draw 4325 2nd St. NW

Customer Sample Number:

Date / Time Collected: 7/31/2023 7:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-015

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 4325 2nd St. NW

Customer Sample Number:

Date / Time Collected: 7/31/2023 7:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-016

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308038-015

Sample Location: 1st Draw 4410 New Hamp. Ave. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 4:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308038-015

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 4410 New Hamp. Ave. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 4:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308038-016

Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308062-051

Sample Location: 1st Draw 4414 14th St. NE

Customer Sample Number:

Date / Time Collected: 7/30/2023 4:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-051

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 4414 14th St. NE

Customer Sample Number:

Date / Time Collected: 7/30/2023 4:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308062-052

Date / Time Received: 8/8/2023 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308039-019

Sample Location: 1st Draw 6403 3rd St. NW

Customer Sample Number:

Date / Time Collected: 7/31/2023 8:58 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-019

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 6403 3rd St. NW

Customer Sample Number:

Date / Time Collected: 7/31/2023 9:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308039-020

Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308038-013

Sample Location: 1st Draw 918 South Carolina Ave. SE
Customer Sample Number:
Date / Time Collected: 7/31/2023 8:16 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308038-013
Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 918 South Carolina Ave. SE
Customer Sample Number:
Date / Time Collected: 7/31/2023 8:18 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308038-014
Date / Time Received: 8/4/2023 7:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2023

Report Number: L-DC-Post-LSR- 2308039-001

Sample Location: 1st Draw 942 T St. NW
Customer Sample Number:
Date / Time Collected: 7/23/2023 3:12 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308039-001
Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Sample Location: 2nd Draw 942 T St. NW
Customer Sample Number:
Date / Time Collected: 7/23/2023 3:15 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308039-002
Date / Time Received: 8/4/2023 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/23/2023

Report Number: L-DC-Post-LSR- 2308094-007

Sample Location: 1st Draw 1616 G St. SE
Customer Sample Number:
Date / Time Collected: 7/28/2023 1:20 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308094-007
Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/16/2023	SBrooks

Sample Location: 2nd Draw 1616 G St. SE
Customer Sample Number:
Date / Time Collected: 7/28/2023 1:23 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308094-008
Date / Time Received: 8/11/2023 9:48:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/16/2023	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/23/2023

Report Number: L-DC-Post-LSR- 2308094-005

Sample Location: 1st Draw 319 4th St. SE

Customer Sample Number:

Date / Time Collected: 7/25/2023 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308094-005

Date / Time Received: 8/11/2023 9:48:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/16/2023	SBrooks

Sample Location: 2nd Draw 319 4th St. SE

Customer Sample Number:

Date / Time Collected: 7/25/2023 7:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308094-006

Date / Time Received: 8/11/2023 9:48:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/16/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-007

Sample Location: 1st Draw 1016 S. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 8/4/2023 5:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-007

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 1016 S. Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 8/4/2023 5:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-008

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-001

Sample Location: 1st Draw 1123 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 7:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-001

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 1123 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 8/1/2023 7:43 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-002

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-003

Sample Location: 1st Draw 1306 Girard St. NE

Customer Sample Number:

Date / Time Collected: 8/2/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-003

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 1306 Girard St. NE

Customer Sample Number:

Date / Time Collected: 8/2/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-004

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-021

Sample Location: 1st Draw 1406 Decatur St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2023 7:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-021

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 1406 Decatur St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2023 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-022

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-023

Sample Location: 1st Draw 1415 4th St. SW

Customer Sample Number:

Date / Time Collected: 8/4/2023 6:34 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-023

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 1415 4th St. SW

Customer Sample Number:

Date / Time Collected: 8/4/2023 6:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-024

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-003

Sample Location: 1st Draw 1615 Allison St. NW

Customer Sample Number:

Date / Time Collected: 8/14/2023 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-003

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 1615 Allison St. NW

Customer Sample Number:

Date / Time Collected: 8/14/2023 6:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-004

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-005

Sample Location: 1st Draw 203 S St. NE

Customer Sample Number:

Date / Time Collected: 8/3/2023 6:03 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-005

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 203 S St. NE

Customer Sample Number:

Date / Time Collected: 8/3/2023 6:06 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-006

Date / Time Received: 8/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-019

Sample Location: 1st Draw 2409 Tunlaw Rd. NW

Customer Sample Number:

Date / Time Collected: 8/12/2023 9:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-019

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 2409 Tunlaw Rd. NW

Customer Sample Number:

Date / Time Collected: 8/12/2023 9:32 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-020

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-015

Sample Location: 1st Draw 2905 12th St. NE

Customer Sample Number:

Date / Time Collected: 8/12/2023 10:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-015

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 2905 12th St. NE

Customer Sample Number:

Date / Time Collected: 8/12/2023 10:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-016

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-005

Sample Location: 1st Draw 3812 Albemarle St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-005

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 3812 Albemarle St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2023 6:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-006

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-013

Sample Location: 1st Draw 4205 IL Ave. NW

Customer Sample Number:

Date / Time Collected: 8/7/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-013

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 4205 IL Ave. NW

Customer Sample Number:

Date / Time Collected: 8/7/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-014

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-015

Sample Location: 1st Draw 4316 15th St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2023 7:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-015

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 4316 15th St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2023 7:11 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-016

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-011

Sample Location: 1st Draw 4506 Iowa Ave. NW

Customer Sample Number:

Date / Time Collected: 8/4/2023 9:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-011

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 4506 Iowa Ave. NW

Customer Sample Number:

Date / Time Collected: 8/4/2023 9:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-012

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-023

Sample Location: 1st Draw 4525 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/16/2023 6:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-023

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 4525 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/16/2023 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-024

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-017

Sample Location: 1st Draw 4825 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/12/2023 9:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-017

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 4825 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/12/2023 9:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-018

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-011

Sample Location: 1st Draw 4829 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-011

Date / Time Received: 8/17/2023 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 4829 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 7/27/2023 6:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-012

Date / Time Received: 8/17/2023 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-021

Sample Location: 1st Draw 5052 Jay St. NE

Customer Sample Number:

Date / Time Collected: 7/23/2023 12:46 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-021

Date / Time Received: 8/17/2023 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	8/24/2023	SBrooks

Sample Location: 2nd Draw 5052 Jay St. NE

Customer Sample Number:

Date / Time Collected: 7/23/2023 12:48 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-022

Date / Time Received: 8/17/2023 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-019

Sample Location: 1st Draw 517 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-019

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 517 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2023 6:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-020

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-007

Sample Location: 1st Draw 624 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 8/14/2023 7:34 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-007

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 624 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 8/14/2023 7:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-008

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308145-009

Sample Location: 1st Draw 818 Randolph St. NW

Customer Sample Number:

Date / Time Collected: 8/4/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-009

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 818 Randolph St. NW

Customer Sample Number:

Date / Time Collected: 8/4/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308145-010

Date / Time Received: 8/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-025

Sample Location: 1st Draw 83 S St. NW
Customer Sample Number:
Date / Time Collected: 8/7/2023 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308132-025
Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 83 S St. NW
Customer Sample Number:
Date / Time Collected: 8/7/2023 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308132-026
Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/29/2023

Report Number: L-DC-Post-LSR- 2308132-009

Sample Location: 1st Draw 920 South Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 8/15/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-009

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Sample Location: 2nd Draw 920 South Carolina Ave. SE

Customer Sample Number:

Date / Time Collected: 8/15/2023 7:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308132-010

Date / Time Received: 8/17/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/24/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-005

Sample Location: 1st Draw 1015 9th St. NE
Customer Sample Number:
Date / Time Collected: 8/20/2023 6:36 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308228-005
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 1015 9th St. NE
Customer Sample Number:
Date / Time Collected: 8/20/2023 6:40 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2308228-006
Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-003

Sample Location: 1st Draw 1327 Dexter Ter. SE

Customer Sample Number:

Date / Time Collected: 8/19/2023 8:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-003

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 1327 Dexter Ter. SE

Customer Sample Number:

Date / Time Collected: 8/19/2023 8:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-004

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-019

Sample Location: 1st Draw 1368 Taylor St. NW

Customer Sample Number:

Date / Time Collected: 8/24/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-019

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 1368 Taylor St. NW

Customer Sample Number:

Date / Time Collected: 8/24/2023 7:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-020

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-007

Sample Location: 1st Draw 1514 Kearny St. NE

Customer Sample Number:

Date / Time Collected: 8/21/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-007

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 1514 Kearny St. NE

Customer Sample Number:

Date / Time Collected: 8/21/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-008

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-025

Sample Location: 1st Draw 1524 Upsher St. NW

Customer Sample Number:

Date / Time Collected: 8/24/2023 5:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-025

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 1524 Upsher St. NW

Customer Sample Number:

Date / Time Collected: 8/24/2023 5:46 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-026

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-021

Sample Location: 1st Draw 1633 Webster St. NW

Customer Sample Number:

Date / Time Collected: 8/24/2023 12:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-021

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 1633 Webster St. NW

Customer Sample Number:

Date / Time Collected: 8/24/2023 12:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-022

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-015

Sample Location: 1st Draw 229 Rock Creek Church Rd. NW

Customer Sample Number:

Date / Time Collected: 8/23/2023 5:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-015

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 229 Rock Creek Church Rd. NW

Customer Sample Number:

Date / Time Collected: 8/23/2023 5:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-016

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-011

Sample Location: 1st Draw 3414 Garfield St. NW

Customer Sample Number:

Date / Time Collected: 8/21/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-011

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 3414 Garfield St. NW

Customer Sample Number:

Date / Time Collected: 8/21/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-012

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-001

Sample Location: 1st Draw 3546 Alton PL NW

Customer Sample Number:

Date / Time Collected: 8/19/2023 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-001

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 3546 Alton PL NW

Customer Sample Number:

Date / Time Collected: 8/19/2023 7:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-002

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-023

Sample Location: 1st Draw 36 R St. NE

Customer Sample Number:

Date / Time Collected: 8/24/2023 1:08 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-023

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 36 R St. NE

Customer Sample Number:

Date / Time Collected: 8/24/2023 1:14 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-024

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-033

Sample Location: 1st Draw 3932 #A Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 8/26/2023 2:50 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-033

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 3932 #A Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 8/26/2023 2:55 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-034

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308184-003

Sample Location: 1st Draw 4808 41st St NW

Customer Sample Number:

Date / Time Collected: 8/7/2023 6:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308184-003

Date / Time Received: 8/24/2023 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Sample Location: 2nd Draw 4808 41st St NW

Customer Sample Number:

Date / Time Collected: 8/7/2023 6:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308184-004

Date / Time Received: 8/24/2023 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308184-009

Sample Location: 1st Draw 516 Columbia Rd. NW

Customer Sample Number:

Date / Time Collected: 8/16/2023 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308184-009

Date / Time Received: 8/24/2023 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 516 Columbia Rd. NW

Customer Sample Number:

Date / Time Collected: 8/16/2023 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308184-010

Date / Time Received: 8/24/2023 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308184-005

Sample Location: 1st Draw 518 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 8/7/2023 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308184-005

Date / Time Received: 8/24/2023 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Sample Location: 2nd Draw 518 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 8/7/2023 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308184-006

Date / Time Received: 8/24/2023 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2309013-001

Sample Location: 1st Draw 526 Madison St. NW

Customer Sample Number:

Date / Time Collected: 8/11/2023 4:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309013-001

Date / Time Received: 9/1/2023 1:20:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-027

Sample Location: 1st Draw 5520 Carolina PL, NE

Customer Sample Number:

Date / Time Collected: 8/25/2023 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-027

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 5520 Carolina PL, NE

Customer Sample Number:

Date / Time Collected: 8/25/2023 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-028

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-013

Sample Location: 1st Draw 560 Peabody St. NW

Customer Sample Number:

Date / Time Collected: 8/21/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-013

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 560 Peabody St. NW

Customer Sample Number:

Date / Time Collected: 8/21/2023 7:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-014

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-017

Sample Location: 1st Draw 5731 13th St. NW

Customer Sample Number:

Date / Time Collected: 8/23/2023 9:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-017

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 5731 13th St. NW

Customer Sample Number:

Date / Time Collected: 8/23/2023 9:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-018

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-031

Sample Location: 1st Draw 812 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2023 8:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-031

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 812 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2023 8:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-032

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/20/2023

Report Number: L-DC-Post-LSR- 2308228-029

Sample Location: 1st Draw 902 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-029

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Sample Location: 2nd Draw 902 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-030

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-043

Sample Location: 1st Draw 112 9th St. SE
Customer Sample Number:
Date / Time Collected: 8/28/2023 9:24 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309071-043
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 112 9th St. SE
Customer Sample Number:
Date / Time Collected: 8/28/2023 9:27 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309071-044
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-055

Sample Location: 1st Draw 1513 Massachusetts Ave. SE

Customer Sample Number:

Date / Time Collected: 9/1/2023 7:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-055

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 1513 Massachusetts Ave. SE

Customer Sample Number:

Date / Time Collected: 9/1/2023 7:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-056

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-029

Sample Location: 1st Draw 1521 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2023 9:23 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-029

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 1521 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2023 9:26 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-030

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-053

Sample Location: 1st Draw 1545 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 9/1/2023 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-053

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 1545 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 9/1/2023 5:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-054

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-031

Sample Location: 1st Draw 1620 Webster St. NW

Customer Sample Number:

Date / Time Collected: 8/26/2023 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-031

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 1620 Webster St. NW

Customer Sample Number:

Date / Time Collected: 8/26/2023 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-032

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309052-009

Sample Location: 1st Draw 1765 Euclid St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-009

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 1765 Euclid St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-010

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-037

Sample Location: 1st Draw 1838 Jackson St. NE

Customer Sample Number:

Date / Time Collected: 8/27/2023 8:23 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-037

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 1838 Jackson St. NE

Customer Sample Number:

Date / Time Collected: 8/27/2023 8:28 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-038

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309052-019

Sample Location: 1st Draw 2115 Q St. SE
Customer Sample Number:
Date / Time Collected: 9/2/2023 7:17 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309052-019
Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 2115 Q St. SE
Customer Sample Number:
Date / Time Collected: 9/2/2023 7:24 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309052-020
Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-057

Sample Location: 1st Draw 2814 Dumbarton St. NW

Customer Sample Number:

Date / Time Collected: 9/5/2023 5:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-057

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 2814 Dumbarton St. NW

Customer Sample Number:

Date / Time Collected: 9/5/2023 5:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-058

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309052-017

Sample Location: 1st Draw 3623 Fulton St. NW

Customer Sample Number:

Date / Time Collected: 8/30/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-017

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 3623 Fulton St. NW

Customer Sample Number:

Date / Time Collected: 8/30/2023 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-018

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-033

Sample Location: 1st Draw 3813 13th St. NW

Customer Sample Number:

Date / Time Collected: 8/26/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-033

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 3813 13th St. NW

Customer Sample Number:

Date / Time Collected: 8/26/2023 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-034

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-047

Sample Location: 1st Draw 407 M St. NW
Customer Sample Number:
Date / Time Collected: 8/30/2023 7:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309071-047
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 407 M St. NW
Customer Sample Number:
Date / Time Collected: 8/30/2023 7:23 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309071-048
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309052-015

Sample Location: 1st Draw 4833 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/28/2023 8:23 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-015

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 4833 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/28/2023 8:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-016

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309052-013

Sample Location: 1st Draw 4905 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/27/2023 3:08 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-013

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 4905 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/27/2023 3:10 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-014

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309052-011

Sample Location: 1st Draw 4916 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/26/2023 7:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-011

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 4916 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/26/2023 7:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-012

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-051

Sample Location: 1st Draw 509 A St. SE
Customer Sample Number:
Date / Time Collected: 8/31/2023 7:05 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309071-051
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 509 A St. SE
Customer Sample Number:
Date / Time Collected: 8/31/2023 7:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309071-052
Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-035

Sample Location: 1st Draw 518 Aspen St. NW

Customer Sample Number:

Date / Time Collected: 8/27/2023 6:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-035

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 518 Aspen St. NW

Customer Sample Number:

Date / Time Collected: 8/27/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-036

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-027

Sample Location: 1st Draw 524 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 8/20/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-027

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 524 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 8/20/2023 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-028

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-045

Sample Location: 1st Draw 5313 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/30/2023 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-045

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 5313 9th St. NW

Customer Sample Number:

Date / Time Collected: 8/30/2023 6:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-046

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309071-049

Sample Location: 1st Draw 5720 13th St. NW

Customer Sample Number:

Date / Time Collected: 8/31/2023 5:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-049

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 5720 13th St. NW

Customer Sample Number:

Date / Time Collected: 8/31/2023 5:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-050

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309052-023

Sample Location: 1st Draw 610 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 9/4/2023 10:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-023

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 610 Tuckerman St. NW

Customer Sample Number:

Date / Time Collected: 9/4/2023 10:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-024

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/29/2023

Report Number: L-DC-Post-LSR- 2309052-021

Sample Location: 1st Draw 915 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 9/3/2023 7:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-021

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/19/2023	Bprakash

Sample Location: 2nd Draw 915 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 9/3/2023 7:03 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309052-022

Date / Time Received: 9/8/2023 12:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309129-009

Sample Location: 1st Draw 1000 Columbia Rd. NW

Customer Sample Number:

Date / Time Collected: 9/3/2023 6:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309129-009

Date / Time Received: 9/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L	H	9/25/2023	Bprakash

Sample Location: 2nd Draw 1000 Columbia Rd. NW

Customer Sample Number:

Date / Time Collected: 9/3/2023 6:35 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309129-010

Date / Time Received: 9/18/2023 11:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L	H	9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/5/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2309129-015

Sample Location: 1st Draw 1327 1st St. NW

Customer Sample Number:

Date / Time Collected: 9/13/2023 9:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309129-015

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1327 1st St. NW

Customer Sample Number:

Date / Time Collected: 9/13/2023 9:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309129-016

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	0.7	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309106-025

Sample Location: 1st Draw 1406 Kearny St. NE

Customer Sample Number:

Date / Time Collected: 9/11/2023 6:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-025

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1406 Kearny St. NE

Customer Sample Number:

Date / Time Collected: 9/11/2023 6:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-026

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309106-021

Sample Location: 1st Draw 1411 Delafield PL NW

Customer Sample Number:

Date / Time Collected: 9/9/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-021

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1411 Delafield PL NW

Customer Sample Number:

Date / Time Collected: 9/9/2023 7:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-022

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/5/2023

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2309166-003

Sample Location: 1st Draw 1500 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 9/18/2023 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309166-003

Date / Time Received: 9/22/2023 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	2.0	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309106-019

Sample Location: 1st Draw 1609 Allison St. NW

Customer Sample Number:

Date / Time Collected: 9/9/2023 6:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-019

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1609 Allison St. NW

Customer Sample Number:

Date / Time Collected: 9/9/2023 6:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-020

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309106-015

Sample Location: 1st Draw 1628 Webster St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-015

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1628 Webster St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2023 6:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-016

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309114-003

Sample Location: 1st Draw 1837 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 7:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309114-003

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 1837 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 7:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309114-004

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309129-013

Sample Location: 1st Draw 2811 26th St. NE

Customer Sample Number:

Date / Time Collected: 9/12/2023 4:47 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309129-013

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 2811 26th St. NE

Customer Sample Number:

Date / Time Collected: 9/12/2023 4:48 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309129-014

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309106-013

Sample Location: 1st Draw 324 D St. SE
Customer Sample Number:
Date / Time Collected: 9/4/2023 5:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309106-013
Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 324 D St. SE
Customer Sample Number:
Date / Time Collected: 9/4/2023 5:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309106-014
Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309106-027

Sample Location: 1st Draw 3421 34th PL NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-027

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 3421 34th PL NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-028

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309106-017

Sample Location: 1st Draw 4726 5th St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2023 3:23 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-017

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	0.9	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 4726 5th St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2023 3:27 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-018

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309106-011

Sample Location: 1st Draw 4822 8th St. NW

Customer Sample Number:

Date / Time Collected: 8/29/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-011

Date / Time Received: 9/14/2023 12:20:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	9.4	ug/L	H	9/25/2023	Bprakash

Sample Location: 2nd Draw 4822 8th St. NW

Customer Sample Number:

Date / Time Collected: 8/29/2023 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-012

Date / Time Received: 9/14/2023 12:20:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	3.8	ug/L	H	9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309106-023

Sample Location: 1st Draw 5235 7th St. NW

Customer Sample Number:

Date / Time Collected: 9/10/2023 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-023

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 5235 7th St. NW

Customer Sample Number:

Date / Time Collected: 9/10/2023 7:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309106-024

Date / Time Received: 9/14/2023 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309114-001

Sample Location: 1st Draw 5416 N. Capitol St. NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 6:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309114-001

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 5416 N. Capitol St. NW

Customer Sample Number:

Date / Time Collected: 9/11/2023 6:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309114-002

Date / Time Received: 9/15/2023 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309145-001

Sample Location: 1st Draw 814 Alabama Ave. SE

Customer Sample Number:

Date / Time Collected: 8/24/2023 2:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309145-001

Date / Time Received: 9/20/2023 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	4.8	ug/L	H	9/25/2023	Bprakash

Sample Location: 2nd Draw 814 Alabama Ave. SE

Customer Sample Number:

Date / Time Collected: 8/24/2023 2:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309145-002

Date / Time Received: 9/20/2023 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	2.6	ug/L	H	9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/5/2023

Report Number: L-DC-Post-LSR- 2309129-011

Sample Location: 1st Draw 829 Delafield PL NW

Customer Sample Number:

Date / Time Collected: 9/10/2023 8:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309129-011

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Sample Location: 2nd Draw 829 Delafield PL NW

Customer Sample Number:

Date / Time Collected: 9/10/2023 8:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309129-012

Date / Time Received: 9/18/2023 11:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.5	ND	ug/L		9/25/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/10/2023

Report Number: L-DC-Post-LSR- 2309071-041

Sample Location: 1st Draw 2018 37th St. NW

Customer Sample Number:

Date / Time Collected: 8/27/2023 10:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-041

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	4.0	25.8	ug/L	H	9/19/2023	Bprakash

Sample Location: 2nd Draw 2018 37th St. NW

Customer Sample Number:

Date / Time Collected: 8/27/2023 10:40 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-042

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	1.0	14.1	ug/L	H	9/28/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/10/2023

Report Number: L-DC-Post-LSR- 2309071-059

Sample Location: 1st Draw 308 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 9/5/2023 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-059

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	1.0	21.0	ug/L		9/28/2023	SBrooks

Sample Location: 2nd Draw 308 Shepherd St. NW

Customer Sample Number:

Date / Time Collected: 9/5/2023 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-060

Date / Time Received: 9/11/2023 11:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/10/2023

Report Number: L-DC-Post-LSR- 2308228-009

Sample Location: 1st Draw 544 Peabody St. NW

Customer Sample Number:

Date / Time Collected: 8/21/2023 6:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-009

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	1.0	1.2	ug/L		9/28/2023	SBrooks

Sample Location: 2nd Draw 544 Peabody St. NW

Customer Sample Number:

Date / Time Collected: 8/21/2023 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2308228-010

Date / Time Received: 8/31/2023 11:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/12/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/10/2023

Report Number: L-DC-Post-LSR- 2309071-039

Sample Location: 1st Draw 819 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 8/27/2023 10:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-039

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2.0	769	ug/L	H	9/28/2023	SBrooks

Sample Location: 2nd Draw 819 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 8/27/2023 10:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309071-040

Date / Time Received: 9/11/2023 11:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	61.3	ug/L	H	9/19/2023	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-Post-LSR- 2309161-020

Sample Location: 1st Draw 134 Quincy PL NE

Customer Sample Number:

Date / Time Collected: 9/18/2023 11:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-020

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 134 Quincy PL NE

Customer Sample Number:

Date / Time Collected: 9/18/2023 11:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-021

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-Post-LSR- 2309161-028

Sample Location: 1st Draw 1615 Webster St. NW

Customer Sample Number:

Date / Time Collected: 9/17/2023 8:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-028

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1615 Webster St. NW

Customer Sample Number:

Date / Time Collected: 9/17/2023 8:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-029

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-Post-LSR- 2309161-026

Sample Location: 1st Draw 1620 G St. SE
Customer Sample Number:
Date / Time Collected: 9/19/2023 9:11 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309161-026
Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1620 G St. SE
Customer Sample Number:
Date / Time Collected: 9/19/2023 9:13 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309161-027
Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-Post-LSR- 2309161-018

Sample Location: 1st Draw 2730 Chesapeake St. NW

Customer Sample Number:

Date / Time Collected: 9/18/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-018

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 2730 Chesapeake St. NW

Customer Sample Number:

Date / Time Collected: 9/18/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-019

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-Post-LSR- 2309161-016

Sample Location: 1st Draw 301 7th St. NE, Apt. 1

Customer Sample Number:

Date / Time Collected: 9/17/2023 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-016

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 301 7th St. NE, Apt. 1

Customer Sample Number:

Date / Time Collected: 9/17/2023 7:44 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-017

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-Post-LSR- 2309161-022

Sample Location: 1st Draw 3010 Franklin St. NE

Customer Sample Number:

Date / Time Collected: 9/18/2023 2:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-022

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 3010 Franklin St. NE

Customer Sample Number:

Date / Time Collected: 9/18/2023 2:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-023

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-Post-LSR- 2309161-013

Sample Location: 1st Draw 44 S St. NW
Customer Sample Number:
Date / Time Collected: 9/13/2023 8:40 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309161-013
Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-Post-LSR- 2309161-014

Sample Location: 1st Draw 4910 9th St. NW

Customer Sample Number:

Date / Time Collected: 9/14/2023 5:10 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-014

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 4910 9th St. NW

Customer Sample Number:

Date / Time Collected: 9/14/2023 5:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-015

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/19/2023

Report Number: L-DC-Post-LSR- 2309161-024

Sample Location: 1st Draw 908 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 9/19/2023 6:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-024

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 908 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 9/19/2023 6:28 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309161-025

Date / Time Received: 9/21/2023 1:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2309208-007

Sample Location: 1st Draw 100 5th St. SE
Customer Sample Number:
Date / Time Collected: 9/20/2023 6:22 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309208-007
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 100 5th St. SE
Customer Sample Number:
Date / Time Collected: 9/20/2023 6:23 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309208-008
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2310016-007

Sample Location: 1st Draw 119 3rd St. NE
Customer Sample Number:
Date / Time Collected: 9/27/2023 2:30 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310016-007
Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 119 3rd St. NE
Customer Sample Number:
Date / Time Collected: 9/27/2023 2:32 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310016-008
Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2309208-009

Sample Location: 1st Draw 1525 Upshur NW

Customer Sample Number:

Date / Time Collected: 9/21/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309208-009

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1525 Upshur NW

Customer Sample Number:

Date / Time Collected: 9/21/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309208-010

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2310016-009

Sample Location: 1st Draw 1801 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 9/28/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310016-009

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 1801 Lamont St. NW

Customer Sample Number:

Date / Time Collected: 9/28/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310016-010

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2309208-003

Sample Location: 1st Draw 22 14th St. NE
Customer Sample Number:
Date / Time Collected: 9/19/2023 5:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309208-003
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 22 14th St. NE
Customer Sample Number:
Date / Time Collected: 9/19/2023 5:05 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309208-004
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2310016-001

Sample Location: 1st Draw 2526 13th St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2023 9:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310016-001

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 2526 13th St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2023 9:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310016-002

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2310016-005

Sample Location: 1st Draw 3546 W PL NW
Customer Sample Number:
Date / Time Collected: 9/27/2023 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310016-005
Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 3546 W PL NW
Customer Sample Number:
Date / Time Collected: 9/27/2023 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310016-006
Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2309208-001

Sample Location: 1st Draw 411 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 9/13/2023 6:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309208-001

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 411 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 9/13/2023 6:11 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309208-002

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2309208-011

Sample Location: 1st Draw 4215 3rd St NW
Customer Sample Number:
Date / Time Collected: 9/26/2023 6:47 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309208-011
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 4215 3rd St NW
Customer Sample Number:
Date / Time Collected: 9/26/2023 6:48 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2309208-012
Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2310016-003

Sample Location: 1st Draw 540 Madison St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2023 10:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310016-003

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 540 Madison St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2023 10:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310016-004

Date / Time Received: 10/2/2023 11:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2310039-005

Sample Location: 1st Draw 748 19th St. NE

Customer Sample Number:

Date / Time Collected: 9/9/2023 9:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310039-005

Date / Time Received: 10/4/2023 8:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/10/2023	Lgallimore

Sample Location: 2nd Draw 748 19th St. NE

Customer Sample Number:

Date / Time Collected: 9/9/2023 9:02 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310039-006

Date / Time Received: 10/4/2023 8:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/23/2023

Report Number: L-DC-Post-LSR- 2309208-005

Sample Location: 1st Draw 811 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 9/19/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309208-005

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Sample Location: 2nd Draw 811 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 9/19/2023 8:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2309208-006

Date / Time Received: 9/27/2023 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310104-007

Sample Location: 1st Draw 129 3rd St., NE
Customer Sample Number:
Date / Time Collected: 10/5/2023 6:55 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310104-007
Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 129 3rd St., NE
Customer Sample Number:
Date / Time Collected: 10/5/2023 6:58 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310104-008
Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310075-003

Sample Location: 1st Draw 1307 Taylor St. NW

Customer Sample Number:

Date / Time Collected: 10/2/2023 7:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-003

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 1307 Taylor St. NW

Customer Sample Number:

Date / Time Collected: 10/2/2023 7:51 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-004

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310173-001

Sample Location: 1st Draw 131 3rd St. NE
Customer Sample Number:
Date / Time Collected: 10/10/2023 6:11 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310173-001
Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 131 3rd St. NE
Customer Sample Number:
Date / Time Collected: 10/10/2023 6:14 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310173-002
Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310104-011

Sample Location: 1st Draw 1510 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-011

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 1510 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 10/6/2023 5:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-012

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310104-001

Sample Location: 1st Draw 1612 Webster St. NW

Customer Sample Number:

Date / Time Collected: 9/23/2023 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-001

Date / Time Received: 10/12/2023 2:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2023	Sbrooks

Sample Location: 2nd Draw 1612 Webster St. NW

Customer Sample Number:

Date / Time Collected: 9/23/2023 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-002

Date / Time Received: 10/12/2023 2:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310104-003

Sample Location: 1st Draw 1621 Webster St. NW

Customer Sample Number:

Date / Time Collected: 10/1/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-003

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 1621 Webster St. NW

Customer Sample Number:

Date / Time Collected: 10/1/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-004

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310173-003

Sample Location: 1st Draw 1831 N. Capitol St. NE

Customer Sample Number:

Date / Time Collected: 10/17/2023 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310173-003

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/31/2023	Sbrooks

Sample Location: 2nd Draw 1831 N. Capitol St. NE

Customer Sample Number:

Date / Time Collected: 10/17/2023 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310173-004

Date / Time Received: 10/24/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/31/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310180-017

Sample Location: 1st Draw 205 Webster St. NW

Customer Sample Number:

Date / Time Collected: 10/18/2023 7:44 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310180-017

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 205 Webster St. NW

Customer Sample Number:

Date / Time Collected: 10/18/2023 7:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310180-018

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310075-005

Sample Location: 1st Draw 3114 45th St. NW

Customer Sample Number:

Date / Time Collected: 10/3/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-005

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 3114 45th St. NW

Customer Sample Number:

Date / Time Collected: 10/3/2023 8:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-006

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310144-001

Sample Location: 1st Draw 4111 7th St NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 6:43 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310144-001

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/31/2023	SBrooks

Sample Location: 2nd Draw 4111 7th St NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 6:44 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310144-002

Date / Time Received: 10/20/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/31/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310180-015

Sample Location: 1st Draw 4429 New Hamp. Ave. NW

Customer Sample Number:

Date / Time Collected: 10/10/2023 8:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310180-015

Date / Time Received: 10/25/2023 10:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/1/2023	SBrooks

Sample Location: 2nd Draw 4429 New Hamp. Ave. NW

Customer Sample Number:

Date / Time Collected: 10/10/2023 8:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310180-016

Date / Time Received: 10/25/2023 10:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310104-005

Sample Location: 1st Draw 5047 Just St. NE

Customer Sample Number:

Date / Time Collected: 10/1/2023 9:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-005

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 5047 Just St. NE

Customer Sample Number:

Date / Time Collected: 10/1/2023 9:22 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-006

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310180-019

Sample Location: 1st Draw 510 Col. Rd. NW

Customer Sample Number:

Date / Time Collected: 10/17/2023 4:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310180-019

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 510 Col. Rd. NW

Customer Sample Number:

Date / Time Collected: 10/17/2023 4:40 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310180-020

Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310104-009

Sample Location: 1st Draw 5403 7th St. NW

Customer Sample Number:

Date / Time Collected: 10/5/2023 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-009

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		10/27/2023	Sbrooks

Sample Location: 2nd Draw 5403 7th St. NW

Customer Sample Number:

Date / Time Collected: 10/5/2023 7:22 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310104-010

Date / Time Received: 10/12/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310075-011

Sample Location: 1st Draw 549 4th St. SE
Customer Sample Number:
Date / Time Collected: 10/6/2023 7:27 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310075-011
Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 549 4th St. SE
Customer Sample Number:
Date / Time Collected: 10/6/2023 7:31 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310075-012
Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310075-009

Sample Location: 1st Draw 6516 8th St. NW

Customer Sample Number:

Date / Time Collected: 10/5/2023 7:59 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-009

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 6516 8th St. NW

Customer Sample Number:

Date / Time Collected: 10/5/2023 8:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-010

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310075-007

Sample Location: 1st Draw 816 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 10/4/2023 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-007

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Sample Location: 2nd Draw 816 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 10/4/2023 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-008

Date / Time Received: 10/11/2023 12:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310180-013

Sample Location: 1st Draw 913 K St. NE
Customer Sample Number:
Date / Time Collected: 10/12/2023 10:54 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310180-013
Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 913 K St. NE
Customer Sample Number:
Date / Time Collected: 10/12/2023 10:58 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310180-014
Date / Time Received: 10/25/2023 10:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/8/2023

Report Number: L-DC-Post-LSR- 2310075-001

Sample Location: 1st Draw 919 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 9/21/2023 4:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-001

Date / Time Received: 10/11/2023 12:45:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2023	SBrooks

Sample Location: 2nd Draw 919 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 9/21/2023 4:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310075-002

Date / Time Received: 10/11/2023 12:45:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-Post-LSR- 2310192-001

Sample Location: 1st Draw 1014 HAMLIN ST NE

Customer Sample Number:

Date / Time Collected: 10/13/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-001

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1014 HAMLIN ST NE

Customer Sample Number:

Date / Time Collected: 10/13/2023 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-002

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-Post-LSR- 2310192-007

Sample Location: 1st Draw 1409 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 10/19/2023 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-007

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1409 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 10/19/2023 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-008

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-Post-LSR- 2310192-005

Sample Location: 1st Draw 1440 Spring Rd. NW

Customer Sample Number:

Date / Time Collected: 10/18/2023 5:16 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-005

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1440 Spring Rd. NW

Customer Sample Number:

Date / Time Collected: 10/18/2023 5:18 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-006

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-Post-LSR- 2310192-009

Sample Location: 1st Draw 15 Bryant St. NW
Customer Sample Number:
Date / Time Collected: 10/21/2023 5:07 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310192-009
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 15 Bryant St. NW
Customer Sample Number:
Date / Time Collected: 10/21/2023 5:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2310192-010
Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-Post-LSR- 2310192-003

Sample Location: 1st Draw 1745 1st St. NW

Customer Sample Number:

Date / Time Collected: 10/15/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-003

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 1745 1st St. NW

Customer Sample Number:

Date / Time Collected: 10/15/2023 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-004

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/13/2023

Report Number: L-DC-Post-LSR- 2310192-011

Sample Location: 1st Draw 6605 8th St. NW

Customer Sample Number:

Date / Time Collected: 10/23/2023 6:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-011

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Sample Location: 2nd Draw 6605 8th St. NW

Customer Sample Number:

Date / Time Collected: 10/23/2023 6:39 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2310192-012

Date / Time Received: 10/26/2023 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/1/2023	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311076-007

Sample Location: 1st Draw 1109 OWEN PL NE

Customer Sample Number:

Date / Time Collected: 11/7/2023 5:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311076-007

Date / Time Received: 11/9/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 1109 OWEN PL NE

Customer Sample Number:

Date / Time Collected: 11/7/2023 5:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311076-008

Date / Time Received: 11/9/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311123-005

Sample Location: 1st Draw 1424 Decatur St. NW

Customer Sample Number:

Date / Time Collected: 11/8/2023 4:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311123-005

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 1424 Decatur St. NW

Customer Sample Number:

Date / Time Collected: 11/8/2023 4:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311123-006

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311066-021

Sample Location: 1st Draw 1537 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 10/31/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311066-021

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 1537 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 10/31/2023 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311066-022

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311066-027

Sample Location: 1st Draw 1547 First St. SW

Customer Sample Number:

Date / Time Collected: 11/7/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311066-027

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311028-039

Sample Location: 1st Draw 1708 Taylor St. NW

Customer Sample Number:

Date / Time Collected: 10/31/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-039

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 1708 Taylor St. NW

Customer Sample Number:

Date / Time Collected: 10/31/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-040

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311021-003

Sample Location: 1st Draw 1726 5th St. NW

Customer Sample Number:

Date / Time Collected: 10/15/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311021-003

Date / Time Received: 11/2/2023 11:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	11/15/2023	Rlamsal

Sample Location: 2nd Draw 1726 5th St. NW

Customer Sample Number:

Date / Time Collected: 10/15/2023 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311021-004

Date / Time Received: 11/2/2023 11:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311028-041

Sample Location: 1st Draw 35 Madison St. NW

Customer Sample Number:

Date / Time Collected: 10/31/2023 3:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-041

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	15.1	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 35 Madison St. NW

Customer Sample Number:

Date / Time Collected: 10/31/2023 3:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-042

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311076-003

Sample Location: 1st Draw 3547 QUEBEC ST NW

Customer Sample Number:

Date / Time Collected: 11/7/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311076-003

Date / Time Received: 11/9/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 3547 QUEBEC ST NW

Customer Sample Number:

Date / Time Collected: 11/7/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311076-004

Date / Time Received: 11/9/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311076-005

Sample Location: 1st Draw 3716 Benton St. NW

Customer Sample Number:

Date / Time Collected: 11/7/2023 8:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311076-005

Date / Time Received: 11/9/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 3716 Benton St. NW

Customer Sample Number:

Date / Time Collected: 11/7/2023 8:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311076-006

Date / Time Received: 11/9/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311066-023

Sample Location: 1st Draw 3723 R St. NW
Customer Sample Number:
Date / Time Collected: 11/6/2023 4:55 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2311066-023
Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 3723 R St. NW
Customer Sample Number:
Date / Time Collected: 11/6/2023 4:57 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2311066-024
Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311028-037

Sample Location: 1st Draw 4915 9th St. NW

Customer Sample Number:

Date / Time Collected: 10/30/2023 7:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-037

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 4915 9th St. NW

Customer Sample Number:

Date / Time Collected: 10/30/2023 7:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-038

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311123-023

Sample Location: 1st Draw 4928 46th St NW

Customer Sample Number:

Date / Time Collected: 11/13/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311123-023

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 4928 46th St NW

Customer Sample Number:

Date / Time Collected: 11/13/2023 7:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311123-024

Date / Time Received: 11/16/2023 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311028-033

Sample Location: 1st Draw 5302 7th St. NW

Customer Sample Number:

Date / Time Collected: 10/29/2023 7:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-033

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 5302 7th St. NW

Customer Sample Number:

Date / Time Collected: 10/29/2023 7:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-034

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311028-035

Sample Location: 1st Draw 549 14TH ST SE

Customer Sample Number:

Date / Time Collected: 10/30/2023 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-035

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 549 14TH ST SE

Customer Sample Number:

Date / Time Collected: 10/30/2023 6:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-036

Date / Time Received: 11/3/2023 12:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311128-015

Sample Location: 1st Draw 6411 3rd St. NW

Customer Sample Number:

Date / Time Collected: 11/12/2023 7:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311128-015

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 6411 3rd St. NW

Customer Sample Number:

Date / Time Collected: 11/12/2023 7:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311128-016

Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311128-011

Sample Location: 1st Draw 719 A St. SE
Customer Sample Number:
Date / Time Collected: 11/12/2023 6:45 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2311128-011
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		11/21/2023	Rlamsal

Sample Location: 2nd Draw 719 A St. SE
Customer Sample Number:
Date / Time Collected: 11/12/2023 6:45 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2311128-012
Date / Time Received: 11/17/2023 12:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/21/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311028-031

Sample Location: 1st Draw 817 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 7:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-031

Date / Time Received: 11/3/2023 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/15/2023	Rlamsal

Sample Location: 2nd Draw 817 Farragut St. NW

Customer Sample Number:

Date / Time Collected: 10/16/2023 7:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311028-032

Date / Time Received: 11/3/2023 12:00:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/29/2023

Report Number: L-DC-Post-LSR- 2311066-025

Sample Location: 1st Draw 916 Evarts St. NE

Customer Sample Number:

Date / Time Collected: 11/6/2023 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311066-025

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Sample Location: 2nd Draw 916 Evarts St. NE

Customer Sample Number:

Date / Time Collected: 11/6/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311066-026

Date / Time Received: 11/8/2023 12:35:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/15/2023	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-Post-LSR- 2311158-017

Sample Location: 1st Draw 3033 Brandywine St NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-017

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/4/2023	Bprakash

Sample Location: 2nd Draw 3033 Brandywine St NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-018

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-Post-LSR- 2311158-019

Sample Location: 1st Draw 328 Shepherd St NW

Customer Sample Number:

Date / Time Collected: 10/29/2023 9:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-019

Date / Time Received: 11/22/2023 12:40:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	12/4/2023	Bprakash

Sample Location: 2nd Draw 328 Shepherd St NW

Customer Sample Number:

Date / Time Collected: 10/29/2023 9:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-020

Date / Time Received: 11/22/2023 12:40:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-Post-LSR- 2311158-015

Sample Location: 1st Draw 4213 3rd St. NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-015

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/4/2023	Bprakash

Sample Location: 2nd Draw 4213 3rd St. NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 7:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-016

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-Post-LSR- 2311158-013

Sample Location: 1st Draw 607 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 11/17/2023 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-013

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/4/2023	Bprakash

Sample Location: 2nd Draw 607 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 11/17/2023 7:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-014

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/12/2023

Report Number: L-DC-Post-LSR- 2311158-003

Sample Location: 1st Draw 810 Farragut St NW

Customer Sample Number:

Date / Time Collected: 11/15/2023 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-003

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/4/2023	Bprakash

Sample Location: 2nd Draw 810 Farragut St NW

Customer Sample Number:

Date / Time Collected: 11/15/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2311158-004

Date / Time Received: 11/22/2023 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/4/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit