



Lead and Copper Compliance Report July through December 2014

Table 1 summarizes the District of Columbia Water and Sewer Authority's (DC Water) Lead and Copper compliance results for the monitoring period July through December 2014.

Table 1. Lead and Copper Summary Data

Number of Samples	
Lead and Copper	104
90th Percentile First Draw Concentrations	
Lead mg/L	0.004
Copper mg/L	0.108
Service Line Materials	
Full Lead	78
Partial Lead	26

The appendices and attachments contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
 - Table A.1 First Draw Lead Results
 - Table A.2 First Draw Copper Results

- Appendix B: Additional Monitoring Data
 - Table B.1 Second Draw Lead Results
 - Table B.2 Second Draw Copper Results

- Appendix C: Additional Sampling Information
 - Table C.1 Sample Kit Distribution
 - Table C.2 Sample Kits Not Returned
 - Table C.3 Samples Returned but Rejected for Compliance Analysis
 - Table C.4 Deviations from Sample Kit Distribution Order
 - Table C.5 Sites with Compliance Results from July 2013 – June 2014 and No Results in July – December 2014
 - Table C.6 Customer Notification of Results

- Attachment 1: Washington Aqueduct Test Results for LCR Compliance
- Attachment 2: Other Additional Monitoring Data:
 - Customer requested tests
 - Post-LSR
 - Lead profiles
 - Other Research
- Attachment 3: Certification of Consumer Tap Results for July through December 2014



Appendix A: Lead and Copper Compliance Data

Table A.1 First Draw Lead Results

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
1	414 G ST NE	Lead	9/1/2014	0.0000
2	75 Bates St NW	Lead	9/22/2014	0.0000
3	1436 S St NW	Partial Lead	10/29/2014	0.0000
4	1315 FRANKLIN ST NE	Lead	7/30/2014	0.0000
5	3416 9th St NE	Partial Lead	10/28/2014	0.0000
6	3036 P St NW	Partial Lead	11/9/2014	0.0000
7	1453 S St NW	Lead	10/30/2014	0.0000
8	53 P St NW	Partial Lead	10/29/2014	0.0000
9	36 Florida Ave NW	Partial Lead	10/29/2014	0.0000
10	1736 Bay St SE	Partial Lead	11/17/2014	0.0000
11	1339 CHILDRESS ST NE	Lead	11/19/2014	0.0000
12	4233 JENIFER ST NW	Lead	11/18/2014	0.0000
13	502 A ST SE	Lead	9/24/2014	0.0000
14	1222 HAMILTON ST NW	Partial Lead	9/23/2014	0.0000
15	4926 Glenbrook Rd NW	Lead	9/24/2014	0.0000
16	15 Milmarson Pl NW	Lead	7/30/2014	0.0000
17	905 Kent Pl NE	Lead	11/17/2014	0.0000
18	609 49TH PL NE	Lead	9/23/2014	0.0000
19	1613 Webster St NW	Lead	7/30/2014	0.0000
20	4425 14th St NE	Lead	7/29/2014	0.0000
21	307 7th St NE	Lead	8/27/2014	0.0000
22	413 4th St SE	Partial Lead	10/29/2014	0.0000
23	313 10TH ST SE	Partial Lead	8/26/2014	0.0000
24	617 6th St NE	Lead	9/25/2014	0.0000
25	1010 10th St NE	Lead	7/30/2014	0.0000
26	4409 Lowell St NW	Lead	10/29/2014	0.0000
27	3722 MCKINLEY ST NW	Partial Lead	10/29/2014	0.0000
28	1319 POTOMAC AVE SE	Partial Lead	10/29/2014	0.0000
29	2007 37TH ST NW	Lead	7/30/2014	0.0000
30	4447 HAWTHORNE ST NW	Lead	9/3/2014	0.0000
31	2830 BRENTWOOD RD NE	Lead	8/26/2014	0.0000
32	4818 8th ST NW	Partial Lead	10/28/2014	0.0000
33	1011 Taylor St NE	Lead	7/30/2014	0.0000
34	5301 RENO RD NW	Partial Lead	10/28/2014	0.0000
35	3809 ALTON PL NW	Partial Lead	10/29/2014	0.0000
36	421 Hamilton St NW	Lead	8/27/2014	0.0000
37	4806 Kansas Ave NW	Lead	9/23/2014	0.0010

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
38	1850 2ND ST NW	Partial Lead	10/27/2014	0.0010
39	331 RALEIGH ST SE	Lead	8/27/2014	0.0010
40	228 V ST NE	Lead	8/26/2014	0.0010
41	3907 13th St NW	Partial Lead	10/28/2014	0.0010
42	3405 HOLMEAD PL NW	Lead	11/18/2014	0.0010
43	4719 9TH ST NW	Lead	9/25/2014	0.0011
44	1808 KEARNEY ST NE	Partial Lead	10/29/2014	0.0011
45	1412 S St NW	Partial Lead	10/28/2014	0.0011
46	1020 INDEPENDENCE AVE SE	Lead	7/28/2014	0.0011
47	2408 2nd St NE	Partial Lead	10/28/2014	0.0011
48	4002 ILLINOIS AVE NW	Lead	11/19/2014	0.0011
49	3916 5TH ST NW	Lead	11/18/2014	0.0011
50	4014 Grant St NE	Lead	11/19/2014	0.0011
51	6308 8th St NW	Lead	9/23/2014	0.0012
52	822 Allison St NW	Lead	9/24/2014	0.0012
53	5223 KANSAS AVE NW	Lead	9/24/2014	0.0012
54	1738 ALLISON ST NW	Lead	7/31/2014	0.0012
55	3807 KANAWHA ST NW	Lead	11/19/2014	0.0012
56	1353 JEFFERSON ST NW	Partial Lead	10/29/2014	0.0013
57	2435 33RD ST SE	Lead	8/28/2014	0.0013
58	4418 14th St NE	Lead	8/27/2014	0.0013
59	816 MADISON ST NW	Lead	9/24/2014	0.0014
60	1620 Webster St NW	Lead	7/30/2014	0.0014
61	3710 Huntington St NW	Lead	8/27/2014	0.0014
62	2212 38th St NW	Lead	10/30/2014	0.0014
63	4627 49th St NW	Lead	9/23/2014	0.0015
64	5923 33rd St NW	Lead	9/24/2014	0.0015
65	1211 Carrollsburg Pl SW	Partial Lead	9/23/2014	0.0016
66	10 S St NW	Lead	7/29/2014	0.0016
67	2832 BRENTWOOD RD NE	Lead	8/27/2014	0.0016
68	4413 5th St NW	Lead	8/26/2014	0.0017
69	4131 YUMA ST NW	Lead	8/27/2014	0.0017
70	3211 Central Ave NE	Lead	8/26/2014	0.0017
71	3917 8th St NW	Partial Lead	10/29/2014	0.0017
72	6210 8th St NW	Lead	9/24/2014	0.0018
73	3636 13TH ST NW	Lead	8/26/2014	0.0019
74	119 16TH ST NE	Lead	7/30/2014	0.0022
75	4310 37th St NW	Lead	8/27/2014	0.0022
76	912 Emerson St NW	Lead	9/23/2014	0.0024
77	1703 D St NE	Lead	7/30/2014	0.0024
78	6205 14TH ST NW	Lead	9/23/2014	0.0026
79	1826 Jackson St NE	Lead	7/30/2014	0.0026
80	1003 Otis St NE	Lead	7/31/2014	0.0027
81	1519 Olive St NE	Lead	7/29/2014	0.0028
82	1113 STAPLES ST NE	Lead	7/30/2014	0.0028
83	913 Hamlin St NE	Lead	9/24/2014	0.0029

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
84	923 9TH ST NE	Lead	11/18/2014	0.0029
85	336 Quackenbos St NE	Lead	8/27/2014	0.0030
86	3030 44TH ST NW	Partial Lead	10/29/2014	0.0031
87	1649 HARVARD ST NW	Lead	7/30/2014	0.0031
88	1346 F St NE	Lead	7/29/2014	0.0032
89	4550 30TH ST NW	Lead	8/27/2014	0.0033
90	1412 Shepherd St NW	Partial Lead	10/28/2014	0.0035
91	1513 27TH ST NW	Lead	7/29/2014	0.0036
92	1715 IRVING ST NE	Lead	7/30/2014	0.0038
93	450 Newton Pl NW	Lead	9/1/2014	0.0039
94	2719 O ST NW	Lead	8/26/2014	0.0044
95	4811 Illinois Ave NW	Lead	9/23/2014	0.0045
96	125 Madison St NW	Lead	7/29/2014	0.0046
97	702 9th St SE	Lead	9/22/2014	0.0048
98	3727 T St NW	Lead	8/26/2014	0.0050
99	12 14TH ST SE	Partial Lead	9/25/2014	0.0053
100	4703 Macarthur Blvd NW	Lead	9/24/2014	0.0055
101	5234 Illinois Ave NW	Lead	9/24/2014	0.0063
102	1505 Buchanan St NW	Lead	7/30/2014	0.0151
103	5220 CHEVY CHASE PKWY NW	Lead	9/24/2014	0.0237
104	223 14th Pl NE	Partial Lead	10/28/2014	0.0327

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory records.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.0000" may have been reported by the laboratory as less than 0.001 mg/L or non-detect.

Table A.2 First Draw Copper Results

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
1	4002 ILLINOIS AVE NW	Lead	11/19/2014	0.003
2	912 Emerson St NW	Lead	9/23/2014	0.005
3	1339 CHILDRESS ST NE	Lead	11/19/2014	0.005
4	3916 5TH ST NW	Lead	11/18/2014	0.005
5	4413 5th St NW	Lead	8/26/2014	0.006
6	1113 STAPLES ST NE	Lead	7/30/2014	0.006
7	1519 Olive St NE	Lead	7/29/2014	0.007
8	816 MADISON ST NW	Lead	9/24/2014	0.008
9	3416 9th St NE	Partial Lead	10/28/2014	0.008
10	1222 HAMILTON ST NW	Partial Lead	9/23/2014	0.009
11	1315 FRANKLIN ST NE	Lead	7/30/2014	0.009
12	53 P St NW	Partial Lead	10/29/2014	0.009
13	6210 8th St NW	Lead	9/24/2014	0.012
14	4719 9TH ST NW	Lead	9/25/2014	0.012
15	1826 Jackson St NE	Lead	7/30/2014	0.012
16	331 RALEIGH ST SE	Lead	8/27/2014	0.015
17	228 V ST NE	Lead	8/26/2014	0.015
18	1011 Taylor St NE	Lead	7/30/2014	0.016
19	3710 Huntington St NW	Lead	8/27/2014	0.016
20	414 G ST NE	Lead	9/1/2014	0.018
21	10 S St NW	Lead	7/29/2014	0.018
22	905 Kent Pl NE	Lead	11/17/2014	0.018
23	6205 14TH ST NW	Lead	9/23/2014	0.019
24	1412 Shepherd St NW	Partial Lead	10/28/2014	0.020
25	913 Hamlin St NE	Lead	9/24/2014	0.021
26	1620 Webster St NW	Lead	7/30/2014	0.022
27	1346 F St NE	Lead	7/29/2014	0.023
28	413 4th St SE	Partial Lead	10/29/2014	0.023
29	4926 Glenbrook Rd NW	Lead	9/24/2014	0.024
30	12 14TH ST SE	Partial Lead	9/25/2014	0.024
31	1020 INDEPENDENCE AVE SE	Lead	7/28/2014	0.024
32	4131 YUMA ST NW	Lead	8/27/2014	0.024
33	336 Quackenbos St NE	Lead	8/27/2014	0.024
34	450 Newton Pl NW	Lead	9/1/2014	0.024
35	822 Allison St NW	Lead	9/24/2014	0.025
36	125 Madison St NW	Lead	7/29/2014	0.025
37	4409 Lowell St NW	Lead	10/29/2014	0.025
38	313 10TH ST SE	Partial Lead	8/26/2014	0.026
39	5234 Illinois Ave NW	Lead	9/24/2014	0.026
40	3809 ALTON PL NW	Partial Lead	10/29/2014	0.027
41	1649 HARVARD ST NW	Lead	7/30/2014	0.027
42	1010 10th St NE	Lead	7/30/2014	0.027
43	3636 13TH ST NW	Lead	8/26/2014	0.027
44	3030 44TH ST NW	Partial Lead	10/29/2014	0.028

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
45	223 14th PI NE	Partial Lead	10/28/2014	0.029
46	4550 30TH ST NW	Lead	8/27/2014	0.031
47	5301 RENO RD NW	Partial Lead	10/28/2014	0.032
48	1715 IRVING ST NE	Lead	7/30/2014	0.034
49	1319 POTOMAC AVE SE	Partial Lead	10/29/2014	0.035
50	1513 27TH ST NW	Lead	7/29/2014	0.035
51	2719 O ST NW	Lead	8/26/2014	0.037
52	307 7th St NE	Lead	8/27/2014	0.037
53	2408 2nd St NE	Partial Lead	10/28/2014	0.037
54	4447 HAWTHORNE ST NW	Lead	9/3/2014	0.038
55	4310 37th St NW	Lead	8/27/2014	0.038
56	2212 38th St NW	Lead	10/30/2014	0.038
57	4233 JENIFER ST NW	Lead	11/18/2014	0.039
58	502 A ST SE	Lead	9/24/2014	0.040
59	2435 33RD ST SE	Lead	8/28/2014	0.040
60	1703 D St NE	Lead	7/30/2014	0.041
61	1353 JEFFERSON ST NW	Partial Lead	10/29/2014	0.042
62	4425 14th St NE	Lead	7/29/2014	0.042
63	3405 HOLMEAD PL NW	Lead	11/18/2014	0.042
64	119 16TH ST NE	Lead	7/30/2014	0.043
65	4418 14th St NE	Lead	8/27/2014	0.044
66	4627 49th St NW	Lead	9/23/2014	0.045
67	421 Hamilton St NW	Lead	8/27/2014	0.047
68	3727 T St NW	Lead	8/26/2014	0.051
69	3036 P St NW	Partial Lead	11/9/2014	0.051
70	2832 BRENTWOOD RD NE	Lead	8/27/2014	0.052
71	1738 ALLISON ST NW	Lead	7/31/2014	0.053
72	1850 2ND ST NW	Partial Lead	10/27/2014	0.057
73	702 9th St SE	Lead	9/22/2014	0.058
74	1613 Webster St NW	Lead	7/30/2014	0.059
75	1003 Otis St NE	Lead	7/31/2014	0.060
76	6308 8th St NW	Lead	9/23/2014	0.061
77	15 Milmarson PI NW	Lead	7/30/2014	0.064
78	5223 KANSAS AVE NW	Lead	9/24/2014	0.066
79	75 Bates St NW	Lead	9/22/2014	0.067
80	1453 S St NW	Lead	10/30/2014	0.067
81	4014 Grant St NE	Lead	11/19/2014	0.067
82	1505 Buchanan St NW	Lead	7/30/2014	0.069
83	3211 Central Ave NE	Lead	8/26/2014	0.070
84	3917 8th St NW	Partial Lead	10/29/2014	0.070
85	3807 KANAWHA ST NW	Lead	11/19/2014	0.072
86	2007 37TH ST NW	Lead	7/30/2014	0.076
87	2830 BRENTWOOD RD NE	Lead	8/26/2014	0.079
88	4811 Illinois Ave NW	Lead	9/23/2014	0.085
89	1412 S St NW	Partial Lead	10/28/2014	0.090
90	4818 8th ST NW	Partial Lead	10/28/2014	0.095

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
91	1211 Carrollsburg Pl SW	Partial Lead	9/23/2014	0.100
92	923 9TH ST NE	Lead	11/18/2014	0.101
93	4806 Kansas Ave NW	Lead	9/23/2014	0.104
94	1808 KEARNEY ST NE	Partial Lead	10/29/2014	0.108
95	1736 Bay St SE	Partial Lead	11/17/2014	0.111
96	617 6th St NE	Lead	9/25/2014	0.114
97	609 49TH PL NE	Lead	9/23/2014	0.115
98	5923 33rd St NW	Lead	9/24/2014	0.120
99	4703 Macarthur Blvd NW	Lead	9/24/2014	0.127
100	3907 13th St NW	Partial Lead	10/28/2014	0.127
101	1436 S St NW	Partial Lead	10/29/2014	0.164
102	5220 CHEVY CHASE PKWY NW	Lead	9/24/2014	0.175
103	36 Florida Ave NW	Partial Lead	10/29/2014	0.192
104	3722 MCKINLEY ST NW	Partial Lead	10/29/2014	0.207

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory records.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.000" may have been reported by the laboratory as less than 0.001 mg/L or non-detect.

Appendix B: Additional Monitoring Data

Tables B.1 and B.2 present results from the second draw samples collected at the time of the Lead and Copper Rule compliance sampling. Additional monitoring data presented in Attachment 2 to this report contains sample data collected from other DC Water programs that focused on lead, copper, or other metals that included lead sample results. A description of the program followed by the data set is included in Attachment 2.

Table B.1 Second Draw Lead Results

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
1	414 G ST NE	Lead	9/1/2014	0.0000
2	4926 Glenbrook Rd NW	Lead	9/24/2014	0.0000
3	75 Bates St NW	Lead	9/22/2014	0.0000
4	609 49TH PL NE	Lead	9/23/2014	0.0000
5	502 A ST SE	Lead	9/24/2014	0.0000
6	1436 S St NW	Partial Lead	10/29/2014	0.0000
7	1315 FRANKLIN ST NE	Lead	7/30/2014	0.0000
8	3416 9th St NE	Partial Lead	10/28/2014	0.0000
9	1453 S St NW	Lead	10/30/2014	0.0000
10	53 P St NW	Partial Lead	10/29/2014	0.0000
11	36 Florida Ave NW	Partial Lead	10/29/2014	0.0000
12	3722 MCKINLEY ST NW	Partial Lead	10/29/2014	0.0000
13	1736 Bay St SE	Partial Lead	11/17/2014	0.0000
14	4233 JENIFER ST NW	Lead	11/18/2014	0.0000
15	1613 Webster St NW	Lead	7/30/2014	0.0000
16	336 Quackenbos St NE	Lead	8/27/2014	0.0000
17	3036 P St NW	Partial Lead	11/9/2014	0.0000
18	905 Kent Pl NE	Lead	11/17/2014	0.0000
19	15 Milmarson Pl NW	Lead	7/30/2014	0.0000
20	4627 49th St NW	Lead	9/23/2014	0.0000
21	12 14TH ST SE	Partial Lead	9/25/2014	0.0000
22	307 7th St NE	Lead	8/27/2014	0.0000
23	413 4th St SE	Partial Lead	10/29/2014	0.0000
24	4447 HAWTHORNE ST NW	Lead	9/3/2014	0.0000
25	2007 37TH ST NW	Lead	7/30/2014	0.0000
26	1010 10th St NE	Lead	7/30/2014	0.0000
27	1738 ALLISON ST NW	Lead	7/31/2014	0.0000
28	4425 14th St NE	Lead	7/29/2014	0.0000
29	617 6th St NE	Lead	9/25/2014	0.0000
30	1412 S St NW	Partial Lead	10/28/2014	0.0000
31	2830 BRENTWOOD RD NE	Lead	8/26/2014	0.0000
32	4409 Lowell St NW	Lead	10/29/2014	0.0000
33	1222 HAMILTON ST NW	Partial Lead	9/23/2014	0.0000
34	5223 KANSAS AVE NW	Lead	9/24/2014	0.0000
35	1011 Taylor St NE	Lead	7/30/2014	0.0000
36	3710 Huntington St NW	Lead	8/27/2014	0.0000

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
37	3907 13th St NW	Partial Lead	10/28/2014	0.0000
38	4818 8th ST NW	Partial Lead	10/28/2014	0.0000
39	4014 Grant St NE	Lead	11/19/2014	0.0000
40	3807 KANAWHA ST NW	Lead	11/19/2014	0.0010
41	4719 9TH ST NW	Lead	9/25/2014	0.0011
42	816 MADISON ST NW	Lead	9/24/2014	0.0011
43	1319 POTOMAC AVE SE	Partial Lead	10/29/2014	0.0011
44	3809 ALTON PL NW	Partial Lead	10/29/2014	0.0011
45	3916 5TH ST NW	Lead	11/18/2014	0.0011
46	4806 Kansas Ave NW	Lead	9/23/2014	0.0012
47	228 V ST NE	Lead	8/26/2014	0.0012
48	3917 8th St NW	Partial Lead	10/29/2014	0.0012
49	1703 D St NE	Lead	7/30/2014	0.0013
50	5301 RENO RD NW	Partial Lead	10/28/2014	0.0014
51	1808 KEARNEY ST NE	Partial Lead	10/29/2014	0.0014
52	1826 Jackson St NE	Lead	7/30/2014	0.0014
53	1620 Webster St NW	Lead	7/30/2014	0.0014
54	331 RALEIGH ST SE	Lead	8/27/2014	0.0014
55	4418 14th St NE	Lead	8/27/2014	0.0015
56	6308 8th St NW	Lead	9/23/2014	0.0018
57	5923 33rd St NW	Lead	9/24/2014	0.0019
58	3636 13TH ST NW	Lead	8/26/2014	0.0020
59	1353 JEFFERSON ST NW	Partial Lead	10/29/2014	0.0022
60	1519 Olive St NE	Lead	7/29/2014	0.0022
61	912 Emerson St NW	Lead	9/23/2014	0.0023
62	6210 8th St NW	Lead	9/24/2014	0.0024
63	822 Allison St NW	Lead	9/24/2014	0.0024
64	4811 Illinois Ave NW	Lead	9/23/2014	0.0024
65	313 10TH ST SE	Partial Lead	8/26/2014	0.0026
66	6205 14TH ST NW	Lead	9/23/2014	0.0027
67	3030 44TH ST NW	Partial Lead	10/29/2014	0.0027
68	119 16TH ST NE	Lead	7/30/2014	0.0028
69	1715 IRVING ST NE	Lead	7/30/2014	0.0029
70	1113 STAPLES ST NE	Lead	7/30/2014	0.0029
71	10 S St NW	Lead	7/29/2014	0.0030
72	913 Hamlin St NE	Lead	9/24/2014	0.0032
73	1850 2ND ST NW	Partial Lead	10/27/2014	0.0032
74	3405 HOLMEAD PL NW	Lead	11/18/2014	0.0033
75	1003 Otis St NE	Lead	7/31/2014	0.0034
76	421 Hamilton St NW	Lead	8/27/2014	0.0034
77	2804 6TH ST NE	Lead	8/26/2014	0.0034
78	4413 5th St NW	Lead	8/26/2014	0.0035
79	4002 ILLINOIS AVE NW	Lead	11/19/2014	0.0035
80	1649 HARVARD ST NW	Lead	7/30/2014	0.0038
81	923 9TH ST NE	Lead	11/18/2014	0.0039
82	4550 30TH ST NW	Lead	8/27/2014	0.0042

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
83	1412 Shepherd St NW	Partial Lead	10/28/2014	0.0043
84	125 Madison St NW	Lead	7/29/2014	0.0049
85	2832 BRENTWOOD RD NE	Lead	8/27/2014	0.0053
86	2212 38th St NW	Lead	10/30/2014	0.0053
87	4131 YUMA ST NW	Lead	8/27/2014	0.0054
88	4703 Macarthur Blvd NW	Lead	9/24/2014	0.0056
89	2435 33RD ST SE	Lead	8/28/2014	0.0059
90	4310 37th St NW	Lead	8/27/2014	0.0063
91	450 Newton Pl NW	Lead	9/1/2014	0.0072
92	2408 2nd St NE	Partial Lead	10/28/2014	0.0078
93	3211 Central Ave NE	Lead	8/26/2014	0.0082
94	1020 INDEPENDENCE AVE SE	Lead	7/28/2014	0.0088
95	3727 T St NW	Lead	8/26/2014	0.0104
96	1346 F St NE	Lead	7/29/2014	0.0106
97	5234 Illinois Ave NW	Lead	9/24/2014	0.0108
98	223 14th Pl NE	Partial Lead	10/28/2014	0.0108
99	2719 O ST NW	Lead	8/26/2014	0.0109
100	5220 CHEVY CHASE PKWY NW	Lead	9/24/2014	0.0116
101	1513 27TH ST NW	Lead	7/29/2014	0.0122
102	702 9th St SE	Lead	9/22/2014	0.0142
103	1211 Carrollsburg Pl SW	Partial Lead	9/23/2014	0.0176
104	1505 Buchanan St NW	Lead	7/30/2014	0.0210

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) Results expressed as "0.0000" may have been reported by the laboratory as less than 0.001 mg/L or non-detect.
- 3) The second draw samples were rejected from 1339 Childress St NE because they did not follow the sampling procedures for collecting the second draw sample as described in the instructions. The first draw sample was rejected, but the second draw sample was analyzed from 2804 6th St NE.

Table B.2 Second Draw Copper Results

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
1	4413 5th St NW	Lead	8/26/2014	0.003
2	4131 YUMA ST NW	Lead	8/27/2014	0.004
3	3916 5TH ST NW	Lead	11/18/2014	0.004
4	6210 8th St NW	Lead	9/24/2014	0.005
5	912 Emerson St NW	Lead	9/23/2014	0.005
6	816 MADISON ST NW	Lead	9/24/2014	0.005
7	4002 ILLINOIS AVE NW	Lead	11/19/2014	0.005
8	1113 STAPLES ST NE	Lead	7/30/2014	0.006
9	702 9th St SE	Lead	9/22/2014	0.007
10	119 16TH ST NE	Lead	7/30/2014	0.007
11	1513 27TH ST NW	Lead	7/29/2014	0.007
12	4550 30TH ST NW	Lead	8/27/2014	0.007
13	4719 9TH ST NW	Lead	9/25/2014	0.008
14	125 Madison St NW	Lead	7/29/2014	0.008
15	1519 Olive St NE	Lead	7/29/2014	0.008
16	1346 F St NE	Lead	7/29/2014	0.008
17	1020 INDEPENDENCE AVE SE	Lead	7/28/2014	0.008
18	3727 T St NW	Lead	8/26/2014	0.008
19	2212 38th St NW	Lead	10/30/2014	0.008
20	53 P St NW	Partial Lead	10/29/2014	0.008
21	6205 14TH ST NW	Lead	9/23/2014	0.009
22	5301 RENO RD NW	Partial Lead	10/28/2014	0.009
23	2007 37TH ST NW	Lead	7/30/2014	0.009
24	1315 FRANKLIN ST NE	Lead	7/30/2014	0.009
25	331 RALEIGH ST SE	Lead	8/27/2014	0.009
26	450 Newton Pl NW	Lead	9/1/2014	0.009
27	421 Hamilton St NW	Lead	8/27/2014	0.009
28	3416 9th St NE	Partial Lead	10/28/2014	0.009
29	228 V ST NE	Lead	8/26/2014	0.010
30	4418 14th St NE	Lead	8/27/2014	0.010
31	3036 P St NW	Partial Lead	11/9/2014	0.010
32	4014 Grant St NE	Lead	11/19/2014	0.010
33	5220 CHEVY CHASE PKWY NW	Lead	9/24/2014	0.011
34	3710 Huntington St NW	Lead	8/27/2014	0.011
35	905 Kent Pl NE	Lead	11/17/2014	0.011
36	414 G ST NE	Lead	9/1/2014	0.012
37	75 Bates St NW	Lead	9/22/2014	0.012
38	502 A ST SE	Lead	9/24/2014	0.012
39	1010 10th St NE	Lead	7/30/2014	0.012
40	10 S St NW	Lead	7/29/2014	0.012
41	3807 KANAWHA ST NW	Lead	11/19/2014	0.012
42	1620 Webster St NW	Lead	7/30/2014	0.013
43	2435 33RD ST SE	Lead	8/28/2014	0.013
44	3211 Central Ave NE	Lead	8/26/2014	0.013

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
45	336 Quackenbos St NE	Lead	8/27/2014	0.013
46	2832 BRENTWOOD RD NE	Lead	8/27/2014	0.013
47	1453 S St NW	Lead	10/30/2014	0.014
48	2804 6TH ST NE	Lead	8/26/2014	0.014
49	4703 Macarthur Blvd NW	Lead	9/24/2014	0.015
50	617 6th St NE	Lead	9/25/2014	0.015
51	822 Allison St NW	Lead	9/24/2014	0.015
52	3809 ALTON PL NW	Partial Lead	10/29/2014	0.015
53	3405 HOLMEAD PL NW	Lead	11/18/2014	0.015
54	2719 O ST NW	Lead	8/26/2014	0.016
55	1222 HAMILTON ST NW	Partial Lead	9/23/2014	0.016
56	4926 Glenbrook Rd NW	Lead	9/24/2014	0.016
57	307 7th St NE	Lead	8/27/2014	0.016
58	3636 13TH ST NW	Lead	8/26/2014	0.016
59	5234 Illinois Ave NW	Lead	9/24/2014	0.017
60	913 Hamlin St NE	Lead	9/24/2014	0.018
61	4310 37th St NW	Lead	8/27/2014	0.018
62	1011 Taylor St NE	Lead	7/30/2014	0.019
63	4409 Lowell St NW	Lead	10/29/2014	0.019
64	4233 JENIFER ST NW	Lead	11/18/2014	0.019
65	1649 HARVARD ST NW	Lead	7/30/2014	0.020
66	1412 Shepherd St NW	Partial Lead	10/28/2014	0.021
67	5223 KANSAS AVE NW	Lead	9/24/2014	0.022
68	1319 POTOMAC AVE SE	Partial Lead	10/29/2014	0.022
69	1003 Otis St NE	Lead	7/31/2014	0.022
70	36 Florida Ave NW	Partial Lead	10/29/2014	0.022
71	3722 MCKINLEY ST NW	Partial Lead	10/29/2014	0.022
72	313 10TH ST SE	Partial Lead	8/26/2014	0.023
73	1826 Jackson St NE	Lead	7/30/2014	0.024
74	1613 Webster St NW	Lead	7/30/2014	0.026
75	1738 ALLISON ST NW	Lead	7/31/2014	0.026
76	1715 IRVING ST NE	Lead	7/30/2014	0.027
77	4425 14th St NE	Lead	7/29/2014	0.027
78	4627 49th St NW	Lead	9/23/2014	0.028
79	1436 S St NW	Partial Lead	10/29/2014	0.028
80	4447 HAWTHORNE ST NW	Lead	9/3/2014	0.030
81	609 49TH PL NE	Lead	9/23/2014	0.031
82	3030 44TH ST NW	Partial Lead	10/29/2014	0.032
83	1211 Carrollsburg Pl SW	Partial Lead	9/23/2014	0.034
84	12 14TH ST SE	Partial Lead	9/25/2014	0.034
85	1353 JEFFERSON ST NW	Partial Lead	10/29/2014	0.035
86	223 14th Pl NE	Partial Lead	10/28/2014	0.035
87	413 4th St SE	Partial Lead	10/29/2014	0.037
88	3917 8th St NW	Partial Lead	10/29/2014	0.038
89	6308 8th St NW	Lead	9/23/2014	0.039
90	15 Milmarson Pl NW	Lead	7/30/2014	0.039

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
91	4818 8th ST NW	Partial Lead	10/28/2014	0.042
92	1850 2ND ST NW	Partial Lead	10/27/2014	0.045
93	1736 Bay St SE	Partial Lead	11/17/2014	0.046
94	1703 D St NE	Lead	7/30/2014	0.050
95	2408 2nd St NE	Partial Lead	10/28/2014	0.050
96	1808 KEARNEY ST NE	Partial Lead	10/29/2014	0.066
97	4811 Illinois Ave NW	Lead	9/23/2014	0.070
98	5923 33rd St NW	Lead	9/24/2014	0.072
99	3907 13th St NW	Partial Lead	10/28/2014	0.076
100	1505 Buchanan St NW	Lead	7/30/2014	0.077
101	923 9TH ST NE	Lead	11/18/2014	0.080
102	2830 BRENTWOOD RD NE	Lead	8/26/2014	0.094
103	4806 Kansas Ave NW	Lead	9/23/2014	0.112
104	1412 S St NW	Partial Lead	10/28/2014	0.130

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) Results expressed as “0.000” may have been reported by the laboratory as less than 0.001 mg/L or non-detect.
- 3) The second draw samples were rejected from 1339 Childress St NE because they did not follow the sampling criteria for collecting the second draw sample as described in the instructions. The first draw sample was rejected, but the second draw sample was analyzed from 2804 6th St NE.

Appendix C – Additional Sampling Information

Table C.1 Sample Kit Distribution

No	Address	Bottle Delivery Date
1	1505 Buchanan St NW	7/28/2014
2	1106 Allison St NW	7/28/2014
3	1434 Taylor St NW	7/28/2014
4	1020 INDEPENDENCE AVE SE	7/28/2014
5	1705 D St NE	7/28/2014
6	1420 INGRAHAM ST NW	7/28/2014
7	125 Madison St NW	7/28/2014
8	1916 PARK RD NW	7/28/2014
9	1508 GOOD HOPE RD SE	7/28/2014
10	1715 IRVING ST NE	7/28/2014
11	1620 Webster St NW	7/28/2014
12	15 Milmarson PI NW	7/28/2014
13	1911 P ST SE	7/28/2014
14	2121 3RD ST NE	7/28/2014
15	120 VARNUM ST NW	7/28/2014
16	1613 Webster St NW	7/28/2014
17	1428 VARNUM ST NW	7/28/2014
18	1659 NEWTON ST NW	7/28/2014
19	1738 ALLISON ST NW	7/28/2014
20	1513 27TH ST NW	7/28/2014
21	1627 Gales St NE	7/28/2014
22	1318 Wallach PI NW	7/28/2014
23	1305 TAYLOR ST NW	7/28/2014
24	1519 Olive St NE	7/28/2014
25	1375 MONROE ST NW	7/28/2014
26	1529 UPSHUR ST NW	7/28/2014
27	123 TENNESSEE AVE NE	7/28/2014
28	1346 F St NE	7/28/2014
29	1378 Taylor St NW	7/28/2014
30	1113 STAPLES ST NE	7/28/2014
31	109 19th St SE	7/28/2014
32	1424 S ST NW	7/28/2014
33	1262 COLUMBIA RD NW	7/28/2014
34	1635 WEBSTER ST NW	7/28/2014
35	1003 Quebec PI NW	7/28/2014
36	1010 10th St NE	7/28/2014
37	1706 NEW JERSEY AVE NW	7/28/2014
38	119 16TH ST NE	7/28/2014
39	1331 Irving St NE	7/28/2014
40	1826 Jackson St NE	7/28/2014
41	1649 HARVARD ST NW	7/28/2014
42	10 S St NW	7/28/2014

No	Address	Bottle Delivery Date
43	1315 FRANKLIN ST NE	7/28/2014
44	1703 D St NE	7/28/2014
45	4425 14th St NE	7/28/2014
46	2007 37TH ST NW	7/28/2014
47	1003 Otis St NE	7/28/2014
48	1410 ALLISON ST NW	7/28/2014
49	213 49th St NE	7/28/2014
50	1011 Taylor St NE	7/28/2014
51	2809 35TH ST NW	7/28/2014
52	450 Newton Pl NW	8/25/2014
53	421 Hamilton St NW	8/25/2014
54	3710 Huntington St NW	8/25/2014
55	449 S St NW	8/25/2014
56	3636 13TH ST NW	8/25/2014
57	3218 MORRISON ST NW	8/25/2014
58	3206 38th St NW	8/25/2014
59	3706 35th St NW	8/25/2014
60	309 11TH ST SE	8/25/2014
61	228 V ST NE	8/25/2014
62	4214 8th St NW	8/25/2014
63	4418 14th St NE	8/25/2014
64	4550 30TH ST NW	8/25/2014
65	3361 Stuyvesant Pl NW	8/25/2014
66	336 Quackenbos St NE	8/25/2014
67	2830 BRENTWOOD RD NE	8/25/2014
68	3908 13TH ST NW	8/25/2014
69	3211 Central Ave NE	8/25/2014
70	4120 Grant St NE	8/25/2014
71	307 7th St NE	8/25/2014
72	4310 37th St NW	8/25/2014
73	2923 Cathedral AVE NW	8/25/2014
74	331 RALEIGH ST SE	8/25/2014
75	2435 33RD ST SE	8/25/2014
76	2913 Brandywine St NW	8/25/2014
77	3727 T St NW	8/25/2014
78	4610 KANSAS AVE NW	8/25/2014
79	412 BRANDYWINE ST SE	8/25/2014
80	313 10TH ST SE	8/25/2014
81	3033 CAMBRIDGE PL NW	8/25/2014
82	3761 W ST NW	8/25/2014
83	414 G ST NE	8/25/2014
84	2904 P ST SE	8/25/2014
85	2804 6TH ST NE	8/25/2014
86	4413 5th St NW	8/25/2014
87	37 U ST NE	8/25/2014
88	3510 QUESADA ST NW	8/25/2014

No	Address	Bottle Delivery Date
89	3309 35TH ST NW	8/25/2014
90	4054 GRANT ST NE	8/25/2014
91	4525 15TH ST NW	8/25/2014
92	3218 MACOMB ST NW	8/25/2014
93	4131 YUMA ST NW	8/25/2014
94	322 TENNESSEE AVE NE	8/25/2014
95	4307 CHESAPEAKE ST NW	8/25/2014
96	3625 Albermarle St NW	8/25/2014
97	2832 BRENTWOOD RD NE	8/25/2014
98	3724 CHESAPEAKE ST NW	8/25/2014
99	4447 HAWTHORNE ST NW	8/25/2014
100	2719 O ST NW	8/25/2014
101	6308 8th St NW	9/22/2014
102	6001 33rd St NW	9/22/2014
103	6210 8th St NW	9/22/2014
104	5024 7th St NW	9/22/2014
105	6209 30TH ST NW	9/22/2014
106	5223 KANSAS AVE NW	9/22/2014
107	5923 33rd St NW	9/22/2014
108	744 9TH ST SE	9/22/2014
109	5220 CHEVY CHASE PKWY NW	9/22/2014
110	4627 49th St NW	9/22/2014
111	1222 HAMILTON ST NW	9/22/2014
112	617 6th St NE	9/22/2014
113	4806 Kansas Ave NW	9/22/2014
114	5318 9TH ST NW	9/22/2014
115	619 12th St NE	9/22/2014
116	1211 Carrollsburg Pl SW	9/22/2014
117	561 23RD PL NE	9/22/2014
118	702 9th St SE	9/22/2014
119	8 N St SW	9/22/2014
120	4703 Macarthur Blvd NW	9/22/2014
121	636 ROCK CRK CHURCH RD NW	9/22/2014
122	4926 Glenbrook Rd NW	9/22/2014
123	12 14TH ST SE	9/22/2014
124	6105 Dix St NE	9/22/2014
125	834 Delafield Pl NW	9/22/2014
126	926 Hamilton St NW	9/22/2014
127	913 Hamlin St NE	9/22/2014
128	5312 ILLINOIS AVE NW	9/22/2014
129	5007 13TH ST NW	9/22/2014
130	5812 7TH ST NW	9/22/2014
131	6205 14TH ST NW	9/22/2014
132	910 Farragut St NW	9/22/2014
133	621 Upshur St NW	9/22/2014
134	4811 Illinois Ave NW	9/22/2014

No	Address	Bottle Delivery Date
135	6516 8TH ST NW	9/22/2014
136	531 Tennessee Ave NE	9/22/2014
137	816 MADISON ST NW	9/22/2014
138	807 Buchanan St NW	9/22/2014
139	502 A ST SE	9/22/2014
140	912 Emerson St NW	9/22/2014
141	5731 3rd PI NW	9/22/2014
142	5234 Illinois Ave NW	9/22/2014
143	804 Delafield PI NW	9/22/2014
144	522 4TH ST SE	9/22/2014
145	4613 9th St NW	9/22/2014
146	609 49TH PL NE	9/22/2014
147	822 Allison St NW	9/22/2014
148	4719 9TH ST NW	9/22/2014
149	75 Bates St NW	9/22/2014
150	1412 Shepherd St NW	10/27/2014
151	1412 S St NW	10/27/2014
152	4332 BRANDYWINE ST NW	10/27/2014
153	3907 13th St NW	10/27/2014
154	2212 38th St NW	10/27/2014
155	6213 7TH ST NW	10/27/2014
156	3202 38TH ST NW	10/27/2014
157	1353 JEFFERSON ST NW	10/27/2014
158	420 Kenyon St NW	10/27/2014
159	3917 8th St NW	10/27/2014
160	1808 KEARNEY ST NE	10/27/2014
161	3301 BROWN St NW	10/27/2014
162	424 Luray PI NW	10/27/2014
163	3030 44TH ST NW	10/27/2014
164	1319 POTOMAC AVE SE	10/27/2014
165	3809 ALTON PL NW	10/27/2014
166	1436 S St NW	10/27/2014
167	1850 2ND ST NW	10/27/2014
168	3913 8TH ST NW	10/27/2014
169	3601 WARREN ST NW	10/27/2014
170	3531 16TH ST NW	10/27/2014
171	4818 8th ST NW	10/27/2014
172	5301 RENO RD NW	10/27/2014
173	5404 39TH ST NW	10/27/2014
174	1453 S St NW	10/27/2014
175	5003 7TH ST NW	10/27/2014
176	3722 MCKINLEY ST NW	10/27/2014
177	36 Florida Ave NW	10/27/2014
178	413 4th St SE	10/27/2014
179	53 P St NW	10/27/2014
180	4215 39th St NW	10/27/2014

No	Address	Bottle Delivery Date
181	5226 7th St NW	10/27/2014
182	5517 7th St NW	10/27/2014
183	3036 P St NW	10/27/2014
184	1025 44th St NE	10/27/2014
185	333 34th St NE	10/27/2014
186	1420 Hamlin St NE	10/27/2014
187	24 Evarts St NE	10/27/2014
188	223 14th Pl NE	10/27/2014
189	1671 Rosedale St NE	10/27/2014
190	53 V St NW	10/27/2014
191	4409 Lowell St NW	10/27/2014
192	231 K St NE	10/27/2014
193	617 M St NE	10/27/2014
194	317 9th St SE	10/27/2014
195	1357 C St NE	10/27/2014
196	2107 2nd St NE	10/27/2014
197	2408 2nd St NE	10/27/2014
198	308 9th St SE	10/27/2014
199	3416 9th St NE	10/27/2014
200	3807 KANAWHA ST NW	11/17/2014
201	923 9TH ST NE	11/17/2014
202	1339 CHILDRESS ST NE	11/17/2014
203	1529 27TH ST NW	11/17/2014
204	314 VARNUM ST NW	11/17/2014
205	3916 KANSAS AVE NW	11/17/2014
206	2557 36TH ST NW	11/17/2014
207	620 44TH ST NE	11/17/2014
208	4002 ILLINOIS AVE NW	11/17/2014
209	1329 TAYLOR ST NW	11/17/2014
210	19 RHODE ISLAND AVE NW	11/17/2014
211	313 5TH ST NE	11/17/2014
212	3916 5TH ST NW	11/17/2014
213	3405 HOLMEAD PL NW	11/17/2014
214	1430 F ST NE	11/17/2014
215	4233 JENIFER ST NW	11/17/2014
216	5517 7th St NW	11/17/2014
217	905 Kent Pl NE	11/17/2014
218	302 RITTENHOUSE ST NW	11/17/2014
219	580 49th Pl NE	11/17/2014
220	4014 Grant St NE	11/17/2014
221	87 S St NW	11/17/2014
222	641 Gallatin St NW	11/17/2014
223	15 MADISON ST NW	11/17/2014
224	1603 Massachusetts Ave SE	11/17/2014
225	1720 NORTH CAPITOL ST NW	11/17/2014
226	1736 Bay St SE	11/17/2014

No	Address	Bottle Delivery Date
227	605 ROCK CRK CHURCH RD NW	11/17/2014
228	4717 15TH ST NW	11/17/2014
229	2036 17TH ST NW	11/17/2014
230	3424 9TH ST NE	11/17/2014
231	4408 HAYES ST NE	11/17/2014
232	230 G St NE	11/17/2014

Table C.2 Sample Kits Not Returned

No	Address	Bottle Delivery Date
1	1106 Allison St NW	7/28/2014
2	1434 Taylor St NW	7/28/2014
3	1705 D St NE	7/28/2014
4	1420 INGRAHAM ST NW	7/28/2014
5	1916 PARK RD NW	7/28/2014
6	1508 GOOD HOPE RD SE	7/28/2014
7	2121 3RD ST NE	7/28/2014
8	120 VARNUM ST NW	7/28/2014
9	1428 VARNUM ST NW	7/28/2014
10	1659 NEWTON ST NW	7/28/2014
11	1627 Gales St NE	7/28/2014
12	1318 Wallach Pl NW	7/28/2014
13	1305 TAYLOR ST NW	7/28/2014
14	1375 MONROE ST NW	7/28/2014
15	1529 UPSHUR ST NW	7/28/2014
16	1378 Taylor St NW	7/28/2014
17	109 19th St SE	7/28/2014
18	1424 S ST NW	7/28/2014
19	1262 COLUMBIA RD NW	7/28/2014
20	1635 WEBSTER ST NW	7/28/2014
21	1003 Quebec Pl NW	7/28/2014
22	1331 Irving St NE	7/28/2014
23	1410 ALLISON ST NW	7/28/2014
24	213 49th St NE	7/28/2014
25	2809 35TH ST NW	7/28/2014
26	449 S St NW	8/25/2014
27	3218 MORRISON ST NW	8/25/2014
28	3706 35th St NW	8/25/2014
29	309 11TH ST SE	8/25/2014
30	4214 8th St NW	8/25/2014
31	3361 Stuyvesant Pl NW	8/25/2014
32	3908 13TH ST NW	8/25/2014
33	2923 Cathedral AVE NW	8/25/2014
34	2913 Brandywine St NW	8/25/2014
35	4610 KANSAS AVE NW	8/25/2014
36	412 BRANDYWINE ST SE	8/25/2014
37	3761 W ST NW	8/25/2014
38	2904 P ST SE	8/25/2014
39	3510 QUESADA ST NW	8/25/2014
40	3309 35TH ST NW	8/25/2014
41	4054 GRANT ST NE	8/25/2014
42	4525 15TH ST NW	8/25/2014
43	3218 MACOMB ST NW	8/25/2014
44	322 TENNESSEE AVE NE	8/25/2014
45	4307 CHESAPEAKE ST NW	8/25/2014

No	Address	Bottle Delivery Date
46	3625 Albermarle St NW	8/25/2014
47	3724 CHESAPEAKE ST NW	8/25/2014
48	6001 33rd St NW	9/22/2014
49	6209 30TH ST NW	9/22/2014
50	744 9TH ST SE	9/22/2014
51	8 N St SW	9/22/2014
52	636 ROCK CRK CHURCH RD NW	9/22/2014
53	6105 Dix St NE	9/22/2014
54	834 Delafield PI NW	9/22/2014
55	5312 ILLINOIS AVE NW	9/22/2014
56	5007 13TH ST NW	9/22/2014
57	5812 7TH ST NW	9/22/2014
58	910 Farragut St NW	9/22/2014
59	621 Upshur St NW	9/22/2014
60	6516 8TH ST NW	9/22/2014
61	531 Tennessee Ave NE	9/22/2014
62	807 Buchanan St NW	9/22/2014
63	5731 3rd PI NW	9/22/2014
64	804 Delafield PI NW	9/22/2014
65	522 4TH ST SE	9/22/2014
66	4613 9th St NW	9/22/2014
67	4332 BRANDYWINE ST NW	10/27/2014
68	6213 7TH ST NW	10/27/2014
69	3202 38TH ST NW	10/27/2014
70	420 Kenyon St NW	10/27/2014
71	3301 BROWN St NW	10/27/2014
72	424 Luray PI NW	10/27/2014
73	3913 8TH ST NW	10/27/2014
74	3601 WARREN ST NW	10/27/2014
75	3531 16TH ST NW	10/27/2014
76	5404 39TH ST NW	10/27/2014
77	4215 39th St NW	10/27/2014
78	5226 7th St NW	10/27/2014
79	1025 44th St NE	10/27/2014
80	333 34th St NE	10/27/2014
81	1420 Hamlin St NE	10/27/2014
82	24 Evarts St NE	10/27/2014
83	53 V St NW	10/27/2014
84	231 K St NE	10/27/2014
85	617 M St NE	10/27/2014
86	317 9th St SE	10/27/2014
87	1357 C St NE	10/27/2014
88	2107 2nd St NE	10/27/2014
89	308 9th St SE	10/27/2014
90	314 VARNUM ST NW	11/17/2014
91	3916 KANSAS AVE NW	11/17/2014
92	2557 36TH ST NW	11/17/2014

No	Address	Bottle Delivery Date
93	1329 TAYLOR ST NW	11/17/2014
94	19 RHODE ISLAND AVE NW	11/17/2014
95	1430 F ST NE	11/17/2014
96	5517 7th St NW	11/17/2014
97	302 RITTENHOUSE ST NW	11/17/2014
98	580 49th PI NE	11/17/2014
99	87 S St NW	11/17/2014
100	641 Gallatin St NW	11/17/2014
101	1603 Massachusetts Ave SE	11/17/2014
102	1720 NORTH CAPITOL ST NW	11/17/2014
103	605 ROCK CRK CHURCH RD NW	11/17/2014
104	4717 15TH ST NW	11/17/2014
105	3424 9TH ST NE	11/17/2014
106	230 G St NE	11/17/2014

Table C.3 Samples Returned but Rejected for Compliance Analysis

No	Address	Bottle Delivery Date	Reject Reason
1	1911 P ST SE	7/28/2014	Customer noted probable plumbing leak on chain of custody
2	123 TENNESSEE AVE NE	7/28/2014	Ice maker on
3	1706 NEW JERSEY AVE NW	7/28/2014	Ice maker on
4	3206 38th St NW	8/25/2014	Ice maker on
5	4120 Grant St NE	8/25/2014	Stagnation less than 6 hours
6	3033 CAMBRIDGE PL NW	8/25/2014	Ice maker on
7	2804 6TH ST NE	8/25/2014	Stagnation less than 6 hours
8	37 U ST NE	8/25/2014	Ice maker on
9	5024 7th St NW	9/22/2014	Stagnation period unknown
10	5318 9TH ST NW	9/22/2014	Stagnation period unknown
11	619 12th St NE	9/22/2014	No chain of custody provided
12	561 23RD PL NE	9/22/2014	Incomplete chain of custody
13	926 Hamilton St NW	9/22/2014	Incomplete chain of custody
14	5003 7TH ST NW	10/27/2014	Error in stagnation period
15	5517 7th St NW	10/27/2014	Stagnation less than 6 hours
16	1671 Rosedale St NE	10/27/2014	No chain of custody provided
17	1529 27TH ST NW	11/17/2014	Stagnation greater than 18 hours
18	620 44TH ST NE	11/17/2014	Stagnation greater than 18 hours
19	313 5TH ST NE	11/17/2014	Sampling error - bottle not full
20	15 MADISON ST NW	11/17/2014	Ice maker on
21	2036 17TH ST NW	11/17/2014	Leak in plumbing
22	4408 HAYES ST NE	11/17/2014	Stagnation period unknown

Table C.4 Deviations from Sample Order

No	Address	Priority	Scheduled Month	Deviation Reason
1	501 Webster St NW	Primary	Sept	Customer requested to not participate
2	5517 7th St NW	Secondary	Oct	First sample rejected, delivered 2 nd set of bottles in November
3	4425 14th St NE	NEW ^[1]	July	Added site this semester
4	2809 35TH ST NW	NEW ^[1]	July	Added site this semester
5	1329 TAYLOR ST NW	NEW ^[2]	Nov	Added site this semester
6	4717 15TH ST NW	NEW ^[2]	Nov	Added site this semester
7	15 MADISON ST NW	NEW ^[2]	Nov	Added site this semester
8	2036 17TH ST NW	NEW ^[2]	Nov	Added site this semester
9	3424 9TH ST NE	NEW ^[2]	Nov	Added site this semester
10	4408 HAYES ST NE	NEW ^[2]	Nov	Added site this semester
11	1720 NORTH CAPITOL ST NW	NEW ^[2]	Nov	Added site this semester
12	620 44TH ST NE	NEW ^[2]	Nov	Added site this semester
13	1339 CHILDRESS ST NE	NEW ^[2]	Nov	Added site this semester
14	923 9TH ST NE	NEW ^[2]	Nov	Added site this semester
15	314 VARNUM ST NW	NEW ^[2]	Nov	Added site this semester
16	1529 27TH ST NW	NEW ^[2]	Nov	Added site this semester
17	3916 KANSAS AVE NW	NEW ^[2]	Nov	Added site this semester
18	2557 36TH ST NW	NEW ^[2]	Nov	Added site this semester
19	4233 JENIFER ST NW	NEW ^[2]	Nov	Added site this semester
20	4002 ILLINOIS AVE NW	NEW ^[2]	Nov	Added site this semester
21	3807 KANAWHA ST NW	NEW ^[2]	Nov	Added site this semester
22	19 RHODE ISLAND AVE NW	NEW ^[2]	Nov	Added site this semester
23	313 5TH ST NE	NEW ^[2]	Nov	Added site this semester
24	3916 5TH ST NW	NEW ^[2]	Nov	Added site this semester
25	3405 HOLMEAD PL NW	NEW ^[2]	Nov	Added site this semester
26	1430 F ST NE	NEW ^[2]	Nov	Added site this semester
27	4014 Grant St NE	NEW ^[2]	Nov	Added site this semester

Notes:

[1] New participant: Customer contacted DC Water to request a lead test, and agreed to participate in the Lead and Copper Monitoring Program. DC Water confirmed that the address met Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structure with a full lead service line based on DC Water’s customer information and service line inventory records.

[2] New participant: During the July - December 2014 monitoring period, DC Water exhausted its list of pre-approved sampling sites before meeting the required number of LCR sampling results for the monitoring period. DC Water randomly selected this address, which met the Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structure with a full lead service line based on DC Water’s customer information and service line inventory records and the customer agreed to participate.

Table C.5 Sites with Compliance Results from July 2013 through June 2014 and No Results in July through December 2014

No	Address	Reason
1	1003 Quebec PI NW	Did not return bottles; See Table C.2
2	109 19th St SE	Did not return bottles; See Table C.2
3	120 VARNUM ST NW	Did not return bottles; See Table C.2
4	123 TENNESSEE AVE NE	Sample rejected; See Table C.3
5	124 16TH ST NE	Removed from Sample Pool prior to this semester
6	1262 COLUMBIA RD NW	Did not return bottles; See Table C.2
7	1305 TAYLOR ST NW	Did not return bottles; See Table C.2
8	1310 R ST NW	Removed from Sample Pool prior to this semester, requested to not participate
9	1318 Wallach PI NW	Did not return bottles; See Table C.2
10	1331 Irving St NE	Did not return bottles; See Table C.2
11	1375 MONROE ST NW	Did not return bottles; See Table C.2
12	1378 Taylor St NW	Did not return bottles; See Table C.2
13	1420 Hamlin St NE	Did not return bottles; See Table C.2
14	1424 S ST NW	Did not return bottles; See Table C.2
15	1428 VARNUM ST NW	Did not return bottles; See Table C.2
16	1508 GOOD HOPE RD SE	Did not return bottles; See Table C.2
17	1529 UPSHUR ST NW	Did not return bottles; See Table C.2
18	1627 Gales St NE	Did not return bottles; See Table C.2
19	1635 WEBSTER ST NW	Did not return bottles; See Table C.2
20	1659 NEWTON ST NW	Did not return bottles; See Table C.2
21	1671 Rosedale St NE	Sample rejected; See Table C.3
22	1705 D St NE	Did not return bottles; See Table C.2
23	1706 NEW JERSEY AVE NW	Sample rejected; See Table C.3
24	1911 P ST SE	Sample rejected; See Table C.3
25	2121 3RD ST NE	Did not return bottles; See Table C.2
26	231 K St NE	Did not return bottles; See Table C.2
27	2904 P ST SE	Did not return bottles; See Table C.2
28	2913 Brandywine St NW	Did not return bottles; See Table C.2
29	2923 Cathedral AVE NW	Did not return bottles; See Table C.2
30	3033 CAMBRIDGE PL NW	Sample rejected; See Table C.3
31	308 9th St SE	Did not return bottles; See Table C.2
32	309 11TH ST SE	Did not return bottles; See Table C.2
33	317 9th St SE	Did not return bottles; See Table C.2
34	3202 38TH ST NW	Did not return bottles; See Table C.2
35	3206 38th St NW	Sample rejected; See Table C.3
36	3218 MACOMB ST NW	Did not return bottles; See Table C.2
37	3218 MORRISON ST NW	Did not return bottles; See Table C.2
38	322 TENNESSEE AVE NE	Did not return bottles; See Table C.2
39	3301 BROWN St NW	Did not return bottles; See Table C.2
40	3309 35TH ST NW	Did not return bottles; See Table C.2
41	333 34th St NE	Did not return bottles; See Table C.2
42	3510 QUESADA ST NW	Did not return bottles; See Table C.2

No	Address	Reason
43	3625 Albermarle St NW	Did not return bottles; See Table C.2
44	3706 35th St NW	Did not return bottles; See Table C.2
45	3724 CHESAPEAKE ST NW	Did not return bottles; See Table C.2
46	3761 W ST NW	Did not return bottles; See Table C.2
47	3913 8TH ST NW	Did not return bottles; See Table C.2
48	412 BRANDYWINE ST SE	Did not return bottles; See Table C.2
49	4120 Grant St NE	Sample rejected; See Table C.3
50	420 Kenyon St NW	Did not return bottles; See Table C.2
51	4214 8th St NW	Did not return bottles; See Table C.2
52	4215 39th St NW	Did not return bottles; See Table C.2
53	4332 BRANDYWINE ST NW	Did not return bottles; See Table C.2
54	4401 5TH ST NW	Sample rejected; See Table C.3
55	449 S St NW	Did not return bottles; See Table C.2
56	4525 15TH ST NW	Did not return bottles; See Table C.2
57	5003 7TH ST NW	Sample rejected; See Table C.3
58	5007 13TH ST NW	Did not return bottles; See Table C.2
59	501 Webster St NW	Removed from Sample Pool prior to this semester; customer requested to not participate
60	5024 7th St NW	Sample rejected; See Table C.3
61	522 4TH ST SE	Did not return bottles; See Table C.2
62	53 V St NW	Did not return bottles; See Table C.2
63	531 Tennessee Ave NE	Did not return bottles; See Table C.2
64	5312 ILLINOIS AVE NW	Did not return bottles; See Table C.2
65	5318 9TH ST NW	Sample rejected; See Table C.3
66	5404 39TH ST NW	Did not return bottles; See Table C.2
67	561 23RD PL NE	Sample rejected; See Table C.3
68	5731 3rd Pl NW	Did not return bottles; See Table C.2
69	6001 33rd St NW	Did not return bottles; See Table C.2
70	6105 Dix St NE	Did not return bottles; See Table C.2
71	619 12th St NE	Sample rejected; See Table C.3
72	6209 30TH ST NW	Did not return bottles; See Table C.2
73	621 Upshur St NW	Did not return bottles; See Table C.2
74	6213 7TH ST NW	Did not return bottles; See Table C.2
75	636 ROCK CRK CHURCH RD NW	Did not return bottles; See Table C.2
76	744 9TH ST SE	Did not return bottles; See Table C.2
77	8 N St SW	Did not return bottles; See Table C.2
78	807 Buchanan St NW	Did not return bottles; See Table C.2
79	910 Farragut St NW	Did not return bottles; See Table C.2
80	926 Hamilton St NW	Sample rejected; See Table C.3

Table C.6 Customer Notification of Results

No	Address	Collection Date	Date Received from WAD Lab	Date Letter Sent to Customer
1	1020 INDEPENDENCE AVE SE	7/28/2014	9/4/2014	9 /5 /2014
2	125 Madison St NW	7/29/2014	9/4/2014	9 /5 /2014
3	10 S St NW	7/29/2014	9/4/2014	9 /5 /2014
4	1519 Olive St NE	7/29/2014	9/4/2014	9 /5 /2014
5	1346 F St NE	7/29/2014	9/4/2014	9 /5 /2014
6	1513 27TH ST NW	7/29/2014	9/4/2014	9 /5 /2014
7	4425 14th St NE	7/29/2014	9/4/2014	9 /5 /2014
8	119 16TH ST NE	7/30/2014	9/4/2014	9 /5 /2014
9	1649 HARVARD ST NW	7/30/2014	9/4/2014	9 /5 /2014
10	2007 37TH ST NW	7/30/2014	9/4/2014	9 /5 /2014
11	1315 FRANKLIN ST NE	7/30/2014	9/4/2014	9 /5 /2014
12	1010 10th St NE	7/30/2014	9/4/2014	9 /5 /2014
13	1826 Jackson St NE	7/30/2014	9/4/2014	9 /5 /2014
14	1703 D St NE	7/30/2014	9/4/2014	9 /5 /2014
15	1011 Taylor St NE	7/30/2014	9/4/2014	9 /5 /2014
16	1620 Webster St NW	7/30/2014	9/4/2014	9 /5 /2014
17	15 Milmarson Pl NW	7/30/2014	9/4/2014	9 /5 /2014
18	1505 Buchanan St NW	7/30/2014	9/4/2014	9 /5 /2014
19	1613 Webster St NW	7/30/2014	9/4/2014	9 /5 /2014
20	1715 IRVING ST NE	7/30/2014	9/4/2014	9 /5 /2014
21	1113 STAPLES ST NE	7/30/2014	9/4/2014	9 /5 /2014
22	1003 Otis St NE	7/31/2014	9/4/2014	9 /5 /2014
23	1738 ALLISON ST NW	7/31/2014	9/4/2014	9 /5 /2014
24	2719 O ST NW	8/26/2014	9/29/2014	10/2 /2014
25	4413 5th St NW	8/26/2014	9/29/2014	10/2 /2014
26	313 10TH ST SE	8/26/2014	9/29/2014	10/2 /2014
27	228 V ST NE	8/26/2014	9/29/2014	10/2 /2014
28	2830 BRENTWOOD RD NE	8/26/2014	9/29/2014	10/2 /2014
29	3211 Central Ave NE	8/26/2014	9/29/2014	10/2 /2014
30	3727 T St NW	8/26/2014	9/29/2014	10/2 /2014
31	3636 13TH ST NW	8/26/2014	9/29/2014	10/2 /2014
32	2804 6TH ST NE	8/26/2014	9/3/2014	10/2 /2014
33	4131 YUMA ST NW	8/27/2014	9/29/2014	10/2 /2014
34	331 RALEIGH ST SE	8/27/2014	9/29/2014	10/2 /2014
35	4550 30TH ST NW	8/27/2014	9/29/2014	10/2 /2014
36	3710 Huntington St NW	8/27/2014	9/29/2014	10/2 /2014
37	4418 14th St NE	8/27/2014	9/29/2014	10/2 /2014
38	336 Quackenbos St NE	8/27/2014	9/29/2014	10/2 /2014
39	307 7th St NE	8/27/2014	9/29/2014	10/2 /2014
40	4310 37th St NW	8/27/2014	9/29/2014	10/2 /2014
41	421 Hamilton St NW	8/27/2014	9/29/2014	10/2 /2014
42	2832 BRENTWOOD RD NE	8/27/2014	9/29/2014	10/2 /2014
43	2435 33RD ST SE	8/28/2014	9/29/2014	10/2 /2014
44	414 G ST NE	9/1/2014	9/29/2014	10/2 /2014

No	Address	Collection Date	Date Received from WAD Lab	Date Letter Sent to Customer
45	450 Newton Pl NW	9/1/2014	9/29/2014	10/2 /2014
46	702 9th St SE	9/22/2014	10/23/2014	10/24/2014
47	75 Bates St NW	9/22/2014	10/23/2014	10/24/2014
48	1222 HAMILTON ST NW	9/23/2014	10/23/2014	10/24/2014
49	4627 49th St NW	9/23/2014	10/23/2014	10/24/2014
50	1211 Carrollsburg Pl SW	9/23/2014	10/23/2014	10/24/2014
51	912 Emerson St NW	9/23/2014	10/23/2014	10/24/2014
52	6308 8th St NW	9/23/2014	10/23/2014	10/24/2014
53	4806 Kansas Ave NW	9/23/2014	10/23/2014	10/24/2014
54	609 49TH PL NE	9/23/2014	10/23/2014	10/24/2014
55	4811 Illinois Ave NW	9/23/2014	10/23/2014	10/24/2014
56	6205 14TH ST NW	9/23/2014	10/23/2014	10/24/2014
57	4926 Glenbrook Rd NW	9/24/2014	10/23/2014	10/24/2014
58	4703 Macarthur Blvd NW	9/24/2014	10/23/2014	10/24/2014
59	6210 8th St NW	9/24/2014	10/23/2014	10/24/2014
60	5923 33rd St NW	9/24/2014	10/23/2014	10/24/2014
61	5234 Illinois Ave NW	9/24/2014	10/23/2014	10/24/2014
62	913 Hamlin St NE	9/24/2014	10/23/2014	10/24/2014
63	822 Allison St NW	9/24/2014	10/23/2014	10/24/2014
64	816 MADISON ST NW	9/24/2014	10/23/2014	10/24/2014
65	502 A ST SE	9/24/2014	10/23/2014	10/24/2014
66	5223 KANSAS AVE NW	9/24/2014	10/23/2014	10/24/2014
67	5220 CHEVY CHASE PKWY NW	9/24/2014	10/23/2014	10/24/2014
68	617 6th St NE	9/25/2014	10/23/2014	10/24/2014
69	12 14TH ST SE	9/25/2014	10/23/2014	10/24/2014
70	4719 9TH ST NW	9/25/2014	10/23/2014	10/24/2014
71	4447 HAWTHORNE ST NW	9/3/2014	9/29/2014	10/2 /2014
72	1850 2ND ST NW	10/27/2014	12/2/2014	12/3 /2014
73	5301 RENO RD NW	10/28/2014	12/2/2014	12/3 /2014
74	4818 8th ST NW	10/28/2014	12/2/2014	12/3 /2014
75	1412 S St NW	10/28/2014	12/2/2014	12/3 /2014
76	3907 13th St NW	10/28/2014	12/2/2014	12/3 /2014
77	1412 Shepherd St NW	10/28/2014	12/2/2014	12/3 /2014
78	2408 2nd St NE	10/28/2014	12/2/2014	12/3 /2014
79	3416 9th St NE	10/28/2014	12/2/2014	12/3 /2014
80	223 14th Pl NE	10/28/2014	12/2/2014	12/3 /2014
81	1319 POTOMAC AVE SE	10/29/2014	12/2/2014	12/3 /2014
82	3809 ALTON PL NW	10/29/2014	12/2/2014	12/3 /2014
83	3030 44TH ST NW	10/29/2014	12/2/2014	12/3 /2014
84	1808 KEARNEY ST NE	10/29/2014	12/2/2014	12/3 /2014
85	1353 JEFFERSON ST NW	10/29/2014	12/2/2014	12/3 /2014
86	1436 S St NW	10/29/2014	12/2/2014	12/3 /2014
87	3917 8th St NW	10/29/2014	12/2/2014	12/3 /2014
88	4409 Lowell St NW	10/29/2014	12/2/2014	12/3 /2014
89	53 P St NW	10/29/2014	12/2/2014	12/3 /2014
90	413 4th St SE	10/29/2014	12/2/2014	12/3 /2014

No	Address	Collection Date	Date Received from WAD Lab	Date Letter Sent to Customer
91	36 Florida Ave NW	10/29/2014	12/2/2014	12/3 /2014
92	3722 MCKINLEY ST NW	10/29/2014	12/2/2014	12/3 /2014
93	2212 38th St NW	10/30/2014	12/2/2014	12/3 /2014
94	1453 S St NW	10/30/2014	12/2/2014	12/3 /2014
95	1736 Bay St SE	11/17/2014	12/11/2014	12/12/2014
96	905 Kent Pl NE	11/17/2014	12/11/2014	12/12/2014
97	923 9TH ST NE	11/18/2014	12/11/2014	12/12/2014
98	4233 JENIFER ST NW	11/18/2014	12/11/2014	12/12/2014
99	3916 5TH ST NW	11/18/2014	12/11/2014	12/12/2014
100	3405 HOLMEAD PL NW	11/18/2014	12/11/2014	12/12/2014
101	1339 CHILDRESS ST NE	11/19/2014	12/11/2014	12/12/2014
102	4002 ILLINOIS AVE NW	11/19/2014	12/11/2014	12/12/2014
103	3807 KANAWHA ST NW	11/19/2014	12/11/2014	12/12/2014
104	4014 Grant St NE	11/19/2014	12/11/2014	12/12/2014
105	3036 P St NW	11/9/2014	12/2/2014	12/3 /2014

Attachment 1

Washington Aqueduct Test Results for LCR Compliance Samples

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-001

SAMPLE INFORMATION

Sample Number: 1408005-001 Customer Sample Number: 3114988 Project: LCR
Location: 1st Draw 4425 14TH ST NE Type: Dist.

Collection Date: 7/29/2014 Collection Time: 5:33 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.061 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.042 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-002

SAMPLE INFORMATION

Sample Number: 1408005-002 Customer Sample Number: 3114988 Project: LCR
Location: 2nd Draw 4425 14TH ST NE Type: Dist.

Collection Date: 7/29/2014 Collection Time: 5:35 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-003

SAMPLE INFORMATION

Sample Number: 1408005-003 Customer Sample Number: 3111360 Project: LCR
Location: 1st Draw 1519 OLIVE ST NE Type: Dist.

Collection Date: 7/29/2014 Collection Time: 5:46 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.140 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.007 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0028 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-004

SAMPLE INFORMATION

Sample Number: 1408005-004 Customer Sample Number: 3111360 Project: LCR
Location: 2nd Draw 1519 OLIVE ST NE Type: Dist.

Collection Date: 7/29/2014 Collection Time: 5:47 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.136 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0022 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-005

SAMPLE INFORMATION

Sample Number: 1408005-005 Customer Sample Number: 3007205 Project: LCR
Location: 1st Draw 1513 27TH ST NW Type: Dist.

Collection Date: 7/29/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.013 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.035 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0036 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-006

SAMPLE INFORMATION

Sample Number: 1408005-006 Customer Sample Number: 3007205 Project: LCR
Location: 2nd Draw 1513 27TH ST NW Type: Dist.

Collection Date: 7/29/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.013 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.007 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0122 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-007

SAMPLE INFORMATION

Sample Number: 1408005-007 Customer Sample Number: 3025494 Project: LCR
Location: 1st Draw 125 MADISON ST NW Type: Dist.

Collection Date: 7/29/2014 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.098 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.025 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0046 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-008

SAMPLE INFORMATION

Sample Number: 1408005-008 Customer Sample Number: 3025494 Project: LCR
Location: 2nd Draw 125 MADISON ST NW Type: Dist.

Collection Date: 7/29/2014 Collection Time: 18:32 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.102 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0049 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-009

SAMPLE INFORMATION

Sample Number: 1408005-009 Customer Sample Number: 3100684 Project: LCR
Location: 1st Draw 1346 F ST NE Type: Dist.

Collection Date: 7/29/2014 Collection Time: 19:43 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.023 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0032 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-010

SAMPLE INFORMATION

Sample Number: 1408005-010 Customer Sample Number: 3100684 Project: LCR
Location: 2nd Draw 1346 F ST NE Type: Dist.

Collection Date: 7/29/2014 Collection Time: 19:48 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0106 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-011

SAMPLE INFORMATION

Sample Number: 1408005-011 Customer Sample Number: 3099025 Project: LCR
Location: 1st Draw 1010 10TH ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-012

SAMPLE INFORMATION

Sample Number: 1408005-012 Customer Sample Number: 3099025 Project: LCR
Location: 2nd Draw 1010 10TH ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 4:32 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-013

SAMPLE INFORMATION

Sample Number: 1408005-013 Customer Sample Number: 3106027 Project: LCR
Location: 1st Draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.223 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0026 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-014

SAMPLE INFORMATION

Sample Number: 1408005-014 Customer Sample Number: 3106027 Project: LCR
Location: 2nd Draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.100 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.024 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-015

SAMPLE INFORMATION

Sample Number: 1408005-015 Customer Sample Number: 3034000 Project: LCR
Location: 1st Draw 1649 HARVARD ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.085 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0031 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-016

SAMPLE INFORMATION

Sample Number: 1408005-016 Customer Sample Number: 3034000 Project: LCR
Location: 2nd Draw 1649 HARVARD ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 7:24 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.095 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.020 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0038 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-017

SAMPLE INFORMATION

Sample Number: 1408005-017 Customer Sample Number: 3029171 Project: LCR
Location: 1st Draw 1613 WEBSTER ST NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.059 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-018

SAMPLE INFORMATION

Sample Number: 1408005-018 Customer Sample Number: 3029171 Project: LCR
Location: 2nd Draw 1613 WEBSTER ST NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.026 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-019

SAMPLE INFORMATION

Sample Number: 1408005-019 Customer Sample Number: 3105267 Project: LCR
Location: 1st Draw 1715 IRVING ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 7:59 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.145 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.034 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0038 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-020

SAMPLE INFORMATION

Sample Number: 1408005-020 Customer Sample Number: 3105267 Project: LCR
Location: 2nd Draw 1715 IRVING ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 7:59 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.044 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0029 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-021

SAMPLE INFORMATION

Sample Number: 1408005-021 Customer Sample Number: 3104222 Project: LCR
Location: 1st Draw 1315 FRANKLIN ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.020 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-022

SAMPLE INFORMATION

Sample Number: 1408005-022 Customer Sample Number: 3104222 Project: LCR
Location: 2nd Draw 1315 FRANKLIN ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 8:17 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.022 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-023

SAMPLE INFORMATION

Sample Number: 1408005-023 Customer Sample Number: 3027905 Project: LCR
Location: 1st Draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.012 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.069 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0151 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-024

SAMPLE INFORMATION

Sample Number: 1408005-024 Customer Sample Number: 3027905 Project: LCR
Location: 2nd Draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 8:31 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.077 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0210 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-025

SAMPLE INFORMATION

Sample Number: 1408005-025 Customer Sample Number: 3113400 Project: LCR
Location: 1st Draw 1003 OTIS ST NE Type: Dist.

Collection Date: 7/31/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.024 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.060 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0027 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-026

SAMPLE INFORMATION

Sample Number: 1408005-026 Customer Sample Number: 3113400 Project: LCR
Location: 2nd Draw 1003 OTIS ST NE Type: Dist.

Collection Date: 7/31/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.033 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.022 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0034 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-027

SAMPLE INFORMATION

Sample Number: 1408005-027 Customer Sample Number: 3029133 Project: LCR
Location: 1st Draw 1738 ALLISON ST NW Type: Dist.

Collection Date: 7/31/2014 Collection Time: 7:24 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.031 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.053 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408005-028

SAMPLE INFORMATION

Sample Number: 1408005-028 Customer Sample Number: 3029133 Project: LCR
Location: 2nd Draw 1738 ALLISON ST NW Type: Dist.

Collection Date: 7/31/2014 Collection Time: 7:28 Sampler: HOME OWNER Received Date and Time: 8/1/2014 10:53:56 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.026 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408006-001

SAMPLE INFORMATION

Sample Number: 1408006-001 Customer Sample Number: 3073669 Project: LCR
Location: 1st Draw 1020 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 7/28/2014 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 8/1/2014 2:21:45 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.024 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408006-002

SAMPLE INFORMATION

Sample Number: 1408006-002 Customer Sample Number: 3073669 Project: LCR
Location: 2nd Draw 1020 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 7/28/2014 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 8/1/2014 2:21:45 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0088 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408006-003

SAMPLE INFORMATION

Sample Number: 1408006-003 Customer Sample Number: 3113467 Project: LCR
Location: 1st Draw 1011 TAYLOR ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/1/2014 2:21:45 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.072 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.016 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408006-004

SAMPLE INFORMATION

Sample Number: 1408006-004 Customer Sample Number: 3113467 Project: LCR
Location: 2nd Draw 1011 TAYLOR ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 8/1/2014 2:21:45 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.061 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.019 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408025-001

SAMPLE INFORMATION

Sample Number: 1408025-001 Customer Sample Number: 3017940 Project: LCR
Location: 1st Draw 10 S ST NW Type: Dist.

Collection Date: 7/29/2014 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:05:32 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.018 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0016 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408025-002

SAMPLE INFORMATION

Sample Number: 1408025-002 Customer Sample Number: 3017940 Project: LCR
Location: 2nd Draw 10 S ST NW Type: Dist.

Collection Date: 7/29/2014 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:05:32 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0030 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408025-003

SAMPLE INFORMATION

Sample Number: 1408025-003 Customer Sample Number: 3102110 Project: LCR
Location: 1st Draw 1113 STAPLES ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 5:14 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:05:32 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.195 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.006 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0028 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408025-004

SAMPLE INFORMATION

Sample Number: 1408025-004 Customer Sample Number: 3102110 Project: LCR
Location: 2nd Draw 1113 STAPLES ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 5:16 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:05:32 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.006 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0029 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408025-005

SAMPLE INFORMATION

Sample Number: 1408025-005 Customer Sample Number: 3029191 Project: LCR
Location: 1st Draw 1620 WEBSTER ST NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:07 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:05:32 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.021 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.022 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408025-006

SAMPLE INFORMATION

Sample Number: 1408025-006 Customer Sample Number: 3029191 Project: LCR
Location: 2nd Draw 1620 WEBSTER ST NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:14 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:05:32 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.022 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408025-007

SAMPLE INFORMATION

Sample Number: 1408025-007 Customer Sample Number: 3100985 Project: LCR
Location: 1st Draw 1703 D ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 17:21 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:05:32 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.012 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.041 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0024 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408025-008

SAMPLE INFORMATION

Sample Number: 1408025-008 Customer Sample Number: 3100985 Project: LCR
Location: 2nd Draw 1703 D ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 17:23 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:05:32 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.050 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408048-001

SAMPLE INFORMATION

Sample Number: 1408048-001 Customer Sample Number: 3026174 Project: LCR
Location: 1st draw 15 MILMARSON PL NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 5:35 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:07:07 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.064 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408048-002

SAMPLE INFORMATION

Sample Number: 1408048-002 Customer Sample Number: 3026174 Project: LCR
Location: 2nd draw 15 MILMARSON PL NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 5:36 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:07:07 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.039 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	8/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408048-003

SAMPLE INFORMATION

Sample Number: 1408048-003 Customer Sample Number: 3009912 Project: LCR
Location: 1st draw 2007 37TH ST NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:07:07 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.076 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408048-004

SAMPLE INFORMATION

Sample Number: 1408048-004 Customer Sample Number: 3009912 Project: LCR
Location: 2nd draw 2007 37TH ST NW Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:07:07 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	8/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408111-001

SAMPLE INFORMATION

Sample Number: 1408111-001 Customer Sample Number: 3111849 Project: LCR
Location: 1st Draw 119 16TH ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:21:20 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/14/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.043 mg/L	8/14/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0022 mg/L	8/14/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408111-002

SAMPLE INFORMATION

Sample Number: 1408111-002 Customer Sample Number: 3111849 Project: LCR
Location: 2nd Draw 119 16TH ST NE Type: Dist.

Collection Date: 7/30/2014 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:21:20 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/14/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.007 mg/L	8/14/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0028 mg/L	8/14/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-001 Customer Sample Number: 3073239 Project: LCR
Location: 1st draw 313 10TH ST SE Type: Dist.

Collection Date: 8/26/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.012 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.026 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-002 Customer Sample Number: 3073239 Project: LCR
Location: 2nd draw 313 10TH ST SE Type: Dist.

Collection Date: 8/26/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.011 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.023 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0026 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-003 Customer Sample Number: 3007249 Project: LCR
Location: 1st draw 2719 O ST NW Type: Dist.

Collection Date: 8/26/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.037 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0044 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-004 Customer Sample Number: 3007249 Project: LCR
Location: 2nd draw 2719 O ST NW Type: Dist.

Collection Date: 8/26/2014 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.016 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0109 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-005 Customer Sample Number: 3029605 Project: LCR
Location: 1st draw 3636 13TH ST NW Type: Dist.

Collection Date: 8/26/2014 Collection Time: 18:12 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0019 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-006 Customer Sample Number: 3029605 Project: LCR
Location: 2nd draw 3636 13TH ST NW Type: Dist.

Collection Date: 8/26/2014 Collection Time: 18:13 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.016 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0020 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-007 Customer Sample Number: 3010741 Project: LCR
Location: 1st draw 3727 T ST NW Type: Dist.

Collection Date: 8/26/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.129 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.051 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0050 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-008 Customer Sample Number: 3010741 Project: LCR
Location: 2nd draw 3727 T ST NW Type: Dist.

Collection Date: 8/26/2014 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.129 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0104 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-009 Customer Sample Number: 3111675 Project: LCR
Location: 1st draw 307 7TH ST NE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.012 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.037 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-010 Customer Sample Number: 3111675 Project: LCR
Location: 2nd draw 307 7TH ST NE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 7:31 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.010 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.016 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-011 Customer Sample Number: 3107442 Project: LCR
Location: 1st draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 8/26/2014 Collection Time: 17:17 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.039 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.070 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0017 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-012 Customer Sample Number: 3107442 Project: LCR
Location: 2nd draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 8/26/2014 Collection Time: 17:21 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.054 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0082 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-013 Customer Sample Number: 3041310 Project: LCR
Location: 1st draw 4310 37TH ST NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.015 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.038 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0022 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-014 Customer Sample Number: 3041310 Project: LCR
Location: 2nd draw 4310 37TH ST NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.036 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.018 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0063 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409021-015

SAMPLE INFORMATION

Sample Number: 1409021-015 Customer Sample Number: 3023353 Project: LCR
Location: 1st draw 421 HAMILTON ST NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 7:31 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.577 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.047 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-016 Customer Sample Number: 3023353 Project: LCR
Location: 2nd draw 421 HAMILTON ST NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 7:33 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.018 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0034 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-017

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-017 Customer Sample Number: 3058406 Project: LCR
Location: 1st draw 4550 30TH ST NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.031 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0033 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409021-018

SAMPLE INFORMATION

Sample Number: 1409021-018 Customer Sample Number: 3058406 Project: LCR
Location: 2nd draw 4550 30TH ST NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.007 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0042 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-019

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-019 Customer Sample Number: 3107489 Project: LCR
Location: 1st draw 2832 BRENTWOOD RD NE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 5:34 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.036 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.052 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0016 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-020

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-020 Customer Sample Number: 3107489 Project: LCR
Location: 2nd draw 2832 BRENTWOOD RD NE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 5:37 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.036 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0053 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-021

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-021 Customer Sample Number: 3103275 Project: LCR
Location: 2nd draw 2804 6TH ST NE Type: Dist.

Collection Date: 8/26/2014 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.032 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.014 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0034 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-022

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-022 Customer Sample Number: 3107490 Project: LCR
Location: 1st draw 2830 BRENTWOOD RD NE Type: Dist.

Collection Date: 8/26/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.046 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.079 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-023

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-023 Customer Sample Number: 3107490 Project: LCR
Location: 2nd draw 2830 BRENTWOOD RD NE Type: Dist.

Collection Date: 8/26/2014 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.040 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.094 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-024

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-024 Customer Sample Number: 3021581 Project: LCR
Location: 1st draw 4413 5TH ST NW Type: Dist.

Collection Date: 8/26/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.006 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0017 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-025

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-025 Customer Sample Number: 3021581 Project: LCR
Location: 2nd draw 4413 5TH ST NW Type: Dist.

Collection Date: 8/26/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0035 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-026

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-026 Customer Sample Number: 3042399 Project: LCR
Location: 1st draw 4131 YUMA ST., NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.024 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0017 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-027

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-027 Customer Sample Number: 3042399 Project: LCR
Location: 2nd draw 4131 YUMA ST., NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:08 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0054 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-028

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-028 Customer Sample Number: 3104746 Project: LCR
Location: 1st draw 4418 14TH ST. NE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.044 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-029

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-029 Customer Sample Number: 3104746 Project: LCR
Location: 2nd draw 4418 14TH ST. NE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0015 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-030

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-030 Customer Sample Number: 3117544 Project: LCR
Location: 1st draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 5:28 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.213 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.024 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0030 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-031

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-031 Customer Sample Number: 3117544 Project: LCR
Location: 2nd draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.195 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-032

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-032 Customer Sample Number: 3124875 Project: LCR
Location: 1st draw 228 V ST NE Type: Dist.

Collection Date: 8/26/2014 Collection Time: 19:56 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.032 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-033

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-033 Customer Sample Number: 3124875 Project: LCR
Location: 2nd draw 228 V ST NE Type: Dist.

Collection Date: 8/26/2014 Collection Time: 19:58 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.034 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-034

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-034 Customer Sample Number: 3070403 Project: LCR
Location: 1st draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.022 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-035

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-035 Customer Sample Number: 3070703 Project: LCR
Location: 2nd draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:07 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.027 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	9/5/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-036

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-036 Customer Sample Number: 3080372 Project: LCR
Location: 1st draw 2435 33RD ST SE Type: Dist.

Collection Date: 8/28/2014 Collection Time: 5:58 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.081 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.040 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-037

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-037 Customer Sample Number: 3080372 Project: LCR
Location: 2nd draw 2435 33RD ST SE Type: Dist.

Collection Date: 8/28/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.098 mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0059 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-038

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-038 Customer Sample Number: 3040552 Project: LCR
Location: 1st draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.016 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/29/2014
Report Number: LC-W1409021-039

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409021-039 Customer Sample Number: 3040552 Project: LCR
Location: 2nd draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 6:39 Sampler: HOME OWNER Received Date and Time: 9/3/2014 1:43:34 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	9/5/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.011 mg/L	9/5/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409047-001

SAMPLE INFORMATION

Sample Number: 1409047-001 Customer Sample Number: 3052487 Project: LCR
Location: 1st draw 450 NEWTON PL NW Type: Dist.

Collection Date: 9/1/2014 Collection Time: 12:00 Sampler: HOME OWNER Received Date and Time: 9/5/2014 1:14:12 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.042 mg/L	9/17/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.024 mg/L	9/17/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0039 mg/L	9/17/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409047-002

SAMPLE INFORMATION

Sample Number: 1409047-002 Customer Sample Number: 3052487 Project: LCR
Location: 2nd draw 450 NEWTON PL NW Type: Dist.

Collection Date: 9/1/2014 Collection Time: 12:05 Sampler: HOME OWNER Received Date and Time: 9/5/2014 1:14:12 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.025 mg/L	9/17/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	9/17/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0072 mg/L	9/17/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409047-003

SAMPLE INFORMATION

Sample Number: 1409047-003 Customer Sample Number: 3044259 Project: LCR
Location: 1st draw 4447 HAWTHORNE ST NW Type: Dist.

Collection Date: 9/3/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 9/5/2014 1:14:12 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.038 mg/L	9/17/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.038 mg/L	9/17/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	9/17/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409047-004

SAMPLE INFORMATION

Sample Number: 1409047-004 Customer Sample Number: 3044259 Project: LCR
Location: 2nd draw 4447 HAWTHORNE ST NW Type: Dist.

Collection Date: 9/3/2014 Collection Time: 5:33 Sampler: HOME OWNER Received Date and Time: 9/5/2014 1:14:12 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.039 mg/L	9/17/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.030 mg/L	9/17/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	9/17/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409074-001

SAMPLE INFORMATION

Sample Number: 1409074-001 Customer Sample Number: 3127684 Project: LCR
Location: 1st draw 414 G ST NE Type: Dist.

Collection Date: 9/1/2014 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 9/9/2014 3:24:12 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.072 mg/L	9/17/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.018 mg/L	9/17/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	9/17/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409074-002

SAMPLE INFORMATION

Sample Number: 1409074-002 Customer Sample Number: 3127684 Project: LCR
Location: 2nd draw 414 G ST NE Type: Dist.

Collection Date: 9/1/2014 Collection Time: 8:03 Sampler: HOME OWNER Received Date and Time: 9/9/2014 3:24:12 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.027 mg/L	9/17/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	9/17/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	9/17/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/29/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-001

SAMPLE INFORMATION

Sample Number: 1409225-001 Customer Sample Number: 3055284 Project: LCR
Location: 1st draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.024 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.127 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0055 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-002

SAMPLE INFORMATION

Sample Number: 1409225-002 Customer Sample Number: 3055284 Project: LCR
Location: 2nd draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.028 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0056 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-003

SAMPLE INFORMATION

Sample Number: 1409225-003 Customer Sample Number: 3045865 Project: LCR
Location: 1st draw 4926 GLENBROOK RD NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.024 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-004

SAMPLE INFORMATION

Sample Number: 1409225-004 Customer Sample Number: 3045865 Project: LCR
Location: 2nd draw 4926 GLENBROOK RD NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:08 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.010 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.016 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-005

SAMPLE INFORMATION

Sample Number: 1409225-005 Customer Sample Number: 3048790 Project: LCR
Location: 1st draw 6205 14TH ST NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 18:50 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.182 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.019 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0026 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-006

SAMPLE INFORMATION

Sample Number: 1409225-006 Customer Sample Number: 3048790 Project: LCR
Location: 2nd draw 6205 14TH ST NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 18:53 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0027 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-007

SAMPLE INFORMATION

Sample Number: 1409225-007 Customer Sample Number: 3073488 Project: LCR
Location: 1st draw 702 9TH ST SE Type: Dist.

Collection Date: 9/22/2014 Collection Time: 23:00 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.058 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0048 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-008

SAMPLE INFORMATION

Sample Number: 1409225-008 Customer Sample Number: 3043488 Project: LCR
Location: 2nd draw 702 9TH ST SE Type: Dist.

Collection Date: 9/22/2014 Collection Time: 23:00 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.007 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0142 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-009

SAMPLE INFORMATION

Sample Number: 1409225-009 Customer Sample Number: 3049889 Project: LCR
Location: 1st draw 1222 HAMILTON ST NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.021 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-010

SAMPLE INFORMATION

Sample Number: 1409225-010 Customer Sample Number: 3049889 Project: LCR
Location: 2nd draw 1222 HAMILTON ST NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 8:31 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.025 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.016 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-011

SAMPLE INFORMATION

Sample Number: 1409225-011 Customer Sample Number: 3086628 Project: LCR
Location: 1st draw 502 A ST SE Type: Dist.

Collection Date: 9/24/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.038 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.040 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-012

SAMPLE INFORMATION

Sample Number: 1409225-012 Customer Sample Number: 3086628 Project: LCR
Location: 2nd draw 502 A ST SE Type: Dist.

Collection Date: 9/24/2014 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.032 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-013

SAMPLE INFORMATION

Sample Number: 1409225-013 Customer Sample Number: 3043835 Project: LCR
Location: 1st draw 4627 49TH ST NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.031 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.045 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0015 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-014

SAMPLE INFORMATION

Sample Number: 1409225-014 Customer Sample Number: 3043835 Project: LCR
Location: 2nd draw 4627 49TH ST NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.028 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-015

SAMPLE INFORMATION

Sample Number: 1409225-015 Customer Sample Number: 3026837 Project: LCR
Location: 1st draw 6210 8TH ST NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.152 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0018 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-016

SAMPLE INFORMATION

Sample Number: 1409225-016 Customer Sample Number: 3026837 Project: LCR
Location: 2nd draw 6210 8TH ST NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.060 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0024 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-017

SAMPLE INFORMATION

Sample Number: 1409225-017 Customer Sample Number: 3011592 Project: LCR
Location: 1st draw 75 BATES ST NW Type: Dist.

Collection Date: 9/22/2014 Collection Time: 17:20 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.067 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-018

SAMPLE INFORMATION

Sample Number: 1409225-018 Customer Sample Number: 3011592 Project: LCR
Location: 2nd draw 75 BATES ST NW Type: Dist.

Collection Date: 9/22/2014 Collection Time: 17:22 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-019

SAMPLE INFORMATION

Sample Number: 1409225-019 Customer Sample Number: 3026885 Project: LCR
Location: 1st draw 6308 8TH ST NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 18:05 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.045 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.061 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-020

SAMPLE INFORMATION

Sample Number: 1409225-020 Customer Sample Number: 3026885 Project: LCR
Location: 2nd draw 6308 8TH ST NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 18:08 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.050 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.039 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0018 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-021

SAMPLE INFORMATION

Sample Number: 1409225-021 Customer Sample Number: 3051648 Project: LCR
Location: 1st draw 5223 KANSAS AVE NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.033 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.066 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-022

SAMPLE INFORMATION

Sample Number: 1409225-022 Customer Sample Number: 3051648 Project: LCR
Location: 2nd draw 5223 KANSAS AVE NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 8:47 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.039 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.022 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-023

SAMPLE INFORMATION

Sample Number: 1409225-023 Customer Sample Number: 3127230 Project: LCR
Location: 1st draw 617 6TH ST NE Type: Dist.

Collection Date: 9/25/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.030 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.114 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-024

SAMPLE INFORMATION

Sample Number: 1409225-024 Customer Sample Number: 3127230 Project: LCR
Location: 2nd draw 617 6TH ST NE Type: Dist.

Collection Date: 9/25/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.023 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-025

SAMPLE INFORMATION

Sample Number: 1409225-025 Customer Sample Number: 3039097 Project: LCR
Location: 1st draw 5220 CHEVY CHASE PKWY NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 7:07 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.075 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.175 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0237 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-026

SAMPLE INFORMATION

Sample Number: 1409225-026 Customer Sample Number: 3039097 Project: LCR
Location: 2nd draw 5220 CHEVY CHASE PKWY NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.012 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.011 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0116 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-027

SAMPLE INFORMATION

Sample Number: 1409225-027 Customer Sample Number: 3058437 Project: LCR
Location: 1st draw 4806 KANSAS AVE NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 7:36 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.104 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-028

SAMPLE INFORMATION

Sample Number: 1409225-028 Customer Sample Number: 3058437 Project: LCR
Location: 2nd draw 4806 KANSAS AVE NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 7:37 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.112 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-029

SAMPLE INFORMATION

Sample Number: 1409225-029 Customer Sample Number: 3024404 Project: LCR
Location: 1st draw 816 MADISON ST NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 8:04 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.037 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-030

SAMPLE INFORMATION

Sample Number: 1409225-030 Customer Sample Number: 3024404 Project: LCR
Location: 2nd draw 816 MADISON ST NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 8:08 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.036 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-031

SAMPLE INFORMATION

Sample Number: 1409225-031 Customer Sample Number: 3058525 Project: LCR
Location: 1st draw 4811 ILLINOIS AVE NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.158 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.085 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0045 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-032

SAMPLE INFORMATION

Sample Number: 1409225-032 Customer Sample Number: 3058525 Project: LCR
Location: 2nd draw 4811 ILLINOIS AVE NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.144 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.070 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0024 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-033

SAMPLE INFORMATION

Sample Number: 1409225-033 Customer Sample Number: 3092716 Project: LCR
Location: 1st draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.036 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.100 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0016 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-034

SAMPLE INFORMATION

Sample Number: 1409225-034 Customer Sample Number: 3092716 Project: LCR
Location: 2nd draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 8:11 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.037 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.034 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0176 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-035

SAMPLE INFORMATION

Sample Number: 1409225-035 Customer Sample Number: 3075175 Project: LCR
Location: 1st draw 12 14TH ST SE Type: Dist.

Collection Date: 9/25/2014 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.024 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0053 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-036

SAMPLE INFORMATION

Sample Number: 1409225-036 Customer Sample Number: 3075175 Project: LCR
Location: 2nd draw 12 14TH ST SE Type: Dist.

Collection Date: 9/25/2014 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.034 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-037

SAMPLE INFORMATION

Sample Number: 1409225-037 Customer Sample Number: 3022216 Project: LCR
Location: 1st draw 4719 9TH ST NW Type: Dist.

Collection Date: 9/25/2014 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-038

SAMPLE INFORMATION

Sample Number: 1409225-038 Customer Sample Number: 3022216 Project: LCR
Location: 2nd draw 4719 9TH ST NW Type: Dist.

Collection Date: 9/25/2014 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-039

SAMPLE INFORMATION

Sample Number: 1409225-039 Customer Sample Number: 3051579 Project: LCR
Location: 1st draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:39 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.033 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.026 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0063 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-040

SAMPLE INFORMATION

Sample Number: 1409225-040 Customer Sample Number: 3051579 Project: LCR
Location: 2nd draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:41 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.035 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.017 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0108 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-041

SAMPLE INFORMATION

Sample Number: 1409225-041 Customer Sample Number: 3120431 Project: LCR
Location: 1st draw 913 HAMLIN ST NE Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.021 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0029 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-042

SAMPLE INFORMATION

Sample Number: 1409225-042 Customer Sample Number: 3120431 Project: LCR
Location: 2nd draw 913 HAMLIN ST NE Type: Dist.

Collection Date: 9/24/2014 Collection Time: 6:01 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.018 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0032 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-043

SAMPLE INFORMATION

Sample Number: 1409225-043 Customer Sample Number: 3021723 Project: LCR
Location: 1st draw 822 ALLISON ST NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.011 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.025 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-044

SAMPLE INFORMATION

Sample Number: 1409225-044 Customer Sample Number: 3021723 Project: LCR
Location: 2nd draw 822 ALLISON ST NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0024 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-045

SAMPLE INFORMATION

Sample Number: 1409225-045 Customer Sample Number: 3109344 Project: LCR
Location: 1st draw 609 49TH PL NE Type: Dist.

Collection Date: 9/23/2014 Collection Time: 20:25 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.013 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.115 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-046

SAMPLE INFORMATION

Sample Number: 1409225-046 Customer Sample Number: 3109344 Project: LCR
Location: 2nd draw 609 49TH PL NE Type: Dist.

Collection Date: 9/23/2014 Collection Time: 20:27 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.031 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-047

SAMPLE INFORMATION

Sample Number: 1409225-047 Customer Sample Number: 3022524 Project: LCR
Location: 1st draw 912 EMERSON ST. NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0024 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-048

SAMPLE INFORMATION

Sample Number: 1409225-048 Customer Sample Number: 3022524 Project: LCR
Location: 2nd draw 912 EMERSON ST. NW Type: Dist.

Collection Date: 9/23/2014 Collection Time: 5:31 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0023 mg/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-049

SAMPLE INFORMATION

Sample Number: 1409225-049 Customer Sample Number: 3038936 Project: LCR
Location: 1st draw 5923 33RD ST NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 7:09 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.025 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.120 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0015 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1409225-050

SAMPLE INFORMATION

Sample Number: 1409225-050 Customer Sample Number: 3038936 Project: LCR
Location: 2nd draw 5923 33RD ST NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 7:11 Sampler: HOME OWNER Received Date and Time: 9/30/2014 10:26:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.024 mg/L	10/16/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.072 mg/L	10/16/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0019 mg/L	10/16/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-001

SAMPLE INFORMATION

Sample Number: 1410228-001 Customer Sample Number: 3002525 Project: LCR
Location: 1st draw 1453 S ST NW Type: Dist.

Collection Date: 10/30/2014 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.015 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.067 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-002

SAMPLE INFORMATION

Sample Number: 1410228-002 Customer Sample Number: 3002525 Project: LCR
Location: 2nd draw 1453 S ST NW Type: Dist.

Collection Date: 10/30/2014 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.014 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-003

SAMPLE INFORMATION

Sample Number: 1410228-003 Customer Sample Number: 3010160 Project: LCR
Location: 1st draw 2212 38TH ST NW Type: Dist.

Collection Date: 10/30/2014 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.021 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.038 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-004

SAMPLE INFORMATION

Sample Number: 1410228-004 Customer Sample Number: 3010160 Project: LCR
Location: 2nd draw 2212 38TH ST NW Type: Dist.

Collection Date: 10/30/2014 Collection Time: 6:07 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.045 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0053 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-005

SAMPLE INFORMATION

Sample Number: 1410228-005 Customer Sample Number: 3130077 Project: LCR
Location: 1st draw 223 14TH PL NE Type: Dist.

Collection Date: 10/28/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.053 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.029 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0327 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-006

SAMPLE INFORMATION

Sample Number: 1410228-006 Customer Sample Number: 3130077 Project: LCR
Location: 2nd draw 223 14TH PL NE Type: Dist.

Collection Date: 10/28/2014 Collection Time: 7:31 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.102 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.035 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0108 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-007

SAMPLE INFORMATION

Sample Number: 1410228-007 Customer Sample Number: 3072261 Project: LCR
Location: 1st draw 413 4TH ST SE Type: Dist.

Collection Date: 10/29/2014 Collection Time: 5:34 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.050 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.023 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-008

SAMPLE INFORMATION

Sample Number: 1410228-008 Customer Sample Number: 3072261 Project: LCR
Location: 2nd draw 413 4TH ST SE Type: Dist.

Collection Date: 10/29/2014 Collection Time: 5:36 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.030 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.037 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-009

SAMPLE INFORMATION

Sample Number: 1410228-009 Customer Sample Number: 3006873 Project: LCR
Location: 1st draw 53 P ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.042 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-010

SAMPLE INFORMATION

Sample Number: 1410228-010 Customer Sample Number: 3006873 Project: LCR
Location: 2nd draw 53 P ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.050 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-011

SAMPLE INFORMATION

Sample Number: 1410228-011 Customer Sample Number: 3087203 Project: LCR
Location: 1st draw 1319 POTOMAC AVE SE Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:07 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.035 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-012

SAMPLE INFORMATION

Sample Number: 1410228-012 Customer Sample Number: 3087203 Project: LCR
Location: 2nd draw 1319 POTOMAC AVE SE Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.022 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-013

SAMPLE INFORMATION

Sample Number: 1410228-013 Customer Sample Number: 3018911 Project: LCR
Location: 1st draw 1850 2ND ST NW Type: Dist.

Collection Date: 10/27/2014 Collection Time: 19:48 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.057 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-014

SAMPLE INFORMATION

Sample Number: 1410228-014 Customer Sample Number: 3018911 Project: LCR
Location: 2nd draw 1850 2ND ST NW Type: Dist.

Collection Date: 10/27/2014 Collection Time: 19:48 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.045 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0032 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-015

SAMPLE INFORMATION

Sample Number: 1410228-015 Customer Sample Number: 3103161 Project: LCR
Location: 1st draw 2408 2ND ST NE Type: Dist.

Collection Date: 10/28/2014 Collection Time: 23:08 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.037 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-016

SAMPLE INFORMATION

Sample Number: 1410228-016 Customer Sample Number: 3103161 Project: LCR
Location: 2nd draw 2408 2ND ST NE Type: Dist.

Collection Date: 10/28/2014 Collection Time: 23:09 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.050 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0078 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-017

SAMPLE INFORMATION

Sample Number: 1410228-017 Customer Sample Number: 3002494 Project: LCR
Location: 1st draw 1412 S ST NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.022 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.090 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-018

SAMPLE INFORMATION

Sample Number: 1410228-018 Customer Sample Number: 3002494 Project: LCR
Location: 2nd draw 1412 S ST NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.022 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.130 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-019

SAMPLE INFORMATION

Sample Number: 1410228-019 Customer Sample Number: 3029267 Project: LCR
Location: 1st draw 3907 13TH ST NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 18:55 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.032 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.127 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-020

SAMPLE INFORMATION

Sample Number: 1410228-020 Customer Sample Number: 3029267 Project: LCR
Location: 2nd draw 3907 13TH ST NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 18:57 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.039 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.076 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-021

SAMPLE INFORMATION

Sample Number: 1410228-021 Customer Sample Number: 3020687 Project: LCR
Location: 1st draw 3917 8TH ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.046 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.070 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0017 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-022

SAMPLE INFORMATION

Sample Number: 1410228-022 Customer Sample Number: 3020687 Project: LCR
Location: 2nd draw 3917 8TH ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:12 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.057 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.038 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-023

SAMPLE INFORMATION

Sample Number: 1410228-023 Customer Sample Number: 3044360 Project: LCR
Location: 1st draw 4409 LOWELL ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.351 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.025 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-024

SAMPLE INFORMATION

Sample Number: 1410228-024 Customer Sample Number: 3044360 Project: LCR
Location: 2nd draw 4409 LOWELL ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:54 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.060 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.019 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-025

SAMPLE INFORMATION

Sample Number: 1410228-025 Customer Sample Number: 3041213 Project: LCR
Location: 1st draw 3809 ALTON PL NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-026

SAMPLE INFORMATION

Sample Number: 1410228-026 Customer Sample Number: 3041213 Project: LCR
Location: 2nd draw 3809 ALTON PL NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:41 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-027

SAMPLE INFORMATION

Sample Number: 1410228-027 Customer Sample Number: 3030408 Project: LCR
Location: 1st draw 1412 SHEPHERD ST NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 19:10 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.245 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.020 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0035 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-028

SAMPLE INFORMATION

Sample Number: 1410228-028 Customer Sample Number: 3030408 Project: LCR
Location: 2nd draw 1412 SHEPHERD ST NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 19:11 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.142 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.021 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0043 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-029

SAMPLE INFORMATION

Sample Number: 1410228-029 Customer Sample Number: 3055102 Project: LCR
Location: 1st draw 3030 44TH ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.030 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.028 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0031 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-030

SAMPLE INFORMATION

Sample Number: 1410228-030 Customer Sample Number: 3055102 Project: LCR
Location: 2nd draw 3030 44TH ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:52 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.020 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.032 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0027 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-031

SAMPLE INFORMATION

Sample Number: 1410228-031 Customer Sample Number: 3049333 Project: LCR
Location: 1st draw 1353 JEFFERSON ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.042 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-032

SAMPLE INFORMATION

Sample Number: 1410228-032 Customer Sample Number: 3049333 Project: LCR
Location: 2nd draw 1353 JEFFERSON ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.035 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0022 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-033

SAMPLE INFORMATION

Sample Number: 1410228-033 Customer Sample Number: 3039888 Project: LCR
Location: 1st draw 5301 RENO RD NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 8:58 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.032 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-034

SAMPLE INFORMATION

Sample Number: 1410228-034 Customer Sample Number: 3039888 Project: LCR
Location: 2nd draw 5301 RENO RD NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 9:02 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.012 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-035

SAMPLE INFORMATION

Sample Number: 1410228-035 Customer Sample Number: 3002478 Project: LCR
Location: 1st draw 1436 S ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:08 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.164 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-036

SAMPLE INFORMATION

Sample Number: 1410228-036 Customer Sample Number: 3002478 Project: LCR
Location: 2nd draw 1436 S ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.028 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-037

SAMPLE INFORMATION

Sample Number: 1410228-037 Customer Sample Number: 3022580 Project: LCR
Location: 1st draw 4818 8TH ST NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 19:18 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.095 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410228-038

SAMPLE INFORMATION

Sample Number: 1410228-038 Customer Sample Number: 3022580 Project: LCR
Location: 2nd draw 4818 8TH ST NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 19:21 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:14:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.042 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411015-001

SAMPLE INFORMATION

Sample Number: 1411015-001 Customer Sample Number: 3103403 Project: LCR
Location: 1st draw 3416 9TH ST NE Type: Dist.

Collection Date: 10/28/2014 Collection Time: 6:29 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:48:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.025 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411015-002

SAMPLE INFORMATION

Sample Number: 1411015-002 Customer Sample Number: 3103403 Project: LCR
Location: 2nd draw 3416 9TH ST NE Type: Dist.

Collection Date: 10/28/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:48:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.050 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411015-003

SAMPLE INFORMATION

Sample Number: 1411015-003 Customer Sample Number: 3006813 Project: LCR
Location: 1st draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 3:40 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:48:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.192 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411015-004

SAMPLE INFORMATION

Sample Number: 1411015-004 Customer Sample Number: 3006813 Project: LCR
Location: 2nd draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 3:42 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:48:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.022 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411015-005

SAMPLE INFORMATION

Sample Number: 1411015-005 Customer Sample Number: 3039291 Project: LCR
Location: 1st draw 3722 MCKINLEY ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:48:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.207 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411015-006

SAMPLE INFORMATION

Sample Number: 1411015-006 Customer Sample Number: 3039291 Project: LCR
Location: 2nd draw 3722 MCKINLEY ST NW Type: Dist.

Collection Date: 10/29/2014 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:48:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.022 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411015-007

SAMPLE INFORMATION

Sample Number: 1411015-007 Customer Sample Number: 3106057 Project: LCR
Location: 1st draw 1808 KEARNEY ST NE Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:01 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:48:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.056 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.108 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411015-008

SAMPLE INFORMATION

Sample Number: 1411015-008 Customer Sample Number: 3106057 Project: LCR
Location: 2nd draw 1808 KEARNEY ST NE Type: Dist.

Collection Date: 10/29/2014 Collection Time: 7:07 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:48:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.038 mg/L	11/12/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.066 mg/L	11/12/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	11/12/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411105-001

SAMPLE INFORMATION

Sample Number: 1411105-001 Customer Sample Number: 3008069 Project: LCR
Location: 1st draw 3036 P ST NW Type: Dist.

Collection Date: 11/9/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:07:36 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	11/18/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.051 mg/L	11/18/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	11/18/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411105-002

SAMPLE INFORMATION

Sample Number: 1411105-002 Customer Sample Number: 3008069 Project: LCR
Location: 2nd draw 3036 P ST NW Type: Dist.

Collection Date: 11/9/2014 Collection Time: 7:32 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:07:36 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.015 mg/L	11/18/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	11/18/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	11/18/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-001 Customer Sample Number: 3122857 Project: LCR
Location: 1st draw 923 9TH ST., NE Type: Dist.

Collection Date: 11/18/2014 Collection Time: 8:50 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.101 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0029 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-002 Customer Sample Number: 3122857 Project: LCR
Location: 2nd draw 923 9TH ST., NE Type: Dist.

Collection Date: 11/18/2014 Collection Time: 8:55 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.016 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.080 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0039 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-003 Customer Sample Number: 3051041 Project: LCR
Location: 1st draw 4002 ILLINOIS AVE., NW Type: Dist.

Collection Date: 11/19/2014 Collection Time: 4:45 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.012 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-004 Customer Sample Number: 3051041 Project: LCR
Location: 2nd draw 4002 ILLINOIS AVE., NW Type: Dist.

Collection Date: 11/19/2014 Collection Time: 4:45 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.016 mg/L	12/11/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	12/11/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0035 mg/L	12/11/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-005 Customer Sample Number: 3040469 Project: LCR
Location: 1st draw 3807 KANAWHA ST., NW Type: Dist.

Collection Date: 11/19/2014 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.135 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.072 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-006 Customer Sample Number: 3040469 Project: LCR
Location: 2nd draw 3807 KANAWHA ST., NW Type: Dist.

Collection Date: 11/19/2014 Collection Time: 6:22 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.121 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-007 Customer Sample Number: 3122831 Project: LCR
Location: 1st draw 905 KENT PL NE Type: Dist.

Collection Date: 11/17/2014 Collection Time: 16:55 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.070 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.018 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	12/10/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-008 Customer Sample Number: 3122831 Project: LCR
Location: 2nd draw 905 KENT PL NE Type: Dist.

Collection Date: 11/17/2014 Collection Time: 16:58 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.100 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.011 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-009 Customer Sample Number: 3029819 Project: LCR
Location: 1st draw 3405 HOLMEAD PL., NW Type: Dist.

Collection Date: 11/18/2014 Collection Time: 6:19 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.043 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.042 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-010 Customer Sample Number: 3029819 Project: LCR
Location: 2nd draw 3405 HOLMEAD PL., NW Type: Dist.

Collection Date: 11/18/2014 Collection Time: 6:21 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0033 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/11/2014
Report Number: LC-W1411160-011

SAMPLE INFORMATION

Sample Number: 1411160-011 Customer Sample Number: 3020804 Project: LCR
Location: 1st draw 3916 5TH ST., NW Type: Dist.

Collection Date: 11/18/2014 Collection Time: 7:24 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-012 Customer Sample Number: 3020804 Project: LCR
Location: 2nd draw 3916 5TH ST., NW Type: Dist.

Collection Date: 11/18/2014 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.013 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-013 Customer Sample Number: 3040167 Project: LCR
Location: 1st draw 4233 JENIFER ST., NW Type: Dist.

Collection Date: 11/18/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.039 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-014 Customer Sample Number: 3040167 Project: LCR
Location: 2nd draw 4233 JENIFER ST., NW Type: Dist.

Collection Date: 11/18/2014 Collection Time: 18:01 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.019 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/11/2014
Report Number: LC-W1411160-015

SAMPLE INFORMATION

Sample Number: 1411160-015 Customer Sample Number: 3108737 Project: LCR
Location: 1st draw 4014 GRANT ST., NE Type: Dist.

Collection Date: 11/19/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.067 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-016 Customer Sample Number: 3108737 Project: LCR
Location: 2nd draw 4014 GRANT ST., NE Type: Dist.

Collection Date: 11/19/2014 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	12/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/11/2014
Report Number: LC-W1411160-017

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411160-017 Customer Sample Number: 3076112 Project: LCR
Location: 1st draw 1736 BAY ST SE Type: Dist.

Collection Date: 11/17/2014 Collection Time: 16:08 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.111 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/11/2014
Report Number: LC-W1411160-018

SAMPLE INFORMATION

Sample Number: 1411160-018 Customer Sample Number: 3076112 Project: LCR
Location: 2nd draw 1736 BAY ST SE Type: Dist.

Collection Date: 11/17/2014 Collection Time: 16:10 Sampler: HOME OWNER Received Date and Time: 11/21/2014 10:43:13 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.027 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.046 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/11/2014
Report Number: LC-W1411189-001

SAMPLE INFORMATION

Sample Number: 1411189-001 Customer Sample Number: 3101976 Project: LCR
Location: 1st draw 1339 CHILDRESS ST NE Type: Dist.

Collection Date: 11/19/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 11/25/2014 3:33:26 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.119 mg/L	12/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	12/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	12/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/11/2014
Date

Attachment 2

Other Additional Non-Regulated Monitoring Data

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406182-001

SAMPLE INFORMATION

Sample Number: 1406182-001 Customer Sample Number: 3038974 Program: DS
Location: 1st draw 5700 32ND ST NW Type: Dist.

Collection Date: 6/18/2014 Collection Time: 21:08 Sampler: HOME OWNER Received Date and Time: 6/24/2014 8:58:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	1.2 ug/L	6/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406182-002

SAMPLE INFORMATION

Sample Number: 1406182-002 Customer Sample Number: 3038974 Program: DS
Location: 2nd draw 5700 32ND ST NW Type: Dist.

Collection Date: 6/18/2014 Collection Time: 21:14 Sampler: HOME OWNER Received Date and Time: 6/24/2014 8:58:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	6/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 7/9/2014
Report Number: LC-W1406216-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1406216-001 Customer Sample Number: 3020832 Program: DS
Location: 1st Draw 417 SHEPHERD ST Type: Dist.
Collection Date: 6/22/2014 Collection Time: 21:42 Sampler: HOME OWNER Received Date and Time: 6/27/2014 11:31:49 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	1.0 ug/L	7/2/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 7/9/2014
Report Number: LC-W1406216-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1406216-002 Customer Sample Number: 3020832 Program: DS
Location: 2nd Draw 417 SHEPHERD ST Type: Dist.

Collection Date: 6/22/2014 Collection Time: 21:45 Sampler: HOME OWNER Received Date and Time: 6/27/2014 11:31:49 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 7/9/2014
Report Number: LC-W1406216-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1406216-003 Customer Sample Number: 3047628 Program: DS
Location: 1st Draw 8030 14TH ST NW Type: Dist.

Collection Date: 6/22/2014 Collection Time: 10:10 Sampler: HOME OWNER Received Date and Time: 6/27/2014 11:31:49 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 7/9/2014
Report Number: LC-W1406216-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1406216-004 Customer Sample Number: 3047628 Program: DS
Location: 2nd Draw 8030 14TH ST NW Type: Dist.

Collection Date: 6/22/2014 Collection Time: 10:15 Sampler: HOME OWNER Received Date and Time: 6/27/2014 11:31:49 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 7/9/2014
Report Number: LC-W1406216-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1406216-005 Customer Sample Number: 3035078 Program: DS
Location: 1st Draw 2815 38TH ST NW Type: Dist.

Collection Date: 6/24/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 6/27/2014 11:31:49 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 7/9/2014
Report Number: LC-W1406216-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1406216-006 Customer Sample Number: 3035078 Program: DS
Location: 2nd Draw 2815 38TH ST NW Type: Dist.

Collection Date: 6/24/2014 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 6/27/2014 11:31:49 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-001

SAMPLE INFORMATION

Sample Number: 1407131-001 Customer Sample Number: 3074446 Program: DS
Location: 1st draw 1349 S. CAROLINA AVE SE Type: Dist.

Collection Date: 7/7/2014 Collection Time: 6:26 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-002

SAMPLE INFORMATION

Sample Number: 1407131-002 Customer Sample Number: 3074446 Program: DS
Location: 2nd draw 1349 S. CAROLINA AVE SE Type: Dist.

Collection Date: 7/7/2014 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-003

SAMPLE INFORMATION

Sample Number: 1407131-003 Customer Sample Number: 3017906 Program: DS
Location: 1st draw 78 S ST NW Type: Dist.

Collection Date: 7/7/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-004

SAMPLE INFORMATION

Sample Number: 1407131-004 Customer Sample Number: 3017906 Program: DS
Location: 2nd draw 78 S ST NW Type: Dist.

Collection Date: 7/7/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-005

SAMPLE INFORMATION

Sample Number: 1407131-005 Customer Sample Number: 3041828 Program: DS
Location: 1st draw 3514 34TH ST NW Type: Dist.
Collection Date: 7/7/2014 Collection Time: 19:15 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-006

SAMPLE INFORMATION

Sample Number: 1407131-006 Customer Sample Number: 3041828 Program: DS
Location: 2nd draw 3514 34TH ST NW Type: Dist.

Collection Date: 7/7/2014 Collection Time: 19:20 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-009

SAMPLE INFORMATION

Sample Number: 1407131-009 Customer Sample Number: Program: DS
Location: 1st draw 1935 39TH ST NW Type: Dist.
Collection Date: 7/15/2014 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-010

SAMPLE INFORMATION

Sample Number: 1407131-010 Customer Sample Number: Program: DS
Location: 2nd draw 1935 39TH ST NW Type: Dist.

Collection Date: 7/15/2014 Collection Time: 6:56 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407144-001

SAMPLE INFORMATION

Sample Number: 1407144-001 Customer Sample Number: 3021576 Program: DS
Location: 1st draw 4403 5TH ST NW Type: Dist.

Collection Date: 7/16/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 7/21/2014 10:39:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	6.4 ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407144-002

SAMPLE INFORMATION

Sample Number: 1407144-002 Customer Sample Number: 3021576 Program: DS
Location: 2nd draw 4403 5TH ST NW Type: Dist.

Collection Date: 7/16/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 7/21/2014 10:39:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	6.0 ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407144-003

SAMPLE INFORMATION

Sample Number: 1407144-003 Customer Sample Number: 3030703 Program: DS
Location: 1st draw 3304 BROWN ST NW Type: Dist.

Collection Date: 7/16/2014 Collection Time: 8:22 Sampler: HOME OWNER Received Date and Time: 7/21/2014 10:39:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407144-004

SAMPLE INFORMATION

Sample Number: 1407144-004 Customer Sample Number: 3030703 Program: DS
Location: 2nd draw 3304 BROWN ST NW Type: Dist.

Collection Date: 7/16/2014 Collection Time: 8:27 Sampler: HOME OWNER Received Date and Time: 7/21/2014 10:39:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407144-005

SAMPLE INFORMATION

Sample Number: 1407144-005 Customer Sample Number: 3029288 Program: DS
Location: 1st draw 1210 SHEPHERD ST NW Type: Dist.
Collection Date: 7/9/2014 Collection Time: 6:44 Sampler: HOME OWNER Received Date and Time: 7/21/2014 10:39:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.2 ug/L	7/23/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407144-006

SAMPLE INFORMATION

Sample Number: 1407144-006 Customer Sample Number: 3029288 Program: DS
Location: 2nd draw 1210 SHEPHERD ST NW Type: Dist.

Collection Date: 7/9/2014 Collection Time: 6:47 Sampler: HOME OWNER Received Date and Time: 7/21/2014 10:39:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	7/23/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407175-001

SAMPLE INFORMATION

Sample Number: 1407175-001 Customer Sample Number: 3120335 Program: DS
Location: 1st draw 4302 12TH PL NE Type: Dist.

Collection Date: 7/20/2014 Collection Time: 8:25 Sampler: HOME OWNER Received Date and Time: 7/23/2014 3:56:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	7/24/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407175-002

SAMPLE INFORMATION

Sample Number: 1407175-002 Customer Sample Number: 3120335 Program: DS
Location: 2nd draw 4302 12TH PL NE Type: Dist.

Collection Date: 7/20/2014 Collection Time: 8:27 Sampler: HOME OWNER Received Date and Time: 7/23/2014 3:56:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	7/24/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407188-001

SAMPLE INFORMATION

Sample Number: 1407188-001 Customer Sample Number: 3019622 Program: DS
Location: 1st draw 651 IRVING ST NW Type: Dist.

Collection Date: 7/20/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/25/2014 7:55:01 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.1 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407188-002

SAMPLE INFORMATION

Sample Number: 1407188-002 Customer Sample Number: 3019622 Program: DS
Location: 2nd draw 651 IRVING ST NW Type: Dist.

Collection Date: 7/20/2014 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 7/25/2014 7:55:01 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.8 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407188-003

SAMPLE INFORMATION

Sample Number: 1407188-003 Customer Sample Number: 3111684 Program: DS
Location: 1st draw 331 7TH ST NW Type: Dist.

Collection Date: 7/21/2014 Collection Time: 19:53 Sampler: HOME OWNER Received Date and Time: 7/25/2014 7:55:01 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407188-004

SAMPLE INFORMATION

Sample Number: 1407188-004 Customer Sample Number: 3111684 Program: DS
Location: 2nd draw 331 7TH ST NW Type: Dist.

Collection Date: 7/21/2014 Collection Time: 19:56 Sampler: HOME OWNER Received Date and Time: 7/25/2014 7:55:01 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407207-001

SAMPLE INFORMATION

Sample Number: 1407207-001 Customer Sample Number: 3058288 Program: DS
Location: 1st draw 4630 30TH ST NW Type: Dist.

Collection Date: 7/23/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/28/2014 3:41:10 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407207-002

SAMPLE INFORMATION

Sample Number: 1407207-002 Customer Sample Number: 3058288 Program: DS
Location: 2nd draw 4630 30TH ST NW Type: Dist.

Collection Date: 7/23/2014 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 7/28/2014 3:41:10 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	6.5 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407207-003

SAMPLE INFORMATION

Sample Number: 1407207-003 Customer Sample Number: 3146982 Program: DS
Location: 1st draw 3422 R ST NW Type: Dist.

Collection Date: 7/23/2014 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 7/28/2014 3:41:10 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	8.8 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407207-004

SAMPLE INFORMATION

Sample Number: 1407207-004 Customer Sample Number: 3146982 Program: DS
Location: 2nd draw 3422 R ST NW Type: Dist.

Collection Date: 7/23/2014 Collection Time: 9:35 Sampler: HOME OWNER Received Date and Time: 7/28/2014 3:41:10 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.6 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407207-005

SAMPLE INFORMATION

Sample Number: 1407207-005 Customer Sample Number: 3126194 Program: DS
Location: 1st draw 101 8TH ST NW APT 2 Type: Dist.

Collection Date: 7/24/2014 Collection Time: 4:45 Sampler: HOME OWNER Received Date and Time: 7/28/2014 3:41:10 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407207-006

SAMPLE INFORMATION

Sample Number: 1407207-006 Customer Sample Number: 3126494 Program: DS
Location: 2nd draw 101 8TH ST NW APT 2 Type: Dist.

Collection Date: 7/24/2014 Collection Time: 4:47 Sampler: HOME OWNER Received Date and Time: 7/28/2014 3:41:10 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407217-001

SAMPLE INFORMATION

Sample Number: 1407217-001 Customer Sample Number: 3029358 Program: DS
Location: 1st Draw 934 SHEPHERD ST. NW Type: Dist.

Collection Date: 7/25/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 7/29/2014 3:44:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.1 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407217-002

SAMPLE INFORMATION

Sample Number: 1407217-002 Customer Sample Number: 3029358 Program: DS
Location: 2nd Draw 934 SHEPHERD ST. NW Type: Dist.

Collection Date: 7/25/2014 Collection Time: 7:33 Sampler: HOME OWNER Received Date and Time: 7/29/2014 3:44:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	6.9 ug/L	7/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407228-003

SAMPLE INFORMATION

Sample Number: 1407228-003 Customer Sample Number: 3020862 Program: DS
Location: 1st draw 4005 4TH ST NW Type: Dist.

Collection Date: 7/26/2014 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 7/31/2014 12:16:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.0 ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407228-004

SAMPLE INFORMATION

Sample Number: 1407228-004 Customer Sample Number: 3020862 Program: DS
Location: 2nd draw 4005 4TH ST NW Type: Dist.

Collection Date: 7/26/2014 Collection Time: 17:46 Sampler: HOME OWNER Received Date and Time: 7/31/2014 12:16:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407228-005

SAMPLE INFORMATION

Sample Number: 1407228-005 Customer Sample Number: 3125386 Program: DS
Location: 1st draw 106 U ST NE Type: Dist.

Collection Date: 7/26/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/31/2014 12:16:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407228-006

SAMPLE INFORMATION

Sample Number: 1407228-006 Customer Sample Number: 3125386 Program: DS
Location: 2nd draw 106 U ST NE Type: Dist.

Collection Date: 7/26/2014 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 7/31/2014 12:16:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408028-001

SAMPLE INFORMATION

Sample Number: 1408028-001 Customer Sample Number: 3089489 Program: DS
Location: 1st Draw 1441 A ST SE Type: Dist.

Collection Date: 7/25/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:32:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408028-002

SAMPLE INFORMATION

Sample Number: 1408028-002 Customer Sample Number: 3089489 Program: DS
Location: 2nd Draw 1441 A ST SE Type: Dist.

Collection Date: 7/25/2014 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:32:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408028-003

SAMPLE INFORMATION

Sample Number: 1408028-003 Customer Sample Number: 3047291 Program: DS
Location: 1st Draw 1442 IRIS ST NW Type: Dist.

Collection Date: 7/29/2014 Collection Time: 20:45 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:32:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.1 ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408028-004

SAMPLE INFORMATION

Sample Number: 1408028-004 Customer Sample Number: 3047291 Program: DS
Location: 2nd Draw 1442 IRIS ST NW Type: Dist.

Collection Date: 7/29/2014 Collection Time: 20:58 Sampler: HOME OWNER Received Date and Time: 8/5/2014 9:32:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.2 ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408049-001

SAMPLE INFORMATION

Sample Number: 1408049-001 Customer Sample Number: 3099206 Program: DS
Location: 1st draw 1009 K ST NE Type: Dist.

Collection Date: 8/1/2014 Collection Time: 17:40 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:10:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408049-002

SAMPLE INFORMATION

Sample Number: 1408049-002 Customer Sample Number: 3099206 Program: DS
Location: 2nd draw 1009 K ST NE Type: Dist.

Collection Date: 8/1/2014 Collection Time: 17:42 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:10:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408049-005

SAMPLE INFORMATION

Sample Number: 1408049-005 Customer Sample Number: 3034539 Program: DS
Location: 1st draw 2325 ASHMEAD PL NW Type: Dist.

Collection Date: 8/5/2014 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:10:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408049-006

SAMPLE INFORMATION

Sample Number: 1408049-006 Customer Sample Number: 3034539 Program: DS
Location: 2nd draw 2325 ASHMEAD PL NW Type: Dist.

Collection Date: 8/5/2014 Collection Time: 8:17 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:10:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/21/2014
Report Number: LC-W1408112-001

SAMPLE INFORMATION

Sample Number: 1408112-001 Customer Sample Number: 3040588 Program: DS
Location: 1st Draw 3731 FESSENDEN ST, NW Type: Dist.

Collection Date: 8/7/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:28:35 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/14/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/21/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/21/2014
Report Number: LC-W1408112-002

SAMPLE INFORMATION

Sample Number: 1408112-002 Customer Sample Number: 3040588 Program: DS
Location: 2nd Draw 3731 FESSENDEN ST, NW Type: Dist.

Collection Date: 8/7/2014 Collection Time: 7:32 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:28:35 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/14/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/21/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/21/2014
Report Number: LC-W1408112-003

SAMPLE INFORMATION

Sample Number: 1408112-003 Customer Sample Number: 3123697 Program: DS
Location: 1st Draw 1230 WYLIE ST NE Type: Dist.
Collection Date: 8/7/2014 Collection Time: 18:10 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:28:35 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	8/14/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/21/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/21/2014
Report Number: LC-W1408112-004

SAMPLE INFORMATION

Sample Number: 1408112-004 Customer Sample Number: 3123697 Program: DS
Location: 2nd Draw 1230 WYLIE ST NE Type: Dist.

Collection Date: 8/7/2014 Collection Time: 18:12 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:28:35 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	8/14/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/21/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408123-003

SAMPLE INFORMATION

Sample Number: 1408123-003 Customer Sample Number: 3123711 Program: DS
Location: 1st Draw 1257 WYLIE STREET NE Type: Dist.

Collection Date: 8/11/2014 Collection Time: 18:05 Sampler: HOME OWNER Received Date and Time: 8/15/2014 9:09:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408123-004

SAMPLE INFORMATION

Sample Number: 1408123-004 Customer Sample Number: 3123711 Program: DS
Location: 2nd Draw 1257 WYLIE STREET NE Type: Dist.

Collection Date: 8/11/2014 Collection Time: 18:05 Sampler: HOME OWNER Received Date and Time: 8/15/2014 9:09:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408145-001

SAMPLE INFORMATION

Sample Number: 1408145-001 Customer Sample Number: 3051759 Program: DS
Location: 1st draw 5113 NEW HAMPSHIRE AVE NW Type: Dist.
Collection Date: 8/13/2014 Collection Time: 6:24 Sampler: HOME OWNER Received Date and Time: 8/19/2014 8:44:36 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408145-002

SAMPLE INFORMATION

Sample Number: 1408145-002 Customer Sample Number: 3051759 Program: DS
Location: 2nd draw 5113 NEW HAMPSHIRE AVE NW Type: Dist.

Collection Date: 8/13/2014 Collection Time: 6:27 Sampler: HOME OWNER Received Date and Time: 8/19/2014 8:44:36 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408182-003

SAMPLE INFORMATION

Sample Number: 1408182-003 Customer Sample Number: 3044903 Program: DS
Location: 1st draw 4464 GREENWICH PKY NW Type: Dist.
Collection Date: 8/17/2014 Collection Time: 8:40 Sampler: HOME OWNER Received Date and Time: 8/22/2014 8:30:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408182-004

SAMPLE INFORMATION

Sample Number: 1408182-004 Customer Sample Number: 3044903 Program: DS
Location: 2nd draw 4464 GREENWICH PKY NW Type: Dist.

Collection Date: 8/17/2014 Collection Time: 8:42 Sampler: HOME OWNER Received Date and Time: 8/22/2014 8:30:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408182-005

SAMPLE INFORMATION

Sample Number: 1408182-005 Customer Sample Number: 3037696 Program: DS
Location: 1st draw 5901 32ND ST NW Type: Dist.

Collection Date: 8/18/2014 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 8/22/2014 8:30:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408182-006

SAMPLE INFORMATION

Sample Number: 1408182-006 Customer Sample Number: 3037696 Program: DS
Location: 2nd draw 5901 32ND ST NW Type: Dist.

Collection Date: 8/18/2014 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 8/22/2014 8:30:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-001

SAMPLE INFORMATION

Sample Number: 1408212-001 Customer Sample Number: 3098593 Program: DS
Location: 1st draw 12 5TH ST NE Type: Dist.

Collection Date: 8/18/2014 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	10.0 ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-002

SAMPLE INFORMATION

Sample Number: 1408212-002 Customer Sample Number: 3098593 Program: DS
Location: 2nd draw 12 5TH ST NE Type: Dist.

Collection Date: 8/18/2014 Collection Time: 6:29 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-003

SAMPLE INFORMATION

Sample Number: 1408212-003 Customer Sample Number: 3081004 Program: DS
Location: 1st draw 2106 16TH ST SE Type: Dist.

Collection Date: 8/20/2014 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	11.9 ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-004

SAMPLE INFORMATION

Sample Number: 1408212-004 Customer Sample Number: 3081004 Program: DS
Location: 2nd draw 2106 16TH ST SE Type: Dist.

Collection Date: 8/20/2014 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	16.8 ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-007

SAMPLE INFORMATION

Sample Number: 1408212-007 Customer Sample Number: 3001987 Program: DS
Location: 1st draw 1822 16TH ST NW Type: Dist.

Collection Date: 8/22/2014 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-008

SAMPLE INFORMATION

Sample Number: 1408212-008 Customer Sample Number: 3001987 Program: DS
Location: 2nd draw 1822 16TH ST NW Type: Dist.

Collection Date: 8/22/2014 Collection Time: 6:39 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-009

SAMPLE INFORMATION

Sample Number: 1408212-009 Customer Sample Number: 3103160 Program: DS
Location: 1st draw 2406 2ND ST NE Type: Dist.

Collection Date: 8/25/2014 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-010

SAMPLE INFORMATION

Sample Number: 1408212-010 Customer Sample Number: 3103160 Program: DS
Location: 2nd draw 2406 2ND ST NE Type: Dist.

Collection Date: 8/25/2014 Collection Time: 8:47 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408145-005

SAMPLE INFORMATION

Sample Number: 1408145-005 Customer Sample Number: Program: DS250
Location: 1st draw 3020 GAINESVILLE ST SE Type: Dist.
Collection Date: 8/16/2014 Collection Time: 2:35 Sampler: HOME OWNER Received Date and Time: 8/19/2014 8:44:36 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	8/26/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408145-006

SAMPLE INFORMATION

Sample Number: 1408145-006 Customer Sample Number: Program: DS250
Location: 2nd draw 3020 GAINESVILLE ST SE Type: Dist.

Collection Date: 8/16/2014 Collection Time: 2:35 Sampler: HOME OWNER Received Date and Time: 8/19/2014 8:44:36 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	8/26/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-003

SAMPLE INFORMATION

Sample Number: 1408235-003 Customer Sample Number: 3038174 Program: DS
Location: 1st draw 6217 WESTERN AVE NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 4:50 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	6.3 ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-004

SAMPLE INFORMATION

Sample Number: 1408235-004 Customer Sample Number: 3038174 Program: DS
Location: 2nd draw 6217 WESTERN AVE NW Type: Dist.

Collection Date: 8/27/2014 Collection Time: 4:50 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	6.7 ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-005

SAMPLE INFORMATION

Sample Number: 1408235-005 Customer Sample Number: 3036654 Program: DS
Location: 1st draw 3576 APPLETON ST NW Type: Dist.
Collection Date: 8/28/2014 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-006

SAMPLE INFORMATION

Sample Number: 1408235-006 Customer Sample Number: 3036654 Program: DS
Location: 2nd draw 3576 APPLETON ST NW Type: Dist.

Collection Date: 8/28/2014 Collection Time: 6:18 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-007

SAMPLE INFORMATION

Sample Number: 1408235-007 Customer Sample Number: 3035275 Program: DS
Location: 1st draw 3211 IDAHO AVE NW Type: Dist.

Collection Date: 8/28/2014 Collection Time: 15:13 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.1 ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-008

SAMPLE INFORMATION

Sample Number: 1408235-008 Customer Sample Number: 3035275 Program: DS
Location: 2nd draw 3211 IDAHO AVE NW Type: Dist.

Collection Date: 8/28/2014 Collection Time: 15:15 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-009

SAMPLE INFORMATION

Sample Number: 1408235-009 Customer Sample Number: 3031475 Program: DS
Location: 1st draw 1823 LAMONT ST NW Type: Dist.
Collection Date: 8/28/2014 Collection Time: 18:14 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	9/5/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-010

SAMPLE INFORMATION

Sample Number: 1408235-010 Customer Sample Number: 3031475 Program: DS
Location: 2nd draw 1823 LAMONT ST NW Type: Dist.

Collection Date: 8/28/2014 Collection Time: 18:15 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.2 ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409029-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409029-001 Customer Sample Number: 3043997 Program: DS
Location: 1st draw 4200 FORDHAM RD NW Type: Dist.
Collection Date: 8/30/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 3:04:50 PM Received By: MChicoine

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/29/2014
Report Number: LC-W1409029-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1409029-002 Customer Sample Number: 3043997 Program: DS
Location: 2nd draw 4200 FORDHAM RD NW Type: Dist.
Collection Date: 8/30/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/3/2014 3:04:50 PM Received By: MChicoine

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409075-001

SAMPLE INFORMATION

Sample Number: 1409075-001 Customer Sample Number: 3003486 Program: DS
Location: 1st draw 2232 12TH PLACE NW Type: Dist.

Collection Date: 9/2/2014 Collection Time: 18:35 Sampler: HOME OWNER Received Date and Time: 9/9/2014 3:29:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409075-002

SAMPLE INFORMATION

Sample Number: 1409075-002 Customer Sample Number: 3003486 Program: DS
Location: 2nd draw 2232 12TH PLACE NW Type: Dist.

Collection Date: 9/2/2014 Collection Time: 18:38 Sampler: HOME OWNER Received Date and Time: 9/9/2014 3:29:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409075-004

SAMPLE INFORMATION

Sample Number: 1409075-004 Customer Sample Number: 3104676 Program: DS
Location: 2nd draw 4419 13TH ST NE Type: Dist.

Collection Date: 9/3/2014 Collection Time: 17:55 Sampler: HOME OWNER Received Date and Time: 9/9/2014 3:29:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-001

SAMPLE INFORMATION

Sample Number: 1409120-001 Customer Sample Number: 3038107 Program: DS
Location: 1st draw 3204 STEPHENSON PL NW Type: Dist.
Collection Date: 9/8/2014 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-002

SAMPLE INFORMATION

Sample Number: 1409120-002 Customer Sample Number: 3038107 Program: DS
Location: 2nd draw 3204 STEPHENSON PL NW Type: Dist.

Collection Date: 9/8/2014 Collection Time: 6:44 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-007

SAMPLE INFORMATION

Sample Number: 1409120-007 Customer Sample Number: 3097820 Program: DS
Location: 1st draw 620 3RD ST NE Type: Dist.

Collection Date: 9/9/2014 Collection Time: 5:19 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.8 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-008

SAMPLE INFORMATION

Sample Number: 1409120-008 Customer Sample Number: 3097820 Program: DS
Location: 2nd draw 620 3RD ST NE Type: Dist.

Collection Date: 9/9/2014 Collection Time: 5:22 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-011

SAMPLE INFORMATION

Sample Number: 1409120-011 Customer Sample Number: 3043566 Program: DS
Location: 1st draw 4510 BRANDYWINE ST NW Type: Dist.

Collection Date: 9/10/2014 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-012

SAMPLE INFORMATION

Sample Number: 1409120-012 Customer Sample Number: 3043566 Program: DS
Location: 2nd draw 4510 BRANDYWINE ST NW Type: Dist.

Collection Date: 9/10/2014 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.4 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409159-001

SAMPLE INFORMATION

Sample Number: 1409159-001 Customer Sample Number: 3008657 Program: DS
Location: 1st draw 3249 O ST. NW Type: Dist.

Collection Date: 9/12/2014 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 9/19/2014 11:50:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409159-002

SAMPLE INFORMATION

Sample Number: 1409159-002 Customer Sample Number: 3008567 Program: DS
Location: 2nd draw 3249 O ST. NW Type: Dist.

Collection Date: 9/12/2014 Collection Time: 8:11 Sampler: HOME OWNER Received Date and Time: 9/19/2014 11:50:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409159-003

SAMPLE INFORMATION

Sample Number: 1409159-003 Customer Sample Number: Program:
Location: 1st draw 1412 34TH STREET NW Type: Dist.

Collection Date: 9/17/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 9/19/2014 11:50:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409159-004

SAMPLE INFORMATION

Sample Number: 1409159-004 Customer Sample Number: Program:
Location: 2nd draw 1412 34TH STREET NW Type: Dist.

Collection Date: 9/17/2014 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 9/19/2014 11:50:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409184-001

SAMPLE INFORMATION

Sample Number: 1409184-001 Customer Sample Number: 3052536 Program: DS
Location: 1st draw 743 QUEBEC PL NW Type: Dist.

Collection Date: 9/10/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/23/2014 4:16:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409184-002

SAMPLE INFORMATION

Sample Number: 1409184-002 Customer Sample Number: 3052536 Program: DS
Location: 2nd draw 743 QUEBEC PL NW Type: Dist.

Collection Date: 9/10/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/23/2014 4:16:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.8 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409184-003

SAMPLE INFORMATION

Sample Number: 1409184-003 Customer Sample Number: 3042041 Program: DS
Location: 1st draw 4320 44TH ST NW Type: Dist.

Collection Date: 9/12/2014 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 9/23/2014 4:16:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409184-004

SAMPLE INFORMATION

Sample Number: 1409184-004 Customer Sample Number: 3042041 Program: DS
Location: 2nd draw 4320 44TH ST NW Type: Dist.

Collection Date: 9/12/2014 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 9/23/2014 4:16:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409188-001

SAMPLE INFORMATION

Sample Number: 1409188-001 Customer Sample Number: 3125801 Program: DS
Location: 1st draw 926 8TH ST NE Type: Dist.

Collection Date: 9/17/2014 Collection Time: 17:13 Sampler: HOME OWNER Received Date and Time: 9/24/2014 10:12:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409188-002

SAMPLE INFORMATION

Sample Number: 1409188-002 Customer Sample Number: 3125801 Program: DS
Location: 2nd draw 926 8TH ST NE Type: Dist.

Collection Date: 9/17/2014 Collection Time: 17:16 Sampler: HOME OWNER Received Date and Time: 9/24/2014 10:12:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409188-003

SAMPLE INFORMATION

Sample Number: 1409188-003 Customer Sample Number: 3109562 Program: DS
Location: 1st draw 5205 BLAINE ST NE Type: Dist.

Collection Date: 9/18/2014 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 9/24/2014 10:12:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409188-004

SAMPLE INFORMATION

Sample Number: 1409188-004 Customer Sample Number: 3109562 Program: DS
Location: 2nd draw 5205 BLAINE ST NE Type: Dist.

Collection Date: 9/18/2014 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 9/24/2014 10:12:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409188-005

SAMPLE INFORMATION

Sample Number: 1409188-005 Customer Sample Number: 3073741 Program: DS
Location: 1st draw 117 11TH ST SE Type: Dist.

Collection Date: 9/19/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 9/24/2014 10:12:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409188-006

SAMPLE INFORMATION

Sample Number: 1409188-006 Customer Sample Number: 3073741 Program: DS
Location: 2nd draw 117 11TH ST SE Type: Dist.

Collection Date: 9/19/2014 Collection Time: 7:19 Sampler: HOME OWNER Received Date and Time: 9/24/2014 10:12:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-005

SAMPLE INFORMATION

Sample Number: 1409210-005 Customer Sample Number: 3034617 Program: DS
Location: 1st Draw 1854 MINTWOOD PL NW #6 Type: Dist.
Collection Date: 9/23/2014 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/29/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-006

SAMPLE INFORMATION

Sample Number: 1409210-006 Customer Sample Number: 3034617 Program: DS
Location: 2nd Draw 1854 MINTWOOD PL NW #6 Type: Dist.

Collection Date: 9/23/2014 Collection Time: 7:44 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-009

SAMPLE INFORMATION

Sample Number: 1409210-009 Customer Sample Number: 3020187 Program: DS
Location: 1st Draw 627 OTIS PL NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 15:50 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-010

SAMPLE INFORMATION

Sample Number: 1409210-010 Customer Sample Number: 3020187 Program: DS
Location: 2nd Draw 627 OTIS PL NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 15:53 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.6 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410044-001

SAMPLE INFORMATION

Sample Number: 1410044-001 Customer Sample Number: 3044740 Program: DS
Location: 1st Draw 1433 44TH ST NW Type: Dist.

Collection Date: 10/1/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/7/2014 12:22:13 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410044-002

SAMPLE INFORMATION

Sample Number: 1410044-002 Customer Sample Number: 3044740 Program: DS
Location: 1st Draw 1433 44TH ST NW Type: Dist.

Collection Date: 10/1/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 10/7/2014 12:22:13 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-003

SAMPLE INFORMATION

Sample Number: 1410058-003 Customer Sample Number: 3047976 Program: DS
Location: 1st draw 1338 GERANIUM ST NW Type: Dist.
Collection Date: 10/2/2014 Collection Time: 17:22 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.9 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-004

SAMPLE INFORMATION

Sample Number: 1410058-004 Customer Sample Number: 3047976 Program: DS
Location: 2nd draw 1338 GERANIUM ST NW Type: Dist.

Collection Date: 10/2/2014 Collection Time: 17:25 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	11.6 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-005

SAMPLE INFORMATION

Sample Number: 1410058-005 Customer Sample Number: 3103208 Program: DS
Location: 1st draw 2405 3RD ST NE Type: Dist.

Collection Date: 10/5/2014 Collection Time: 10:00 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-006

SAMPLE INFORMATION

Sample Number: 1410058-006 Customer Sample Number: 3103208 Program: DS
Location: 2nd draw 2405 3RD ST NE Type: Dist.

Collection Date: 10/5/2014 Collection Time: 10:05 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	5.7 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-007

SAMPLE INFORMATION

Sample Number: 1410058-007 Customer Sample Number: 3114597 Program: DS
Location: 1st draw 1701 HOLBROOK ST NE Type: Dist.
Collection Date: 10/5/2014 Collection Time: 12:00 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-008

SAMPLE INFORMATION

Sample Number: 1410058-008 Customer Sample Number: 3114597 Program: DS
Location: 2nd draw 1701 HOLBROOK ST NE Type: Dist.

Collection Date: 10/5/2014 Collection Time: 12:02 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/23/2014
Report Number: LC-W1410080-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-003 Customer Sample Number: 3015844 Program: DS
Location: 1st Draw 1822 FLORIDA AVE NW Type: Dist.
Collection Date: 10/1/2014 Collection Time: 6:37 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/23/2014
Report Number: LC-W1410080-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-004 Customer Sample Number: 3015844 Program: DS
Location: 2nd Draw 1822 FLORIDA AVE NW Type: Dist.
Collection Date: 10/1/2014 Collection Time: 6:41 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/23/2014
Report Number: LC-W1410080-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-007 Customer Sample Number: 3042026 Program: DS
Location: 1st Draw 4433 YUMA ST. NW Type: Dist.
Collection Date: 10/7/2014 Collection Time: 5:10 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/23/2014
Report Number: LC-W1410080-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-008 Customer Sample Number: 3042026 Program: DS
Location: 2nd Draw 4433 YUMA ST. NW Type: Dist.
Collection Date: 10/7/2014 Collection Time: 5:12 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/23/2014
Report Number: LC-W1410080-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-009 Customer Sample Number: 3027782 Program: DS
Location: 1st Draw 1814 LAMONT ST NW Type: Dist.
Collection Date: 10/8/2014 Collection Time: 6:00 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/23/2014
Report Number: LC-W1410080-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-010 Customer Sample Number: 3027782 Program: DS
Location: 2nd Draw 1814 LAMONT ST NW Type: Dist.
Collection Date: 10/8/2014 Collection Time: 6:05 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1409075-003

SAMPLE INFORMATION

Sample Number: 1409075-003 Customer Sample Number: 3104676 Program: DS
Location: 1st draw 4419 13TH ST NE Type: Dist.

Collection Date: 9/3/2014 Collection Time: 17:53 Sampler: HOME OWNER Received Date and Time: 9/9/2014 3:29:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	11.2 ug/L	10/3/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1409230-001

SAMPLE INFORMATION

Sample Number: 1409230-001 Customer Sample Number: 3036146 Program: DS
Location: 1st Draw 3409 ASHLEY TERRACE, NW Type: Dist.

Collection Date: 9/26/2014 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 9/30/2014 1:00:30 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1409230-002

SAMPLE INFORMATION

Sample Number: 1409230-002 Customer Sample Number: 3036146 Program: DS
Location: 2nd Draw 3409 ASHLEY TERRACE, NW Type: Dist.

Collection Date: 9/26/2014 Collection Time: 7:43 Sampler: HOME OWNER Received Date and Time: 9/30/2014 1:00:30 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-003

SAMPLE INFORMATION

Sample Number: 1410021-003 Customer Sample Number: 3053158 Program: DS
Location: 1st Draw 5318 BROAD BRANCH RD NW Type: Dist.

Collection Date: 9/27/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.1 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-004

SAMPLE INFORMATION

Sample Number: 1410021-004 Customer Sample Number: 3053158 Program: DS
Location: 2nd Draw 5318 BROAD BRANCH RD NW Type: Dist.

Collection Date: 9/27/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	12.2 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-005

SAMPLE INFORMATION

Sample Number: 1410021-005 Customer Sample Number: 3040438 Program: DS
Location: 1st Draw 3803 JENIFER ST. NW Type: Dist.

Collection Date: 9/27/2014 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.0 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-006

SAMPLE INFORMATION

Sample Number: 1410021-006 Customer Sample Number: 3040438 Program: DS
Location: 2nd Draw 3803 JENIFER ST. NW Type: Dist.

Collection Date: 9/27/2014 Collection Time: 8:05 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	6.5 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-007

SAMPLE INFORMATION

Sample Number: 1410021-007 Customer Sample Number: 3080789 Program: DS
Location: 1st Draw 3005 30TH ST. SE Type: Dist.

Collection Date: 9/27/2014 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-008

SAMPLE INFORMATION

Sample Number: 1410021-008 Customer Sample Number: 3080789 Program: DS
Location: 2nd Draw 3005 30TH ST. SE Type: Dist.

Collection Date: 9/27/2014 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-009

SAMPLE INFORMATION

Sample Number: 1410021-009 Customer Sample Number: 3030593 Program: DS
Location: 1st Draw 1459 MONROE ST NW Type: Dist.

Collection Date: 9/29/2014 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.1 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-010

SAMPLE INFORMATION

Sample Number: 1410021-010 Customer Sample Number: 3030593 Program: DS
Location: 2nd Draw 1459 MONROE ST NW Type: Dist.

Collection Date: 9/29/2014 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/28/2014
Report Number: LC-W1410080-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-001 Customer Sample Number: 3029731 Program: DS
Location: 1st Draw 1017 MONROE ST NW APT 1 Type: Dist.
Collection Date: 9/28/2014 Collection Time: 6:10 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/28/2014
Report Number: LC-W1410080-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-002 Customer Sample Number: 3029731 Program: DS
Location: 2nd Draw 1017 MONROE ST NW APT 1 Type: Dist.
Collection Date: 9/28/2014 Collection Time: 6:11 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-001 Customer Sample Number: 3113466 Program: DS
Location: 1st draw 4116 12TH ST NE Type: Dist.

Collection Date: 10/7/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-002 Customer Sample Number: 3113466 Program: DS
Location: 2nd draw 4116 12TH ST NE Type: Dist.
Collection Date: 10/7/2014 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-003 Customer Sample Number: 3056401 Program: DS
Location: 1st draw 3006 45TH ST NW Type: Dist.
Collection Date: 10/7/2014 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.6 ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-004 Customer Sample Number: 3056401 Program: DS
Location: 2nd draw 3006 45TH ST NW Type: Dist.
Collection Date: 10/7/2014 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.0 ug/L	10/21/2017	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-005 Customer Sample Number: 3036148 Program: DS
Location: 1st draw 3415 ASHLEY TERR NW Type: Dist.
Collection Date: 10/12/2014 Collection Time: 16:57 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	10/21/2017	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-006 Customer Sample Number: 3036148 Program: DS
Location: 2nd draw 3415 ASHLEY TERR NW Type: Dist.
Collection Date: 10/12/2014 Collection Time: 16:59 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-009 Customer Sample Number: 3123326 Program: DS
Location: 1st draw 3321 18TH ST NE Type: Dist.
Collection Date: 10/14/2014 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	5.8 ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-010 Customer Sample Number: 3123326 Program: DS
Location: 2nd draw 3321 18TH ST NE Type: Dist.
Collection Date: 10/14/2014 Collection Time: 6:28 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-011 Customer Sample Number: 3100067 Program: DS
Location: 1st draw 1309 F ST NE Type: Dist.
Collection Date: 10/14/2014 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-012 Customer Sample Number: 3100067 Program: DS
Location: 2nd draw 1309 F ST NE Type: Dist.
Collection Date: 10/14/2014 Collection Time: 8:03 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-001 Customer Sample Number: 3042499 Program: DS
Location: 1st draw 4420 CHESAPEAKE ST., NW Type: Dist.

Collection Date: 10/20/2014 Collection Time: 7:09 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-002 Customer Sample Number: 3042499 Program: DS
Location: 2nd draw 4420 CHESAPEAKE ST., NW Type: Dist.
Collection Date: 10/20/2014 Collection Time: 7:13 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-003 Customer Sample Number: 3103915 Program: DS
Location: 1st draw 1235 OTIS ST., NE Type: Dist.
Collection Date: 10/16/2014 Collection Time: 15:10 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-004 Customer Sample Number: 3103915 Program: DS
Location: 2nd draw 1235 OTIS ST., NE Type: Dist.
Collection Date: 10/16/2014 Collection Time: 15:12 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-005 Customer Sample Number: 3110431 Program: DS
Location: 1st draw 1017 48TH ST., NE Type: Dist.
Collection Date: 10/22/2014 Collection Time: 8:44 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1410187-006 Customer Sample Number: 3110431 Program: DS
Location: 2nd draw 1017 48TH ST., NE Type: Dist.

Collection Date: 10/22/2014 Collection Time: 8:48 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-007 Customer Sample Number: 3038992 Program: DS
Location: 1st draw 3214 QUESADA ST., NW Type: Dist.
Collection Date: 10/20/2014 Collection Time: 17:40 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-008 Customer Sample Number: 3038992 Program: DS
Location: 2nd draw 3214 QUESADA ST., NW Type: Dist.
Collection Date: 10/20/2014 Collection Time: 17:44 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-009 Customer Sample Number: 3103981 Program: DS
Location: 1st draw 1244 GIRARD ST., NE Type: Dist.
Collection Date: 10/21/2014 Collection Time: 18:53 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	5.4 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-010 Customer Sample Number: 3103981 Program: DS
Location: 2nd draw 1244 GIRARD ST., NE Type: Dist.
Collection Date: 10/21/2014 Collection Time: 18:54 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	7.0 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-011 Customer Sample Number: 3125311 Program: DS
Location: 1st draw 124 U ST., NE Type: Dist.
Collection Date: 10/14/2014 Collection Time: 9:50 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority

Report Date: 11/26/2014
Report Number: LC-W1410187-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410187-012 Customer Sample Number: 3125311 Program: DS
Location: 2nd draw 124 U ST., NE Type: Dist.

Collection Date: 10/14/2014 Collection Time: 9:52 Sampler: HOMEOWNER Received Date and Time: 10/24/2014 12:21:52 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.9 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410229-001

SAMPLE INFORMATION

Sample Number: 1410229-001 Customer Sample Number: 3009868 Program: DS
Location: 1st draw 2016 TUNLAN RD NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:39:23 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410229-002

SAMPLE INFORMATION

Sample Number: 1410229-002 Customer Sample Number: 3009868 Program: DS
Location: 2nd draw 2016 TUNLAN RD NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:39:23 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410229-005

SAMPLE INFORMATION

Sample Number: 1410229-005 Customer Sample Number: 3055961 Program: DS
Location: 1st draw 4227 46TH ST NW Type: Dist.

Collection Date: 10/23/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:39:23 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410229-006

SAMPLE INFORMATION

Sample Number: 1410229-006 Customer Sample Number: 3055961 Program: DS
Location: 2nd draw 4227 46TH ST NW Type: Dist.

Collection Date: 10/23/2014 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:39:23 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411016-001

SAMPLE INFORMATION

Sample Number: 1411016-001 Customer Sample Number: 3095161 Program: DS250
Location: 1st draw 704 QUINCY ST NE APT. 2 Type: Dist.
Collection Date: 10/31/2014 Collection Time: 6:39 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:54:10 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411016-002

SAMPLE INFORMATION

Sample Number: 1411016-002 Customer Sample Number: 3095161 Program: DS250
Location: 2nd draw 704 QUINCY ST NE APT. 2 Type: Dist.

Collection Date: 10/31/2014 Collection Time: 6:41 Sampler: HOME OWNER Received Date and Time: 11/4/2014 8:54:10 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-003

SAMPLE INFORMATION

Sample Number: 1411106-003 Customer Sample Number: 3049910 Program: DS
Location: 1st draw 1310 DELAFIELD PL NW Type: Dist.
Collection Date: 11/5/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.2 ug/L	11/18/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/1/2014
Report Number: LC-W1411106-004

SAMPLE INFORMATION

Sample Number: 1411106-004 Customer Sample Number: 3049910 Program: DS
Location: 2nd draw 1310 DELAFIELD PL NW Type: Dist.

Collection Date: 11/5/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-005

SAMPLE INFORMATION

Sample Number: 1411106-005 Customer Sample Number: 3098822 Program: DS
Location: 1st draw 714 L ST NE Type: Dist.

Collection Date: 11/10/2014 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-006

SAMPLE INFORMATION

Sample Number: 1411106-006 Customer Sample Number: 3098822 Program: DS
Location: 2nd draw 714 L ST NE Type: Dist.

Collection Date: 11/10/2014 Collection Time: 6:08 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/26/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-007

SAMPLE INFORMATION

Sample Number: 1411106-007 Customer Sample Number: 3045932 Program: DS
Location: 1st draw 5136 MACOMB ST NW Type: Dist.

Collection Date: 11/4/2014 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-008

SAMPLE INFORMATION

Sample Number: 1411106-008 Customer Sample Number: 3045932 Program: DS
Location: 2nd draw 5136 MACOMB ST NW Type: Dist.

Collection Date: 11/4/2014 Collection Time: 5:44 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-009

SAMPLE INFORMATION

Sample Number: 1411106-009 Customer Sample Number: 3128588 Program: DS
Location: 1st draw 1109 MARYLAND AVE NE #2 Type: Dist.

Collection Date: 11/8/2014 Collection Time: 8:11 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.6 ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-010

SAMPLE INFORMATION

Sample Number: 1411106-010 Customer Sample Number: 3128588 Program: DS
Location: 2nd draw 1109 MARYLAND AVE NE #2 Type: Dist.

Collection Date: 11/8/2014 Collection Time: 8:14 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-011

SAMPLE INFORMATION

Sample Number: 1411106-011 Customer Sample Number: 3079701 Program: DS
Location: 1st draw 1719 HIGHWOOD PL SE Type: Dist.

Collection Date: 11/4/2014 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-012

SAMPLE INFORMATION

Sample Number: 1411106-012 Customer Sample Number: 3079701 Program: DS
Location: 2nd draw 1719 HIGHWOOD PL SE Type: Dist.

Collection Date: 11/4/2014 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-013

SAMPLE INFORMATION

Sample Number: 1411106-013 Customer Sample Number: 3023321 Program: DS
Location: 1st draw 423 GALLATIN ST NW Type: Dist.

Collection Date: 11/9/2014 Collection Time: 5:56 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-014

SAMPLE INFORMATION

Sample Number: 1411106-014 Customer Sample Number: 3023321 Program: DS
Location: 2nd draw 423 GALLATIN ST NW Type: Dist.

Collection Date: 11/9/2014 Collection Time: 5:57 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.8 ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-001

SAMPLE INFORMATION

Sample Number: 1411138-001 Customer Sample Number: 3033825 Program: DS
Location: 1st draw 1838 IRVING ST NW Type: Dist.

Collection Date: 11/14/2014 Collection Time: 20:17 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-002

SAMPLE INFORMATION

Sample Number: 1411138-002 Customer Sample Number: 3033825 Program: DS
Location: 2nd draw 1838 IRVING ST NW Type: Dist.

Collection Date: 11/14/2014 Collection Time: 20:19 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-003

SAMPLE INFORMATION

Sample Number: 1411138-003 Customer Sample Number: 3074573 Program: DS
Location: 1st draw 1421 D ST SE Type: Dist.

Collection Date: 11/12/2014 Collection Time: 17:40 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-004

SAMPLE INFORMATION

Sample Number: 1411138-004 Customer Sample Number: 3074573 Program: DS
Location: 2nd draw 1421 D ST SE Type: Dist.

Collection Date: 11/12/2014 Collection Time: 17:42 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-005

SAMPLE INFORMATION

Sample Number: 1411138-005 Customer Sample Number: 3028378 Program: DS
Location: 1st draw 1439 TAYLOR ST NW Type: Dist.

Collection Date: 11/11/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.6 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-006

SAMPLE INFORMATION

Sample Number: 1411138-006 Customer Sample Number: 3028378 Program: DS
Location: 2nd draw 1439 TAYLOR ST NW Type: Dist.

Collection Date: 11/11/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	5.3 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-007

SAMPLE INFORMATION

Sample Number: 1411138-007 Customer Sample Number: 3000882 Program: DS
Location: 1st draw 1309 22ND ST NW Type: Dist.

Collection Date: 11/10/2014 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.6 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-008

SAMPLE INFORMATION

Sample Number: 1411138-008 Customer Sample Number: 3000882 Program: DS
Location: 2nd draw 1309 22ND ST NW Type: Dist.

Collection Date: 11/10/2014 Collection Time: 6:44 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-009

SAMPLE INFORMATION

Sample Number: 1411138-009 Customer Sample Number: 3121201 Program: DS
Location: 1st draw 607 CONSTITUTION AVE NE Type: Dist.

Collection Date: 11/16/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.0 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-010

SAMPLE INFORMATION

Sample Number: 1411138-010 Customer Sample Number: 3121201 Program: DS
Location: 2nd draw 607 CONSTITUTION AVE NE Type: Dist.

Collection Date: 11/16/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.9 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-013

SAMPLE INFORMATION

Sample Number: 1411138-013 Customer Sample Number: 3104665 Program: DS
Location: 1st draw 4410 13TH PL NE Type: Dist.

Collection Date: 11/16/2014 Collection Time: 15:55 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-014

SAMPLE INFORMATION

Sample Number: 1411138-014 Customer Sample Number: 3104665 Program: DS
Location: 2nd draw 4410 13TH PL NE Type: Dist.

Collection Date: 11/16/2014 Collection Time: 15:57 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: LC-W1411159-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411159-001 Customer Sample Number: 3058735 Program: DS
Location: 1st draw 1420 VAN BUREN ST., NW Type: Dist.

Collection Date: 11/17/2014 Collection Time: 16:00 Sampler: HOMEOWNER Received Date and Time: 11/21/2014 10:27:21 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: LC-W1411159-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411159-002 Customer Sample Number: 3058735 Program: DS
Location: 2nd draw 1420 VAN BUREN ST., NW Type: Dist.

Collection Date: 11/17/2014 Collection Time: 16:02 Sampler: HOMEOWNER Received Date and Time: 11/21/2014 10:27:21 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412051-001

SAMPLE INFORMATION

Sample Number: 1412051-001 Customer Sample Number: 3002674 Program: DS
Location: 1st Draw 1419 W STREET NW Type: Dist.

Collection Date: 11/27/2014 Collection Time: 7:42 Sampler: HOME OWNER Received Date and Time: 12/5/2014 10:16:29 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412051-002

SAMPLE INFORMATION

Sample Number: 1412051-002 Customer Sample Number: 3002674 Program: DS
Location: 2nd Draw 1419 W STREET NW Type: Dist.

Collection Date: 11/27/2014 Collection Time: 7:46 Sampler: HOME OWNER Received Date and Time: 12/5/2014 10:16:29 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412051-003

SAMPLE INFORMATION

Sample Number: 1412051-003 Customer Sample Number: 3073873 Program: DS
Location: 1st Draw 246 11TH ST. SE Type: Dist.

Collection Date: 11/28/2014 Collection Time: 12:10 Sampler: HOME OWNER Received Date and Time: 12/5/2014 10:16:29 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412051-004

SAMPLE INFORMATION

Sample Number: 1412051-004 Customer Sample Number: 3073873 Program: DS
Location: 2nd Draw 246 11TH ST. SE Type: Dist.

Collection Date: 11/28/2014 Collection Time: 12:11 Sampler: HOME OWNER Received Date and Time: 12/5/2014 10:16:29 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412070-001

SAMPLE INFORMATION

Sample Number: 1412070-001 Customer Sample Number: 3040561 Program: DS
Location: 1st draw 3717 HUNTINGTON ST NW Type: Dist.

Collection Date: 12/3/2014 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 12/8/2014 4:06:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	64.6 ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412070-002

SAMPLE INFORMATION

Sample Number: 1412070-002 Customer Sample Number: 3040561 Program: DS
Location: 2nd draw 3717 HUNTINGTON ST NW Type: Dist.

Collection Date: 12/3/2014 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 12/8/2014 4:06:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412070-003

SAMPLE INFORMATION

Sample Number: 1412070-003 Customer Sample Number: 3127653 Program: DS
Location: 1st draw 810 5TH ST NE APT 2 Type: Dist.

Collection Date: 12/4/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 12/8/2014 4:06:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412070-004

SAMPLE INFORMATION

Sample Number: 1412070-004 Customer Sample Number: 3127653 Program: DS
Location: 2nd draw 810 5TH ST NE APT 2 Type: Dist.

Collection Date: 12/4/2014 Collection Time: 7:12 Sampler: HOME OWNER Received Date and Time: 12/8/2014 4:06:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off 4.5 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406227-001

SAMPLE INFORMATION

Sample Number: 1406227-001 Customer Sample Number: 3072639 Program: Post-LSR
Location: 1st draw 622 D ST SE Type: Dist.

Collection Date: 6/25/2014 Collection Time: 19:50 Sampler: HOME OWNER Received Date and Time: 6/30/2014 11:21:13 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406227-002

SAMPLE INFORMATION

Sample Number: 1406227-002 Customer Sample Number: 3072639 Program: Post-LSR
Location: 2nd draw 622 D ST SE Type: Dist.

Collection Date: 6/25/2014 Collection Time: 19:55 Sampler: HOME OWNER Received Date and Time: 6/30/2014 11:21:13 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406227-003

SAMPLE INFORMATION

Sample Number: 1406227-003 Customer Sample Number: 3021392 Program: Post-LSR
Location: 1st draw 4323 4TH ST NW Type: Dist.
Collection Date: 6/25/2014 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 6/30/2014 11:21:13 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	1.7 ug/L	7/2/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406227-004

SAMPLE INFORMATION

Sample Number: 1406227-004 Customer Sample Number: 3021392 Program: Post-LSR
Location: 2nd draw 4323 4TH ST NW Type: Dist.

Collection Date: 6/25/2014 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 6/30/2014 11:21:13 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406227-005

SAMPLE INFORMATION

Sample Number: 1406227-005 Customer Sample Number: 3072640 Program: Post-LSR
Location: 1st draw 624 D ST SE Type: Dist.

Collection Date: 6/27/2014 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 6/30/2014 11:21:13 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406227-006

SAMPLE INFORMATION

Sample Number: 1406227-006 Customer Sample Number: 3072640 Program: Post-LSR
Location: 2nd draw 624 D ST SE Type: Dist.

Collection Date: 6/27/2014 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 6/30/2014 11:21:13 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	7/2/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-007

SAMPLE INFORMATION

Sample Number: 1407131-007 Customer Sample Number: 3028822 Program: Post-LSR
Location: 1st draw 1718 UPSHUR ST NW Type: Dist.
Collection Date: 7/8/2014 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	7/23/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407131-008

SAMPLE INFORMATION

Sample Number: 1407131-008 Customer Sample Number: 3028822 Program: Post-LSR
Location: 2nd draw 1718 UPSHUR ST NW Type: Dist.
Collection Date: 7/8/2014 Collection Time: 6:22 Sampler: HOME OWNER Received Date and Time: 7/17/2014 3:55:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	7/23/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407228-001

SAMPLE INFORMATION

Sample Number: 1407228-001 Customer Sample Number: 3009887 Program: Post-LSR
Location: 1st draw 2113 37TH ST NW Type: Dist.
Collection Date: 7/27/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 7/31/2014 12:16:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.6 ug/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1407228-002

SAMPLE INFORMATION

Sample Number: 1407228-002 Customer Sample Number: 3009887 Program: Post-LSR
Location: 2nd draw 2113 37TH ST NW Type: Dist.
Collection Date: 7/27/2014 Collection Time: 7:16 Sampler: HOME OWNER Received Date and Time: 7/31/2014 12:16:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408049-003

SAMPLE INFORMATION

Sample Number: 1408049-003 Customer Sample Number: 3031449 Program: Post-LSR
Location: 1st draw 1836 LAMONT ST NW Type: Dist.
Collection Date: 8/4/2014 Collection Time: 18:31 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:10:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.6 ug/L	8/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/15/2014
Report Number: LC-W1408049-004

SAMPLE INFORMATION

Sample Number: 1408049-004 Customer Sample Number: 3031449 Program: Post-LSR
Location: 2nd draw 1836 LAMONT ST NW Type: Dist.

Collection Date: 8/4/2014 Collection Time: 18:33 Sampler: HOME OWNER Received Date and Time: 8/7/2014 10:10:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.1 ug/L	8/12/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/15/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/21/2014
Report Number: LC-W1408112-005

SAMPLE INFORMATION

Sample Number: 1408112-005 Customer Sample Number: 3081020 Program: Post-LSR
Location: 1st Draw 1724 W ST, SE Type: Dist.

Collection Date: 8/8/2014 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:28:35 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/14/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/21/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/21/2014
Report Number: LC-W1408112-006

SAMPLE INFORMATION

Sample Number: 1408112-006 Customer Sample Number: 3081020 Program: Post-LSR
Location: 2nd Draw 1724 W ST, SE Type: Dist.
Collection Date: 8/8/2014 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:28:35 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/14/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/21/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/21/2014
Report Number: LC-W1408112-007

SAMPLE INFORMATION

Sample Number: 1408112-007 Customer Sample Number: 3021393 Program: Post-LSR
Location: 1st Draw 4325 4TH ST. NW Type: Dist.
Collection Date: 8/11/2014 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:28:35 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	8/14/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/21/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/21/2014
Report Number: LC-W1408112-008

SAMPLE INFORMATION

Sample Number: 1408112-008 Customer Sample Number: 3021393 Program: Post-LSR
Location: 2nd Draw 4325 4TH ST. NW Type: Dist.

Collection Date: 8/11/2014 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 8/13/2014 3:28:35 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	8/14/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/21/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408123-001

SAMPLE INFORMATION

Sample Number: 1408123-001 Customer Sample Number: 3072644 Program: Post-LSR
Location: 1st Draw 632 D ST SE Type: Dist.

Collection Date: 8/11/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 8/15/2014 9:09:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408123-002

SAMPLE INFORMATION

Sample Number: 1408123-002 Customer Sample Number: 3072644 Program: Post-LSR
Location: 2nd Draw 632 D ST SE Type: Dist.

Collection Date: 8/11/2014 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 8/15/2014 9:09:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408145-003

SAMPLE INFORMATION

Sample Number: 1408145-003 Customer Sample Number: 3072641 Program: Post-LSR
Location: 1st draw 626 D ST SE Type: Dist.

Collection Date: 8/15/2014 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 8/19/2014 8:44:36 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.4 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408145-004

SAMPLE INFORMATION

Sample Number: 1408145-004 Customer Sample Number: 3082641 Program: Post-LSR
Location: 2nd draw 626 D ST SE Type: Dist.

Collection Date: 8/15/2014 Collection Time: 7:22 Sampler: HOME OWNER Received Date and Time: 8/19/2014 8:44:36 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408182-001

SAMPLE INFORMATION

Sample Number: 1408182-001 Customer Sample Number: 3030569 Program: Post-LSR
Location: 1st draw 3553 16TH ST NW Type: Dist.

Collection Date: 8/16/2014 Collection Time: 10:35 Sampler: HOME OWNER Received Date and Time: 8/22/2014 8:30:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408182-002

SAMPLE INFORMATION

Sample Number: 1408182-002 Customer Sample Number: 3030569 Program: Post-LSR
Location: 2nd draw 3553 16TH ST NW Type: Dist.

Collection Date: 8/16/2014 Collection Time: 10:37 Sampler: HOME OWNER Received Date and Time: 8/22/2014 8:30:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	8/26/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-005

SAMPLE INFORMATION

Sample Number: 1408212-005 Customer Sample Number: 3072632 Program: Post-LSR
Location: 1st draw 608 D ST SE Type: Dist.

Collection Date: 8/21/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408212-006

SAMPLE INFORMATION

Sample Number: 1408212-006 Customer Sample Number: 3072632 Program: Post-LSR
Location: 2nd draw 608 D ST SE Type: Dist.

Collection Date: 8/21/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 8/26/2014 3:23:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	8/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-001

SAMPLE INFORMATION

Sample Number: 1408235-001 Customer Sample Number: 3072643 Program: Post-LSR
Location: 1st draw 630 D STREET SE Type: Dist.

Collection Date: 8/23/2014 Collection Time: 7:32 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1408235-002

SAMPLE INFORMATION

Sample Number: 1408235-002 Customer Sample Number: 3072643 Program: Post-LSR
Location: 2nd draw 630 D STREET SE Type: Dist.

Collection Date: 8/23/2014 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 8/29/2014 2:01:00 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/5/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409075-005

SAMPLE INFORMATION

Sample Number: 1409075-005 Customer Sample Number: 3122845 Program: Post-LSR
Location: 1st draw 925 K ST. NE Type: Dist.

Collection Date: 9/3/2014 Collection Time: 19:20 Sampler: HOME OWNER Received Date and Time: 9/9/2014 3:29:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.6 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409075-006

SAMPLE INFORMATION

Sample Number: 1409075-006 Customer Sample Number: 3122845 Program: Post-LSR
Location: 2nd draw 925 K ST. NE Type: Dist.

Collection Date: 9/3/2014 Collection Time: 19:25 Sampler: HOME OWNER Received Date and Time: 9/9/2014 3:29:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.7 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-003

SAMPLE INFORMATION

Sample Number: 1409120-003 Customer Sample Number: 3010045 Program: Post-LSR
Location: 1st draw 3726 BENTON ST NW Type: Dist.
Collection Date: 9/8/2014 Collection Time: 7:24 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-004

SAMPLE INFORMATION

Sample Number: 1409120-004 Customer Sample Number: 3010045 Program: Post-LSR
Location: 2nd draw 3726 BENTON ST NW Type: Dist.

Collection Date: 9/8/2014 Collection Time: 7:27 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-005

SAMPLE INFORMATION

Sample Number: 1409120-005 Customer Sample Number: 3021273 Program: Post-LSR
Location: 1st draw 4306 4TH ST NW Type: Dist.
Collection Date: 9/8/2014 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.7 ug/L	9/17/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-006

SAMPLE INFORMATION

Sample Number: 1409120-006 Customer Sample Number: 3021273 Program: Post-LSR
Location: 2nd draw 4306 4TH ST NW Type: Dist.
Collection Date: 9/8/2014 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-009

SAMPLE INFORMATION

Sample Number: 1409120-009 Customer Sample Number: 3072638 Program: Post-LSR
Location: 1st draw 620 D ST SE Type: Dist.
Collection Date: 9/10/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: LC-W1409120-010

SAMPLE INFORMATION

Sample Number: 1409120-010 Customer Sample Number: 3072638 Program: Post-LSR
Location: 2nd draw 620 D ST SE Type: Dist.

Collection Date: 9/10/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 9/15/2014 1:12:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409134-001

SAMPLE INFORMATION

Sample Number: 1409134-001 Customer Sample Number: 3021391 Program: Post-LSR
Location: 1st draw 4321 4TH ST NW Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 9/17/2014 11:54:40 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409134-002

SAMPLE INFORMATION

Sample Number: 1409134-002 Customer Sample Number: 3021391 Program: Post-LSR
Location: 2nd draw 4321 4TH ST NW Type: Dist.
Collection Date: 9/11/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 9/17/2014 11:54:40 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/29/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409159-005

SAMPLE INFORMATION

Sample Number: 1409159-005 Customer Sample Number: 3040944 Program: Post-LSR
Location: 1st draw 4121 BRANDYWINE ST NW Type: Dist.
Collection Date: 9/17/2014 Collection Time: 8:49 Sampler: HOME OWNER Received Date and Time: 9/19/2014 11:50:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409159-006

SAMPLE INFORMATION

Sample Number: 1409159-006 Customer Sample Number: 3040944 Program: Post-LSR
Location: 2nd draw 4121 BRANDYWINE ST NW Type: Dist.
Collection Date: 9/17/2014 Collection Time: 8:53 Sampler: HOME OWNER Received Date and Time: 9/19/2014 11:50:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/29/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409188-007

SAMPLE INFORMATION

Sample Number: 1409188-007 Customer Sample Number: 3036876 Program: Post-LSR
Location: 1st draw 3629 ELLICOTT ST NW Type: Dist.
Collection Date: 9/22/2014 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 9/24/2014 10:12:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409188-008

SAMPLE INFORMATION

Sample Number: 1409188-008 Customer Sample Number: 3036876 Program: Post-LSR
Location: 2nd draw 3629 ELLICOTT ST NW Type: Dist.
Collection Date: 9/22/2014 Collection Time: 5:44 Sampler: HOME OWNER Received Date and Time: 9/24/2014 10:12:15 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	9/29/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-001

SAMPLE INFORMATION

Sample Number: 1409210-001 Customer Sample Number: 3027861 Program: Post-LSR
Location: 1st Draw 1508 BUCHANAN ST NW Type: Dist.
Collection Date: 9/20/2014 Collection Time: 8:43 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	9/29/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-002

SAMPLE INFORMATION

Sample Number: 1409210-002 Customer Sample Number: 3027861 Program: Post-LSR
Location: 2nd Draw 1508 BUCHANAN ST NW Type: Dist.
Collection Date: 9/20/2014 Collection Time: 8:46 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	9/29/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-003

SAMPLE INFORMATION

Sample Number: 1409210-003 Customer Sample Number: Program: Post-LSR
Location: 1st Draw 1320 D ST. SE Type: Dist.

Collection Date: 9/21/2014 Collection Time: 8:23 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-004

SAMPLE INFORMATION

Sample Number: 1409210-004 Customer Sample Number: Program: Post-LSR
Location: 2nd Draw 1320 D ST. SE Type: Dist.

Collection Date: 9/21/2014 Collection Time: 8:25 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-007

SAMPLE INFORMATION

Sample Number: 1409210-007 Customer Sample Number: 3039987 Program: Post-LSR
Location: 1st Draw 3743 MILITARY RD NW Type: Dist.
Collection Date: 9/24/2014 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2014
Report Number: LC-W1409210-008

SAMPLE INFORMATION

Sample Number: 1409210-008 Customer Sample Number: 3039987 Program: Post-LSR
Location: 2nd Draw 3743 MILITARY RD NW Type: Dist.

Collection Date: 9/24/2014 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 9/26/2014 11:50:17 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	9/29/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410044-003

SAMPLE INFORMATION

Sample Number: 1410044-003 Customer Sample Number: 3018882 Program: Post-LSR
Location: 1st Draw 1815 2ND ST NW Type: Dist.

Collection Date: 10/3/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 10/7/2014 12:22:13 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410044-004

SAMPLE INFORMATION

Sample Number: 1410044-004 Customer Sample Number: 3018882 Program: Post-LSR
Location: 2nd Draw 1815 2ND ST NW Type: Dist.

Collection Date: 10/3/2014 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 10/7/2014 12:22:13 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410044-005

SAMPLE INFORMATION

Sample Number: 1410044-005 Customer Sample Number: 3127694 Program: Post-LSR
Location: 1st Draw 714 7TH ST NE Type: Dist.

Collection Date: 10/6/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 10/7/2014 12:22:13 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410044-006

SAMPLE INFORMATION

Sample Number: 1410044-006 Customer Sample Number: 3127694 Program: Post-LSR
Location: 2nd Draw 714 7TH ST NE Type: Dist.

Collection Date: 10/6/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 10/7/2014 12:22:13 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-001

SAMPLE INFORMATION

Sample Number: 1410058-001 Customer Sample Number: 3104722 Program: Post-LSR
Location: 1st draw 1326 ALLISON ST NE Type: Dist.
Collection Date: 10/1/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-002

SAMPLE INFORMATION

Sample Number: 1410058-002 Customer Sample Number: 3104722 Program: Post-LSR
Location: 2nd draw 1326 ALLISON ST NE Type: Dist.

Collection Date: 10/1/2014 Collection Time: 6:09 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-009

SAMPLE INFORMATION

Sample Number: 1410058-009 Customer Sample Number: 3027991 Program: Post-LSR
Location: 1st draw 1129 ALLISON ST. NW Type: Dist.

Collection Date: 10/6/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2014
Report Number: LC-W1410058-010

SAMPLE INFORMATION

Sample Number: 1410058-010 Customer Sample Number: 3027991 Program: Post-LSR
Location: 2nd draw 1129 ALLISON ST. NW Type: Dist.

Collection Date: 10/6/2014 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 10/8/2014 1:11:18 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/23/2014
Report Number: LC-W1410080-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-005 Customer Sample Number: 3050145 Program: Post-LSR
Location: 1st Draw 1800 2ND ST. NW Type: Dist.
Collection Date: 10/6/2014 Collection Time: 8:40 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/23/2014
Report Number: LC-W1410080-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410080-006 Customer Sample Number: 3050145 Program: Post-LSR
Location: 2nd Draw 1800 2ND ST. NW Type: Dist.
Collection Date: 10/6/2014 Collection Time: 8:45 Sampler: HOMEOWNER Received Date and Time: 10/10/2014 8:42:10 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-001

SAMPLE INFORMATION

Sample Number: 1410021-001 Customer Sample Number: 3113282 Program: Post-LSR
Location: 1st Draw 605 GIRARD ST NE Type: Dist.

Collection Date: 9/26/2014 Collection Time: 17:26 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/28/2014
Report Number: LC-W1410021-002

SAMPLE INFORMATION

Sample Number: 1410021-002 Customer Sample Number: 3113282 Program: Post-LSR
Location: 2nd Draw 605 GIRARD ST NE Type: Dist.

Collection Date: 9/26/2014 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 10/3/2014 9:05:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/16/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-007 Customer Sample Number: 3021270 Program: Post-LSR
Location: 1st draw 4300 4TH ST NW Type: Dist.
Collection Date: 10/14/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/7/2014
Report Number: LC-W1410129-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1410129-008 Customer Sample Number: 3021270 Program: Post-LSR
Location: 2nd draw 4300 4TH ST NW Type: Dist.
Collection Date: 10/14/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/17/2014 9:13:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	10/21/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/7/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410229-003

SAMPLE INFORMATION

Sample Number: 1410229-003 Customer Sample Number: 3050152 Program: Post-LSR
Location: 1st draw 1712 2ND ST NW Type: Dist.
Collection Date: 10/28/2014 Collection Time: 5:23 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:39:23 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	11/12/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410229-004

SAMPLE INFORMATION

Sample Number: 1410229-004 Customer Sample Number: 3050152 Program: Post-LSR
Location: 2nd draw 1712 2ND ST NW Type: Dist.

Collection Date: 10/28/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:39:23 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410229-007

SAMPLE INFORMATION

Sample Number: 1410229-007 Customer Sample Number: 3062029 Program: Post-LSR
Location: 1st draw 1700 2ND ST NW #6 Type: Dist.

Collection Date: 10/27/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:39:23 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1410229-008

SAMPLE INFORMATION

Sample Number: 1410229-008 Customer Sample Number: 3062029 Program: Post-LSR
Location: 2nd draw 1700 2ND ST NW #6 Type: Dist.

Collection Date: 10/27/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/31/2014 10:39:23 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/12/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-001

SAMPLE INFORMATION

Sample Number: 1411106-001 Customer Sample Number: 3050086 Program: Post-LSR
Location: 1st draw 1717 2ND ST NW Type: Dist.

Collection Date: 11/5/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411106-002

SAMPLE INFORMATION

Sample Number: 1411106-002 Customer Sample Number: 3050086 Program: Post-LSR
Location: 2nd draw 1717 2ND ST NW Type: Dist.

Collection Date: 11/5/2014 Collection Time: 7:18 Sampler: HOME OWNER Received Date and Time: 11/14/2014 11:13:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.8 ug/L	11/18/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-011

SAMPLE INFORMATION

Sample Number: 1411138-011 Customer Sample Number: 3020939 Program: Post-LSR
Location: 1st draw 728 UPSHUR ST NW Type: Dist.

Collection Date: 11/10/2014 Collection Time: 14:11 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/20/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-012

SAMPLE INFORMATION

Sample Number: 1411138-012 Customer Sample Number: 3020939 Program: Post-LSR
Location: 2nd draw 728 UPSHUR ST NW Type: Dist.

Collection Date: 11/10/2014 Collection Time: 14:13 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-015

SAMPLE INFORMATION

Sample Number: 1411138-015 Customer Sample Number: 3022760 Program: Post-LSR
Location: 1st draw 820 GALLATIN ST NW Type: Dist.
Collection Date: 11/12/2014 Collection Time: 5:50 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.9 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-016

SAMPLE INFORMATION

Sample Number: 1411138-016 Customer Sample Number: 3022760 Program: Post-LSR
Location: 2nd draw 820 GALLATIN ST NW Type: Dist.

Collection Date: 11/12/2014 Collection Time: 5:51 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-017

SAMPLE INFORMATION

Sample Number: 1411138-017 Customer Sample Number: 3021281 Program: Post-LSR
Location: 1st draw 4324 4TH ST NW Type: Dist.

Collection Date: 11/11/2014 Collection Time: 4:27 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/20/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/26/2014
Report Number: LC-W1411138-018

SAMPLE INFORMATION

Sample Number: 1411138-018 Customer Sample Number: 3021281 Program: Post-LSR
Location: 2nd draw 4324 4TH ST NW Type: Dist.
Collection Date: 11/11/2014 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 11/19/2014 11:35:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	11/20/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/26/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412051-005

SAMPLE INFORMATION

Sample Number: 1412051-005 Customer Sample Number: 3106806 Program: Post-LSR
Location: 1st Draw 2226 NEWTON ST NE Type: Dist.

Collection Date: 12/2/2014 Collection Time: 6:41 Sampler: HOME OWNER Received Date and Time: 12/5/2014 10:16:29 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412051-006

SAMPLE INFORMATION

Sample Number: 1412051-006 Customer Sample Number: 3106806 Program: Post-LSR
Location: 2nd Draw 2226 NEWTON ST NE Type: Dist.

Collection Date: 12/2/2014 Collection Time: 6:44 Sampler: HOME OWNER Received Date and Time: 12/5/2014 10:16:29 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412070-005

SAMPLE INFORMATION

Sample Number: 1412070-005 Customer Sample Number: 3036071 Program: Post-LSR
Location: 1st draw 2938 NEWARK ST NW Type: Dist.

Collection Date: 12/5/2014 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 12/8/2014 4:06:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: LC-W1412070-006

SAMPLE INFORMATION

Sample Number: 1412070-006 Customer Sample Number: 3036071 Program: Post-LSR
Location: 2nd draw 2938 NEWARK ST NW Type: Dist.

Collection Date: 12/5/2014 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 12/8/2014 4:06:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	12/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

Lead Profile Information

DC Water surveys the plumbing of customers' homes and collects consecutive samples to identify the sources of lead. The homes are those that had elevated lead from previous samples collected for compliance monitoring or from other programs.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-001

SAMPLE INFORMATION

Sample Number: 1406037-001
Location: 1
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/5/2014
Collection Time: 8:30
Sampler: IC/YT
Received Date and Time: 6/5/2014 2:13:24 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.63 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	117 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	214 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.10 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-001

SAMPLE INFORMATION

Sample Number: 1406037-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-002

SAMPLE INFORMATION

Sample Number: 1406037-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.57 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	102 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	204 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.31 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-002

SAMPLE INFORMATION

Sample Number: 1406037-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-003

SAMPLE INFORMATION

Sample Number: 1406037-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	28.6 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	23.4 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.26 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-003

SAMPLE INFORMATION

Sample Number: 1406037-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-004

SAMPLE INFORMATION

Sample Number: 1406037-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	25.5 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	24.3 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.79 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-004

SAMPLE INFORMATION

Sample Number: 1406037-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-005

SAMPLE INFORMATION

Sample Number: 1406037-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	27.4 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	27.2 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.10 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-005

SAMPLE INFORMATION

Sample Number: 1406037-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-006

SAMPLE INFORMATION

Sample Number: 1406037-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-007

SAMPLE INFORMATION

Sample Number: 1406037-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	23.1 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	23.1 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.60 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-007

SAMPLE INFORMATION

Sample Number: 1406037-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-008

SAMPLE INFORMATION

Sample Number: 1406037-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-009

SAMPLE INFORMATION

Sample Number: 1406037-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-010

SAMPLE INFORMATION

Sample Number: 1406037-010
Customer Sample Number:
Location: 05F
Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 6/5/2014
Collection Time: 8:30
Sampler: IC/YT
Received Date and Time: 6/5/2014 2:13:24 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	19.5 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	26.7 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.88 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-010

SAMPLE INFORMATION

Sample Number: 1406037-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-011

SAMPLE INFORMATION

Sample Number: 1406037-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	20.0 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	16.5 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	10.4 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-011

SAMPLE INFORMATION

Sample Number: 1406037-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

**US Army Corps of Engineers
Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number:M- W1406037-012

SAMPLE INFORMATION

Sample Number: 1406037-012	Customer Sample Number:			
Location: 06F LPR 2513 NORTH CAPITOL ST NE FILTERED	Type: Dist.			
Collection Date: 6/5/2014	Collection Time: 8:30	Sampler: IC/YT	Received Date and Time: 6/5/2014 2:13:24 PM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	17.5 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	18.0 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	8.53 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-012

SAMPLE INFORMATION

Sample Number: 1406037-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-013

SAMPLE INFORMATION

Sample Number: 1406037-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	22.7 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	14.0 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	7.05 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-013

SAMPLE INFORMATION

Sample Number: 1406037-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-014

SAMPLE INFORMATION

Sample Number: 1406037-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-015

SAMPLE INFORMATION

Sample Number: 1406037-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	22.7 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	12.6 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.57 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-015

SAMPLE INFORMATION

Sample Number: 1406037-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-016

SAMPLE INFORMATION

Sample Number: 1406037-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	20.6 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	16.0 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.96 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-016

SAMPLE INFORMATION

Sample Number: 1406037-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-017

SAMPLE INFORMATION

Sample Number: 1406037-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-018

SAMPLE INFORMATION

Sample Number: 1406037-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	18.5 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	14.8 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.83 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-018

SAMPLE INFORMATION

Sample Number: 1406037-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-019

SAMPLE INFORMATION

Sample Number: 1406037-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	17.4 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	10.8 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.89 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-019

SAMPLE INFORMATION

Sample Number: 1406037-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-020

SAMPLE INFORMATION

Sample Number: 1406037-020
Customer Sample Number:
Location: 10F
Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	15.3 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	13.1 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.21 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-020

SAMPLE INFORMATION

Sample Number: 1406037-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-021

SAMPLE INFORMATION

Sample Number: 1406037-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	15.3 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.70 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-021

SAMPLE INFORMATION

Sample Number: 1406037-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-022

SAMPLE INFORMATION

Sample Number: 1406037-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	12.9 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	12.0 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-022

SAMPLE INFORMATION

Sample Number: 1406037-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-023

SAMPLE INFORMATION

Sample Number: 1406037-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	13.9 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.60 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-023

SAMPLE INFORMATION

Sample Number: 1406037-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-024

SAMPLE INFORMATION

Sample Number: 1406037-024
Location: 12F
LPR 2513 NORTH CAPITOL ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	11.8 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	10.9 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.8 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-024

SAMPLE INFORMATION

Sample Number: 1406037-024
Location: 12F
LPR 2513 NORTH CAPITOL ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-025

SAMPLE INFORMATION

Sample Number: 1406037-025

Customer Sample Number:

Location: H1

Type: Dist.

LPR 2513 NORTH CAPITOL ST NE UNFILTERED

Collection Date:
6/5/2014

Collection Time:
8:30

Sampler:
IC/YT

Received Date and Time:
6/5/2014 2:13:00 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.26 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	32.6 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	32.1 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.54 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-025

SAMPLE INFORMATION

Sample Number: 1406037-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-026

SAMPLE INFORMATION

Sample Number: 1406037-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-027

SAMPLE INFORMATION

Sample Number: 1406037-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	19.5 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	15.6 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.46 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-027

SAMPLE INFORMATION

Sample Number: 1406037-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-028

SAMPLE INFORMATION

Sample Number: 1406037-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	18.2 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	12.8 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.14 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-028

SAMPLE INFORMATION

Sample Number: 1406037-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-029

SAMPLE INFORMATION

Sample Number: 1406037-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	15.0 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.92 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-029

SAMPLE INFORMATION

Sample Number: 1406037-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-030

SAMPLE INFORMATION

Sample Number: 1406037-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	15.8 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	10.2 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.03 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-030

SAMPLE INFORMATION

Sample Number: 1406037-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/14/2014
 Report Number: M- W1406037-031

SAMPLE INFORMATION

Sample Number: 1406037-031 Customer Sample Number:
 Location: H7 Type: Dist.
 LPR 2513 NORTH CAPITOL ST NE UNFILTERED
 Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	16.9 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	36.7 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.08 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-031

SAMPLE INFORMATION

Sample Number: 1406037-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-032

SAMPLE INFORMATION

Sample Number: 1406037-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-033

SAMPLE INFORMATION

Sample Number: 1406037-033
Location: H9
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/5/2014
Collection Time: 8:30
Sampler: IC/YT
Received Date and Time: 6/5/2014 2:13:24 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	16.0 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	11.8 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.82 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-033

SAMPLE INFORMATION

Sample Number: 1406037-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-034

SAMPLE INFORMATION

Sample Number: 1406037-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-035

SAMPLE INFORMATION

Sample Number: 1406037-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 6/5/2014 Collection Time: 8:30 Sampler: IC/YT Received Date and Time: 6/5/2014 2:13:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/6/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/6/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	17.7 ug/L	6/6/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	15.0 ug/L	6/6/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.89 ug/L	6/6/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-035

SAMPLE INFORMATION

Sample Number: 1406037-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406037-036

SAMPLE INFORMATION

Sample Number: 1406037-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/5/2014 8:30 IC/YT 6/5/2014 2:13:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-001

SAMPLE INFORMATION

Sample Number: 1406219-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-002

SAMPLE INFORMATION

Sample Number: 1406219-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	31.5 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	17.3 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-002

SAMPLE INFORMATION

Sample Number: 1406219-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-003

SAMPLE INFORMATION

Sample Number: 1406219-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	9.80 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	14.7 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.09 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-003

SAMPLE INFORMATION

Sample Number: 1406219-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-004

SAMPLE INFORMATION

Sample Number: 1406219-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-005

SAMPLE INFORMATION

Sample Number: 1406219-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.53 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-005

SAMPLE INFORMATION

Sample Number: 1406219-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-006

SAMPLE INFORMATION

Sample Number: 1406219-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-007

SAMPLE INFORMATION

Sample Number: 1406219-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-008

SAMPLE INFORMATION

Sample Number: 1406219-008
Location: 04F
LPR 3042 NEWARK ST NW (FILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 6/26/2014
Collection Time: 7:00
Sampler: CW/IC
Received Date and Time: 6/27/2014 12:21:37 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.11 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-008

SAMPLE INFORMATION

Sample Number: 1406219-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-009

SAMPLE INFORMATION

Sample Number: 1406219-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.0 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.74 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-009

SAMPLE INFORMATION

Sample Number: 1406219-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-010

SAMPLE INFORMATION

Sample Number: 1406219-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-011

SAMPLE INFORMATION

Sample Number: 1406219-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.46 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-011

SAMPLE INFORMATION

Sample Number: 1406219-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/14/2014
 Report Number:M- W1406219-012

SAMPLE INFORMATION

Sample Number: 1406219-012	Customer Sample Number:			
Location: 06F LPR 3042 NEWARK ST NW (FILTERED)	Type: Dist.			
Collection Date: 6/26/2014	Collection Time: 7:00	Sampler: CW/IC	Received Date and Time: 6/27/2014 12:21:37 PM	Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.96 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-012

SAMPLE INFORMATION

Sample Number: 1406219-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-013

SAMPLE INFORMATION

Sample Number: 1406219-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.08 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.0 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-013

SAMPLE INFORMATION

Sample Number: 1406219-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-014

SAMPLE INFORMATION

Sample Number: 1406219-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-015

SAMPLE INFORMATION

Sample Number: 1406219-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.99 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.02 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-015

SAMPLE INFORMATION

Sample Number: 1406219-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-016

SAMPLE INFORMATION

Sample Number: 1406219-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-017

SAMPLE INFORMATION

Sample Number: 1406219-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.87 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-017

SAMPLE INFORMATION

Sample Number: 1406219-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-018

SAMPLE INFORMATION

Sample Number: 1406219-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.34 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-018

SAMPLE INFORMATION

Sample Number: 1406219-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-019

SAMPLE INFORMATION

Sample Number: 1406219-019
Location: 10
LPR 3042 NEWARK ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.55 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.31 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-019

SAMPLE INFORMATION

Sample Number: 1406219-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-020

SAMPLE INFORMATION

Sample Number: 1406219-020
Location: 10F
LPR 3042 NEWARK ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.96 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-020

SAMPLE INFORMATION

Sample Number: 1406219-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-021

SAMPLE INFORMATION

Sample Number: 1406219-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-022

SAMPLE INFORMATION

Sample Number: 1406219-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.28 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-022

SAMPLE INFORMATION

Sample Number: 1406219-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-023

SAMPLE INFORMATION

Sample Number: 1406219-023
Location: 12
LPR 3042 NEWARK ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
6/26/2014	7:00	CW/IC	6/27/2014 12:21:37 PM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.01 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	7.38 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	26.9 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.8 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-023

SAMPLE INFORMATION

Sample Number: 1406219-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-024

SAMPLE INFORMATION

Sample Number: 1406219-024
Location: 12F
LPR 3042 NEWARK ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.21 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-024

SAMPLE INFORMATION

Sample Number: 1406219-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 3042 NEWARK ST NW (FILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-025

SAMPLE INFORMATION

Sample Number: 1406219-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.29 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	16.6 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	12.1 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	14.5 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.65 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-025

SAMPLE INFORMATION

Sample Number: 1406219-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-026

SAMPLE INFORMATION

Sample Number: 1406219-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.12 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.81 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.8 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-026

SAMPLE INFORMATION

Sample Number: 1406219-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-027

SAMPLE INFORMATION

Sample Number: 1406219-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.09 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	7.05 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.8 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-027

SAMPLE INFORMATION

Sample Number: 1406219-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number:M- W1406219-028

SAMPLE INFORMATION

Sample Number: 1406219-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.10 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.98 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-028

SAMPLE INFORMATION

Sample Number: 1406219-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-029

SAMPLE INFORMATION

Sample Number: 1406219-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.13 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.76 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-029

SAMPLE INFORMATION

Sample Number: 1406219-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-030

SAMPLE INFORMATION

Sample Number: 1406219-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.12 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.50 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-030

SAMPLE INFORMATION

Sample Number: 1406219-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-031

SAMPLE INFORMATION

Sample Number: 1406219-031

Customer Sample Number:

Location: H7

Type: Dist.

LPR 3042 NEWARK ST NW (UNFILTERED)

Collection Date:
6/26/2014

Collection Time:
7:00

Sampler:
CW/IC

Received Date and Time:
6/27/2014 12:21:37 PM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.12 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.55 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-031

SAMPLE INFORMATION

Sample Number: 1406219-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-032

SAMPLE INFORMATION

Sample Number: 1406219-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-033

SAMPLE INFORMATION

Sample Number: 1406219-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.14 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	10.4 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.01 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.8 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-033

SAMPLE INFORMATION

Sample Number: 1406219-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-034

SAMPLE INFORMATION

Sample Number: 1406219-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-035

SAMPLE INFORMATION

Sample Number: 1406219-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-036

SAMPLE INFORMATION

Sample Number: 1406219-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: 6/26/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 6/27/2014 12:21:37 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.12 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.07 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406219-036

SAMPLE INFORMATION

Sample Number: 1406219-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3042 NEWARK ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/26/2014 7:00 CW/IC 6/27/2014 12:21:37 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number:M- W1406220-001

SAMPLE INFORMATION

Sample Number: 1406220-001
Location: 1
LPR 2102 2ND ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.07 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	54.5 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	99.2 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.42 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-001

SAMPLE INFORMATION

Sample Number: 1406220-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-002

SAMPLE INFORMATION

Sample Number: 1406220-002
Location: 1F
LPR 2102 2ND ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/14/2014
 Report Number: M- W1406220-003

SAMPLE INFORMATION

Sample Number: 1406220-003 Customer Sample Number:
 Location: 02 Type: Dist.
 LPR 2102 2ND ST NW UNFILTERED

Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	41.5 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.36 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-003

SAMPLE INFORMATION

Sample Number: 1406220-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-004

SAMPLE INFORMATION

Sample Number: 1406220-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-005

SAMPLE INFORMATION

Sample Number: 1406220-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-006

SAMPLE INFORMATION

Sample Number: 1406220-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	30.2 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.86 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-006

SAMPLE INFORMATION

Sample Number: 1406220-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-007

SAMPLE INFORMATION

Sample Number: 1406220-007
Location: 04
LPR 2102 2ND ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	33.4 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.92 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-007

SAMPLE INFORMATION

Sample Number: 1406220-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-008

SAMPLE INFORMATION

Sample Number: 1406220-008
Location: 04F
LPR 2102 2ND ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-009

SAMPLE INFORMATION

Sample Number: 1406220-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-010

SAMPLE INFORMATION

Sample Number: 1406220-010
Location: 05F
LPR 2102 2ND ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	15.7 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	10.0 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-010

SAMPLE INFORMATION

Sample Number: 1406220-010
Customer Sample Number:
Location: 05F
Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-011

SAMPLE INFORMATION

Sample Number: 1406220-011
Location: 06
LPR 2102 2ND ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-012

SAMPLE INFORMATION

Sample Number: 1406220-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-013

SAMPLE INFORMATION

Sample Number: 1406220-013
Location: 07
LPR 2102 2ND ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/27/2014	Collection Time: 8:00	Sampler: AB/DVC	Received Date and Time: 6/27/2014 1:18:34 PM	Received By: LGallimore
-------------------------------	--------------------------	--------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	12.5 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	16.5 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-013

SAMPLE INFORMATION

Sample Number: 1406220-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-014

SAMPLE INFORMATION

Sample Number: 1406220-014
Location: 07F
LPR 2102 2ND ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	11.4 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	14.2 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-014

SAMPLE INFORMATION

Sample Number: 1406220-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-015

SAMPLE INFORMATION

Sample Number: 1406220-015
Location: 08
LPR 2102 2ND ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/27/2014	Collection Time: 8:00	Sampler: AB/DVC	Received Date and Time: 6/27/2014 1:18:34 PM	Received By: LGallimore
-------------------------------	--------------------------	--------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	12.6 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	11.0 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-015

SAMPLE INFORMATION

Sample Number: 1406220-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-016

SAMPLE INFORMATION

Sample Number: 1406220-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-017

SAMPLE INFORMATION

Sample Number: 1406220-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	12.6 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	10.3 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-017

SAMPLE INFORMATION

Sample Number: 1406220-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-018

SAMPLE INFORMATION

Sample Number: 1406220-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-019

SAMPLE INFORMATION

Sample Number: 1406220-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	11.4 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	6.36 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-019

SAMPLE INFORMATION

Sample Number: 1406220-019
Location: 10
LPR 2102 2ND ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-020

SAMPLE INFORMATION

Sample Number: 1406220-020
Location: 10F
LPR 2102 2ND ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	10.2 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.94 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-020

SAMPLE INFORMATION

Sample Number: 1406220-020
Location: 10F
LPR 2102 2ND ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-021

SAMPLE INFORMATION

Sample Number: 1406220-021
Location: 11
LPR 2102 2ND ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	10.9 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.26 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-021

SAMPLE INFORMATION

Sample Number: 1406220-021
Location: 11
LPR 2102 2ND ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-022

SAMPLE INFORMATION

Sample Number: 1406220-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	9.84 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.26 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-022

SAMPLE INFORMATION

Sample Number: 1406220-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-023

SAMPLE INFORMATION

Sample Number: 1406220-023
Location: 12
LPR 2102 2ND ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/14/2014
 Report Number: M- W1406220-024

SAMPLE INFORMATION

Sample Number: 1406220-024	Customer Sample Number:			
Location: 12F LPR 2102 2ND ST NW FILTERED	Type: Dist.			
Collection Date: 6/27/2014	Collection Time: 8:00	Sampler: AB/DVC	Received Date and Time: 6/27/2014 1:18:34 PM	Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	9.85 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.57 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-024

SAMPLE INFORMATION

Sample Number: 1406220-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-025

SAMPLE INFORMATION

Sample Number: 1406220-025
Location: H1
LPR 2102 2ND ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/27/2014
Collection Time: 8:00
Sampler: AB/DVC
Received Date and Time: 6/27/2014 1:18:34 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	13.4 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.33 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-025

SAMPLE INFORMATION

Sample Number: 1406220-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-026

SAMPLE INFORMATION

Sample Number: 1406220-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-027

SAMPLE INFORMATION

Sample Number: 1406220-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-028

SAMPLE INFORMATION

Sample Number: 1406220-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-029

SAMPLE INFORMATION

Sample Number: 1406220-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-030

SAMPLE INFORMATION

Sample Number: 1406220-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-031

SAMPLE INFORMATION

Sample Number: 1406220-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	10.1 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.23 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-031

SAMPLE INFORMATION

Sample Number: 1406220-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-032

SAMPLE INFORMATION

Sample Number: 1406220-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 6/27/2014 Collection Time: 8:00 Sampler: AB/DVC Received Date and Time: 6/27/2014 1:18:34 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/1/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/1/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	10.2 ug/L	7/1/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/1/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.05 ug/L	7/1/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-032

SAMPLE INFORMATION

Sample Number: 1406220-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-033

SAMPLE INFORMATION

Sample Number: 1406220-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-034

SAMPLE INFORMATION

Sample Number: 1406220-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-035

SAMPLE INFORMATION

Sample Number: 1406220-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406220-036

SAMPLE INFORMATION

Sample Number: 1406220-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/27/2014 8:00 AB/DVC 6/27/2014 1:18:34 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-001

SAMPLE INFORMATION

Sample Number: 1406228-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-002

SAMPLE INFORMATION

Sample Number: 1406228-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-003

SAMPLE INFORMATION

Sample Number: 1406228-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-004

SAMPLE INFORMATION

Sample Number: 1406228-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-005

SAMPLE INFORMATION

Sample Number: 1406228-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-006

SAMPLE INFORMATION

Sample Number: 1406228-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-007

SAMPLE INFORMATION

Sample Number: 1406228-007
Location: 04
LPR 4122 7TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/30/2014
Collection Time: 8:00
Sampler: CW
Received Date and Time: 6/30/2014 11:39:23 AM
Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	12.9 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	35.9 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	8.00 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-007

SAMPLE INFORMATION

Sample Number: 1406228-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-008

SAMPLE INFORMATION

Sample Number: 1406228-008
Customer Sample Number:
Location: 04F
Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014
Collection Time: 8:00
Sampler: CW
Received Date and Time: 6/30/2014 11:39:23 AM
Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-009

SAMPLE INFORMATION

Sample Number: 1406228-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-010

SAMPLE INFORMATION

Sample Number: 1406228-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-011

SAMPLE INFORMATION

Sample Number: 1406228-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	9.36 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	23.2 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-011

SAMPLE INFORMATION

Sample Number: 1406228-011
Location: 06
LPR 4122 7TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/30/2014
Collection Time: 8:00
Sampler: CW
Received Date and Time: 6/30/2014 11:39:23 AM
Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-012

SAMPLE INFORMATION

Sample Number: 1406228-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-013

SAMPLE INFORMATION

Sample Number: 1406228-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	7.32 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	24.4 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-013

SAMPLE INFORMATION

Sample Number: 1406228-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-014

SAMPLE INFORMATION

Sample Number: 1406228-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-015

SAMPLE INFORMATION

Sample Number: 1406228-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	23.6 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	18.2 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-015

SAMPLE INFORMATION

Sample Number: 1406228-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-016

SAMPLE INFORMATION

Sample Number: 1406228-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	20.9 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	14.9 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-016

SAMPLE INFORMATION

Sample Number: 1406228-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-017

SAMPLE INFORMATION

Sample Number: 1406228-017
Location: 09
LPR 4122 7TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/30/2014
Collection Time: 8:00
Sampler: CW
Received Date and Time: 6/30/2014 11:39:23 AM
Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	15.8 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	17.6 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-017

SAMPLE INFORMATION

Sample Number: 1406228-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-018

SAMPLE INFORMATION

Sample Number: 1406228-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-019

SAMPLE INFORMATION

Sample Number: 1406228-019
Location: 10
LPR 4122 7TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
6/30/2014	8:00	CW	6/30/2014 11:39:23 AM	BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.00 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	18.3 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-019

SAMPLE INFORMATION

Sample Number: 1406228-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-020

SAMPLE INFORMATION

Sample Number: 1406228-020
Location: 10F
LPR 4122 7TH ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/30/2014
Collection Time: 8:00
Sampler: CW
Received Date and Time: 6/30/2014 11:39:23 AM
Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.58 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	15.2 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-020

SAMPLE INFORMATION

Sample Number: 1406228-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-021

SAMPLE INFORMATION

Sample Number: 1406228-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-022

SAMPLE INFORMATION

Sample Number: 1406228-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-023

SAMPLE INFORMATION

Sample Number: 1406228-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.01 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.34 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-023

SAMPLE INFORMATION

Sample Number: 1406228-023
Location: 12
LPR 4122 7TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-024

SAMPLE INFORMATION

Sample Number: 1406228-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-025

SAMPLE INFORMATION

Sample Number: 1406228-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-026

SAMPLE INFORMATION

Sample Number: 1406228-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.81 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.17 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-026

SAMPLE INFORMATION

Sample Number: 1406228-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-027

SAMPLE INFORMATION

Sample Number: 1406228-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-028

SAMPLE INFORMATION

Sample Number: 1406228-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-029

SAMPLE INFORMATION

Sample Number: 1406228-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-030

SAMPLE INFORMATION

Sample Number: 1406228-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-031

SAMPLE INFORMATION

Sample Number: 1406228-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.38 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.72 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-031

SAMPLE INFORMATION

Sample Number: 1406228-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-032

SAMPLE INFORMATION

Sample Number: 1406228-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-033

SAMPLE INFORMATION

Sample Number: 1406228-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-034

SAMPLE INFORMATION

Sample Number: 1406228-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-035

SAMPLE INFORMATION

Sample Number: 1406228-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 6/30/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 6/30/2014 11:39:23 AM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/2/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/2/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.15 ug/L	7/2/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/2/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.73 ug/L	7/2/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-035

SAMPLE INFORMATION

Sample Number: 1406228-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1406228-036

SAMPLE INFORMATION

Sample Number: 1406228-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/30/2014 8:00 CW 6/30/2014 11:39:23 AM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-001

SAMPLE INFORMATION

Sample Number: 1407018-001
Location: 1
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	24.4 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.38 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-001

SAMPLE INFORMATION

Sample Number: 1407018-001
Location: 1
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-002

SAMPLE INFORMATION

Sample Number: 1407018-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-003

SAMPLE INFORMATION

Sample Number: 1407018-003
Location: 02
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014	Collection Time: 8:00	Sampler: AB	Received Date and Time: 7/2/2014 1:10:16 PM	Received By: JCross
------------------------------	--------------------------	----------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	12.4 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	23.9 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.47 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-003

SAMPLE INFORMATION

Sample Number: 1407018-003
Location: 02
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-004

SAMPLE INFORMATION

Sample Number: 1407018-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-005

SAMPLE INFORMATION

Sample Number: 1407018-005
Location: 03
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014	Collection Time: 8:00	Sampler: AB	Received Date and Time: 7/2/2014 1:10:16 PM	Received By: JCross
------------------------------	--------------------------	----------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.13 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	17.8 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	19.4 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.05 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-005

SAMPLE INFORMATION

Sample Number: 1407018-005
Location: 03
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number:M- W1407018-006

SAMPLE INFORMATION

Sample Number: 1407018-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.0 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	17.5 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-006

SAMPLE INFORMATION

Sample Number: 1407018-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-007

SAMPLE INFORMATION

Sample Number: 1407018-007
Location: 04
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.47 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	19.7 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	15.6 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.92 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-007

SAMPLE INFORMATION

Sample Number: 1407018-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number:M- W1407018-008

SAMPLE INFORMATION

Sample Number: 1407018-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.26 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	14.3 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.09 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-008

SAMPLE INFORMATION

Sample Number: 1407018-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-009

SAMPLE INFORMATION

Sample Number: 1407018-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.03 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	19.8 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	8.90 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.80 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-009

SAMPLE INFORMATION

Sample Number: 1407018-009
Location: 05
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-010

SAMPLE INFORMATION

Sample Number: 1407018-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-011

SAMPLE INFORMATION

Sample Number: 1407018-011
Location: 06
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-012

SAMPLE INFORMATION

Sample Number: 1407018-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-013

SAMPLE INFORMATION

Sample Number: 1407018-013
Location: 07
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.42 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	21.2 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.62 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.72 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-013

SAMPLE INFORMATION

Sample Number: 1407018-013
Location: 07
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-014

SAMPLE INFORMATION

Sample Number: 1407018-014
Location: 07F
LPR 5442 31ST ST. NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 7/2/2014
Collection Time: 8:00
Sampler: AB
Received Date and Time: 7/2/2014 1:10:16 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.06 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.03 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.31 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-014

SAMPLE INFORMATION

Sample Number: 1407018-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/14/2014
 Report Number:M- W1407018-015

SAMPLE INFORMATION

Sample Number: 1407018-015
 Location: 08
 LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
 Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.52 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	21.3 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.31 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.58 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-015

SAMPLE INFORMATION

Sample Number: 1407018-015
Location: 08
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-016

SAMPLE INFORMATION

Sample Number: 1407018-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-017

SAMPLE INFORMATION

Sample Number: 1407018-017
Location: 09
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-018

SAMPLE INFORMATION

Sample Number: 1407018-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-019

SAMPLE INFORMATION

Sample Number: 1407018-019
Location: 10
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-020

SAMPLE INFORMATION

Sample Number: 1407018-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-021

SAMPLE INFORMATION

Sample Number: 1407018-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-022

SAMPLE INFORMATION

Sample Number: 1407018-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-023

SAMPLE INFORMATION

Sample Number: 1407018-023
Location: 12
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
7/2/2014	8:00	AB	7/2/2014 1:10:16 PM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.51 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	16.9 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.43 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.42 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-023

SAMPLE INFORMATION

Sample Number: 1407018-023
Location: 12
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-024

SAMPLE INFORMATION

Sample Number: 1407018-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-025

SAMPLE INFORMATION

Sample Number: 1407018-025
Location: 13
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014	Collection Time: 8:00	Sampler: AB	Received Date and Time: 7/2/2014 1:10:16 PM	Received By: JCross
------------------------------	--------------------------	----------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.44 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	16.2 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.46 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.78 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-025

SAMPLE INFORMATION

Sample Number: 1407018-025
Location: 13
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-026

SAMPLE INFORMATION

Sample Number: 1407018-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-027

SAMPLE INFORMATION

Sample Number: 1407018-027
Location: 14
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.47 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	16.4 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.71 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.30 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-027

SAMPLE INFORMATION

Sample Number: 1407018-027
Location: 14
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-028

SAMPLE INFORMATION

Sample Number: 1407018-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-029

SAMPLE INFORMATION

Sample Number: 1407018-029
Location: 15
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014	Collection Time: 8:00	Sampler: AB	Received Date and Time: 7/2/2014 1:10:16 PM	Received By: JCross
------------------------------	--------------------------	----------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.43 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	15.4 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.42 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.87 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-029

SAMPLE INFORMATION

Sample Number: 1407018-029
Location: 15
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-030

SAMPLE INFORMATION

Sample Number: 1407018-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-031

SAMPLE INFORMATION

Sample Number: 1407018-031
Location: H1
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/14/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-032

SAMPLE INFORMATION

Sample Number: 1407018-032
Location: H2
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014	Collection Time: 8:00	Sampler: AB	Received Date and Time: 7/2/2014 1:10:16 PM	Received By: JCross
------------------------------	--------------------------	----------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.50 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	28.8 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.96 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	6.10 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-032

SAMPLE INFORMATION

Sample Number: 1407018-032 Customer Sample Number:
Location: H2 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-033

SAMPLE INFORMATION

Sample Number: 1407018-033 Customer Sample Number:
Location: H3 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-034

SAMPLE INFORMATION

Sample Number: 1407018-034 Customer Sample Number:
Location: H4 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.35 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	23.2 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.71 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.02 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-034

SAMPLE INFORMATION

Sample Number: 1407018-034 Customer Sample Number:
Location: H4 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-035

SAMPLE INFORMATION

Sample Number: 1407018-035 Customer Sample Number:
Location: H5 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-036

SAMPLE INFORMATION

Sample Number: 1407018-036 Customer Sample Number:
Location: H6 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.26 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	22.4 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.76 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.82 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-036

SAMPLE INFORMATION

Sample Number: 1407018-036 Customer Sample Number:
Location: H6 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-037

SAMPLE INFORMATION

Sample Number: 1407018-037
Location: H7
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.27 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	21.3 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.72 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.48 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-037

SAMPLE INFORMATION

Sample Number: 1407018-037 Customer Sample Number:
Location: H7 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number:M- W1407018-038

SAMPLE INFORMATION

Sample Number: 1407018-038
Location: H8
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.22 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	20.8 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.24 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.39 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-038

SAMPLE INFORMATION

Sample Number: 1407018-038 Customer Sample Number:
Location: H8 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-039

SAMPLE INFORMATION

Sample Number: 1407018-039 Customer Sample Number:
Location: H9 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-040

SAMPLE INFORMATION

Sample Number: 1407018-040 Customer Sample Number:
Location: H10 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-041

SAMPLE INFORMATION

Sample Number: 1407018-041 Customer Sample Number:
Location: H11 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.24 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	18.9 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.95 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.97 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-041

SAMPLE INFORMATION

Sample Number: 1407018-041 Customer Sample Number:
Location: H11 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-042

SAMPLE INFORMATION

Sample Number: 1407018-042
Location: H12
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.23 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	18.3 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.52 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.90 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-042

SAMPLE INFORMATION

Sample Number: 1407018-042 Customer Sample Number:
Location: H12 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-043

SAMPLE INFORMATION

Sample Number: 1407018-043 Customer Sample Number:
Location: H13 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-044

SAMPLE INFORMATION

Sample Number: 1407018-044 Customer Sample Number:
Location: H14 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 7/2/2014 Collection Time: 8:00 Sampler: AB Received Date and Time: 7/2/2014 1:10:16 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.24 ug/L	7/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	18.2 ug/L	7/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.81 ug/L	7/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	7/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.77 ug/L	7/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-044

SAMPLE INFORMATION

Sample Number: 1407018-044 Customer Sample Number:
Location: H14 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/14/2014
Report Number: M- W1407018-045

SAMPLE INFORMATION

Sample Number: 1407018-045 Customer Sample Number:
Location: H15 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/2/2014 8:00 AB 7/2/2014 1:10:16 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/14/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-001

SAMPLE INFORMATION

Sample Number: 1408110-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-002

SAMPLE INFORMATION

Sample Number: 1408110-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-003

SAMPLE INFORMATION

Sample Number: 1408110-003
Location: 02
LPR 4633 47TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/12/2014
Collection Time: 8:00
Sampler: DM/YT
Received Date and Time: 8/13/2014 3:18:03 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.19 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	29.6 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	59.8 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	94.5 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.65 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-003

SAMPLE INFORMATION

Sample Number: 1408110-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-004

SAMPLE INFORMATION

Sample Number: 1408110-004	Customer Sample Number:			
Location: 02F LPR 4633 47TH ST NW FILTERED	Type: Dist.			
Collection Date: 8/12/2014	Collection Time: 8:00	Sampler: DM/YT	Received Date and Time: 8/13/2014 3:18:03 PM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	48.9 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	22.0 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.21 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-004

SAMPLE INFORMATION

Sample Number: 1408110-004
Customer Sample Number:
Location: 02F
Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014
Collection Time: 8:00
Sampler: DM/YT
Received Date and Time: 8/13/2014 3:18:03 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 9/4/2014
 Report Number:M- W1408110-005

SAMPLE INFORMATION

Sample Number: 1408110-005 Customer Sample Number:
 Location: 03 Type: Dist.
 LPR 4633 47TH ST NW UNFILTERED

Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.02 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.4 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	26.9 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	22.2 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.80 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-005

SAMPLE INFORMATION

Sample Number: 1408110-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-006

SAMPLE INFORMATION

Sample Number: 1408110-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-007

SAMPLE INFORMATION

Sample Number: 1408110-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.39 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	25.7 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.4 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	44.2 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.02 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-007

SAMPLE INFORMATION

Sample Number: 1408110-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-008

SAMPLE INFORMATION

Sample Number: 1408110-008	Customer Sample Number:			
Location: 04F LPR 4633 47TH ST NW FILTERED	Type: Dist.			
Collection Date: 8/12/2014	Collection Time: 8:00	Sampler: DM/YT	Received Date and Time: 8/13/2014 3:18:03 PM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.77 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.9 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	19.2 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.12 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-008

SAMPLE INFORMATION

Sample Number: 1408110-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

**US Army Corps of Engineers
Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-009

SAMPLE INFORMATION

Sample Number: 1408110-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.46 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	23.1 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.0 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	25.4 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.14 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-009

SAMPLE INFORMATION

Sample Number: 1408110-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-010

SAMPLE INFORMATION

Sample Number: 1408110-010
Customer Sample Number:
Location: 05F
Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014
Collection Time: 8:00
Sampler: DM/YT
Received Date and Time: 8/13/2014 3:18:03 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-011

SAMPLE INFORMATION

Sample Number: 1408110-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.37 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.2 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.54 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.1 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.77 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-011

SAMPLE INFORMATION

Sample Number: 1408110-011
Location: 06
LPR 4633 47TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/12/2014
Collection Time: 8:00
Sampler: DM/YT
Received Date and Time: 8/13/2014 3:18:03 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-012

SAMPLE INFORMATION

Sample Number: 1408110-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-013

SAMPLE INFORMATION

Sample Number: 1408110-013
Location: 07
LPR 4633 47TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.59 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.3 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.7 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	90.8 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.01 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-013

SAMPLE INFORMATION

Sample Number: 1408110-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-014

SAMPLE INFORMATION

Sample Number: 1408110-014
Customer Sample Number:
Location: 07F
Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014
Collection Time: 8:00
Sampler: DM/YT
Received Date and Time: 8/13/2014 3:18:03 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-015

SAMPLE INFORMATION

Sample Number: 1408110-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.37 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.2 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.73 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	18.3 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.47 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-015

SAMPLE INFORMATION

Sample Number: 1408110-015
Location: 08
LPR 4633 47TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/12/2014
Collection Time: 8:00
Sampler: DM/YT
Received Date and Time: 8/13/2014 3:18:03 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number:M- W1408110-016

SAMPLE INFORMATION

Sample Number: 1408110-016
Location: 08F
LPR 4633 47TH ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/12/2014
Collection Time: 8:00
Sampler: DM/YT
Received Date and Time: 8/13/2014 3:18:03 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.93 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.92 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.6 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-016

SAMPLE INFORMATION

Sample Number: 1408110-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-017

SAMPLE INFORMATION

Sample Number: 1408110-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.52 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	27.1 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.06 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.7 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.34 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-017

SAMPLE INFORMATION

Sample Number: 1408110-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-018

SAMPLE INFORMATION

Sample Number: 1408110-018

Customer Sample Number:

Location: 09F

Type: Dist.

LPR 4633 47TH ST NW FILTERED

Collection Date:
8/12/2014

Collection Time:
8:00

Sampler:
DM/YT

Received Date and Time:
8/13/2014 3:18:03 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.96 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.20 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	24.7 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-018

SAMPLE INFORMATION

Sample Number: 1408110-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-019

SAMPLE INFORMATION

Sample Number: 1408110-019
Location: 10
LPR 4633 47TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/12/2014
Collection Time: 8:00
Sampler: DM/YT
Received Date and Time: 8/13/2014 3:18:03 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-020

SAMPLE INFORMATION

Sample Number: 1408110-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-021

SAMPLE INFORMATION

Sample Number: 1408110-021
Location: 11
LPR 4633 47TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-022

SAMPLE INFORMATION

Sample Number: 1408110-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-023

SAMPLE INFORMATION

Sample Number: 1408110-023
Location: 12
LPR 4633 47TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
8/12/2014	8:00	DM/YT	8/13/2014 3:18:03 PM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.43 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.6 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.06 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	75.2 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.87 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-023

SAMPLE INFORMATION

Sample Number: 1408110-023
Location: 12
LPR 4633 47TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-024

SAMPLE INFORMATION

Sample Number: 1408110-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 4633 47TH ST NW FILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-025

SAMPLE INFORMATION

Sample Number: 1408110-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-026

SAMPLE INFORMATION

Sample Number: 1408110-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 9/4/2014
 Report Number: M- W1408110-027

SAMPLE INFORMATION

Sample Number: 1408110-027

Customer Sample Number:

Location: H3

Type: Dist.

LPR 4633 47TH ST NW UNFILTERED

Collection Date:
8/12/2014

Collection Time:
8:00

Sampler:
DM/YT

Received Date and Time:
8/13/2014 3:18:03 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.32 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.4 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.12 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.08 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.49 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-027

SAMPLE INFORMATION

Sample Number: 1408110-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-028

SAMPLE INFORMATION

Sample Number: 1408110-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-029

SAMPLE INFORMATION

Sample Number: 1408110-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-030

SAMPLE INFORMATION

Sample Number: 1408110-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-031

SAMPLE INFORMATION

Sample Number: 1408110-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.29 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.8 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.27 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.21 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.12 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-031

SAMPLE INFORMATION

Sample Number: 1408110-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-032

SAMPLE INFORMATION

Sample Number: 1408110-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-033

SAMPLE INFORMATION

Sample Number: 1408110-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: 8/12/2014 Collection Time: 8:00 Sampler: DM/YT Received Date and Time: 8/13/2014 3:18:03 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.33 ug/L	8/14/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.9 ug/L	8/14/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.02 ug/L	8/14/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.26 ug/L	8/14/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.04 ug/L	8/14/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-033

SAMPLE INFORMATION

Sample Number: 1408110-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-034

SAMPLE INFORMATION

Sample Number: 1408110-034
Location: H10
LPR 4633 47TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/12/2014
Collection Time: 8:00
Sampler: DM/YT
Received Date and Time: 8/13/2014 3:18:03 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-035

SAMPLE INFORMATION

Sample Number: 1408110-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408110-036

SAMPLE INFORMATION

Sample Number: 1408110-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 4633 47TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/12/2014 8:00 DM/YT 8/13/2014 3:18:03 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-001

SAMPLE INFORMATION

Sample Number: 1408198-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-003

SAMPLE INFORMATION

Sample Number: 1408198-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-004

SAMPLE INFORMATION

Sample Number: 1408198-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-005

SAMPLE INFORMATION

Sample Number: 1408198-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.75 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.39 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.66 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-005

SAMPLE INFORMATION

Sample Number: 1408198-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-006

SAMPLE INFORMATION

Sample Number: 1408198-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-007

SAMPLE INFORMATION

Sample Number: 1408198-007
Location: 04
LPR 4122 7TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/25/2014
Collection Time: 8:05
Sampler: AB/YT
Received Date and Time: 8/25/2014 2:39:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-008

SAMPLE INFORMATION

Sample Number: 1408198-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-009

SAMPLE INFORMATION

Sample Number: 1408198-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-011

SAMPLE INFORMATION

Sample Number: 1408198-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.68 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.10 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.1 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-011

SAMPLE INFORMATION

Sample Number: 1408198-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-012

SAMPLE INFORMATION

Sample Number: 1408198-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-013

SAMPLE INFORMATION

Sample Number: 1408198-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-014

SAMPLE INFORMATION

Sample Number: 1408198-014
Customer Sample Number:
Location: 07F
Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014
Collection Time: 8:05
Sampler: AB/YT
Received Date and Time: 8/25/2014 2:39:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-015

SAMPLE INFORMATION

Sample Number: 1408198-015
Location: 08
LPR 4122 7TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-016

SAMPLE INFORMATION

Sample Number: 1408198-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-017

SAMPLE INFORMATION

Sample Number: 1408198-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.8 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.60 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.9 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-017

SAMPLE INFORMATION

Sample Number: 1408198-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-018

SAMPLE INFORMATION

Sample Number: 1408198-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.4 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.97 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.4 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-018

SAMPLE INFORMATION

Sample Number: 1408198-018
Location: 09F
LPR 4122 7TH ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/25/2014
Collection Time: 8:05
Sampler: AB/YT
Received Date and Time: 8/25/2014 2:39:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-019

SAMPLE INFORMATION

Sample Number: 1408198-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.10 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.54 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.0 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-019

SAMPLE INFORMATION

Sample Number: 1408198-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-020

SAMPLE INFORMATION

Sample Number: 1408198-020
Location: 10F
LPR 4122 7TH ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-021

SAMPLE INFORMATION

Sample Number: 1408198-021
Location: 11
LPR 4122 7TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/25/2014
Collection Time: 8:05
Sampler: AB/YT
Received Date and Time: 8/25/2014 2:39:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.02 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.19 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.3 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-021

SAMPLE INFORMATION

Sample Number: 1408198-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 9/4/2014
 Report Number: M- W1408198-022

SAMPLE INFORMATION

Sample Number: 1408198-022	Customer Sample Number:			
Location: 11F LPR 4122 7TH ST NW FILTERED	Type: Dist.			
Collection Date: 8/25/2014	Collection Time: 8:05	Sampler: AB/YT	Received Date and Time: 8/25/2014 2:39:54 PM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.65 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.94 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.97 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-022

SAMPLE INFORMATION

Sample Number: 1408198-022
Location: 11F
LPR 4122 7TH ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/25/2014
Collection Time: 8:05
Sampler: AB/YT
Received Date and Time: 8/25/2014 2:39:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-023

SAMPLE INFORMATION

Sample Number: 1408198-023
Location: 12
LPR 4122 7TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/25/2014	Collection Time: 8:05	Sampler: AB/YT	Received Date and Time: 8/25/2014 2:39:54 PM	Received By: JCross
-------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.38 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.10 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.37 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-023

SAMPLE INFORMATION

Sample Number: 1408198-023
Location: 12
LPR 4122 7TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-024

SAMPLE INFORMATION

Sample Number: 1408198-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-025

SAMPLE INFORMATION

Sample Number: 1408198-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-026

SAMPLE INFORMATION

Sample Number: 1408198-026 Customer Sample Number:
Location: H1F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-027

SAMPLE INFORMATION

Sample Number: 1408198-027 Customer Sample Number:
Location: H2 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-028

SAMPLE INFORMATION

Sample Number: 1408198-028 Customer Sample Number:
Location: H2F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-029

SAMPLE INFORMATION

Sample Number: 1408198-029 Customer Sample Number:
Location: H3 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-030

SAMPLE INFORMATION

Sample Number: 1408198-030 Customer Sample Number:
Location: H3F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-031

SAMPLE INFORMATION

Sample Number: 1408198-031 Customer Sample Number:
Location: H4 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-032

SAMPLE INFORMATION

Sample Number: 1408198-032 Customer Sample Number:
Location: H4F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-033

SAMPLE INFORMATION

Sample Number: 1408198-033 Customer Sample Number:
Location: H6 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-035

SAMPLE INFORMATION

Sample Number: 1408198-035 Customer Sample Number:
Location: H7 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-036

SAMPLE INFORMATION

Sample Number: 1408198-036 Customer Sample Number:
Location: H7F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-037

SAMPLE INFORMATION

Sample Number: 1408198-037
Customer Sample Number:
Location: H8
Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: 8/25/2014
Collection Time: 8:05
Sampler: AB/YT
Received Date and Time: 8/25/2014 2:39:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-038

SAMPLE INFORMATION

Sample Number: 1408198-038 Customer Sample Number:
Location: H8F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-039

SAMPLE INFORMATION

Sample Number: 1408198-039 Customer Sample Number:
Location: H9 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-040

SAMPLE INFORMATION

Sample Number: 1408198-040
Location: H9F
LPR 4122 7TH ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/25/2014
Collection Time: 8:05
Sampler: AB/YT
Received Date and Time: 8/25/2014 2:39:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.61 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.76 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.77 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-040

SAMPLE INFORMATION

Sample Number: 1408198-040 Customer Sample Number:
Location: H9F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-041

SAMPLE INFORMATION

Sample Number: 1408198-041 Customer Sample Number:
Location: H10 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-042

SAMPLE INFORMATION

Sample Number: 1408198-042 Customer Sample Number:
Location: H10F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-043

SAMPLE INFORMATION

Sample Number: 1408198-043 Customer Sample Number:
Location: H11 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-044

SAMPLE INFORMATION

Sample Number: 1408198-044 Customer Sample Number:
Location: H11F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-045

SAMPLE INFORMATION

Sample Number: 1408198-045 Customer Sample Number:
Location: H12 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-046

SAMPLE INFORMATION

Sample Number: 1408198-046 Customer Sample Number:
Location: H12F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-047

SAMPLE INFORMATION

Sample Number: 1408198-047 Customer Sample Number:
Location: H5 Type: Dist.
LPR 4122 7TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/25/2014 8:05 AB/YT 8/25/2014 2:39:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-048

SAMPLE INFORMATION

Sample Number: 1408198-048 Customer Sample Number:
Location: H5F Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014 Collection Time: 8:05 Sampler: AB/YT Received Date and Time: 8/25/2014 2:39:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	8/27/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/27/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.97 ug/L	8/27/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.20 ug/L	8/27/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.88 ug/L	8/27/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: M- W1408198-048

SAMPLE INFORMATION

Sample Number: 1408198-048
Customer Sample Number:
Location: H5F
Type: Dist.
LPR 4122 7TH ST NW FILTERED
Collection Date: 8/25/2014
Collection Time: 8:05
Sampler: AB/YT
Received Date and Time: 8/25/2014 2:39:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-001

SAMPLE INFORMATION

Sample Number: 1407055-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.57 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	104 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	205 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.14 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-001

SAMPLE INFORMATION

Sample Number: 1407055-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-002

SAMPLE INFORMATION

Sample Number: 1407055-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-003

SAMPLE INFORMATION

Sample Number: 1407055-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-004

SAMPLE INFORMATION

Sample Number: 1407055-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-005

SAMPLE INFORMATION

Sample Number: 1407055-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.7 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.7 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.68 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-005

SAMPLE INFORMATION

Sample Number: 1407055-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-006

SAMPLE INFORMATION

Sample Number: 1407055-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.0 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	13.9 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-006

SAMPLE INFORMATION

Sample Number: 1407055-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-007

SAMPLE INFORMATION

Sample Number: 1407055-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.4 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	15.4 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.17 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-007

SAMPLE INFORMATION

Sample Number: 1407055-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-008

SAMPLE INFORMATION

Sample Number: 1407055-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-009

SAMPLE INFORMATION

Sample Number: 1407055-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.6 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	17.9 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.78 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-009

SAMPLE INFORMATION

Sample Number: 1407055-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-010

SAMPLE INFORMATION

Sample Number: 1407055-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.2 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	17.2 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.37 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-010

SAMPLE INFORMATION

Sample Number: 1407055-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-011

SAMPLE INFORMATION

Sample Number: 1407055-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.8 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.8 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.60 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-011

SAMPLE INFORMATION

Sample Number: 1407055-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-012

SAMPLE INFORMATION

Sample Number: 1407055-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.2 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.6 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.46 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-012

SAMPLE INFORMATION

Sample Number: 1407055-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-013

SAMPLE INFORMATION

Sample Number: 1407055-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-014

SAMPLE INFORMATION

Sample Number: 1407055-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.0 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.71 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.96 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-014

SAMPLE INFORMATION

Sample Number: 1407055-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-015

SAMPLE INFORMATION

Sample Number: 1407055-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.0 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.71 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.64 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-015

SAMPLE INFORMATION

Sample Number: 1407055-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-016

SAMPLE INFORMATION

Sample Number: 1407055-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.2 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.61 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.52 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-016

SAMPLE INFORMATION

Sample Number: 1407055-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-017

SAMPLE INFORMATION

Sample Number: 1407055-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.8 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.90 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.56 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-017

SAMPLE INFORMATION

Sample Number: 1407055-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-018

SAMPLE INFORMATION

Sample Number: 1407055-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-019

SAMPLE INFORMATION

Sample Number: 1407055-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.4 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.66 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.32 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-019

SAMPLE INFORMATION

Sample Number: 1407055-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-020

SAMPLE INFORMATION

Sample Number: 1407055-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.8 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.00 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.69 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-020

SAMPLE INFORMATION

Sample Number: 1407055-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-021

SAMPLE INFORMATION

Sample Number: 1407055-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.5 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.45 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.15 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-021

SAMPLE INFORMATION

Sample Number: 1407055-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-022

SAMPLE INFORMATION

Sample Number: 1407055-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-023

SAMPLE INFORMATION

Sample Number: 1407055-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-024

SAMPLE INFORMATION

Sample Number: 1407055-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.9 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.61 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.24 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-024

SAMPLE INFORMATION

Sample Number: 1407055-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-025

SAMPLE INFORMATION

Sample Number: 1407055-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	9/9/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.6 ug/L	9/9/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	33.0 ug/L	9/9/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	23.0 ug/L	9/9/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.18 ug/L	9/9/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-025

SAMPLE INFORMATION

Sample Number: 1407055-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-026

SAMPLE INFORMATION

Sample Number: 1407055-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.1 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.95 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.95 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-026

SAMPLE INFORMATION

Sample Number: 1407055-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-027

SAMPLE INFORMATION

Sample Number: 1407055-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-028

SAMPLE INFORMATION

Sample Number: 1407055-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.9 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.63 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.53 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-028

SAMPLE INFORMATION

Sample Number: 1407055-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-029

SAMPLE INFORMATION

Sample Number: 1407055-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-030

SAMPLE INFORMATION

Sample Number: 1407055-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.1 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.30 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.62 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-030

SAMPLE INFORMATION

Sample Number: 1407055-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-031

SAMPLE INFORMATION

Sample Number: 1407055-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.8 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.54 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.55 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-031

SAMPLE INFORMATION

Sample Number: 1407055-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-032

SAMPLE INFORMATION

Sample Number: 1407055-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-033

SAMPLE INFORMATION

Sample Number: 1407055-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-034

SAMPLE INFORMATION

Sample Number: 1407055-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 7/8/2014 Collection Time: 8:00 Sampler: CW Received Date and Time: 7/8/2014 3:44:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	7/24/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	7/24/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.4 ug/L	7/24/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.86 ug/L	7/24/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.60 ug/L	7/24/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-034

SAMPLE INFORMATION

Sample Number: 1407055-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-035

SAMPLE INFORMATION

Sample Number: 1407055-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1407055-036

SAMPLE INFORMATION

Sample Number: 1407055-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
7/8/2014 8:00 CW 7/8/2014 3:44:56 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-001

SAMPLE INFORMATION

Sample Number: 1408071-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-002

SAMPLE INFORMATION

Sample Number: 1408071-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-003

SAMPLE INFORMATION

Sample Number: 1408071-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.8 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.8 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.09 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-003

SAMPLE INFORMATION

Sample Number: 1408071-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-004

SAMPLE INFORMATION

Sample Number: 1408071-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-005

SAMPLE INFORMATION

Sample Number: 1408071-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-007

SAMPLE INFORMATION

Sample Number: 1408071-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-008

SAMPLE INFORMATION

Sample Number: 1408071-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.4 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	17.0 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.47 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-009

SAMPLE INFORMATION

Sample Number: 1408071-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-010

SAMPLE INFORMATION

Sample Number: 1408071-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-011

SAMPLE INFORMATION

Sample Number: 1408071-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-013

SAMPLE INFORMATION

Sample Number: 1408071-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-014

SAMPLE INFORMATION

Sample Number: 1408071-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.4 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.8 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.33 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-014

SAMPLE INFORMATION

Sample Number: 1408071-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-015

SAMPLE INFORMATION

Sample Number: 1408071-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-016

SAMPLE INFORMATION

Sample Number: 1408071-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-017

SAMPLE INFORMATION

Sample Number: 1408071-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-018

SAMPLE INFORMATION

Sample Number: 1408071-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-019

SAMPLE INFORMATION

Sample Number: 1408071-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.28 ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.5 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.18 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.15 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-019

SAMPLE INFORMATION

Sample Number: 1408071-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-020

SAMPLE INFORMATION

Sample Number: 1408071-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.6 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.02 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.23 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-020

SAMPLE INFORMATION

Sample Number: 1408071-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-021

SAMPLE INFORMATION

Sample Number: 1408071-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.64 ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.7 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.50 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.02 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-021

SAMPLE INFORMATION

Sample Number: 1408071-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-022

SAMPLE INFORMATION

Sample Number: 1408071-022	Customer Sample Number:			
Location: 1F LPR 2513 NORTH CAPITOL ST NE FILTERED	Type: Dist.			
Collection Date: 8/11/2014	Collection Time: 8:00	Sampler: IC/DC	Received Date and Time: 8/11/2014 11:21:20 AM	Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.1 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.49 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.29 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-022

SAMPLE INFORMATION

Sample Number: 1408071-022 Customer Sample Number:
Location: 1F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-023

SAMPLE INFORMATION

Sample Number: 1408071-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.03 ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.0 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.77 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.98 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-023

SAMPLE INFORMATION

Sample Number: 1408071-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-024

SAMPLE INFORMATION

Sample Number: 1408071-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2513 NORTH CAPITOL ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-025

SAMPLE INFORMATION

Sample Number: 1408071-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-026

SAMPLE INFORMATION

Sample Number: 1408071-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-027

SAMPLE INFORMATION

Sample Number: 1408071-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.99 ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.5 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.31 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.89 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-027

SAMPLE INFORMATION

Sample Number: 1408071-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-028

SAMPLE INFORMATION

Sample Number: 1408071-028
Customer Sample Number:
Location: H4
Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014
Collection Time: 8:00
Sampler: IC/DC
Received Date and Time: 8/11/2014 11:21:20 AM
Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-029

SAMPLE INFORMATION

Sample Number: 1408071-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.93 ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.0 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	13.3 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.92 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-029

SAMPLE INFORMATION

Sample Number: 1408071-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number:M- W1408071-030

SAMPLE INFORMATION

Sample Number: 1408071-030
Customer Sample Number:
Location: H6
Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014
Collection Time: 8:00
Sampler: IC/DC
Received Date and Time: 8/11/2014 11:21:20 AM
Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.88 ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.1 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.4 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.96 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-030

SAMPLE INFORMATION

Sample Number: 1408071-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-031

SAMPLE INFORMATION

Sample Number: 1408071-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: 8/11/2014 Collection Time: 8:00 Sampler: IC/DC Received Date and Time: 8/11/2014 11:21:20 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.86 ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.7 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.83 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.70 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-031

SAMPLE INFORMATION

Sample Number: 1408071-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-032

SAMPLE INFORMATION

Sample Number: 1408071-032

Customer Sample Number:

Location: H8

Type: Dist.

LPR 2513 NORTH CAPITOL ST NE UNFILTERED

Collection Date:
8/11/2014

Collection Time:
8:00

Sampler:
IC/DC

Received Date and Time:
8/11/2014 11:21:20 AM

Received By:
DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.86 ug/L	8/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	8/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.3 ug/L	8/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.31 ug/L	8/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.08 ug/L	8/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-032

SAMPLE INFORMATION

Sample Number: 1408071-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-033

SAMPLE INFORMATION

Sample Number: 1408071-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/10/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-034

SAMPLE INFORMATION

Sample Number: 1408071-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-035

SAMPLE INFORMATION

Sample Number: 1408071-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/10/2014
Report Number: M- W1408071-036

SAMPLE INFORMATION

Sample Number: 1408071-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2513 NORTH CAPITOL ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/11/2014 8:00 IC/DC 8/11/2014 11:21:20 AM DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/10/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-001

SAMPLE INFORMATION

Sample Number: 1409035-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.99 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.4 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	40.8 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	18.8 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.69 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-001

SAMPLE INFORMATION

Sample Number: 1409035-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-002

SAMPLE INFORMATION

Sample Number: 1409035-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-003

SAMPLE INFORMATION

Sample Number: 1409035-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.57 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	29.9 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.1 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.76 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.37 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-003

SAMPLE INFORMATION

Sample Number: 1409035-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 9/29/2014
 Report Number: M- W1409035-004

SAMPLE INFORMATION

Sample Number: 1409035-004	Customer Sample Number:			
Location: 02F	Type: Dist.			
LPR 3211 NEWARK ST NW FILTERED				
Collection Date: 9/4/2014	Collection Time: 7:30	Sampler: MS/CW	Received Date and Time: 9/4/2014 12:39:05 PM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.93 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.2 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.80 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-004

SAMPLE INFORMATION

Sample Number: 1409035-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-005

SAMPLE INFORMATION

Sample Number: 1409035-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.98 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	38.1 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.4 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.63 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.25 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-005

SAMPLE INFORMATION

Sample Number: 1409035-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-006

SAMPLE INFORMATION

Sample Number: 1409035-006
Location: 03F
LPR 3211 NEWARK ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/4/2014
Collection Time: 7:30
Sampler: MS/CW
Received Date and Time: 9/4/2014 12:39:05 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.62 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.4 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.28 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-006

SAMPLE INFORMATION

Sample Number: 1409035-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-007

SAMPLE INFORMATION

Sample Number: 1409035-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-008

SAMPLE INFORMATION

Sample Number: 1409035-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-009

SAMPLE INFORMATION

Sample Number: 1409035-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-010

SAMPLE INFORMATION

Sample Number: 1409035-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-011

SAMPLE INFORMATION

Sample Number: 1409035-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.68 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	32.7 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.0 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.78 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.71 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-011

SAMPLE INFORMATION

Sample Number: 1409035-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-012

SAMPLE INFORMATION

Sample Number: 1409035-012
Location: 06F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014	Collection Time: 7:30	Sampler: MS/CW	Received Date and Time: 9/4/2014 12:39:05 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.85 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.6 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.71 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-012

SAMPLE INFORMATION

Sample Number: 1409035-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-013

SAMPLE INFORMATION

Sample Number: 1409035-013
Location: 07
LPR 3211 NEWARK ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/4/2014
Collection Time: 7:30
Sampler: MS/CW
Received Date and Time: 9/4/2014 12:39:05 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.30 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	26.0 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.5 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.40 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.50 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-013

SAMPLE INFORMATION

Sample Number: 1409035-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-014

SAMPLE INFORMATION

Sample Number: 1409035-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-015

SAMPLE INFORMATION

Sample Number: 1409035-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-016

SAMPLE INFORMATION

Sample Number: 1409035-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-017

SAMPLE INFORMATION

Sample Number: 1409035-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.02 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	23.6 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.7 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.20 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.9 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-017

SAMPLE INFORMATION

Sample Number: 1409035-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-018

SAMPLE INFORMATION

Sample Number: 1409035-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-019

SAMPLE INFORMATION

Sample Number: 1409035-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.11 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.6 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.5 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.39 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.2 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-019

SAMPLE INFORMATION

Sample Number: 1409035-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-020

SAMPLE INFORMATION

Sample Number: 1409035-020
Location: 10F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.49 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.0 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.8 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.99 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-020

SAMPLE INFORMATION

Sample Number: 1409035-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-021

SAMPLE INFORMATION

Sample Number: 1409035-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.01 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.5 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	36.6 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.38 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	39.4 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-021

SAMPLE INFORMATION

Sample Number: 1409035-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-022

SAMPLE INFORMATION

Sample Number: 1409035-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-023

SAMPLE INFORMATION

Sample Number: 1409035-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-025

SAMPLE INFORMATION

Sample Number: 1409035-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.03 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.0 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	61.4 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.89 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	28.6 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-025

SAMPLE INFORMATION

Sample Number: 1409035-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-026

SAMPLE INFORMATION

Sample Number: 1409035-026
Location: 13F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-027

SAMPLE INFORMATION

Sample Number: 1409035-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-028

SAMPLE INFORMATION

Sample Number: 1409035-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-029

SAMPLE INFORMATION

Sample Number: 1409035-029 Customer Sample Number:
Location: 15 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-030

SAMPLE INFORMATION

Sample Number: 1409035-030
Location: 15F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.77 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	82.0 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	23.7 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.2 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-030

SAMPLE INFORMATION

Sample Number: 1409035-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-031

SAMPLE INFORMATION

Sample Number: 1409035-031 Customer Sample Number:
Location: 16 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-032

SAMPLE INFORMATION

Sample Number: 1409035-032
Location: 16F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.90 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	104 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	24.6 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.2 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-032

SAMPLE INFORMATION

Sample Number: 1409035-032
Location: 16F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-033

SAMPLE INFORMATION

Sample Number: 1409035-033 Customer Sample Number:
Location: 17 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-034

SAMPLE INFORMATION

Sample Number: 1409035-034
Location: 17F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.02 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	121 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	32.0 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.8 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-034

SAMPLE INFORMATION

Sample Number: 1409035-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-035

SAMPLE INFORMATION

Sample Number: 1409035-035 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-036

SAMPLE INFORMATION

Sample Number: 1409035-036 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.67 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	30.7 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	145 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	17.4 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.94 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-036

SAMPLE INFORMATION

Sample Number: 1409035-036 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-037

SAMPLE INFORMATION

Sample Number: 1409035-037 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.70 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	29.2 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	113 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.46 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.51 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-037

SAMPLE INFORMATION

Sample Number: 1409035-037 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-038

SAMPLE INFORMATION

Sample Number: 1409035-038 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-039

SAMPLE INFORMATION

Sample Number: 1409035-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-040

SAMPLE INFORMATION

Sample Number: 1409035-040 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.89 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	28.3 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	33.2 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.97 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.10 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-040

SAMPLE INFORMATION

Sample Number: 1409035-040 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-041

SAMPLE INFORMATION

Sample Number: 1409035-041 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.72 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	27.5 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	25.8 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.10 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.97 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-041

SAMPLE INFORMATION

Sample Number: 1409035-041 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-042

SAMPLE INFORMATION

Sample Number: 1409035-042 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-043

SAMPLE INFORMATION

Sample Number: 1409035-043 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-044

SAMPLE INFORMATION

Sample Number: 1409035-044 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-045

SAMPLE INFORMATION

Sample Number: 1409035-045 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.64 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	26.2 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.0 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.89 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.20 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-045

SAMPLE INFORMATION

Sample Number: 1409035-045 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-046

SAMPLE INFORMATION

Sample Number: 1409035-046 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.64 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	26.6 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.0 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.64 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.11 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-046

SAMPLE INFORMATION

Sample Number: 1409035-046 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-047

SAMPLE INFORMATION

Sample Number: 1409035-047 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-048

SAMPLE INFORMATION

Sample Number: 1409035-048 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.66 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	27.8 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.1 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.56 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.83 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-048

SAMPLE INFORMATION

Sample Number: 1409035-048 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-049

SAMPLE INFORMATION

Sample Number: 1409035-049 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.62 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	27.2 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.9 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.20 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.91 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-049

SAMPLE INFORMATION

Sample Number: 1409035-049 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-050

SAMPLE INFORMATION

Sample Number: 1409035-050 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.61 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	26.1 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.7 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.15 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.03 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-050

SAMPLE INFORMATION

Sample Number: 1409035-050 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-051

SAMPLE INFORMATION

Sample Number: 1409035-051 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-052

SAMPLE INFORMATION

Sample Number: 1409035-052

Customer Sample Number:

Location: H18

Type: Dist.

LPR 3211 NEWARK ST NW UNFILTERED

Collection Date:
9/4/2014

Collection Time:
7:30

Sampler:
MS/CW

Received Date and Time:
9/4/2014 12:39:05 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.60 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	25.8 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.3 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.15 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.26 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-052

SAMPLE INFORMATION

Sample Number: 1409035-052 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-053

SAMPLE INFORMATION

Sample Number: 1409035-053 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.68 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	26.2 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	24.0 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.42 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.08 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-053

SAMPLE INFORMATION

Sample Number: 1409035-053 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-054

SAMPLE INFORMATION

Sample Number: 1409035-054 Customer Sample Number:
Location: H20 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.65 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	25.7 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	30.2 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.17 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.36 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-054

SAMPLE INFORMATION

Sample Number: 1409035-054 Customer Sample Number:
Location: H20 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-055

SAMPLE INFORMATION

Sample Number: 1409035-055
Location: 18F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.08 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	131 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	39.2 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.68 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-055

SAMPLE INFORMATION

Sample Number: 1409035-055 Customer Sample Number:
Location: 18F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-056

SAMPLE INFORMATION

Sample Number: 1409035-056
Location: 19F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014	Collection Time: 7:30	Sampler: MS/CW	Received Date and Time: 9/4/2014 12:39:05 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.19 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	130 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	36.1 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.51 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-056

SAMPLE INFORMATION

Sample Number: 1409035-056
Location: 19F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-057

SAMPLE INFORMATION

Sample Number: 1409035-057
Location: 20F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.21 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	135 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	39.7 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.88 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-057

SAMPLE INFORMATION

Sample Number: 1409035-057 Customer Sample Number:
Location: 20F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-058

SAMPLE INFORMATION

Sample Number: 1409035-058 Customer Sample Number:
Location: refrigerator Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-059

SAMPLE INFORMATION

Sample Number: 1409035-059 Customer Sample Number:
Location: carbon filter Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-060

SAMPLE INFORMATION

Sample Number: 1409035-060 Customer Sample Number:
Location: 18 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED

Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.46 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	42.8 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	180 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	43.2 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	25.7 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-060

SAMPLE INFORMATION

Sample Number: 1409035-060 Customer Sample Number:
Location: 18 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-061

SAMPLE INFORMATION

Sample Number: 1409035-061 Customer Sample Number:
Location: 19 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.56 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	34.9 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	193 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	43.4 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.07 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-061

SAMPLE INFORMATION

Sample Number: 1409035-061 Customer Sample Number:
Location: 19 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-062

SAMPLE INFORMATION

Sample Number: 1409035-062 Customer Sample Number:
Location: 20 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 9/4/2014 Collection Time: 7:30 Sampler: MS/CW Received Date and Time: 9/4/2014 12:39:05 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.65 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	42.0 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	201 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	47.9 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.9 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409035-062

SAMPLE INFORMATION

Sample Number: 1409035-062 Customer Sample Number:
Location: 20 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/4/2014 7:30 MS/CW 9/4/2014 12:39:05 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-001

SAMPLE INFORMATION

Sample Number: 1409119-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-002

SAMPLE INFORMATION

Sample Number: 1409119-002
Location: 1F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-003

SAMPLE INFORMATION

Sample Number: 1409119-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	10.3 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.2 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.53 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.09 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-004

SAMPLE INFORMATION

Sample Number: 1409119-004
Location: 02F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-005

SAMPLE INFORMATION

Sample Number: 1409119-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-006

SAMPLE INFORMATION

Sample Number: 1409119-006
Location: 03F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-007

SAMPLE INFORMATION

Sample Number: 1409119-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-008

SAMPLE INFORMATION

Sample Number: 1409119-008
Location: 04F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-009

SAMPLE INFORMATION

Sample Number: 1409119-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-010

SAMPLE INFORMATION

Sample Number: 1409119-010
Location: 05F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.6 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.65 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.27 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-010

SAMPLE INFORMATION

Sample Number: 1409119-010
Location: 05F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-011

SAMPLE INFORMATION

Sample Number: 1409119-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-012

SAMPLE INFORMATION

Sample Number: 1409119-012
Location: 06F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.6 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	13.0 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.52 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-012

SAMPLE INFORMATION

Sample Number: 1409119-012
Location: 06F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-013

SAMPLE INFORMATION

Sample Number: 1409119-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-014

SAMPLE INFORMATION

Sample Number: 1409119-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 1327 S ST SE FILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.1 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.86 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.17 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-014

SAMPLE INFORMATION

Sample Number: 1409119-014
Location: 07F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-015

SAMPLE INFORMATION

Sample Number: 1409119-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-016

SAMPLE INFORMATION

Sample Number: 1409119-016
Location: 08F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.62 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.96 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.11 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-016

SAMPLE INFORMATION

Sample Number: 1409119-016
Location: 08F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-017

SAMPLE INFORMATION

Sample Number: 1409119-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.22 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	20.2 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.55 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.71 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.52 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-017

SAMPLE INFORMATION

Sample Number: 1409119-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-018

SAMPLE INFORMATION

Sample Number: 1409119-018
Location: 09F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014	Collection Time: 7:00	Sampler: CW/IC	Received Date and Time: 9/15/2014 1:09:29 PM	Received By: JCross
-------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-019

SAMPLE INFORMATION

Sample Number: 1409119-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-020

SAMPLE INFORMATION

Sample Number: 1409119-020
Location: 10F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-021

SAMPLE INFORMATION

Sample Number: 1409119-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/11/2014 7:00 CW/IC 9/15/2014 1:09:29 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-022

SAMPLE INFORMATION

Sample Number: 1409119-022
Location: 11F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-023

SAMPLE INFORMATION

Sample Number: 1409119-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-024

SAMPLE INFORMATION

Sample Number: 1409119-024
Location: 12F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.20 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.29 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.74 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-024

SAMPLE INFORMATION

Sample Number: 1409119-024
Location: 12F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-025

SAMPLE INFORMATION

Sample Number: 1409119-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-026

SAMPLE INFORMATION

Sample Number: 1409119-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.68 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	453 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	131 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	37.0 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	48.0 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-026

SAMPLE INFORMATION

Sample Number: 1409119-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-027

SAMPLE INFORMATION

Sample Number: 1409119-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.07 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	234 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	83.3 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	27.0 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	25.0 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-027

SAMPLE INFORMATION

Sample Number: 1409119-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-028

SAMPLE INFORMATION

Sample Number: 1409119-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-029

SAMPLE INFORMATION

Sample Number: 1409119-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-030

SAMPLE INFORMATION

Sample Number: 1409119-030
Location: H6
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/11/2014
Collection Time: 7:00
Sampler: CW/IC
Received Date and Time: 9/15/2014 1:09:29 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.44 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	77.6 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	32.9 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.8 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.62 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-030

SAMPLE INFORMATION

Sample Number: 1409119-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-031

SAMPLE INFORMATION

Sample Number: 1409119-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.25 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	64.1 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	28.8 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.9 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.29 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-031

SAMPLE INFORMATION

Sample Number: 1409119-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-032

SAMPLE INFORMATION

Sample Number: 1409119-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.13 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	55.4 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	26.7 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.0 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.47 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-032

SAMPLE INFORMATION

Sample Number: 1409119-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-033

SAMPLE INFORMATION

Sample Number: 1409119-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-034

SAMPLE INFORMATION

Sample Number: 1409119-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.97 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	44.2 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.7 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.29 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.37 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-034

SAMPLE INFORMATION

Sample Number: 1409119-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-035

SAMPLE INFORMATION

Sample Number: 1409119-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  9/29/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-036

SAMPLE INFORMATION

Sample Number: 1409119-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.86 ug/L	9/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	36.0 ug/L	9/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.3 ug/L	9/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.33 ug/L	9/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.31 ug/L	9/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/29/2014
Report Number: M- W1409119-036

SAMPLE INFORMATION

Sample Number: 1409119-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 9/11/2014 Collection Time: 7:00 Sampler: CW/IC Received Date and Time: 9/15/2014 1:09:29 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/29/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-001

SAMPLE INFORMATION

Sample Number: 1409158-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: 10 X dilution

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-002

SAMPLE INFORMATION

Sample Number: 1409158-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-003

SAMPLE INFORMATION

Sample Number: 1409158-003
Location: 02
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.01 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	12.8 ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.7 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	48.1 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	174 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-003

SAMPLE INFORMATION

Sample Number: 1409158-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-004

SAMPLE INFORMATION

Sample Number: 1409158-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-005

SAMPLE INFORMATION

Sample Number: 1409158-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-006

SAMPLE INFORMATION

Sample Number: 1409158-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-007

SAMPLE INFORMATION

Sample Number: 1409158-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-008

SAMPLE INFORMATION

Sample Number: 1409158-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-009

SAMPLE INFORMATION

Sample Number: 1409158-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-010

SAMPLE INFORMATION

Sample Number: 1409158-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.37 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.4 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.5 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-010

SAMPLE INFORMATION

Sample Number: 1409158-010
Customer Sample Number:
Location: 05F
Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014
Collection Time: 8:30
Sampler: CW/IC
Received Date and Time: 9/19/2014 11:43:07 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-011

SAMPLE INFORMATION

Sample Number: 1409158-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-012

SAMPLE INFORMATION

Sample Number: 1409158-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.3 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.3 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.12 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-012

SAMPLE INFORMATION

Sample Number: 1409158-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-013

SAMPLE INFORMATION

Sample Number: 1409158-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-014

SAMPLE INFORMATION

Sample Number: 1409158-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.63 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.8 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.04 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-014

SAMPLE INFORMATION

Sample Number: 1409158-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-015

SAMPLE INFORMATION

Sample Number: 1409158-015
Location: 08
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.99 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.61 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.1 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-015

SAMPLE INFORMATION

Sample Number: 1409158-015
Location: 08
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-016

SAMPLE INFORMATION

Sample Number: 1409158-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.99 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.5 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.17 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-016

SAMPLE INFORMATION

Sample Number: 1409158-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-017

SAMPLE INFORMATION

Sample Number: 1409158-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-018

SAMPLE INFORMATION

Sample Number: 1409158-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-019

SAMPLE INFORMATION

Sample Number: 1409158-019
Location: 10
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/19/2014	Collection Time: 8:30	Sampler: CW/IC	Received Date and Time: 9/19/2014 11:43:07 AM	Received By: JCross
-------------------------------	--------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.29 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.7 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.21 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-019

SAMPLE INFORMATION

Sample Number: 1409158-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-020

SAMPLE INFORMATION

Sample Number: 1409158-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-021

SAMPLE INFORMATION

Sample Number: 1409158-021
Location: 11
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.40 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.05 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.96 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-021

SAMPLE INFORMATION

Sample Number: 1409158-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-022

SAMPLE INFORMATION

Sample Number: 1409158-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-023

SAMPLE INFORMATION

Sample Number: 1409158-023
Location: 12
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number:M- W1409158-024

SAMPLE INFORMATION

Sample Number: 1409158-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	10/16/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/16/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.43 ug/L	10/16/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.01 ug/L	10/16/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.56 ug/L	10/16/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-024

SAMPLE INFORMATION

Sample Number: 1409158-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-025

SAMPLE INFORMATION

Sample Number: 1409158-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.07 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	46.7 ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	39.6 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	52.9 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8 10 x dilution	ug/L	ug/L	0.2 ug/L	1010 ug/L	9/29/2014	RHoffa

Comment: 10 x dilution

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-025

SAMPLE INFORMATION

Sample Number: 1409158-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: 10 x dilution

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-026

SAMPLE INFORMATION

Sample Number: 1409158-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-027

SAMPLE INFORMATION

Sample Number: 1409158-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.97 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	48.8 ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.6 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.0 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	126 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-027

SAMPLE INFORMATION

Sample Number: 1409158-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-028

SAMPLE INFORMATION

Sample Number: 1409158-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-029

SAMPLE INFORMATION

Sample Number: 1409158-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.91 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.6 ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.9 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	13.6 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	127 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-029

SAMPLE INFORMATION

Sample Number: 1409158-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-030

SAMPLE INFORMATION

Sample Number: 1409158-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-031

SAMPLE INFORMATION

Sample Number: 1409158-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.67 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	25.4 ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.0 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.7 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.8 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-031

SAMPLE INFORMATION

Sample Number: 1409158-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 10/27/2014
 Report Number: M- W1409158-032

SAMPLE INFORMATION

Sample Number: 1409158-032
 Location: H8
 LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
 Type: Dist.

Collection Date: 9/19/2014	Collection Time: 8:30	Sampler: CW/IC	Received Date and Time: 9/19/2014 11:43:07 AM	Received By: JCross
-------------------------------	--------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	27.1 ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.6 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.2 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	46.5 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-032

SAMPLE INFORMATION

Sample Number: 1409158-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/27/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-033

SAMPLE INFORMATION

Sample Number: 1409158-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.61 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.9 ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.2 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.51 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.6 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-033

SAMPLE INFORMATION

Sample Number: 1409158-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-034

SAMPLE INFORMATION

Sample Number: 1409158-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 9/19/2014 Collection Time: 8:30 Sampler: CW/IC Received Date and Time: 9/19/2014 11:43:07 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.49 ug/L	9/29/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.3 ug/L	9/29/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.7 ug/L	9/29/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	16.8 ug/L	9/29/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.7 ug/L	9/29/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-034

SAMPLE INFORMATION

Sample Number: 1409158-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-035

SAMPLE INFORMATION

Sample Number: 1409158-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2014
Report Number: M- W1409158-036

SAMPLE INFORMATION

Sample Number: 1409158-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/19/2014 8:30 CW/IC 9/19/2014 11:43:07 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/27/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-001

SAMPLE INFORMATION

Sample Number: 1410042-001
Location: 1
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/7/2014
Collection Time: 7:00
Sampler: CW/DVC
Received Date and Time: 10/7/2014 12:13:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-002

SAMPLE INFORMATION

Sample Number: 1410042-002
Location: 1F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.9 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	28.2 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	53.6 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-002

SAMPLE INFORMATION

Sample Number: 1410042-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 1327 S ST SE FILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-003

SAMPLE INFORMATION

Sample Number: 1410042-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	35.4 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.6 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.47 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.08 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-004

SAMPLE INFORMATION

Sample Number: 1410042-004
Location: 02F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-005

SAMPLE INFORMATION

Sample Number: 1410042-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1327 S ST SE UNFILTERED

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.3 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	11.8 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.3 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.85 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.17 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-005

SAMPLE INFORMATION

Sample Number: 1410042-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-006

SAMPLE INFORMATION

Sample Number: 1410042-006
Location: 03F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.8 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.5 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.79 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-006

SAMPLE INFORMATION

Sample Number: 1410042-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 1327 S ST SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-007

SAMPLE INFORMATION

Sample Number: 1410042-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-009

SAMPLE INFORMATION

Sample Number: 1410042-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-010

SAMPLE INFORMATION

Sample Number: 1410042-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 1327 S ST SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-011

SAMPLE INFORMATION

Sample Number: 1410042-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	35.1 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.09 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.4 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.3 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.45 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.07 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-011

SAMPLE INFORMATION

Sample Number: 1410042-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-012

SAMPLE INFORMATION

Sample Number: 1410042-012
Location: 06F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
10/7/2014	7:00	CW/DVC	10/7/2014 12:13:54 PM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.8 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.3 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.41 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-012

SAMPLE INFORMATION

Sample Number: 1410042-012
Location: 06F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-013

SAMPLE INFORMATION

Sample Number: 1410042-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	34.8 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.07 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	11.5 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.8 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.12 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-013

SAMPLE INFORMATION

Sample Number: 1410042-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-014

SAMPLE INFORMATION

Sample Number: 1410042-014
Customer Sample Number:
Location: 07F
Type: Dist.
LPR 1327 S ST SE FILTERED
Collection Date: 10/7/2014
Collection Time: 7:00
Sampler: CW/DVC
Received Date and Time: 10/7/2014 12:13:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number:M- W1410042-015

SAMPLE INFORMATION

Sample Number: 1410042-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	34.6 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.06 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	11.3 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.4 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.86 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-015

SAMPLE INFORMATION

Sample Number: 1410042-015
Location: 08
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/7/2014
Collection Time: 7:00
Sampler: CW/DVC
Received Date and Time: 10/7/2014 12:13:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-016

SAMPLE INFORMATION

Sample Number: 1410042-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 1327 S ST SE FILTERED

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.9 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.76 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.15 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-016

SAMPLE INFORMATION

Sample Number: 1410042-016
Location: 08F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-017

SAMPLE INFORMATION

Sample Number: 1410042-017
Location: 09
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/7/2014
Collection Time: 7:00
Sampler: CW/DVC
Received Date and Time: 10/7/2014 12:13:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	35.8 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.08 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.2 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.5 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.73 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-017

SAMPLE INFORMATION

Sample Number: 1410042-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-018

SAMPLE INFORMATION

Sample Number: 1410042-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 1327 S ST SE FILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-019

SAMPLE INFORMATION

Sample Number: 1410042-019
Location: 10
LPR 1327 S ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-020

SAMPLE INFORMATION

Sample Number: 1410042-020
Location: 10F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014	Collection Time: 7:00	Sampler: CW/DVC	Received Date and Time: 10/7/2014 12:13:54 PM	Received By: JCross
-------------------------------	--------------------------	--------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	31.0 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.14 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.64 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-020

SAMPLE INFORMATION

Sample Number: 1410042-020
Location: 10F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-021

SAMPLE INFORMATION

Sample Number: 1410042-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	35.0 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.08 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	10.4 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.1 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.53 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-021

SAMPLE INFORMATION

Sample Number: 1410042-021
Location: 11
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/7/2014
Collection Time: 7:00
Sampler: CW/DVC
Received Date and Time: 10/7/2014 12:13:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-022

SAMPLE INFORMATION

Sample Number: 1410042-022
Location: 11F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-023

SAMPLE INFORMATION

Sample Number: 1410042-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-024

SAMPLE INFORMATION

Sample Number: 1410042-024
Location: 12F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-025

SAMPLE INFORMATION

Sample Number: 1410042-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	62.5 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.93 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	65.9 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	26.1 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	18.7 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.15 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-025

SAMPLE INFORMATION

Sample Number: 1410042-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-026

SAMPLE INFORMATION

Sample Number: 1410042-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	46.3 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.53 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	37.8 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.4 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.7 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.96 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-026

SAMPLE INFORMATION

Sample Number: 1410042-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-027

SAMPLE INFORMATION

Sample Number: 1410042-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	45.7 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.49 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	34.9 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.4 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.85 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.08 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-027

SAMPLE INFORMATION

Sample Number: 1410042-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-028

SAMPLE INFORMATION

Sample Number: 1410042-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	45.1 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.51 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	37.1 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.9 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.49 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.21 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-028

SAMPLE INFORMATION

Sample Number: 1410042-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-029

SAMPLE INFORMATION

Sample Number: 1410042-029
Location: H5
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/7/2014
Collection Time: 7:00
Sampler: CW/DVC
Received Date and Time: 10/7/2014 12:13:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-030

SAMPLE INFORMATION

Sample Number: 1410042-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.1 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.32 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	26.9 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.9 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.20 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.17 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-030

SAMPLE INFORMATION

Sample Number: 1410042-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-031

SAMPLE INFORMATION

Sample Number: 1410042-031
Customer Sample Number:
Location: H7
Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014
Collection Time: 7:00
Sampler: CW/DVC
Received Date and Time: 10/7/2014 12:13:54 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.6 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.29 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.1 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.0 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.56 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.99 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-031

SAMPLE INFORMATION

Sample Number: 1410042-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-033

SAMPLE INFORMATION

Sample Number: 1410042-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-034

SAMPLE INFORMATION

Sample Number: 1410042-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 10/7/2014 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 10/7/2014 12:13:54 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.4 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.26 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.0 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.4 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.33 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.94 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-034

SAMPLE INFORMATION

Sample Number: 1410042-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-035

SAMPLE INFORMATION

Sample Number: 1410042-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410042-036

SAMPLE INFORMATION

Sample Number: 1410042-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/7/2014 7:00 CW/DVC 10/7/2014 12:13:54 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-001

SAMPLE INFORMATION

Sample Number: 1410057-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	37.8 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.56 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	85.6 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	61.6 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	21.5 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-001

SAMPLE INFORMATION

Sample Number: 1410057-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-002

SAMPLE INFORMATION

Sample Number: 1410057-002
Customer Sample Number:
Location: 01F
Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Michael Chicoine, Laboratory Manager
11/17/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-003

SAMPLE INFORMATION

Sample Number: 1410057-003
Location: 02
LPR 3211 NEWARK ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.9 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.9 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	30.3 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.26 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.08 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-003

SAMPLE INFORMATION

Sample Number: 1410057-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-004

SAMPLE INFORMATION

Sample Number: 1410057-004
Customer Sample Number:
Location: 02F
Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.1 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.37 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	26.1 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.21 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-005

SAMPLE INFORMATION

Sample Number: 1410057-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.6 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.49 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	29.2 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.14 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.33 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-005

SAMPLE INFORMATION

Sample Number: 1410057-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-006

SAMPLE INFORMATION

Sample Number: 1410057-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-007

SAMPLE INFORMATION

Sample Number: 1410057-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-008

SAMPLE INFORMATION

Sample Number: 1410057-008
Customer Sample Number:
Location: 04F
Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-009

SAMPLE INFORMATION

Sample Number: 1410057-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.5 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.37 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	35.1 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.72 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.23 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-009

SAMPLE INFORMATION

Sample Number: 1410057-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-010

SAMPLE INFORMATION

Sample Number: 1410057-010
Customer Sample Number:
Location: 05F
Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-011

SAMPLE INFORMATION

Sample Number: 1410057-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-012

SAMPLE INFORMATION

Sample Number: 1410057-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-013

SAMPLE INFORMATION

Sample Number: 1410057-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.0 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.58 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	26.7 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.95 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.36 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-013

SAMPLE INFORMATION

Sample Number: 1410057-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-014

SAMPLE INFORMATION

Sample Number: 1410057-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.2 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.10 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.8 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.89 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.19 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-014

SAMPLE INFORMATION

Sample Number: 1410057-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-015

SAMPLE INFORMATION

Sample Number: 1410057-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.4 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.51 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	26.3 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.67 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.76 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-015

SAMPLE INFORMATION

Sample Number: 1410057-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-016

SAMPLE INFORMATION

Sample Number: 1410057-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-017

SAMPLE INFORMATION

Sample Number: 1410057-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.9 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.48 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	27.3 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.59 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.08 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-017

SAMPLE INFORMATION

Sample Number: 1410057-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-018

SAMPLE INFORMATION

Sample Number: 1410057-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	29.7 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	24.3 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.64 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.58 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-018

SAMPLE INFORMATION

Sample Number: 1410057-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-019

SAMPLE INFORMATION

Sample Number: 1410057-019
Location: 10
LPR 3211 NEWARK ST NW UNFILTERED
Customer Sample Number:
Type: Dist.

Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.4 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.49 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	31.0 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.51 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.92 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-019

SAMPLE INFORMATION

Sample Number: 1410057-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-020

SAMPLE INFORMATION

Sample Number: 1410057-020
Location: 10F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.9 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	26.5 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.53 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.63 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-020

SAMPLE INFORMATION

Sample Number: 1410057-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-021

SAMPLE INFORMATION

Sample Number: 1410057-021
Location: 11
LPR 3211 NEWARK ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.1 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.42 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	38.2 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.71 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.86 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-021

SAMPLE INFORMATION

Sample Number: 1410057-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-022

SAMPLE INFORMATION

Sample Number: 1410057-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.4 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	34.9 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.62 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-022

SAMPLE INFORMATION

Sample Number: 1410057-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-023

SAMPLE INFORMATION

Sample Number: 1410057-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	37.8 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.38 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	50.5 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.25 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.80 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-023

SAMPLE INFORMATION

Sample Number: 1410057-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-025

SAMPLE INFORMATION

Sample Number: 1410057-025
Location: 13
LPR 3211 NEWARK ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-026

SAMPLE INFORMATION

Sample Number: 1410057-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-027

SAMPLE INFORMATION

Sample Number: 1410057-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	37.3 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.40 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	93.1 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.55 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.44 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-027

SAMPLE INFORMATION

Sample Number: 1410057-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-028

SAMPLE INFORMATION

Sample Number: 1410057-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-029

SAMPLE INFORMATION

Sample Number: 1410057-029 Customer Sample Number:
Location: 15 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	36.7 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.35 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	110 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.81 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.39 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-029

SAMPLE INFORMATION

Sample Number: 1410057-029
Location: 15
LPR 3211 NEWARK ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-030

SAMPLE INFORMATION

Sample Number: 1410057-030
Location: 15F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.1 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	100 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.18 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.49 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-030

SAMPLE INFORMATION

Sample Number: 1410057-030
Location: 15F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-031

SAMPLE INFORMATION

Sample Number: 1410057-031
Location: 16
LPR 3211 NEWARK ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	36.8 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.34 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	135 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.98 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.15 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-031

SAMPLE INFORMATION

Sample Number: 1410057-031
Location: 16
LPR 3211 NEWARK ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-032

SAMPLE INFORMATION

Sample Number: 1410057-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-033

SAMPLE INFORMATION

Sample Number: 1410057-033 Customer Sample Number:
Location: 17 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	36.4 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.31 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	167 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.47 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.48 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-033

SAMPLE INFORMATION

Sample Number: 1410057-033 Customer Sample Number:
Location: 17 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-034

SAMPLE INFORMATION

Sample Number: 1410057-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.9 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	151 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.54 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-034

SAMPLE INFORMATION

Sample Number: 1410057-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-035

SAMPLE INFORMATION

Sample Number: 1410057-035
Customer Sample Number:
Location: H1
Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-036

SAMPLE INFORMATION

Sample Number: 1410057-036 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED

Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	38.4 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.39 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	155 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.07 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-036

SAMPLE INFORMATION

Sample Number: 1410057-036 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-037

SAMPLE INFORMATION

Sample Number: 1410057-037
Location: H3
LPR 3211 NEWARK ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	38.3 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.28 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	136 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.85 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-037

SAMPLE INFORMATION

Sample Number: 1410057-037
Customer Sample Number:
Location: H3
Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-038

SAMPLE INFORMATION

Sample Number: 1410057-038 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-039

SAMPLE INFORMATION

Sample Number: 1410057-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.6 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.44 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	11.2 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	102 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.94 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-039

SAMPLE INFORMATION

Sample Number: 1410057-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-040

SAMPLE INFORMATION

Sample Number: 1410057-040 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED

Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	42.6 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.66 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.7 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	81.6 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.89 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-040

SAMPLE INFORMATION

Sample Number: 1410057-040 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-041

SAMPLE INFORMATION

Sample Number: 1410057-041 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	46.5 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.88 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.2 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	66.4 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.00 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.41 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-041

SAMPLE INFORMATION

Sample Number: 1410057-041
Customer Sample Number:
Location: H7
Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-042

SAMPLE INFORMATION

Sample Number: 1410057-042 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	45.9 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.83 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.9 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	41.1 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.63 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.38 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-043

SAMPLE INFORMATION

Sample Number: 1410057-043 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-044

SAMPLE INFORMATION

Sample Number: 1410057-044 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.2 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.8 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	29.7 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.72 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.05 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-044

SAMPLE INFORMATION

Sample Number: 1410057-044
Customer Sample Number:
Location: H10
Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-045

SAMPLE INFORMATION

Sample Number: 1410057-045 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-047

SAMPLE INFORMATION

Sample Number: 1410057-047 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.1 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.76 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	20.0 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	24.2 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.10 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.03 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-047

SAMPLE INFORMATION

Sample Number: 1410057-047 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-049

SAMPLE INFORMATION

Sample Number: 1410057-049 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.2 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.77 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	20.9 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.2 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.04 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-049

SAMPLE INFORMATION

Sample Number: 1410057-049 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  11/17/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-050

SAMPLE INFORMATION

Sample Number: 1410057-050 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.6 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.83 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.9 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.4 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.20 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-050

SAMPLE INFORMATION

Sample Number: 1410057-050
Customer Sample Number:
Location: H16
Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-051

SAMPLE INFORMATION

Sample Number: 1410057-051 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014 Collection Time: 7:15 Sampler: CW Received Date and Time: 10/8/2014 12:47:30 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.4 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.79 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	23.1 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.5 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.44 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.07 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-051

SAMPLE INFORMATION

Sample Number: 1410057-051 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-052

SAMPLE INFORMATION

Sample Number: 1410057-052 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-053

SAMPLE INFORMATION

Sample Number: 1410057-053
Location: H19
LPR 3211 NEWARK ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	43.3 ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.76 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	20.0 ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	33.9 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.24 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.11 ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-053

SAMPLE INFORMATION

Sample Number: 1410057-053 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/8/2014 7:15 CW 10/8/2014 12:47:30 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-054

SAMPLE INFORMATION

Sample Number: 1410057-054
Customer Sample Number:
Location: H20
Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 10/8/2014
Collection Time: 7:15
Sampler: CW
Received Date and Time: 10/8/2014 12:47:30 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-055

SAMPLE INFORMATION

Sample Number: 1410057-055

Customer Sample Number:

Location:

Type: Dist.

LPR REFRIGERATOR UNFILTERED

Collection Date:
10/8/2014

Collection Time:
7:15

Sampler:
0

Received Date and Time:
10/8/2014 12:47:30 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.69 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-055

SAMPLE INFORMATION

Sample Number: 1410057-055

Customer Sample Number:

Location:

Type: Dist.

LPR REFRIGERATOR UNFILTERED

Collection Date:
10/8/2014

Collection Time:
7:15

Sampler:
0

Received Date and Time:
10/8/2014 12:47:30 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-056

SAMPLE INFORMATION

Sample Number: 1410057-056

Customer Sample Number:

Location:

Type: Dist.

LPR CARBON FILTER UNFILTERED

Collection Date:
10/8/2014

Collection Time:
7:15

Sampler:
0

Received Date and Time:
10/8/2014 12:47:30 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.45 ug/L	10/21/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	10/21/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.86 ug/L	10/21/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	933 ug/L	10/21/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	10/21/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/17/2014
Report Number: M- W1410057-056

SAMPLE INFORMATION

Sample Number: 1410057-056

Customer Sample Number:

Location:

Type: Dist.

LPR CARBON FILTER UNFILTERED

Collection Date:
10/8/2014

Collection Time:
7:15

Sampler:
0

Received Date and Time:
10/8/2014 12:47:30 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

11/17/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-001

SAMPLE INFORMATION

Sample Number: 1411103-001
Location: 1
LPR 2106 16TH ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/12/2014
Collection Time: 9:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 10:53:55 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.4 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	86.3 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	32.9 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	194 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	99.1 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-001

SAMPLE INFORMATION

Sample Number: 1411103-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-002

SAMPLE INFORMATION

Sample Number: 1411103-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-003

SAMPLE INFORMATION

Sample Number: 1411103-003
Location: 02
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/12/2014	9:00	DVC/CW	11/14/2014 10:53:55 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.1 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.4 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	19.6 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	32.7 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-003

SAMPLE INFORMATION

Sample Number: 1411103-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-004

SAMPLE INFORMATION

Sample Number: 1411103-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-005

SAMPLE INFORMATION

Sample Number: 1411103-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-006

SAMPLE INFORMATION

Sample Number: 1411103-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.7 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.69 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	18.0 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	24.1 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-006

SAMPLE INFORMATION

Sample Number: 1411103-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-007

SAMPLE INFORMATION

Sample Number: 1411103-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.3 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.03 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.8 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.5 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-007

SAMPLE INFORMATION

Sample Number: 1411103-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-008

SAMPLE INFORMATION

Sample Number: 1411103-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-009

SAMPLE INFORMATION

Sample Number: 1411103-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-010

SAMPLE INFORMATION

Sample Number: 1411103-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-011

SAMPLE INFORMATION

Sample Number: 1411103-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-012

SAMPLE INFORMATION

Sample Number: 1411103-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.5 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.8 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.7 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.50 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-012

SAMPLE INFORMATION

Sample Number: 1411103-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-013

SAMPLE INFORMATION

Sample Number: 1411103-013
Location: 07
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/12/2014	9:00	DVC/CW	11/14/2014 10:53:55 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.4 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.95 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.0 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.3 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-013

SAMPLE INFORMATION

Sample Number: 1411103-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-014

SAMPLE INFORMATION

Sample Number: 1411103-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-015

SAMPLE INFORMATION

Sample Number: 1411103-015
Location: 08
LPR 2106 16TH ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/12/2014
Collection Time: 9:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 10:53:55 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-016

SAMPLE INFORMATION

Sample Number: 1411103-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-017

SAMPLE INFORMATION

Sample Number: 1411103-017
Location: 09
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.6 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.33 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.38 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.83 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-017

SAMPLE INFORMATION

Sample Number: 1411103-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-018

SAMPLE INFORMATION

Sample Number: 1411103-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-019

SAMPLE INFORMATION

Sample Number: 1411103-019
Location: 10
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.6 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.38 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.44 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.36 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-019

SAMPLE INFORMATION

Sample Number: 1411103-019
Location: 10
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-020

SAMPLE INFORMATION

Sample Number: 1411103-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-021

SAMPLE INFORMATION

Sample Number: 1411103-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-022

SAMPLE INFORMATION

Sample Number: 1411103-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.8 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.42 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.41 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.89 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-022

SAMPLE INFORMATION

Sample Number: 1411103-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-023

SAMPLE INFORMATION

Sample Number: 1411103-023
Location: 12
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.9 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.36 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.65 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.34 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-023

SAMPLE INFORMATION

Sample Number: 1411103-023
Location: 12
LPR 2106 16TH ST SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-024

SAMPLE INFORMATION

Sample Number: 1411103-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.6 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.50 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.07 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.83 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-024

SAMPLE INFORMATION

Sample Number: 1411103-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2106 16TH ST SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-025

SAMPLE INFORMATION

Sample Number: 1411103-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-026

SAMPLE INFORMATION

Sample Number: 1411103-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.4 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.58 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.3 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.40 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-026

SAMPLE INFORMATION

Sample Number: 1411103-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-027

SAMPLE INFORMATION

Sample Number: 1411103-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.6 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.82 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.45 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.39 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-027

SAMPLE INFORMATION

Sample Number: 1411103-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-028

SAMPLE INFORMATION

Sample Number: 1411103-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-029

SAMPLE INFORMATION

Sample Number: 1411103-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-030

SAMPLE INFORMATION

Sample Number: 1411103-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-031

SAMPLE INFORMATION

Sample Number: 1411103-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	41.6 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.37 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.48 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.82 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-031

SAMPLE INFORMATION

Sample Number: 1411103-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-032

SAMPLE INFORMATION

Sample Number: 1411103-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.3 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.42 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.14 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.7 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-032

SAMPLE INFORMATION

Sample Number: 1411103-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-033

SAMPLE INFORMATION

Sample Number: 1411103-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-034

SAMPLE INFORMATION

Sample Number: 1411103-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/12/2014 9:00 DVC/CW 11/14/2014 10:53:55 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-035

SAMPLE INFORMATION

Sample Number: 1411103-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.1 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.52 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.91 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.18 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-035

SAMPLE INFORMATION

Sample Number: 1411103-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411103-036

SAMPLE INFORMATION

Sample Number: 1411103-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2106 16TH ST SE UNFILTERED
Collection Date: 11/12/2014 Collection Time: 9:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 10:53:55 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-001

SAMPLE INFORMATION

Sample Number: 1411104-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.0 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.27 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	37.0 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.7 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	20.2 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-001

SAMPLE INFORMATION

Sample Number: 1411104-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-002

SAMPLE INFORMATION

Sample Number: 1411104-002
Location: 1F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/14/2014	7:00	DVC/CW	11/14/2014 11:01:40 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.2 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.25 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.2 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	20.1 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-002

SAMPLE INFORMATION

Sample Number: 1411104-002
Location: 1F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-003

SAMPLE INFORMATION

Sample Number: 1411104-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.8 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.44 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	42.0 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.6 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.28 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-003

SAMPLE INFORMATION

Sample Number: 1411104-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-004

SAMPLE INFORMATION

Sample Number: 1411104-004
Location: 02F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.8 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.34 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.4 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.77 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-004

SAMPLE INFORMATION

Sample Number: 1411104-004
Location: 02F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-005

SAMPLE INFORMATION

Sample Number: 1411104-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/14/2014 7:00 DVC/CW 11/14/2014 11:01:40 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-006

SAMPLE INFORMATION

Sample Number: 1411104-006
Location: 03F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/14/2014	7:00	DVC/CW	11/14/2014 11:01:40 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.9 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.35 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.3 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.02 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-006

SAMPLE INFORMATION

Sample Number: 1411104-006
Location: 03F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-007

SAMPLE INFORMATION

Sample Number: 1411104-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.8 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.50 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	41.6 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.0 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.12 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.34 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-007

SAMPLE INFORMATION

Sample Number: 1411104-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-008

SAMPLE INFORMATION

Sample Number: 1411104-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 1327 S ST SE FILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.3 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.45 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.4 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.68 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-008

SAMPLE INFORMATION

Sample Number: 1411104-008
Location: 04F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-009

SAMPLE INFORMATION

Sample Number: 1411104-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-010

SAMPLE INFORMATION

Sample Number: 1411104-010
Location: 05F
LPR 1327 S ST SE FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.4 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.54 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.4 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.78 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-010

SAMPLE INFORMATION

Sample Number: 1411104-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 1327 S ST SE FILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-011

SAMPLE INFORMATION

Sample Number: 1411104-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-012

SAMPLE INFORMATION

Sample Number: 1411104-012
Location: 06F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/14/2014	7:00	DVC/CW	11/14/2014 11:01:40 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.9 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.61 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.84 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.18 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-012

SAMPLE INFORMATION

Sample Number: 1411104-012
Location: 06F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-013

SAMPLE INFORMATION

Sample Number: 1411104-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-014

SAMPLE INFORMATION

Sample Number: 1411104-014
Location: 07F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.4 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.56 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.25 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.51 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-014

SAMPLE INFORMATION

Sample Number: 1411104-014
Location: 07F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-015

SAMPLE INFORMATION

Sample Number: 1411104-015
Location: 08
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.3 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.52 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	30.4 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.97 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.18 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.43 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-015

SAMPLE INFORMATION

Sample Number: 1411104-015
Location: 08
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-016

SAMPLE INFORMATION

Sample Number: 1411104-016
Location: 08F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-017

SAMPLE INFORMATION

Sample Number: 1411104-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.8 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.54 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	28.2 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.93 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.00 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.07 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-017

SAMPLE INFORMATION

Sample Number: 1411104-017
Customer Sample Number:
Location: 09
Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-018

SAMPLE INFORMATION

Sample Number: 1411104-018
Location: 09F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.0 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.48 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.00 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.48 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-018

SAMPLE INFORMATION

Sample Number: 1411104-018
Location: 09F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-019

SAMPLE INFORMATION

Sample Number: 1411104-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-020

SAMPLE INFORMATION

Sample Number: 1411104-020
Location: 10F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/14/2014	7:00	DVC/CW	11/14/2014 11:01:40 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.5 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.57 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.75 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.11 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-020

SAMPLE INFORMATION

Sample Number: 1411104-020
Location: 10F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-021

SAMPLE INFORMATION

Sample Number: 1411104-021
Location: 11
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.0 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.68 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.3 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.69 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.83 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-021

SAMPLE INFORMATION

Sample Number: 1411104-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/14/2014 7:00 DVC/CW 11/14/2014 11:01:40 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-022

SAMPLE INFORMATION

Sample Number: 1411104-022
Location: 11F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-023

SAMPLE INFORMATION

Sample Number: 1411104-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.0 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.71 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.7 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.62 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.71 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-023

SAMPLE INFORMATION

Sample Number: 1411104-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-024

SAMPLE INFORMATION

Sample Number: 1411104-024
Location: 12F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.8 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.66 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.68 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.78 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-024

SAMPLE INFORMATION

Sample Number: 1411104-024
Location: 12F
LPR 1327 S ST SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-025

SAMPLE INFORMATION

Sample Number: 1411104-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-026

SAMPLE INFORMATION

Sample Number: 1411104-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-027

SAMPLE INFORMATION

Sample Number: 1411104-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-028

SAMPLE INFORMATION

Sample Number: 1411104-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-029

SAMPLE INFORMATION

Sample Number: 1411104-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/14/2014 7:00 DVC/CW 11/14/2014 11:01:40 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-030

SAMPLE INFORMATION

Sample Number: 1411104-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-031

SAMPLE INFORMATION

Sample Number: 1411104-031
Location: H7
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.0 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.87 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	40.8 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.1 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.96 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.35 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-031

SAMPLE INFORMATION

Sample Number: 1411104-031
Location: H7
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-032

SAMPLE INFORMATION

Sample Number: 1411104-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.5 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.88 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	40.9 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.7 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	50.3 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.54 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-032

SAMPLE INFORMATION

Sample Number: 1411104-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-033

SAMPLE INFORMATION

Sample Number: 1411104-033
Customer Sample Number:
Location: H9
Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.6 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.88 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	39.6 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.5 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.56 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.31 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-033

SAMPLE INFORMATION

Sample Number: 1411104-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/14/2014 7:00 DVC/CW 11/14/2014 11:01:40 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-034

SAMPLE INFORMATION

Sample Number: 1411104-034
Location: H10
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.2 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.86 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	38.3 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.2 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.32 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.22 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-034

SAMPLE INFORMATION

Sample Number: 1411104-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/14/2014 7:00 DVC/CW 11/14/2014 11:01:40 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-035

SAMPLE INFORMATION

Sample Number: 1411104-035
Location: H11
LPR 1327 S ST SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.8 ug/L	11/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.93 ug/L	11/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	39.6 ug/L	11/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.6 ug/L	11/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.00 ug/L	11/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.11 ug/L	11/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-035

SAMPLE INFORMATION

Sample Number: 1411104-035
Customer Sample Number:
Location: H11
Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014
Collection Time: 7:00
Sampler: DVC/CW
Received Date and Time: 11/14/2014 11:01:40 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/3/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/3/2014
Report Number: M- W1411104-036

SAMPLE INFORMATION

Sample Number: 1411104-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 1327 S ST SE UNFILTERED
Collection Date: 11/14/2014 Collection Time: 7:00 Sampler: DVC/CW Received Date and Time: 11/14/2014 11:01:40 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/3/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-001
Location: 01
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.8 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.38 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	46.2 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	56.5 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	19.6 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-001
Location: 01
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-002
Location: 01F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.4 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.25 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	45.7 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	22.4 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-002
Location: 01F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-003
Location: 02
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.7 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.13 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	12.4 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	36.2 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.52 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-003
Location: 02
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-004
Location: 02F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.04 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	33.8 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.3 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-004
Location: 02F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-005
Location: 03
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.4 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.18 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	12.0 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	42.5 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.16 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-005
Location: 03
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-006
Location: 03F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	33.6 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.15 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-006
Location: 03F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-007
Location: 04
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.12 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	11.8 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.3 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.01 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-007
Location: 04
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-008
Location: 04F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.8 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	32.7 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.79 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-008
Location: 04F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-009
Location: 05
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.9 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.13 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	12.5 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	39.9 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.03 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-009
Location: 05
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-010
Location: 05F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.9 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	35.0 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.35 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-010
Location: 05F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-011
Location: 06
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.6 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.21 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.0 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	38.2 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.28 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-011
Location: 06
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-012
Location: 06F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.0 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.01 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	33.5 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.73 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-012
Location: 06F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-013
Location: 07
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.8 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.25 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.9 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	39.4 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.90 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.02 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-013
Location: 07
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-014
Location: 07F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.4 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.05 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	34.3 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.26 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-014
Location: 07F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-015

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-015
Location: 08
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.0 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.23 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.6 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	38.3 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.49 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-015

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-015
Location: 08
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-016
Location: 08F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.0 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.05 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	34.0 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.33 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-016
Location: 08F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-017

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-017
Location: 09
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.8 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.25 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.4 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	38.9 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.53 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-017

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-017
Location: 09
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-018

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-018
Location: 09F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.5 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.25 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	34.4 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.54 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.01 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-018

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-018
Location: 09F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-019

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-019
Location: 10
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.2 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.26 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.9 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	39.2 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.47 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-019

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-019
Location: 10
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-020

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-020
Location: 10F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.9 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.06 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	33.4 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.49 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-020

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-020
Location: 10F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-021

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-021
Location: 11
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.30 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	15.2 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	40.0 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.19 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-021

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-021
Location: 11
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-022

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-022
Location: 11F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.08 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	34.4 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.86 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-022

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-022
Location: 11F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-023

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-023
Location: 12
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.9 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.22 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.2 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.6 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.21 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-023

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-023
Location: 12
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-024

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-024
Location: 12F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.7 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.08 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	34.2 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.17 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-024

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-024
Location: 12F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-025

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-025
Location: 13
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.7 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.29 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.8 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	39.2 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.42 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-025

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-025
Location: 13
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-026

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-026
Location: 13F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.1 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.13 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	35.1 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.79 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-026

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-026
Location: 13F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-027

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-027
Location: 14
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.5 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.36 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.2 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	40.1 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.40 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-027

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-027
Location: 14
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-028

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-028
Location: 14F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.15 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	35.5 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.37 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-028

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-028
Location: 14F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-029

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-029
Location: 15
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.4 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.39 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.7 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	41.4 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.33 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-029

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-029
Location: 15
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-030

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-030
Location: 15F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.7 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.17 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	35.9 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.65 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-030

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-030
Location: 15F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-031

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-031
Location: 16
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.7 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.37 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.8 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	41.3 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.24 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-031

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-031
Location: 16
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-032

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-032
Location: 16F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.1 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.18 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	36.7 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.57 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2014
Report Number: M- W1411057-032

SAMPLE INFORMATION

Sample Number: 1411057-032
Location: 16F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-033

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-033
Location: 17
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.4 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.42 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	20.2 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	43.1 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.20 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-033

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-033
Location: 17
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-034

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-034
Location: 17F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.1 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.21 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.4 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.96 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-034

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-034
Location: 17F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-035

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-035
Location: 18
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.4 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.42 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.8 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	38.9 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.11 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-035

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-035
Location: 18
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-036

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-036
Location: 18F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.7 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.23 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	33.7 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.32 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-036

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-036
Location: 18F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-037

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-037
Location: 19
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.2 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.46 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	20.4 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	32.8 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.16 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-037

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-037
Location: 19
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-038

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-038
Location: 19F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.4 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.25 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	28.7 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.72 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-038

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-038
Location: 19F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-039

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-039
Location: 20
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.49 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	20.7 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	28.6 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.32 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-039

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-039
Location: 20
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-040

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-040
Location: 20F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.2 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.26 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	25.3 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.77 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-040

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-040
Location: 20F
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-041

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-041
Location: H1
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.7 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.52 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.4 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	27.7 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.97 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-041

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-041
Location: H1
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-042

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-042
Location: H2
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.8 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.49 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.0 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.1 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.07 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-042

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-042
Location: H2
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-043

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-043
Location: H3
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.5 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.48 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.1 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.2 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.09 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-043

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-043
Location: H3
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-044

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-044
Location: H4
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.6 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.48 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.6 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.6 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.06 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-044

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-044
Location: H4
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-045

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-045
Location: H5
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.6 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.48 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.2 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.2 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.28 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-045

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-045
Location: H5
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-046

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-046
Location: H6
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.51 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.9 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.7 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.00 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-046

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-046
Location: H6
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-047

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-047
Location: H7
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.9 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.54 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.0 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.5 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.99 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-047

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-047
Location: H7
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-048

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-048
Location: H8
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.9 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.51 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.6 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.5 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.97 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-048

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-048
Location: H8
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-049

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-049
Location: H9
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.7 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.50 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.9 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.3 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.88 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-049

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-049
Location: H9
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-050

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-050
Location: H10
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.4 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.55 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	23.2 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.3 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.04 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-050

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-050
Location: H10
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-051

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-051
Location: H11
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.1 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.53 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.6 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.0 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.13 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-051

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-051
Location: H11
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-052

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-052
Location: H12
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.2 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.57 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	23.2 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.1 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.94 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-052

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-052
Location: H12
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-053

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-053
Location: H13
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.59 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.7 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.9 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.24 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-053

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-053
Location: H13
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-054

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-054
Location: H14
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.9 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.58 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.6 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.1 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.19 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-054

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-054
Location: H14
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-055

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-055
Location: H15
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
11/7/2014	7:15	IC/DC	11/7/2014 11:37:06 AM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.7 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.59 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.1 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.0 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.30 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-055

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-055
Location: H15
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-056

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-056
Location: H16
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.1 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.62 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.9 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.8 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.97 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-056

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3211 NEWARK ST., NW
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
11/7/2014 7:15 IC/DC 11/7/2014 11:37:06 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-057

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-057
Location: H17
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: IC/DC	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	-------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.3 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.57 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.8 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.5 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.92 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-057

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-057
Location: H17
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-058

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-058
Location: H18
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.0 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.59 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	23.7 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.9 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.94 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-058

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-058
Location: H18
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 12/18/2014
Report Number: M- W1411057-059

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-059
Location: H19
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.9 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.60 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	25.2 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.4 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.88 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-059

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-059
Location: H19
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-060

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-060
Location: H20
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	27.1 ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.61 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	24.6 ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.7 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.17 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-060

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-060
Location: H20
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: IC/DC Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-061

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-061
Location: refrigerator
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: HOME OWNER	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	------------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.86 ug/L	11/18/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-061

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-061
Location: refrigerator
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-062

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-062
Location: carbon filter
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014	Collection Time: 7:15	Sampler: HOME OWNER	Received Date and Time: 11/7/2014 11:37:06 AM	Received By: TPasquale
-------------------------------	--------------------------	------------------------	--	---------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.19 ug/L	11/18/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	11/18/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.17 ug/L	11/18/2014	RHoffa
Zinc	EPA 200.8 10 X dilution	ug/L	ug/L	0.5 ug/L	1130 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	11/18/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 12/18/2014
Report Number: M- W1411057-062

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1411057-062
Location: carbon filter
LPR 3211 NEWARK ST., NW

Customer Sample Number:
Type: Dist.

Collection Date: 11/7/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 11/7/2014 11:37:06 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2014
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

DC Water Fountain and Sink Samples

At the request of DC Water's Union, DC Water's water quality staff collected lead samples from all locations that are used by employees for drinking purposes. Sample sites included fountains and sinks at all DC Water owned facilities.

Sampling procedures included flushing lines for several minutes, stagnating for at least 15 hours and collecting samples using 250 mL plastic bottles. All samples were analyzed by the Washington Aqueduct.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406195-009

SAMPLE INFORMATION

Sample Number: 1406195-009 Customer Sample Number: Project: UNION
Location: BP9 5000 OVERLOOK AVE. COF 4TH Type: Dist.
 FLOOR (FOUNTAIN #3)

Collection Date: 6/24/2014 Collection Time: 11:00 Sampler: HB Received Date and Time: 6/24/2014 3:03:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	6/27/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.058 mg/L	6/27/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	6/27/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406195-012

SAMPLE INFORMATION

Sample Number: 1406195-012 Customer Sample Number: Project: UNION
Location: BP12 5000 OVERLOOK AVE. COF 5TH Type: Dist.
 FLOOR (FOUNTAIN #3)

Collection Date: 6/24/2014 Collection Time: 11:15 Sampler: HB Received Date and Time: 6/24/2014 3:03:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/27/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.156 mg/L	6/27/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	6/27/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406195-013

SAMPLE INFORMATION

Sample Number: 1406195-013 Customer Sample Number: Project: UNION
Location: BP14 5000 OVERLOOK AVE. CMF Type: Dist.
 MACHINE SHOP

Collection Date: 6/24/2014 Collection Time: 12:05 Sampler: HB Received Date and Time: 6/24/2014 3:03:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	6/27/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.019 mg/L	6/27/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	ND mg/L	6/27/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406195-014

SAMPLE INFORMATION

Sample Number: 1406195-014 Customer Sample Number: Project: UNION
Location: BP15 5000 OVERLOOK AVE. CMF Type: Dist.
 MAINTENANCE SHOP

Collection Date: 6/24/2014 Collection Time: 12:15 Sampler: HB Received Date and Time: 6/24/2014 3:03:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.015 mg/L	6/27/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.124 mg/L	6/27/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	6/27/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406211-003


SAMPLE INFORMATION

Sample Number: 1406211-003 Customer Sample Number: Project: UNION
Location: BP18 5000 OVERLOOK AVE CMF 1ST Type: Dist.
 FLOOR (RESTROOM)

Collection Date: 6/26/2014 Collection Time: 11:50 Sampler: HB Received Date and Time: 6/26/2014 2:29:05 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/27/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.046 mg/L	6/27/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	ND mg/L	6/27/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  7/9/2014
Michael Chicoine, Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 7/9/2014
Report Number: LC-W1406211-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1406211-013 Customer Sample Number: Project: UNION
Location: BP33 5000 OVERLOOK AVE Type: Dist.
SECONDARY BLOWER 2FL

Collection Date: 6/26/2014 Collection Time: 10:40 Sampler: HB Received Date and Time: 6/26/2014 2:29:05 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/27/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.136 mg/L	6/27/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	6/27/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406211-014

SAMPLE INFORMATION

Sample Number: 1406211-014 Customer Sample Number: Project: UNION
Location: BP34 5000 OVERLOOK AVE SOLID Type: Dist.
PROCESSING 1F HALLWAY

Collection Date: 6/26/2014 Collection Time: 9:30 Sampler: HB Received Date and Time: 6/26/2014 2:29:05 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.011 mg/L	6/27/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.068 mg/L	6/27/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	6/27/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1406211-019

SAMPLE INFORMATION

Sample Number: 1406211-019 Customer Sample Number: Project: UNION
Location: BP39 5000 OVERLOOK AVE VISITORS Type: Dist.
CENTER 2ND FL #2(LOW)

Collection Date: 6/26/2014 Collection Time: 10:25 Sampler: HB Received Date and Time: 6/26/2014 2:29:05 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	6/27/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.000 mg/L	6/27/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	ND mg/L	6/27/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1407008-001

SAMPLE INFORMATION

Sample Number: 1407008-001 Customer Sample Number: Project: UNION
Location: 1-B BRYANT ST. 1ST FLOOR NORTH Type: Dist.
HIGH

Collection Date: 7/1/2014 Collection Time: 9:45 Sampler: HB Received Date and Time: 7/1/2014 2:52:56 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	7/2/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.052 mg/L	7/2/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	7/2/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

7/9/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1407008-003

SAMPLE INFORMATION

Sample Number: 1407008-003 Customer Sample Number: Project: UNION
Location: 3-B BRYANT ST. 1ST FLOOR SOUTH Type: Dist.

Collection Date: 7/1/2014 Collection Time: 10:00 Sampler: HB Received Date and Time: 7/1/2014 2:52:56 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.011 mg/L	7/2/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.061 mg/L	7/2/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	7/2/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

7/9/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1407008-006

SAMPLE INFORMATION

Sample Number: 1407008-006 Customer Sample Number: Project: UNION
Location: 6-B BRYANT ST. 2ND FLOOR SOUTH Type: Dist.

Collection Date: 7/1/2014 Collection Time: 10:25 Sampler: HB Received Date and Time: 7/1/2014 2:52:56 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.013 mg/L	7/2/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.048 mg/L	7/2/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	7/2/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

7/9/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1407008-007

SAMPLE INFORMATION

Sample Number: 1407008-007 Customer Sample Number: Project: UNION
Location: 7-B BRYANT ST. 3RD FLOOR NW HIGH Type: Dist.

Collection Date: 7/1/2014 Collection Time: 10:35 Sampler: HB Received Date and Time: 7/1/2014 2:52:56 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	7/2/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.106 mg/L	7/2/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	7/2/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

7/9/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1407008-008

SAMPLE INFORMATION

Sample Number: 1407008-008 Customer Sample Number: Project: UNION
Location: 8-B BRYANT ST. 3RD FLOOR NW LOW Type: Dist.

Collection Date: 7/1/2014 Collection Time: 10:40 Sampler: HB Received Date and Time: 7/1/2014 2:52:56 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.012 mg/L	7/2/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.099 mg/L	7/2/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	7/2/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

7/9/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1407008-015

SAMPLE INFORMATION

Sample Number: 1407008-015 Customer Sample Number: Project: UNION
Location: 17-B BRYANT ST. KITCHEN 3RD FLOOR Type: Dist.

Collection Date: 7/1/2014 Collection Time: 10:45 Sampler: HB Received Date and Time: 7/1/2014 2:52:56 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	7/2/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.077 mg/L	7/2/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	7/2/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

7/9/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/9/2014
Report Number: LC-W1407008-016

SAMPLE INFORMATION

Sample Number: 1407008-016 Customer Sample Number: Project: UNION
Location: 18-B BRYANT ST KITCHEN 1ST FLOOR Type: Dist.

Collection Date: 7/1/2014 Collection Time: 9:20 Sampler: HB Received Date and Time: 7/1/2014 2:52:56 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.015 mg/L	7/2/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.039 mg/L	7/2/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	7/2/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

7/9/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408178-001

SAMPLE INFORMATION

Sample Number: 1408178-001 Customer Sample Number: Project: UNION
Location: 4-O O STREET BUILDING F (BREAK ROOM) Type: Dist.
Collection Date: 8/21/2014 Collection Time: 12:20 Sampler: HB Received Date and Time: 8/21/2014 2:51:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.083 mg/L	8/26/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.142 mg/L	8/26/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	8/26/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408178-004

SAMPLE INFORMATION

Sample Number: 1408178-004 Customer Sample Number: Project: UNION
Location: 7-O O STREET BUILDING H (1ST FLOOR) (NORTH) Type: Dist.

Collection Date: 8/21/2014 Collection Time: 11:10 Sampler: HB Received Date and Time: 8/21/2014 2:51:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/26/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.286 mg/L	8/26/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	8/26/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408178-005

SAMPLE INFORMATION

Sample Number: 1408178-005 Customer Sample Number: Project: UNION
Location: 8-O O STREET BUILDING H (1ST FLOOR) (SOUTH) Type: Dist.
Collection Date: 8/21/2014 Collection Time: 11:20 Sampler: HB Received Date and Time: 8/21/2014 2:51:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/26/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.421 mg/L	8/26/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	8/26/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408178-006

SAMPLE INFORMATION

Sample Number: 1408178-006 Customer Sample Number: Project: UNION
Location: 9-O O STREET BUILDING H (2ND FLOOR) Type: Dist.

Collection Date: 8/21/2014 Collection Time: 11:45 Sampler: HB Received Date and Time: 8/21/2014 2:51:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.060 mg/L	8/26/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.592 mg/L	8/26/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0028 mg/L	8/26/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408178-008

SAMPLE INFORMATION

Sample Number: 1408178-008 Customer Sample Number: Project: UNION
Location: 13-O O STREET BUILDING FLEET SHOP Type: Dist.

Collection Date: 8/21/2014 Collection Time: 10:25 Sampler: HB Received Date and Time: 8/21/2014 2:51:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.057 mg/L	8/26/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.094 mg/L	8/26/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	8/26/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2014
Report Number: LC-W1408178-010

SAMPLE INFORMATION

Sample Number: 1408178-010 Customer Sample Number: Project: UNION
Location: 1-R FORT RENO 1ST FLOOR Type: Dist.

Collection Date: 8/21/2014 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/21/2014 2:51:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	8/26/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.055 mg/L	8/26/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	8/26/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2014
Date

Attachment 3

Customer Letter Distribution Certification



Certification of Consumer Notification of Tap Results

Water System Name: DC Water and Sewer Authority (DC Water)

PWSID: DC000002

Monitoring Period to which the notice applies: July 2014 – December 2014

Dates results were received from laboratory: See Attached Table C.6 from Report

Dates results were provided to customers: See Attached Table C.6 from Report

The water system names above hereby certifies that its lead consumer notice has been provided to each person it serves at the specific sampling site from which the sample was tested. The water system also certifies that these results and the following information were provided to such persons within 30 days of receiving the test results from the laboratory:

- X Individual tap results from lead tap water monitoring carried out under the requirements of §141.86.
- X An explanation of the health effects of lead.
- X Steps that consumers can take to reduce exposure to lead in drinking water.
- X Contact information for your water utility.
- X The maximum contaminant level goals and action levels for lead, and the definitions of these two term from §141.153(c).

Certified by:

Name Jessica Edwards-Brandt
 Title Manager, Water Quality, Drinking Water Division
 Phone # 202-364-3123 Date January 9, 2015

Notices were distributed to customers by mail.

Sincerely,

Jessica Edwards-Brandt
Manager, Drinking Water Division



Month, day, year

«First_name» «Last_Name»

«Address»

Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»:

Thank you for participating in DC Water’s Lead and Copper Compliance Monitoring Program. Your participation helps us assess the effectiveness of the U.S. Army Corps of Engineers Washington Aqueduct corrosion control treatment to minimize corrosion of lead service pipes, household plumbing and fixtures that may contribute to lead and copper concentrations in drinking water.

Below are the test results from the two water samples that you collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential sources near the tap where the sample is collected. This sample is required by the Environmental Protection Agency (EPA).
- Second draw: Measures lead release from the lead service pipe and household plumbing. DC Water voluntarily collects this sample to assess the contribution of lead in water from the lead service line.

Sample	Lead Level (ppb)	Copper Level (ppb)
First Draw		
Second Draw		

Service Line Material

Public Space: Lead

Private Property: Lead

If this information is inaccurate, please contact the Drinking Water Division at 202-612-3440.

DC Water recommends that you filter your water to minimize potential lead exposure if lead is present in your drinking water, if you have pipes or plumbing fixtures that contain lead, or if you don’t know the material type. If you are pregnant, nursing or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free when it leaves the Washington Aqueduct treatment plant, but lead can enter water when it comes in contact with pipes or plumbing fixtures that contain lead. As noted above, your property has a lead service pipe, which connects the water main in the street to household plumbing. DC Water operates a lead service replacement program and will replace the public portion of the service line during a water main replacement, or if you agree to replace the portion on your private property.

Under the authority of the Safe Drinking Water Act, EPA set a Maximum Contaminant Level Goal (MCLG) for lead at zero and for copper at 1,300 parts per billion (ppb). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. EPA also set an action level for lead at 15 ppb and for copper at 1,300 ppb. The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. These requirements are triggered if more than 10 percent of all first draw samples collected during any monitoring period exceed the action levels. Your lead and copper results may be higher or lower than the action levels, which does not reflect DC Water’s compliance with the LCR. DC Water will notify all customers if the District’s water exceeds the lead or copper action level.

Lead can pose significant health risks if too much of it enters the body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead from other sources (such as lead-based paint and contaminated soil) can increase a person's overall exposure, which adds to the effects of lead in water.

The District Department of the Environment (DDOE) offers information on blood lead testing for young children, pregnant women and nursing mothers. For more information on minimizing lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov or visit EPA's website at www.epa.gov/lead.

DC Water strongly encourages residents to take the following steps to reduce lead exposure:

Remove lead sources

- Replace your lead service pipe with copper. For more information about lead pipe replacement, contact the Drinking Water Division at 202-612-3440.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). Effective in 2014, fixtures that are labeled "lead-free" cannot contain more than 0.25 percent lead. Flush cold water taps, with the aerator removed, at highest flow rate for 5 minutes once a day for 3 days after installing new household pipes or fixtures.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. Visit the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your water before using it for drinking or cooking. Once you notice a temperature change, continue running your water for 2 more minutes to receive fresh water from the water main.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

For more information, contact the Drinking Water Division at 202-612-3440 or visit www.dewater.com/lead.

Sincerely,



Jessica Edwards-Brandt
Manager, Drinking Water Division



Month, day, year

«First_name» «Last_Name»

«Address»

Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»:

Thank you for participating in DC Water’s Lead and Copper Compliance Monitoring Program. Your participation helps us assess the effectiveness of the U.S. Army Corps of Engineers Washington Aqueduct corrosion control treatment to minimize corrosion of lead service pipes, household plumbing and fixtures that may contribute to lead and copper concentrations in drinking water.

Below are the test results from the two water samples that you collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential sources near the tap where the sample is collected. This sample is required by the Environmental Protection Agency (EPA).
- Second draw: Measures lead release from the lead service pipe and household plumbing. DC Water voluntarily collects this sample to assess the contribution of lead in water from the lead service line.

Sample	Lead Level (ppb)	Copper Level (ppb)
First Draw		
Second Draw		

Service Line Material

Public Space: Lead

Private Property: Non-lead

If this information is inaccurate, please contact the Drinking Water Division at 202-612-3440.

DC Water recommends that you filter your water to minimize potential lead exposure if lead is present in your drinking water, if you have pipes or plumbing fixtures that contain lead, or if you don’t know the material type. If you are pregnant, nursing or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free when it leaves the Washington Aqueduct treatment plant, but lead can enter water when it comes in contact with pipes or plumbing fixtures that contain lead. As noted above, your property has a lead service pipe, which connects the water main in the street to household plumbing. DC Water operates a lead service replacement program and will replace the public portion of the service line during a water main replacement, or if you agree to replace the portion on your private property.

Under the authority of the Safe Drinking Water Act, EPA set a Maximum Contaminant Level Goal (MCLG) for lead at zero and for copper at 1,300 parts per billion (ppb). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. EPA also set an action level for lead at 15 ppb and for copper at 1,300 ppb. The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. These requirements are triggered if more than 10 percent of all first draw samples collected during any monitoring period exceed the action levels. Your lead and copper results may be higher or lower than the action levels, which does not reflect DC Water’s compliance with the LCR. DC Water will notify all customers if the District’s water exceeds the lead or copper action level.

Lead can pose significant health risks if too much of it enters the body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead from other sources (such as lead-based paint and contaminated soil) can increase a person's overall exposure, which adds to the effects of lead in water.

The District Department of the Environment (DDOE) offers information on blood lead testing for young children, pregnant women and nursing mothers. For more information on minimizing lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov or visit EPA's website at www.epa.gov/lead.

DC Water strongly encourages residents to take the following steps to reduce lead exposure:

Remove lead sources

- Replace your lead service pipe with copper. For more information about lead pipe replacement, contact the Drinking Water Division at 202-612-3440.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). Effective in 2014, fixtures that are labeled "lead-free" cannot contain more than 0.25 percent lead. Flush cold water taps, with the aerator removed, at highest flow rate for 5 minutes once a day for 3 days after installing new household pipes or fixtures.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. Visit the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your water before using it for drinking or cooking. Once you notice a temperature change, continue running your water for 2 more minutes to receive fresh water from the water main.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

For more information, contact the Drinking Water Division at 202-612-3440 or visit www.dewater.com/lead.

Sincerely,



Jessica Edwards-Brandt
Manager, Drinking Water Division



Month, day, year

«First_name» «Last_Name»

«Address»

Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»:

Thank you for participating in DC Water’s Lead and Copper Compliance Monitoring Program. Your participation helps us assess the effectiveness of the U.S. Army Corps of Engineers Washington Aqueduct corrosion control treatment to minimize corrosion of lead service pipes, household plumbing and fixtures that may contribute to lead and copper concentrations in drinking water.

Below are the test results from the two water samples that you collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential sources near the tap where the sample is collected. This sample is required by the Environmental Protection Agency (EPA).
- Second draw: Measures lead release from the lead service pipe and household plumbing. DC Water voluntarily collects this sample to assess the contribution of lead in water from the lead service line.

Sample	Lead Level (ppb)	Copper Level (ppb)
First Draw		
Second Draw		

Service Line Material

Public Space: Non-lead

Private Property: Lead

If this information is inaccurate, please contact the Drinking Water Division at 202-612-3440.

DC Water recommends that you filter your water to minimize potential lead exposure if lead is present in your drinking water, if you have pipes or plumbing fixtures that contain lead, or if you don’t know the material type. If you are pregnant, nursing or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free when it leaves the Washington Aqueduct treatment plant, but lead can enter water when it comes in contact with pipes or plumbing fixtures that contain lead. As noted above, your property has a lead service pipe, which connects the water main in the street to household plumbing. DC Water operates a lead service replacement program and will replace the public portion of the service line during a water main replacement, or if you agree to replace the portion on your private property.

Under the authority of the Safe Drinking Water Act, EPA set a Maximum Contaminant Level Goal (MCLG) for lead at zero and for copper at 1,300 parts per billion (ppb). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. EPA also set an action level for lead at 15 ppb and for copper at 1,300 ppb. The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. These requirements are triggered if more than 10 percent of all first draw samples collected during any monitoring period exceed the action levels. Your lead and copper results may be higher or lower than the action levels, which does not reflect DC Water’s compliance with the LCR. DC Water will notify all customers if the District’s water exceeds the lead or copper action level.

Lead can pose significant health risks if too much of it enters the body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead from other sources (such as lead-based paint and contaminated soil) can increase a person's overall exposure, which adds to the effects of lead in water.

The District Department of the Environment (DDOE) offers information on blood lead testing for young children, pregnant women and nursing mothers. For more information on minimizing lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov or visit EPA's website at www.epa.gov/lead.

DC Water strongly encourages residents to take the following steps to reduce lead exposure:

Remove lead sources

- Replace your lead service pipe with copper. For more information about lead pipe replacement, contact the Drinking Water Division at 202-612-3440.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). Effective in 2014, fixtures that are labeled "lead-free" cannot contain more than 0.25 percent lead. Flush cold water taps, with the aerator removed, at highest flow rate for 5 minutes once a day for 3 days after installing new household pipes or fixtures.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. Visit the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your water before using it for drinking or cooking. Once you notice a temperature change, continue running your water for 2 more minutes to receive fresh water from the water main.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

For more information, contact the Drinking Water Division at 202-612-3440 or visit www.dewater.com/lead.

Sincerely,



Jessica Edwards-Brandt
Manager, Drinking Water Division