



NOTES:

1. 1" DOMESTIC METER SETTER AS SHOWN.
2. 1 1/2" - 2" METER SETTER REQUIRES A METER VALVE ON EACH SIDE (NOT SHOWN ON DETAIL)
3. IF THE BUILDING OR APPROVED PROJECTION IS AT OR EXTENDS BEYOND THE PROPERTY LINE, THE CURB STOP SHALL BE PLACED 18 INCHES FROM FACE OF BUILDING OR APPROVED PROJECTION.
4. FOR NEW BUILDING CONSTRUCTION ONLY (IF REQUIRED): THE FIRE SERVICE LINE SHALL INCLUDE A SHUT-OFF VALVE INSTALLED INSIDE THE BUILDING.
5. FOR NEW BUILDING CONSTRUCTION ONLY (IF REQUIRED): THE DOMESTIC SERVICE LINE SHALL INCLUDE A PRESSURE REDUCING VALVE AND SHUT-OFF VALVE INSTALLED INSIDE THE BUILDING.

APPROVED DATE: January 2, 2004

DIRECTOR, DEPARTMENT OF ENGINEERING
AND TECHNICAL SERVICES

REVISION NO.: 1
DATE: 6/20/03
PREPARED BY: J. Shabelski
CHECKED BY: W.DARROW

STANDARD DETAIL

WATER SERVICE CONNECTIONS
1" THRU 2" DIAMETER