



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-009

Sample Location: 1st Draw 10 S St NW
Customer Sample Number: 3017940
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 3:55 PM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-009
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0370	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0026	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 10 S St NW
Customer Sample Number: 3017940
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 3:58 PM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-010
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0152	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0018	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-007

Sample Location: 1st Draw 1020 Independence Ave SE
Customer Sample Number: 3073669
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:35 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-007
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0170	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0006	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 1020 Independence Ave SE
Customer Sample Number: 3073669
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:36 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-008
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0065	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0431	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0006	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-019

Sample Location: 1st Draw 114 Madison St. NW
Customer Sample Number: 3025476
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 8:04 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-019
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0547	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0504	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0011	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 114 Madison St. NW
Customer Sample Number: 3025476
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 8:07 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-020
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0171	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0881	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0018	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402050-011

Sample Location: 1st Draw 1247 Girard St NE

Customer Sample Number: 3104199

Sample Collected By: HOMEOWNER

Date / Time Collected: 2/4/2024 6:50 AM

Customer Program Code: LCR

Laboratory Sample Number: 2402050-011

Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.101	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0169	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 1247 Girard St NE

Customer Sample Number: 3104199

Sample Collected By: HOMEOWNER

Date / Time Collected: 2/4/2024 6:52 AM

Customer Program Code: LCR

Laboratory Sample Number: 2402050-012

Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0550	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0133	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-013

Sample Location: 1st Draw 132 11th St SE
Customer Sample Number: 3073773
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 4:58 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-013
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0237	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0249	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 132 11th St SE
Customer Sample Number: 3073773
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 5:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-014
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0140	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0119	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402039-001

Sample Location: 1st Draw 1346 F ST NE
Customer Sample Number: 3100684
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/1/2024 7:10 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402039-001
Date / Time Received: 2/6/2024 4:52:38 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0100	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0212	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0009	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 1346 F ST NE
Customer Sample Number: 3100684
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/1/2024 7:13 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402039-002
Date / Time Received: 2/6/2024 4:52:39 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0046	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0149	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0018	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-035

Sample Location: 1st Draw 1408 Decatur St NW
Customer Sample Number: 3027601
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 5:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-035
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0525	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0907	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0127	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 1408 Decatur St NW
Customer Sample Number: 3027601
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 5:10 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-036
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0043	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0255	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0014	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-015

Sample Location: 1st Draw 1505 Buchanan St NW
Customer Sample Number: 3027905
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:13 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-015
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0564	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0419	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0012	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 1505 Buchanan St NW
Customer Sample Number: 3027905
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-016
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0106	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0437	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0026	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-029

Sample Location: 1st Draw 1519 Olive St NE
Customer Sample Number: 3111360
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 5:35 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-029
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0058	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0270	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 1519 Olive St NE
Customer Sample Number: 3111360
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 5:49 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-030
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0041	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0265	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-021

Sample Location: 1st Draw 2007 37th St NW
Customer Sample Number: 3009912
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 5:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-021
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0643	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0122	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 2007 37th St NW
Customer Sample Number: 3009912
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 5:01 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-022
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0075	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0118	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-027

Sample Location: 1st Draw 2036 17th St NW

Customer Sample Number: 3001351

Sample Collected By: HOMEOWNER

Date / Time Collected: 1/31/2024 7:02 AM

Customer Program Code: LCR

Laboratory Sample Number: 2402010-027

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0336	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0234	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 2036 17th St NW

Customer Sample Number: 3001351

Sample Collected By: HOMEOWNER

Date / Time Collected: 1/31/2024 7:04 AM

Customer Program Code: LCR

Laboratory Sample Number: 2402010-028

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0100	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0149	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-038

Sample Location: 1st Draw 2717 O St. NW
Customer Sample Number: 3007250
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 5:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-038
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0757	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0766	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-001

Sample Location: 1st Draw 307 South Carolina Ave SE
Customer Sample Number: 3086661
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 5:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-001
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0365	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 307 South Carolina Ave SE
Customer Sample Number: 3086661
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 5:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-002
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0103	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0011	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402039-007

Sample Location: 1st Draw 3074 Clinton St. NE
Customer Sample Number: 3107532
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/1/2024 4:45 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402039-007
Date / Time Received: 2/6/2024 2:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0136	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.208	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 3074 Clinton St. NE
Customer Sample Number: 3107532
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/1/2024 4:50 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402039-008
Date / Time Received: 2/6/2024 2:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0139	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.212	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402039-003

Sample Location: 1st Draw 317 Tennessee Ave. NE
Customer Sample Number: 3122297
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:14 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402039-003
Date / Time Received: 2/6/2024 2:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0574	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0130	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 317 Tennessee Ave. NE
Customer Sample Number: 3122297
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402039-004
Date / Time Received: 2/6/2024 2:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0058	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0274	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0004	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-003

Sample Location: 1st Draw 3206 38th St NW
Customer Sample Number: 3035196
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:27 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-003
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0207	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.263	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 3206 38th St NW
Customer Sample Number: 3035196
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-004
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0292	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.232	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0016	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-017

Sample Location: 1st Draw 3211 CENTRAL AVE NE
Customer Sample Number: 3107442
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:46 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-017
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0962	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0949	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0023	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 3211 CENTRAL AVE NE
Customer Sample Number: 3107442
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:48 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-018
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0108	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0552	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0015	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402050-009

Sample Location: 1st Draw 3420 34th St NW

Customer Sample Number: 3041758

Sample Collected By: HOMEOWNER

Date / Time Collected: 2/1/2024 7:00 AM

Customer Program Code: LCR

Laboratory Sample Number: 2402050-009

Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0605	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0247	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0004	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 3420 34th St NW

Customer Sample Number: 3041758

Sample Collected By: HOMEOWNER

Date / Time Collected: 2/1/2024 7:00 AM

Customer Program Code: LCR

Laboratory Sample Number: 2402050-010

Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0300	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0241	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0006	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402039-005

Sample Location: 1st Draw 3567 Holmead PI NW
Customer Sample Number: 3053779
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:06 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402039-005
Date / Time Received: 2/6/2024 2:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0325	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 3567 Holmead PI NW
Customer Sample Number: 3053779
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:09 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402039-006
Date / Time Received: 2/6/2024 2:15:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0199	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-033

Sample Location: 1st Draw 3629 Everett St NW
Customer Sample Number: 3036892
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:31 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-033
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0974	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0296	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 3629 Everett St NW
Customer Sample Number: 3036892
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:33 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-034
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0085	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0259	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0009	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402050-001

Sample Location: 1st Draw 423 Gallatin St NW
Customer Sample Number: 3023321
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:45 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402050-001
Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0086	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0102	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 423 Gallatin St NW
Customer Sample Number: 3023321
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:46 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402050-002
Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0056	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402050-005

Sample Location: 1st Draw 423 Shepherd St NW
Customer Sample Number: 3051028
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/1/2024 6:12 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402050-005
Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0096	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0101	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 423 Shepherd St NW
Customer Sample Number: 3051028
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/1/2024 6:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402050-006
Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0109	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-037

Sample Location: 1st Draw 4322 15th ST NW

Customer Sample Number: 3028095

Sample Collected By: HOMEOWNER

Date / Time Collected: 1/30/2024 7:30 AM

Customer Program Code: LCR

Laboratory Sample Number: 2402010-037

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0135	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0198	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0012	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402050-003

Sample Location: 1st Draw 4418 14TH ST NE
Customer Sample Number: 3104746
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:10 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402050-003
Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0475	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0348	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0006	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 4418 14TH ST NE
Customer Sample Number: 3104746
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402050-004
Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0146	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0207	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-011

Sample Location: 1st Draw 4425 14th St NE
Customer Sample Number: 3114988
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-011
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0394	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0295	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 4425 14th St NE
Customer Sample Number: 3114988
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:32 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-012
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0107	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0279	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-005

Sample Location: 1st Draw 4507 13th St NW

Customer Sample Number: 3028049

Sample Collected By: HOMEOWNER

Date / Time Collected: 1/30/2024 4:30 PM

Customer Program Code: LCR

Laboratory Sample Number: 2402010-005

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0052	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0227	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 4507 13th St NW

Customer Sample Number: 3028049

Sample Collected By: HOMEOWNER

Date / Time Collected: 1/30/2024 4:37 PM

Customer Program Code: LCR

Laboratory Sample Number: 2402010-006

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0058	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0232	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-025

Sample Location: 1st Draw 525 9th St. SE
Customer Sample Number: 3072919
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 5:35 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-025
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0283	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0647	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0008	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 525 9th St. SE
Customer Sample Number: 3072919
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 5:36 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-026
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0149	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0574	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0009	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-031

Sample Location: 1st Draw 5427 Nevada Ave NW
Customer Sample Number: 3039412
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-031
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0072	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.405	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0022	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 5427 Nevada Ave NW
Customer Sample Number: 3039412
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 7:05 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-032
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0031	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0629	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0040	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402050-007

Sample Location: 1st Draw 559 23rd PI NE
Customer Sample Number: 3101450
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:03 PM

Customer Program Code: LCR
Laboratory Sample Number: 2402050-007
Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0243	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 559 23rd PI NE
Customer Sample Number: 3101450
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:05 PM

Customer Program Code: LCR
Laboratory Sample Number: 2402050-008
Date / Time Received: 2/7/2024 8:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0127	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2402010-023

Sample Location: 1st Draw 5600 Nebraska Ave NW
Customer Sample Number: 3037644
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:46 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-023
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0551	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0115	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 5600 Nebraska Ave NW
Customer Sample Number: 3037644
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 6:47 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402010-024
Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0245	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0139	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0008	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/22/2024

Report Number: LC-DC-LCR-2401179-001

Sample Location: 1st Draw 727 Hamilton St NW
Customer Sample Number: 3023311
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/16/2024 6:40 AM

Customer Program Code: LCR
Laboratory Sample Number: 2401179-001
Date / Time Received: 1/24/2024 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0150	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0584	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0012	mg/L	2/8/2024	SBrooks

Sample Location: 2nd Draw 727 Hamilton St NW
Customer Sample Number: 3023311
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/16/2024 6:43 AM

Customer Program Code: LCR
Laboratory Sample Number: 2401179-002
Date / Time Received: 1/24/2024 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0132	mg/L	2/8/2024	SBrooks
Iron	EPA 200.8		0.01	0.0458	mg/L	2/8/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0004	mg/L	2/8/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/7/2024

Report Number: LC-DC-LCR-2402057-005

Sample Location: 1st Draw 1421 Taylor St NW
Customer Sample Number: 3050311
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 9:05 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402057-005
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0057	mg/L	2/23/2024	SBrooks
Iron	EPA 200.8		0.01	0.0109	mg/L	2/23/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/23/2024	SBrooks

Sample Location: 2nd Draw 1421 Taylor St NW
Customer Sample Number: 3050311
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/30/2024 9:08 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402057-006
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0046	mg/L	2/23/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	2/23/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	2/23/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/7/2024

Report Number: LC-DC-LCR-2402057-003

Sample Location: 1st Draw 1649 Harvard St NW
Customer Sample Number: 3034000
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/5/2024 12:00 PM

Customer Program Code: LCR
Laboratory Sample Number: 2402057-003
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0630	mg/L	2/23/2024	SBrooks
Iron	EPA 200.8		0.01	0.176	mg/L	2/23/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0029	mg/L	2/23/2024	SBrooks

Sample Location: 2nd Draw 1649 Harvard St NW
Customer Sample Number: 3034000
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/5/2024 12:06 PM

Customer Program Code: LCR
Laboratory Sample Number: 2402057-004
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0259	mg/L	2/23/2024	SBrooks
Iron	EPA 200.8		0.02	0.574	mg/L	2/23/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0227	mg/L	2/23/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/7/2024

Report Number: LC-DC-LCR-2402057-001

Sample Location: 1st Draw 3810 Military Rd NW
Customer Sample Number: 3040477
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/2/2024 8:45 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402057-001
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0553	mg/L	2/23/2024	SBrooks
Iron	EPA 200.8		0.01	0.0911	mg/L	2/23/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0026	mg/L	2/23/2024	SBrooks

Sample Location: 2nd Draw 3810 Military Rd NW
Customer Sample Number: 3040477
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/2/2024 8:51 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402057-002
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0147	mg/L	2/23/2024	SBrooks
Iron	EPA 200.8		0.01	0.107	mg/L	2/23/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0106	mg/L	2/23/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/7/2024

Report Number: LC-DC-LCR-2402116-001

Sample Location: 1st Draw 619 12th St NE
Customer Sample Number: 3099778
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 7:04 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402116-001
Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0319	mg/L	2/23/2024	SBrooks
Iron	EPA 200.8		0.01	0.225	mg/L	2/23/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0022	mg/L	2/23/2024	SBrooks

Sample Location: 2nd Draw 619 12th St NE
Customer Sample Number: 3099778
Sample Collected By: HOMEOWNER
Date / Time Collected: 1/31/2024 7:07 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402116-002
Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0486	mg/L	2/23/2024	SBrooks
Iron	EPA 200.8		0.01	0.116	mg/L	2/23/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	2/23/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2402181-001

Sample Location: 1st Draw 1115 C St NE
Customer Sample Number: 3099413
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/15/2024 12:10 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402181-001
Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0295	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 1115 C St NE
Customer Sample Number: 3099413
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/15/2024 12:11 AM

Customer Program Code: LCR
Laboratory Sample Number: 2402181-002
Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0084	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-017

Sample Location: 1st Draw 1120 C ST NE
Customer Sample Number: 3099431
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-017
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0550	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 1120 C ST NE
Customer Sample Number: 3099431
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:35 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-018
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0106	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-019

Sample Location: 1st Draw 1148 Abbey PI NE
Customer Sample Number: 3098343
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 8:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-019
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0067	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0258	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0011	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 1148 Abbey PI NE
Customer Sample Number: 3098343
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 8:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-020
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0131	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0328	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0096	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403005-003

Sample Location: 1st Draw 1254 Hamlin St. NE
Customer Sample Number: 3104009
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/29/2024 5:46 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-003
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0647	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0101	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 1254 Hamlin St. NE
Customer Sample Number: 3104009
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/29/2024 5:49 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-004
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0168	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-025

Sample Location: 1st Draw 1416 Montague St NW
Customer Sample Number: 3049298
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 6:50 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-025
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.152	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.0981	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 1416 Montague St NW
Customer Sample Number: 3049298
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 6:52 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-026
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0858	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.179	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0004	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2402180-001

Sample Location: 1st Draw 1611 Lawrence St NE
Customer Sample Number: 3120286
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/19/2024 3:58 PM

Customer Program Code: LCR
Laboratory Sample Number: 2402180-001
Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0750	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 1611 Lawrence St NE
Customer Sample Number: 3120286
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/19/2024 4:02 PM

Customer Program Code: LCR
Laboratory Sample Number: 2402180-002
Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0156	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-027

Sample Location: 1st Draw 18 Milmarson PI NW
Customer Sample Number: 3026169
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-027
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0057	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.113	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 18 Milmarson PI NW
Customer Sample Number: 3026169
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-028
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0096	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0688	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0012	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-033

Sample Location: 1st Draw 2010 Klinge Rd NW
Customer Sample Number: 3031299
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 6:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-033
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0424	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 2010 Klinge Rd NW
Customer Sample Number: 3031299
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 6:20 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-034
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0143	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-013

Sample Location: 1st Draw 3107 Cathedral Ave NW
Customer Sample Number: 3035504
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 7:45 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-013
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0550	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0390	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0014	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 3107 Cathedral Ave NW
Customer Sample Number: 3035504
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 7:50 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-014
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0167	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0670	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0016	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-015

Sample Location: 1st Draw 3112 Park PL NW
Customer Sample Number: 3019519
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 8:08 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-015
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0460	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 3112 Park PL NW
Customer Sample Number: 3019519
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 8:10 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-016
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0067	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0012	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-021

Sample Location: 1st Draw 3114 15th St NE
Customer Sample Number: 3104991
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-021
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0051	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 3114 15th St NE
Customer Sample Number: 3104991
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-022
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0047	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-009

Sample Location: 1st Draw 3206 5TH ST SE
Customer Sample Number: 3088535
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-009
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0077	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 3206 5TH ST SE
Customer Sample Number: 3088535
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:02 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-010
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0048	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0012	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-035

Sample Location: 1st Draw 3511 Idaho Ave NW
Customer Sample Number: 3041916
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:38 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-035
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0971	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 3511 Idaho Ave NW
Customer Sample Number: 3041916
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:40 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-036
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0151	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0010	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-029

Sample Location: 1st Draw 3608 17th St NE
Customer Sample Number: 3105376
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 6:25 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-029
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0292	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0379	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 3608 17th St NE
Customer Sample Number: 3105376
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 6:26 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-030
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0102	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0328	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0018	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-031

Sample Location: 1st Draw 3617 17TH ST NE
Customer Sample Number: 3105391
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 7:13 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-031
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0045	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0324	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 3617 17TH ST NE
Customer Sample Number: 3105391
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 7:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-032
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0097	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0275	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0011	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-005

Sample Location: 1st Draw 408 16th St SE
Customer Sample Number: 3075457
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/26/2024 5:20 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-005
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0408	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 408 16th St SE
Customer Sample Number: 3075457
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/26/2024 5:22 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-006
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0073	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-001

Sample Location: 1st Draw 419 12TH ST SE
Customer Sample Number: 3074020
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 6:43 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-001
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0403	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0175	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 419 12TH ST SE
Customer Sample Number: 3074020
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 6:44 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-002
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0086	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0188	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403005-009

Sample Location: 1st Draw 4312 14TH ST NW
Customer Sample Number: 3028218
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/29/2024 7:14 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-009
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0036	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0587	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 4312 14TH ST NW
Customer Sample Number: 3028218
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/29/2024 7:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-010
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0035	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0697	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-007

Sample Location: 1st Draw 4428 9th St NW
Customer Sample Number: 3021646
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:40 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-007
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0030	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.0230	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 4428 9th St NW
Customer Sample Number: 3021646
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 6:42 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-008
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0047	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.0241	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403005-001

Sample Location: 1st Draw 4710 8th St NW
Customer Sample Number: 3022291
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 10:04 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-001
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0070	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.102	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0015	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 4710 8th St NW
Customer Sample Number: 3022291
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 10:06 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-002
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0084	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.108	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0020	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403005-005

Sample Location: 1st Draw 5010 Klinge St. NW
Customer Sample Number: 3045912
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/29/2024 5:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-005
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0211	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 5010 Klinge St. NW
Customer Sample Number: 3045912
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/29/2024 5:02 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-006
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0061	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-011

Sample Location: 1st Draw 517 5th St NE
Customer Sample Number: 3127813
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 8:13 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-011
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.114	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 517 5th St NE
Customer Sample Number: 3127813
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/27/2024 8:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-012
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0287	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403005-007

Sample Location: 1st Draw 521 9th St. SE
Customer Sample Number: 3072921
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/29/2024 7:51 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-007
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0136	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.0384	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0010	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 521 9th St. SE
Customer Sample Number: 3072921
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/29/2024 7:54 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403005-008
Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0091	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.0390	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: LC-DC-LCR-2403048-003

Sample Location: 1st Draw 811 L St NE
Customer Sample Number: 3120596
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 7:33 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-003
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0193	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0356	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	3/11/2024	Blamsal

Sample Location: 2nd Draw 811 L St NE
Customer Sample Number: 3120596
Sample Collected By: HOMEOWNER
Date / Time Collected: 2/28/2024 7:36 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403048-004
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0708	mg/L	3/11/2024	Blamsal
Iron	EPA 200.8		0.01	0.0339	mg/L	3/11/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0004	mg/L	3/11/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/20/2024

Report Number: LC-DC-LCR-2403060-007

Sample Location: 1st Draw 22 Bates St NW
Customer Sample Number: 3011620
Sample Collected By: HOME OWNER
Date / Time Collected: 3/1/2024 6:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403060-007
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0136	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 22 Bates St NW
Customer Sample Number: 3011620
Sample Collected By: HOME OWNER
Date / Time Collected: 3/1/2024 6:17 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403060-008
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0060	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/20/2024

Report Number: LC-DC-LCR-2403060-003

Sample Location: 1st Draw 232 33rd St NE
Customer Sample Number: 3108359
Sample Collected By: HOME OWNER
Date / Time Collected: 3/1/2024 10:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403060-003
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0243	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.0241	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0037	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 232 33rd St NE
Customer Sample Number: 3108359
Sample Collected By: HOME OWNER
Date / Time Collected: 3/1/2024 10:05 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403060-004
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0143	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.0165	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0015	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/20/2024

Report Number: LC-DC-LCR-2403060-005

Sample Location: 1st Draw 519 RITTENHOUSE ST NW
Customer Sample Number: 3026457
Sample Collected By: HOME OWNER
Date / Time Collected: 2/28/2024 5:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403060-005
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0584	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 519 RITTENHOUSE ST NW
Customer Sample Number: 3026457
Sample Collected By: HOME OWNER
Date / Time Collected: 2/28/2024 5:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403060-006
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0072	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0016	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/20/2024

Report Number: LC-DC-LCR-2403060-001

Sample Location: 1st Draw 5403 39th St NW
Customer Sample Number: 3039969
Sample Collected By: HOMEOWNER
Date / Time Collected: 3/6/2024 7:07 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403060-001
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.126	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.0726	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

Sample Location: 2nd Draw 5403 39th St NW
Customer Sample Number: 3039969
Sample Collected By: HOMEOWNER
Date / Time Collected: 3/6/2024 7:09 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403060-002
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0441	mg/L	3/11/2024	Rlamsal
Iron	EPA 200.8		0.01	0.0969	mg/L	3/11/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/11/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: LC-DC-LCR-2403166-001

Sample Location: 1st Draw 1620 Gales St NE
Customer Sample Number: 3112063
Sample Collected By: HOME OWNER
Date / Time Collected: 3/13/2024 5:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403166-001
Date / Time Received: 3/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0041	mg/L	3/28/2024	Bprakash
Iron	EPA 200.8		0.01	ND	mg/L	3/28/2024	Bprakash
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	3/28/2024	Bprakash

Sample Location: 2nd Draw 1620 Gales St NE
Customer Sample Number: 3112063
Sample Collected By: HOME OWNER
Date / Time Collected: 3/13/2024 5:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403166-002
Date / Time Received: 3/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0072	mg/L	3/28/2024	Bprakash
Iron	EPA 200.8		0.01	ND	mg/L	3/28/2024	Bprakash
Lead	EPA 200.8	0.015	0.0002	0.0008	mg/L	3/28/2024	Bprakash

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: LC-DC-LCR-2403194-001

Sample Location: 1st Draw 813 E St SE
Customer Sample Number: 3072937
Sample Collected By: HOME OWNER
Date / Time Collected: 3/20/2024 7:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403194-001
Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.133	mg/L	3/28/2024	BPrakash
Iron	EPA 200.8		0.01	ND	mg/L	3/28/2024	BPrakash
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/28/2024	BPrakash

Sample Location: 2nd Draw 813 E St SE
Customer Sample Number: 3072937
Sample Collected By: HOME OWNER
Date / Time Collected: 3/20/2024 7:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2403194-002
Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0133	mg/L	3/28/2024	BPrakash
Iron	EPA 200.8		0.01	ND	mg/L	3/28/2024	BPrakash
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	3/28/2024	BPrakash

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-011

Sample Location: 1st Draw 1323 V St. NW
Customer Sample Number: 3010972
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 6:30 PM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-011
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.120	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 1323 V St. NW
Customer Sample Number: 3010972
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 6:30 PM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-012
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0130	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0022	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-009

Sample Location: 1st Draw 1415 F St NE
Customer Sample Number: 3100618
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 6:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-009
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0023	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 1415 F St NE
Customer Sample Number: 3100618
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 6:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-010
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0027	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0116	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404052-001

Sample Location: 1st Draw 1511 Allison St. NW
Customer Sample Number: 3027845
Sample Collected By: HOME OWNER
Date / Time Collected: 4/1/2024 6:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404052-001
Date / Time Received: 4/3/2024 9:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.127	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0882	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0013	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 1511 Allison St. NW
Customer Sample Number: 3027845
Sample Collected By: HOME OWNER
Date / Time Collected: 4/1/2024 6:17 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404052-002
Date / Time Received: 4/3/2024 9:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0191	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0535	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-023

Sample Location: 1st Draw 1522 New Jersey Ave NW
Customer Sample Number: 3006034
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 8:20 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-023
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.241	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.372	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 1522 New Jersey Ave NW
Customer Sample Number: 3006034
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 8:22 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-024
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0644	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.407	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-001

Sample Location: 1st Draw 1534 East Capital St NE
Customer Sample Number: 3120152
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 6:55 PM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-001
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0028	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0214	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 1534 East Capital St NE
Customer Sample Number: 3120152
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 6:59 PM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-002
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0025	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0209	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0009	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-011

Sample Location: 1st Draw 1721 Webster St NW
Customer Sample Number: 3029212
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 7:26 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-011
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0199	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.389	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 1721 Webster St NW
Customer Sample Number: 3029212
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 7:27 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-012
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0403	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0381	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404094-001

Sample Location: 1st Draw 1808 KEARNEY ST NE
Customer Sample Number: 3106057
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 5:45 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404094-001
Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0433	mg/L	4/15/2024	Lgallimore
Iron	EPA 200.8		0.01	0.389	mg/L	4/15/2024	Lgallimore
Lead	EPA 200.8	0.015	0.0002	0.0045	mg/L	4/15/2024	Lgallimore

Sample Location: 2nd Draw 1808 KEARNEY ST NE
Customer Sample Number: 3106057
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 6:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404094-002
Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0223	mg/L	4/15/2024	Lgallimore
Iron	EPA 200.8		0.01	0.179	mg/L	4/15/2024	Lgallimore
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	4/15/2024	Lgallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-001

Sample Location: 1st Draw 2734 34th PI NW
Customer Sample Number: 3057989
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 7:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-001
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0519	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.140	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 2734 34th PI NW
Customer Sample Number: 3057989
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 7:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-002
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0078	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.118	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-007

Sample Location: 1st Draw 34 U St NW
Customer Sample Number: 3051985
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 6:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-007
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0471	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 34 U St NW
Customer Sample Number: 3051985
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 6:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-008
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0072	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-005

Sample Location: 1st Draw 3907 McKinley St. NW
Customer Sample Number: 3039855
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 6:05 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-005
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0125	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 3907 McKinley St. NW
Customer Sample Number: 3039855
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 6:08 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-006
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0144	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404196-003

Sample Location: 1st Draw 4101 4th St NW
Customer Sample Number: 3057184
Sample Collected By: HOME OWNER
Date / Time Collected: 4/21/2024 2:13 PM

Customer Program Code: LCR
Laboratory Sample Number: 2404196-003
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0180	mg/L	5/2/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	5/2/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0012	mg/L	5/2/2024	SBrooks

Sample Location: 2nd Draw 4101 4th St NW
Customer Sample Number: 3057184
Sample Collected By: HOME OWNER
Date / Time Collected: 4/21/2024 2:14 PM

Customer Program Code: LCR
Laboratory Sample Number: 2404196-004
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0116	mg/L	5/2/2024	SBrooks
Iron	EPA 200.8		0.01	ND	mg/L	5/2/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0022	mg/L	5/2/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2405016-001

Sample Location: 1st Draw 4111 38th St NW

Customer Sample Number: 3041539

Sample Collected By: HOME OWNER

Date / Time Collected: 4/24/2024 7:30 AM

Customer Program Code: LCR

Laboratory Sample Number: 2405016-001

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0575	mg/L	5/2/2024	SBrooks
Iron	EPA 200.8		0.01	0.0534	mg/L	5/2/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0013	mg/L	5/2/2024	SBrooks

Sample Location: 2nd Draw 4111 38th St NW

Customer Sample Number: 3041539

Sample Collected By: HOME OWNER

Date / Time Collected: 4/24/2024 7:34 AM

Customer Program Code: LCR

Laboratory Sample Number: 2405016-002

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0687	mg/L	5/2/2024	SBrooks
Iron	EPA 200.8		0.01	0.0177	mg/L	5/2/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0009	mg/L	5/2/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-015

Sample Location: 1st Draw 4125 46th St NW

Customer Sample Number: 3043501

Sample Collected By: HOME OWNER

Date / Time Collected: 3/28/2024 6:00 AM

Customer Program Code: LCR

Laboratory Sample Number: 2404035-015

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.117	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0393	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 4125 46th St NW

Customer Sample Number: 3043501

Sample Collected By: HOME OWNER

Date / Time Collected: 3/28/2024 6:00 AM

Customer Program Code: LCR

Laboratory Sample Number: 2404035-016

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0308	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0450	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-015

Sample Location: 1st Draw 417 Shepherd St NW
Customer Sample Number: 3020832
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 6:32 PM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-015
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0016	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 417 Shepherd St NW
Customer Sample Number: 3020832
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 6:33 PM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-016
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0051	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-007

Sample Location: 1st Draw 4215 39th St NW

Customer Sample Number: 3041124

Sample Collected By: HOME OWNER

Date / Time Collected: 3/27/2024 11:15 PM

Customer Program Code: LCR

Laboratory Sample Number: 2404051-007

Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0805	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0278	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0010	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 4215 39th St NW

Customer Sample Number: 3041124

Sample Collected By: HOME OWNER

Date / Time Collected: 3/27/2024 11:16 PM

Customer Program Code: LCR

Laboratory Sample Number: 2404051-008

Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0172	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0126	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0031	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404052-003

Sample Location: 1st Draw 424 Farragut St NW
Customer Sample Number: 3023449
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 9:45 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404052-003
Date / Time Received: 4/3/2024 9:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.119	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 424 Farragut St NW
Customer Sample Number: 3023449
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 9:45 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404052-004
Date / Time Received: 4/3/2024 9:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0261	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-019

Sample Location: 1st Draw 4421 9th St. NW
Customer Sample Number: 3021641
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 7:50 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-019
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0563	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0345	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 4421 9th St. NW
Customer Sample Number: 3021641
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-020
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0126	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0365	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0032	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-017

Sample Location: 1st Draw 4610 Iowa Ave. NW
Customer Sample Number: 3027674
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 7:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-017
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0784	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0179	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 4610 Iowa Ave. NW
Customer Sample Number: 3027674
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 7:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-018
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0298	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0155	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0012	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-005

Sample Location: 1st Draw 5015 9th St NW
Customer Sample Number: 3022762
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 7:45 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-005
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.364	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.02	0.490	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0091	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 5015 9th St NW
Customer Sample Number: 3022762
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 7:47 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-006
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0174	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.320	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0082	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-003

Sample Location: 1st Draw 5127 5th St NW
Customer Sample Number: 3023335
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 7:56 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-003
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0028	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0476	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 5127 5th St NW
Customer Sample Number: 3023335
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 8:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-004
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0029	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0627	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404196-001

Sample Location: 1st Draw 5227 Sherier PL NW
Customer Sample Number: 3044647
Sample Collected By: HOME OWNER
Date / Time Collected: 4/23/2024 5:24 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404196-001
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0604	mg/L	5/2/2024	SBrooks
Iron	EPA 200.8		0.01	0.0230	mg/L	5/2/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	5/2/2024	SBrooks

Sample Location: 2nd Draw 5227 Sherier PL NW
Customer Sample Number: 3044647
Sample Collected By: HOME OWNER
Date / Time Collected: 4/23/2024 5:27 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404196-002
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0285	mg/L	5/2/2024	SBrooks
Iron	EPA 200.8		0.01	0.0244	mg/L	5/2/2024	SBrooks
Lead	EPA 200.8	0.015	0.0002	0.0016	mg/L	5/2/2024	SBrooks

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-009

Sample Location: 1st Draw 537 3rd St NE
Customer Sample Number: 3128137
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 5:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-009
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0105	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0318	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0035	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 537 3rd St NE
Customer Sample Number: 3128137
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 5:20 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-010
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0225	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0161	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0052	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-003

Sample Location: 1st Draw 540 5th St. SE
Customer Sample Number: 3072134
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 7:11 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-003
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0250	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0239	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0011	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 540 5th St. SE
Customer Sample Number: 3072134
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 7:14 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404051-004
Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0097	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.106	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0008	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-013

Sample Location: 1st Draw 541 Shepherd St. NW
Customer Sample Number: 3021001
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 7:36 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-013
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0043	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 541 Shepherd St. NW
Customer Sample Number: 3021001
Sample Collected By: HOME OWNER
Date / Time Collected: 3/27/2024 7:37 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-014
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0054	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0276	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0008	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404077-001

Sample Location: 1st Draw 5510 9th St NW
Customer Sample Number: 3056796
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 6:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404077-001
Date / Time Received: 4/9/2024 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0051	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 5510 9th St NW
Customer Sample Number: 3056796
Sample Collected By: HOME OWNER
Date / Time Collected: 3/28/2024 6:30 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404077-002
Date / Time Received: 4/9/2024 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0023	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-013

Sample Location: 1st Draw 5603 14TH St. NW

Customer Sample Number: 3049213

Sample Collected By: HOME OWNER

Date / Time Collected: 3/26/2024 6:06 AM

Customer Program Code: LCR

Laboratory Sample Number: 2404051-013

Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0122	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 5603 14TH St. NW

Customer Sample Number: 3049213

Sample Collected By: HOME OWNER

Date / Time Collected: 3/26/2024 6:07 AM

Customer Program Code: LCR

Laboratory Sample Number: 2404051-014

Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0062	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0107	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-017

Sample Location: 1st Draw 6125 29th St. NW

Customer Sample Number: 3037797

Sample Collected By: HOME OWNER

Date / Time Collected: 3/26/2024 5:40 AM

Customer Program Code: LCR

Laboratory Sample Number: 2404035-017

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0455	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0152	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 6125 29th St. NW

Customer Sample Number: 3037797

Sample Collected By: HOME OWNER

Date / Time Collected: 3/26/2024 5:44 AM

Customer Program Code: LCR

Laboratory Sample Number: 2404035-018

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0288	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	0.0156	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404035-021

Sample Location: 1st Draw 658 E ST SE
Customer Sample Number: 3072390
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 8:10 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-021
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0731	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 658 E ST SE
Customer Sample Number: 3072390
Sample Collected By: HOME OWNER
Date / Time Collected: 3/26/2024 8:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2404035-022
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0173	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0002	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LC-DC-LCR-2404051-019

Sample Location: 1st Draw 812 Van Buren St NW

Customer Sample Number: 3027231

Sample Collected By: HOME OWNER

Date / Time Collected: 3/27/2024 6:41 AM

Customer Program Code: LCR

Laboratory Sample Number: 2404051-019

Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0012	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

Sample Location: 2nd Draw 812 Van Buren St NW

Customer Sample Number: 3027231

Sample Collected By: HOME OWNER

Date / Time Collected: 3/27/2024 6:43 AM

Customer Program Code: LCR

Laboratory Sample Number: 2404051-020

Date / Time Received: 4/2/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0008	mg/L	4/10/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	4/10/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	4/10/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LC-DC-LCR-2405069-005

Sample Location: 1st Draw 1211 Carrollsborg PI SW
Customer Sample Number: 3092716
Sample Collected By: HOME OWNER
Date / Time Collected: 5/2/2024 3:24 PM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-005
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0997	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	0.0175	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0005	mg/L	5/16/2024	Blamsal

Sample Location: 2nd Draw 1211 Carrollsborg PI SW
Customer Sample Number: 3092716
Sample Collected By: HOME OWNER
Date / Time Collected: 5/2/2024 3:24 PM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-006
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.105	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	0.0113	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0012	mg/L	5/16/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LC-DC-LCR-2405069-001

Sample Location: 1st Draw 1334 E St. NE
Customer Sample Number: 3127738
Sample Collected By: HOME OWNER
Date / Time Collected: 5/3/2024 9:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-001
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0076	mg/L	5/16/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	5/16/2024	Rlamsal

Sample Location: 2nd Draw 1334 E St. NE
Customer Sample Number: 3127738
Sample Collected By: HOME OWNER
Date / Time Collected: 5/3/2024 9:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-002
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0147	mg/L	5/16/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	5/16/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LC-DC-LCR-2405069-009

Sample Location: 1st Draw 1354 D St SE
Customer Sample Number: 3074483
Sample Collected By: HOME OWNER
Date / Time Collected: 5/2/2024 7:05 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-009
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0151	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	0.0140	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	5/16/2024	Blamsal

Sample Location: 2nd Draw 1354 D St SE
Customer Sample Number: 3074483
Sample Collected By: HOME OWNER
Date / Time Collected: 5/2/2024 7:07 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-010
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0078	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	0.0132	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	5/16/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LC-DC-LCR-2405069-011

Sample Location: 1st Draw 1420 Ingraham St NW

Customer Sample Number: 3049437

Sample Collected By: HOME OWNER

Date / Time Collected: 5/1/2024 12:00 AM

Customer Program Code: LCR

Laboratory Sample Number: 2405069-011

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0486	mg/L	5/16/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	5/16/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LC-DC-LCR-2405069-003

Sample Location: 1st Draw 231 K St NE
Customer Sample Number: 3097777
Sample Collected By: HOME OWNER
Date / Time Collected: 5/1/2024 6:26 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-003
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0890	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	5/16/2024	Blamsal

Sample Location: 2nd Draw 231 K St NE
Customer Sample Number: 3097777
Sample Collected By: HOME OWNER
Date / Time Collected: 5/1/2024 6:28 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-004
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0250	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	5/16/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LC-DC-LCR-2405072-001

Sample Location: 1st Draw 2923 Cathedral Ave NW
Customer Sample Number: 3035494
Sample Collected By: HOME OWNER
Date / Time Collected: 5/4/2024 8:23 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405072-001
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0195	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	0.0771	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	5/16/2024	Blamsal

Sample Location: 2nd Draw 2923 Cathedral Ave NW
Customer Sample Number: 3035494
Sample Collected By: HOME OWNER
Date / Time Collected: 5/4/2024 8:25 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405072-002
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0049	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	ND	mg/L	5/16/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LC-DC-LCR-2405026-003

Sample Location: 1st Draw 3030 44th St NW
Customer Sample Number: 3055102
Sample Collected By: HOME OWNER
Date / Time Collected: 4/24/2024 6:10 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405026-003
Date / Time Received: 5/2/2024 9:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0256	mg/L	5/16/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	5/16/2024	Rlamsal

Sample Location: 2nd Draw 3030 44th St NW
Customer Sample Number: 3055102
Sample Collected By: HOME OWNER
Date / Time Collected: 4/24/2024 6:12 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405026-004
Date / Time Received: 5/2/2024 9:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0218	mg/L	5/16/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0011	mg/L	5/16/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LC-DC-LCR-2405069-007

Sample Location: 1st Draw 414 Douglas St NE
Customer Sample Number: 3125726
Sample Collected By: HOME OWNER
Date / Time Collected: 5/3/2024 5:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-007
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0589	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	0.0125	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0003	mg/L	5/16/2024	Blamsal

Sample Location: 2nd Draw 414 Douglas St NE
Customer Sample Number: 3125726
Sample Collected By: HOME OWNER
Date / Time Collected: 5/3/2024 5:00 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405069-008
Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0159	mg/L	5/16/2024	Blamsal
Iron	EPA 200.8		0.01	0.0153	mg/L	5/16/2024	Blamsal
Lead	EPA 200.8	0.015	0.0002	0.0004	mg/L	5/16/2024	Blamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LC-DC-LCR-2405026-001

Sample Location: 1st Draw 424 Warner St NW
Customer Sample Number: 3006126
Sample Collected By: HOME OWNER
Date / Time Collected: 4/26/2024 6:15 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405026-001
Date / Time Received: 5/2/2024 9:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0629	mg/L	5/16/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0016	mg/L	5/16/2024	Rlamsal

Sample Location: 2nd Draw 424 Warner St NW
Customer Sample Number: 3006126
Sample Collected By: HOME OWNER
Date / Time Collected: 4/26/2024 6:18 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405026-002
Date / Time Received: 5/2/2024 9:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0292	mg/L	5/16/2024	Rlamsal
Iron	EPA 200.8		0.01	ND	mg/L	5/16/2024	Rlamsal
Lead	EPA 200.8	0.015	0.0002	0.0004	mg/L	5/16/2024	Rlamsal

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Report revised on 6/10/24 by MC.
Lab Sample Numbers 2405202-001 & 2405202-001, the
address was changed from 114 3RD ST NE to 114 3RD ST SE
as recorded on the chain-of-custody form.

Robert P. Hoffa, Laboratory Manager

Report Date: 6/10/2024

Report Number: LC-DC-LCR-2405202-001

Sample Location: 1st Draw 114 3RD ST SE
Customer Sample Number: 3071662
Sample Collected By: HOME OWNER
Date / Time Collected: 5/22/2024 8:10 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405202-001
Date / Time Received: 5/28/2024 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0468	mg/L	6/4/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	6/4/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0007	mg/L	6/4/2024	LGallimore

Sample Location: 2nd Draw 114 3RD ST SE
Customer Sample Number: 3071662
Sample Collected By: HOME OWNER
Date / Time Collected: 5/22/2024 8:12 AM

Customer Program Code: LCR
Laboratory Sample Number: 2405202-002
Date / Time Received: 5/28/2024 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0143	mg/L	6/4/2024	LGallimore
Iron	EPA 200.8		0.01	ND	mg/L	6/4/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0004	mg/L	6/4/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/10/2024

Report Number: LC-DC-LCR-2405202-003

Sample Location: 1st Draw 2718 Hamlin ST NE

Customer Sample Number: 3107853

Sample Collected By: HOME OWNER

Date / Time Collected: 5/22/2024 5:18 AM

Customer Program Code: LCR

Laboratory Sample Number: 2405202-003

Date / Time Received: 5/28/2024 1:45:00 PM

Analyte	Method	AL	MRL	Result	Units	Analysis Date	Analyst
Copper	EPA 200.8	1.3	0.0002	0.0145	mg/L	6/4/2024	LGallimore
Iron	EPA 200.8		0.01	0.0207	mg/L	6/4/2024	LGallimore
Lead	EPA 200.8	0.015	0.0002	0.0004	mg/L	6/4/2024	LGallimore

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Iron results are for informational purposes only and cannot be used for compliance.

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**