

Attachment 2

Other Non-Regulated Samples Analyzed for Lead

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-005

Sample Location: 1st Draw 122 Kentucky Ave SE

Customer Sample Number:

Date / Time Collected: 12/7/2023 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-005

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 122 Kentucky Ave SE

Customer Sample Number:

Date / Time Collected: 12/7/2023 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-006

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-011

Sample Location: 1st Draw 1326 T St. NW

Customer Sample Number:

Date / Time Collected: 11/30/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-011

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1326 T St. NW

Customer Sample Number:

Date / Time Collected: 11/30/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-012

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-021

Sample Location: 1st Draw 1371 F St. NE

Customer Sample Number:

Date / Time Collected: 12/4/2023 6:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-021

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1371 F St. NE

Customer Sample Number:

Date / Time Collected: 12/4/2023 6:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-022

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-015

Sample Location: 1st Draw 1400 Montague St NW

Customer Sample Number:

Date / Time Collected: 12/3/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-015

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1400 Montague St NW

Customer Sample Number:

Date / Time Collected: 12/3/2023 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-016

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-019

Sample Location: 1st Draw 1505 A St. NE
Customer Sample Number:
Date / Time Collected: 12/3/2023 7:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-019
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1505 A St. NE
Customer Sample Number:
Date / Time Collected: 12/3/2023 7:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-020
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-017

Sample Location: 1st Draw 1514 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 12/5/2023 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-017

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1514 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 12/5/2023 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-018

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-013

Sample Location: 1st Draw 1619 6th St NW

Customer Sample Number:

Date / Time Collected: 12/8/2023 8:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-013

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1619 6th St NW

Customer Sample Number:

Date / Time Collected: 12/8/2023 8:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-014

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-001

Sample Location: 1st Draw 1623 D St. NE
Customer Sample Number:
Date / Time Collected: 12/8/2023 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2312111-001
Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1623 D St. NE
Customer Sample Number:
Date / Time Collected: 12/8/2023 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2312111-002
Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312048-005

Sample Location: 1st Draw 1708 Allison St NW

Customer Sample Number:

Date / Time Collected: 11/20/2023 4:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2312048-005

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	12/21/2023	Lgallimore

Sample Location: 2nd Draw 1708 Allison St NW

Customer Sample Number:

Date / Time Collected: 11/20/2023 4:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2312048-006

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-009

Sample Location: 1st Draw 1818 Newton St NE

Customer Sample Number:

Date / Time Collected: 12/7/2023 4:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-009

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1818 Newton St NE

Customer Sample Number:

Date / Time Collected: 12/7/2023 4:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-010

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-029

Sample Location: 1st Draw 1840 Burke St. SE

Customer Sample Number:

Date / Time Collected: 11/26/2023 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-029

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1840 Burke St. SE

Customer Sample Number:

Date / Time Collected: 11/26/2023 7:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-030

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-009

Sample Location: 1st Draw 205 Warren St NE

Customer Sample Number:

Date / Time Collected: 12/5/2023 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-009

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 205 Warren St NE

Customer Sample Number:

Date / Time Collected: 12/5/2023 7:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-010

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-013

Sample Location: 1st Draw 213 9th St. SE
Customer Sample Number:
Date / Time Collected: 11/29/2023 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-013
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 213 9th St. SE
Customer Sample Number:
Date / Time Collected: 11/29/2023 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-014
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-023

Sample Location: 1st Draw 238 9th St. SE
Customer Sample Number:
Date / Time Collected: 11/30/2023 7:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-023
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 238 9th St. SE
Customer Sample Number:
Date / Time Collected: 11/30/2023 7:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-024
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-003

Sample Location: 1st Draw 2808 26th St. NE

Customer Sample Number:

Date / Time Collected: 12/6/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-003

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 2808 26th St. NE

Customer Sample Number:

Date / Time Collected: 12/6/2023 6:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-004

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312048-001

Sample Location: 1st Draw 3157 18th St NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312048-001

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Sample Location: 2nd Draw 3157 18th St NW

Customer Sample Number:

Date / Time Collected: 11/17/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312048-002

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-017

Sample Location: 1st Draw 3609 35th St. NW

Customer Sample Number:

Date / Time Collected: 12/5/2023 6:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-017

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 3609 35th St. NW

Customer Sample Number:

Date / Time Collected: 12/5/2023 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-018

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-011

Sample Location: 1st Draw 3700 30th PI NE

Customer Sample Number:

Date / Time Collected: 12/8/2023 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-011

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 3700 30th PI NE

Customer Sample Number:

Date / Time Collected: 12/8/2023 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-012

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-025

Sample Location: 1st Draw 3720 YUMA ST NW

Customer Sample Number:

Date / Time Collected: 12/3/2023 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-025

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 3720 YUMA ST NW

Customer Sample Number:

Date / Time Collected: 12/3/2023 7:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-026

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-019

Sample Location: 1st Draw 3917 Blaine St NE

Customer Sample Number:

Date / Time Collected: 12/6/2023 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2312111-019

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 3917 Blaine St NE

Customer Sample Number:

Date / Time Collected: 12/6/2023 6:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2312111-020

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-001

Sample Location: 1st Draw 4218 3rd St NW

Customer Sample Number:

Date / Time Collected: 12/4/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-001

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 4218 3rd St NW

Customer Sample Number:

Date / Time Collected: 12/4/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-002

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-033

Sample Location: 1st Draw 4715 Sedgwick St NW

Customer Sample Number:

Date / Time Collected: 12/6/2023 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-033

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 4715 Sedgwick St NW

Customer Sample Number:

Date / Time Collected: 12/6/2023 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-034

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-021

Sample Location: 1st Draw 505 9TH ST SE

Customer Sample Number:

Date / Time Collected: 12/8/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-021

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 505 9TH ST SE

Customer Sample Number:

Date / Time Collected: 12/8/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312111-022

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-031

Sample Location: 1st Draw 5522 Carolina PI NW

Customer Sample Number:

Date / Time Collected: 12/5/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-031

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 5522 Carolina PI NW

Customer Sample Number:

Date / Time Collected: 12/5/2023 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2312060-032

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312048-003

Sample Location: 1st Draw 66 Q St NW
Customer Sample Number:
Date / Time Collected: 12/5/2023 1:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2312048-003
Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 66 Q St NW
Customer Sample Number:
Date / Time Collected: 12/5/2023 1:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2312048-004
Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-027

Sample Location: 1st Draw 801 C St. SE
Customer Sample Number:
Date / Time Collected: 12/1/2023 6:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-027
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 801 C St. SE
Customer Sample Number:
Date / Time Collected: 12/1/2023 6:08 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-028
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-033

Sample Location: 1st Draw 810 A St. SE
Customer Sample Number:
Date / Time Collected: 12/3/2023 7:31 AM

Customer Program Code: DS
Laboratory Sample Number: 2312111-033
Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 810 A St. SE
Customer Sample Number:
Date / Time Collected: 12/3/2023 7:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2312111-034
Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312111-007

Sample Location: 1st Draw 879 Bellevue St. SE

Customer Sample Number:

Date / Time Collected: 12/6/2023 2:07 PM

Customer Program Code: DS

Laboratory Sample Number: 2312111-007

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 879 Bellevue St. SE

Customer Sample Number:

Date / Time Collected: 12/6/2023 2:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2312111-008

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS- 2312060-015

Sample Location: 1st Draw 921 W St. NW
Customer Sample Number:
Date / Time Collected: 12/5/2023 6:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-015
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 921 W St. NW
Customer Sample Number:
Date / Time Collected: 12/5/2023 6:57 AM

Customer Program Code: DS
Laboratory Sample Number: 2312060-016
Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS250- 2312061-001

Sample Location: 1st Draw 1204 1/2 33rd St. NW

Customer Sample Number:

Date / Time Collected: 12/3/2023 11:07 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312061-001

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1204 1/2 33rd St. NW

Customer Sample Number:

Date / Time Collected: 12/3/2023 11:07 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312061-002

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS250- 2312049-003

Sample Location: 1st Draw 1390 Kenyon St NW Unit 815

Customer Sample Number:

Date / Time Collected: 11/25/2023 12:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2312049-003

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1390 Kenyon St NW Unit 815

Customer Sample Number:

Date / Time Collected: 11/25/2023 12:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2312049-004

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS250- 2312061-005

Sample Location: 1st Draw 2831 28th St. NW Apt. 40

Customer Sample Number:

Date / Time Collected: 12/1/2023 6:29 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312061-005

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 2831 28th St. NW Apt. 40

Customer Sample Number:

Date / Time Collected: 12/1/2023 6:29 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312061-006

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS250- 2312049-001

Sample Location: 1st Draw 3540 39th St. NW Apt. F648

Customer Sample Number:

Date / Time Collected: 11/19/2023 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2312049-001

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	12/21/2023	Lgallimore

Sample Location: 2nd Draw 3540 39th St. NW Apt. F648

Customer Sample Number:

Date / Time Collected: 11/19/2023 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2312049-002

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-DS250- 2312061-003

Sample Location: 1st Draw 721 Brandywine St SE Apt. 204

Customer Sample Number:

Date / Time Collected: 11/29/2023 9:58 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312061-003

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 721 Brandywine St SE Apt. 204

Customer Sample Number:

Date / Time Collected: 11/29/2023 9:58 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312061-004

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS-2312159-025

Sample Location: 1st Draw 1353 Aspen St. NW

Customer Sample Number:

Date / Time Collected: 12/17/2023 5:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-025

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 1353 Aspen St. NW

Customer Sample Number:

Date / Time Collected: 12/17/2023 5:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-026

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS-2312159-011

Sample Location: 1st Draw 1513 Independence Ave SE

Customer Sample Number:

Date / Time Collected: 12/9/2023 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-011

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 1513 Independence Ave SE

Customer Sample Number:

Date / Time Collected: 12/9/2023 6:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-012

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS-2312159-017

Sample Location: 1st Draw 1516 34th St NW

Customer Sample Number:

Date / Time Collected: 12/14/2023 5:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-017

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 1516 34th St NW

Customer Sample Number:

Date / Time Collected: 12/14/2023 5:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-018

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS-2312159-019

Sample Location: 1st Draw 1616 New Jersey Ave NW

Customer Sample Number:

Date / Time Collected: 12/12/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-019

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 1616 New Jersey Ave NW

Customer Sample Number:

Date / Time Collected: 12/12/2023 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-020

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS-2312159-023

Sample Location: 1st Draw 1729 F St. NE
Customer Sample Number:
Date / Time Collected: 12/10/2023 8:22 AM

Customer Program Code: DS
Laboratory Sample Number: 2312159-023
Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 1729 F St. NE
Customer Sample Number:
Date / Time Collected: 12/10/2023 8:24 AM

Customer Program Code: DS
Laboratory Sample Number: 2312159-024
Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS-2312159-021

Sample Location: 1st Draw 1849 Vernon St NW #B

Customer Sample Number:

Date / Time Collected: 12/15/2023 10:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-021

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 1849 Vernon St NW #B

Customer Sample Number:

Date / Time Collected: 12/15/2023 10:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-022

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS-2312159-027

Sample Location: 1st Draw 2922 Upton St NW

Customer Sample Number:

Date / Time Collected: 12/13/2023 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-027

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 2922 Upton St NW

Customer Sample Number:

Date / Time Collected: 12/13/2023 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-028

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS-2312159-013

Sample Location: 1st Draw 3815 Garfield St NW

Customer Sample Number:

Date / Time Collected: 12/7/2023 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-013

Date / Time Received: 12/22/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	1/4/2024	SBrooks

Sample Location: 2nd Draw 3815 Garfield St NW

Customer Sample Number:

Date / Time Collected: 12/7/2023 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-014

Date / Time Received: 12/22/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS-2312159-015

Sample Location: 1st Draw 4607 Clark PI NW

Customer Sample Number:

Date / Time Collected: 12/14/2023 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-015

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 4607 Clark PI NW

Customer Sample Number:

Date / Time Collected: 12/14/2023 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2312159-016

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS250- 2312156-009

Sample Location: 1st Draw 1111 24th ST. NW #53

Customer Sample Number:

Date / Time Collected: 12/16/2023 7:05 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-009

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 1111 24th ST. NW #53

Customer Sample Number:

Date / Time Collected: 12/16/2023 7:05 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-010

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS250- 2312156-001

Sample Location: 1st Draw 2101 16th St N.W #801

Customer Sample Number:

Date / Time Collected: 12/13/2023 9:07 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-001

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 2101 16th St N.W #801

Customer Sample Number:

Date / Time Collected: 12/13/2023 9:07 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-002

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS250- 2312156-007

Sample Location: 1st Draw 225 I ST. NE #1111

Customer Sample Number:

Date / Time Collected: 12/6/2023 6:05 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-007

Date / Time Received: 12/22/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/4/2024	SBrooks

Sample Location: 2nd Draw 225 I ST. NE #1111

Customer Sample Number:

Date / Time Collected: 12/6/2023 6:05 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-008

Date / Time Received: 12/22/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS250- 2312156-003

Sample Location: 1st Draw 3450 39th St NW #C687

Customer Sample Number:

Date / Time Collected: 12/13/2023 6:39 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-003

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 3450 39th St NW #C687

Customer Sample Number:

Date / Time Collected: 12/13/2023 6:39 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-004

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-DS250- 2312156-005

Sample Location: 1st Draw 4343 Harrison St NW #7

Customer Sample Number:

Date / Time Collected: 12/18/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-005

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 4343 Harrison St NW #7

Customer Sample Number:

Date / Time Collected: 12/18/2023 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2312156-006

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-031

Sample Location: 1st Draw 1008 8th St NE

Customer Sample Number:

Date / Time Collected: 1/7/2024 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-031

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1008 8th St NE

Customer Sample Number:

Date / Time Collected: 1/7/2024 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-032

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-039

Sample Location: 1st Draw 1115 47th PL NE

Customer Sample Number:

Date / Time Collected: 1/7/2024 10:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-039

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1115 47th PL NE

Customer Sample Number:

Date / Time Collected: 1/7/2024 10:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-040

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-003

Sample Location: 1st Draw 120 18th St SE

Customer Sample Number:

Date / Time Collected: 1/8/2024 5:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-003

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 120 18th St SE

Customer Sample Number:

Date / Time Collected: 1/8/2024 5:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-004

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-019

Sample Location: 1st Draw 1208 Lamont St NW #2

Customer Sample Number:

Date / Time Collected: 12/31/2023 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-019

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 1208 Lamont St NW #2

Customer Sample Number:

Date / Time Collected: 12/31/2023 7:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-020

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-013

Sample Location: 1st Draw 126 Rhode Island Ave NW

Customer Sample Number:

Date / Time Collected: 12/24/2023 8:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-013

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 126 Rhode Island Ave NW

Customer Sample Number:

Date / Time Collected: 12/24/2023 8:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-014

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-035

Sample Location: 1st Draw 1315 Tewkesbury PI NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-035

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1315 Tewkesbury PI NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 4:01 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-036

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-029

Sample Location: 1st Draw 1324 Upshur St NW

Customer Sample Number:

Date / Time Collected: 12/26/2023 8:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-029

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 1324 Upshur St NW

Customer Sample Number:

Date / Time Collected: 12/26/2023 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-030

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-017

Sample Location: 1st Draw 1330 Independence AVE SE

Customer Sample Number:

Date / Time Collected: 12/21/2023 7:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-017

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	1/11/2024	Rlamsal

Sample Location: 2nd Draw 1330 Independence AVE SE

Customer Sample Number:

Date / Time Collected: 12/21/2023 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-018

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-001

Sample Location: 1st Draw 1361 F ST. NE

Customer Sample Number:

Date / Time Collected: 1/7/2024 8:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-001

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1361 F ST. NE

Customer Sample Number:

Date / Time Collected: 1/7/2024 8:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-002

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-055

Sample Location: 1st Draw 1541 Douglas St NE

Customer Sample Number:

Date / Time Collected: 1/3/2024 3:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-055

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1541 Douglas St NE

Customer Sample Number:

Date / Time Collected: 1/3/2024 3:36 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-056

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-043

Sample Location: 1st Draw 1547 33rd ST NW

Customer Sample Number:

Date / Time Collected: 12/20/2023 10:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-043

Date / Time Received: 1/12/2024 8:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	1/31/2024	Rlamsal

Sample Location: 2nd Draw 1547 33rd ST NW

Customer Sample Number:

Date / Time Collected: 12/20/2023 10:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-044

Date / Time Received: 1/12/2024 8:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-011

Sample Location: 1st Draw 1837 Burke ST SE

Customer Sample Number:

Date / Time Collected: 1/8/2024 4:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-011

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1837 Burke ST SE

Customer Sample Number:

Date / Time Collected: 1/8/2024 4:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-012

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-057

Sample Location: 1st Draw 1907 35th PI NW

Customer Sample Number:

Date / Time Collected: 1/7/2024 10:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-057

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1907 35th PI NW

Customer Sample Number:

Date / Time Collected: 1/7/2024 10:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-058

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-025

Sample Location: 1st Draw 1926 6th St NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-025

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1926 6th St NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 5:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-026

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-023

Sample Location: 1st Draw 231 Farragut St NW

Customer Sample Number:

Date / Time Collected: 12/13/2023 6:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-023

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/11/2024	Rlamsal

Sample Location: 2nd Draw 231 Farragut St NW

Customer Sample Number:

Date / Time Collected: 12/13/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-024

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-009

Sample Location: 1st Draw 2417 Huidekoper PI NW
Customer Sample Number:
Date / Time Collected: 1/2/2024 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2401043-009
Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 2417 Huidekoper PI NW
Customer Sample Number:
Date / Time Collected: 1/2/2024 7:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2401043-010
Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-023

Sample Location: 1st Draw 245 Gallatin ST NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 6:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-023

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 245 Gallatin ST NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-024

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-007

Sample Location: 1st Draw 2453 1/2 P St NW

Customer Sample Number:

Date / Time Collected: 1/3/2024 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-007

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 2453 1/2 P St NW

Customer Sample Number:

Date / Time Collected: 1/3/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-008

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-019

Sample Location: 1st Draw 2908 Ellicott St NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 7:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-019

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 2908 Ellicott St NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 7:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-020

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-017

Sample Location: 1st Draw 2934 Fessenden St NW

Customer Sample Number:

Date / Time Collected: 1/2/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-017

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 2934 Fessenden St NW

Customer Sample Number:

Date / Time Collected: 1/2/2024 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-018

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-069

Sample Location: 1st Draw 309 10th St NE

Customer Sample Number:

Date / Time Collected: 1/5/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-069

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 309 10th St NE

Customer Sample Number:

Date / Time Collected: 1/5/2024 7:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-070

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-049

Sample Location: 1st Draw 320 17th St SE

Customer Sample Number:

Date / Time Collected: 1/3/2024 5:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-049

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 320 17th St SE

Customer Sample Number:

Date / Time Collected: 1/3/2024 5:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-050

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-037

Sample Location: 1st Draw 3315 Idaho Ave NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-037

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 3315 Idaho Ave NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 6:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-038

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-041

Sample Location: 1st Draw 333 U ST NW

Customer Sample Number:

Date / Time Collected: 1/5/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-041

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 333 U ST NW

Customer Sample Number:

Date / Time Collected: 1/5/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-042

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-025

Sample Location: 1st Draw 3922 44th ST NW

Customer Sample Number:

Date / Time Collected: 12/23/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-025

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 3922 44th ST NW

Customer Sample Number:

Date / Time Collected: 12/23/2023 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-026

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-029

Sample Location: 1st Draw 419 5th ST SE

Customer Sample Number:

Date / Time Collected: 12/31/2023 6:18 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-029

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 419 5th ST SE

Customer Sample Number:

Date / Time Collected: 12/31/2023 6:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-030

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-073

Sample Location: 1st Draw 434 24th ST NE

Customer Sample Number:

Date / Time Collected: 12/31/2023 4:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-073

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 434 24th ST NE

Customer Sample Number:

Date / Time Collected: 12/31/2023 4:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2401088-074

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-027

Sample Location: 1st Draw 4834 7th St. NW

Customer Sample Number:

Date / Time Collected: 12/20/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-027

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/11/2024	Rlamsal

Sample Location: 2nd Draw 4834 7th St. NW

Customer Sample Number:

Date / Time Collected: 12/20/2023 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-028

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-047

Sample Location: 1st Draw 53 Buchanan St NE

Customer Sample Number:

Date / Time Collected: 1/6/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-047

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 53 Buchanan St NE

Customer Sample Number:

Date / Time Collected: 1/6/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-048

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-015

Sample Location: 1st Draw 5447 Chevy Chase Pkwy

Customer Sample Number:

Date / Time Collected: 1/2/2024 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-015

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 5447 Chevy Chase Pkwy

Customer Sample Number:

Date / Time Collected: 1/2/2024 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-016

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-053

Sample Location: 1st Draw 605 4th PI SW
Customer Sample Number:
Date / Time Collected: 12/31/2023 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2401088-053
Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 605 4th PI SW
Customer Sample Number:
Date / Time Collected: 12/31/2023 8:02 AM

Customer Program Code: DS
Laboratory Sample Number: 2401088-054
Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-065

Sample Location: 1st Draw 6401 33rd ST NW

Customer Sample Number:

Date / Time Collected: 1/9/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-065

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 6401 33rd ST NW

Customer Sample Number:

Date / Time Collected: 1/9/2024 7:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-066

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-011

Sample Location: 1st Draw 649 20th St NE

Customer Sample Number:

Date / Time Collected: 11/20/2023 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-011

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/11/2024	Rlamsal

Sample Location: 2nd Draw 649 20th St NE

Customer Sample Number:

Date / Time Collected: 11/20/2023 6:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-012

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-007

Sample Location: 1st Draw 664 Acker PI NE

Customer Sample Number:

Date / Time Collected: 1/8/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-007

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 664 Acker PI NE

Customer Sample Number:

Date / Time Collected: 1/8/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-008

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-061

Sample Location: 1st Draw 664 Columbia Rd NW

Customer Sample Number:

Date / Time Collected: 1/5/2024 8:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-061

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 664 Columbia Rd NW

Customer Sample Number:

Date / Time Collected: 1/5/2024 8:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-062

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-013

Sample Location: 1st Draw 6950 33rd St., NW

Customer Sample Number:

Date / Time Collected: 1/3/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-013

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 6950 33rd St., NW

Customer Sample Number:

Date / Time Collected: 1/3/2024 9:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-014

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-033

Sample Location: 1st Draw 696 4th ST NE

Customer Sample Number:

Date / Time Collected: 12/11/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-033

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/31/2024	Rlamsal

Sample Location: 2nd Draw 696 4th ST NE

Customer Sample Number:

Date / Time Collected: 12/11/2023 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-034

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-021

Sample Location: 1st Draw 720 9th St SE
Customer Sample Number:
Date / Time Collected: 1/3/2024 6:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2401043-021
Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 720 9th St SE
Customer Sample Number:
Date / Time Collected: 1/3/2024 6:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2401043-022
Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401088-027

Sample Location: 1st Draw 744 Park Rd NW

Customer Sample Number:

Date / Time Collected: 1/2/2024 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-027

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 744 Park Rd NW

Customer Sample Number:

Date / Time Collected: 1/2/2024 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2401088-028

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-031

Sample Location: 1st Draw 824 12th St NE

Customer Sample Number:

Date / Time Collected: 12/18/2023 5:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-031

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/31/2024	Rlamsal

Sample Location: 2nd Draw 824 12th St NE

Customer Sample Number:

Date / Time Collected: 12/18/2023 5:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-032

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS-2401043-015

Sample Location: 1st Draw 940 French St NW

Customer Sample Number:

Date / Time Collected: 1/3/2024 7:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-015

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 940 French St NW

Customer Sample Number:

Date / Time Collected: 1/3/2024 7:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2401043-016

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS250- 2401089-011

Sample Location: 1st Draw 1 Scott Circle #501

Customer Sample Number:

Date / Time Collected: 1/6/2024 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-011

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1 Scott Circle #501

Customer Sample Number:

Date / Time Collected: 1/6/2024 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-012

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS250- 2401089-013

Sample Location: 1st Draw 150 I St SE Apt 1027

Customer Sample Number:

Date / Time Collected: 11/15/2023 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-013

Date / Time Received: 1/12/2024 8:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/31/2024	Rlamsal

Sample Location: 2nd Draw 150 I St SE Apt 1027

Customer Sample Number:

Date / Time Collected: 11/15/2023 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-014

Date / Time Received: 1/12/2024 8:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS250- 2401089-005

Sample Location: 1st Draw 1823 Newton ST NW #102

Customer Sample Number:

Date / Time Collected: 1/5/2024 5:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-005

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1823 Newton ST NW #102

Customer Sample Number:

Date / Time Collected: 1/5/2024 5:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-006

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS250- 2401089-001

Sample Location: 1st Draw 1900 Lamont St NW Apt 306

Customer Sample Number:

Date / Time Collected: 1/6/2024 10:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-001

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 1900 Lamont St NW Apt 306

Customer Sample Number:

Date / Time Collected: 1/6/2024 10:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-002

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS250- 2401037-001

Sample Location: 1st Draw 3720 39th St NW A163

Customer Sample Number:

Date / Time Collected: 12/27/2023 12:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2401037-001

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 3720 39th St NW A163

Customer Sample Number:

Date / Time Collected: 12/27/2023 12:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2401037-002

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS250- 2401089-007

Sample Location: 1st Draw 4201 Cathedral Ave. NW (502W)

Customer Sample Number:

Date / Time Collected: 1/7/2024 4:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-007

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 4201 Cathedral Ave. NW (502W)

Customer Sample Number:

Date / Time Collected: 1/7/2024 4:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-008

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS250- 2401089-003

Sample Location: 1st Draw 504 C ST NE Unit 5

Customer Sample Number:

Date / Time Collected: 1/5/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-003

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 504 C ST NE Unit 5

Customer Sample Number:

Date / Time Collected: 1/5/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-004

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-DS250- 2401089-009

Sample Location: 1st Draw 534 Taylor St. NW (A)

Customer Sample Number:

Date / Time Collected: 1/6/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-009

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 534 Taylor St. NW (A)

Customer Sample Number:

Date / Time Collected: 1/6/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401089-010

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-055

Sample Location: 1st Draw 1020 G Street NE

Customer Sample Number:

Date / Time Collected: 1/17/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-055

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1020 G Street NE

Customer Sample Number:

Date / Time Collected: 1/17/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-056

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-027

Sample Location: 1st Draw 110 15th St NE

Customer Sample Number:

Date / Time Collected: 11/28/2023 5:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2401188-027

Date / Time Received: 1/26/2024 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L	H	2/8/2024	SBrooks

Sample Location: 2nd Draw 110 15th St NE

Customer Sample Number:

Date / Time Collected: 11/28/2023 5:01 PM

Customer Program Code: DS

Laboratory Sample Number: 2401188-028

Date / Time Received: 1/26/2024 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.8	ug/L	H	2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-011

Sample Location: 1st Draw 1111 Independence Ave SE

Customer Sample Number:

Date / Time Collected: 1/15/2024 2:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-011

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1111 Independence Ave SE

Customer Sample Number:

Date / Time Collected: 1/15/2024 2:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-012

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-017

Sample Location: 1st Draw 1133 Bellevue St SE

Customer Sample Number:

Date / Time Collected: 1/10/2024 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-017

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1133 Bellevue St SE

Customer Sample Number:

Date / Time Collected: 1/10/2024 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-018

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-025

Sample Location: 1st Draw 116 V St NW
Customer Sample Number:
Date / Time Collected: 1/8/2024 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-025
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 116 V St NW
Customer Sample Number:
Date / Time Collected: 1/8/2024 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-026
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-015

Sample Location: 1st Draw 122 Webster ST NW

Customer Sample Number:

Date / Time Collected: 1/16/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-015

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 122 Webster ST NW

Customer Sample Number:

Date / Time Collected: 1/16/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-016

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-027

Sample Location: 1st Draw 1231 Otis ST NE

Customer Sample Number:

Date / Time Collected: 1/13/2024 6:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-027

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1231 Otis ST NE

Customer Sample Number:

Date / Time Collected: 1/13/2024 6:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-028

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-007

Sample Location: 1st Draw 1232 D ST SE
Customer Sample Number:
Date / Time Collected: 1/21/2024 9:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2401188-007
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1232 D ST SE
Customer Sample Number:
Date / Time Collected: 1/21/2024 9:08 AM

Customer Program Code: DS
Laboratory Sample Number: 2401188-008
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-053

Sample Location: 1st Draw 1322 Ritchie PI NE

Customer Sample Number:

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-053

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1322 Ritchie PI NE

Customer Sample Number:

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-054

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-021

Sample Location: 1st Draw 1355 Oak ST NW

Customer Sample Number:

Date / Time Collected: 1/18/2024 5:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2401188-021

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1355 Oak ST NW

Customer Sample Number:

Date / Time Collected: 1/18/2024 5:32 PM

Customer Program Code: DS

Laboratory Sample Number: 2401188-022

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-041

Sample Location: 1st Draw 1414 Montello Ave NE

Customer Sample Number:

Date / Time Collected: 1/9/2024 8:37 PM

Customer Program Code: DS

Laboratory Sample Number: 2401166-041

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1414 Montello Ave NE

Customer Sample Number:

Date / Time Collected: 1/9/2024 8:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2401166-042

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-013

Sample Location: 1st Draw 1423 35th ST NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 4:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2401166-013

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1423 35th ST NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 4:54 PM

Customer Program Code: DS

Laboratory Sample Number: 2401166-014

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-021

Sample Location: 1st Draw 1512 Park Rd NW #2

Customer Sample Number:

Date / Time Collected: 1/12/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-021

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1512 Park Rd NW #2

Customer Sample Number:

Date / Time Collected: 1/12/2024 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-022

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-011

Sample Location: 1st Draw 1800 S ST NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-011

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1800 S ST NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 7:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-012

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-009

Sample Location: 1st Draw 1811 Burke ST SE

Customer Sample Number:

Date / Time Collected: 1/15/2024 3:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-009

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1811 Burke ST SE

Customer Sample Number:

Date / Time Collected: 1/15/2024 3:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-010

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-007

Sample Location: 1st Draw 1831 N. Capitol St. NE

Customer Sample Number:

Date / Time Collected: 1/17/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-007

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1831 N. Capitol St. NE

Customer Sample Number:

Date / Time Collected: 1/17/2024 7:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-008

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-025

Sample Location: 1st Draw 1921 R ST SE
Customer Sample Number:
Date / Time Collected: 1/20/2024 11:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2401188-025
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1921 R ST SE
Customer Sample Number:
Date / Time Collected: 1/20/2024 11:10 AM

Customer Program Code: DS
Laboratory Sample Number: 2401188-026
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-027

Sample Location: 1st Draw 2017 4th ST NW

Customer Sample Number:

Date / Time Collected: 1/10/2024 12:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2401166-027

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 2017 4th ST NW

Customer Sample Number:

Date / Time Collected: 1/10/2024 12:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2401166-028

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-005

Sample Location: 1st Draw 2108 1st ST NW Apt 1

Customer Sample Number:

Date / Time Collected: 1/5/2024 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-005

Date / Time Received: 1/23/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	2/8/2024	SBrooks

Sample Location: 2nd Draw 2108 1st ST NW Apt 1

Customer Sample Number:

Date / Time Collected: 1/5/2024 7:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-006

Date / Time Received: 1/23/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-031

Sample Location: 1st Draw 2202 Cathedral Ave NW

Customer Sample Number:

Date / Time Collected: 1/7/2024 5:27 PM

Customer Program Code: DS

Laboratory Sample Number: 2401188-031

Date / Time Received: 1/26/2024 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks

Sample Location: 2nd Draw 2202 Cathedral Ave NW

Customer Sample Number:

Date / Time Collected: 1/7/2024 5:29 PM

Customer Program Code: DS

Laboratory Sample Number: 2401188-032

Date / Time Received: 1/26/2024 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-015

Sample Location: 1st Draw 2411 Randolph ST NE

Customer Sample Number:

Date / Time Collected: 1/9/2024 7:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-015

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 2411 Randolph ST NE

Customer Sample Number:

Date / Time Collected: 1/9/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-016

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-005

Sample Location: 1st Draw 2726 Olive ST NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 6:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-005

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 2726 Olive ST NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 6:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-006

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-025

Sample Location: 1st Draw 2838 Chesterfield PI NW

Customer Sample Number:

Date / Time Collected: 1/12/2024 6:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-025

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 2838 Chesterfield PI NW

Customer Sample Number:

Date / Time Collected: 1/12/2024 6:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-026

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-029

Sample Location: 1st Draw 3210 12th ST SE

Customer Sample Number:

Date / Time Collected: 1/7/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-029

Date / Time Received: 1/26/2024 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks

Sample Location: 2nd Draw 3210 12th ST SE

Customer Sample Number:

Date / Time Collected: 1/7/2024 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-030

Date / Time Received: 1/26/2024 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-023

Sample Location: 1st Draw 324 Gallatin ST NW

Customer Sample Number:

Date / Time Collected: 1/15/2024 12:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-023

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 324 Gallatin ST NW

Customer Sample Number:

Date / Time Collected: 1/15/2024 12:06 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-024

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-023

Sample Location: 1st Draw 335 Oneida St NE

Customer Sample Number:

Date / Time Collected: 1/9/2024 6:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-023

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 335 Oneida St NE

Customer Sample Number:

Date / Time Collected: 1/9/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-024

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-003

Sample Location: 1st Draw 3412 21st ST SE

Customer Sample Number:

Date / Time Collected: 1/5/2024 5:58 PM

Customer Program Code: DS

Laboratory Sample Number: 2401166-003

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3412 21st ST SE

Customer Sample Number:

Date / Time Collected: 1/5/2024 6:01 PM

Customer Program Code: DS

Laboratory Sample Number: 2401166-004

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-003

Sample Location: 1st Draw 3417 Lowell ST NW

Customer Sample Number:

Date / Time Collected: 1/22/2024 7:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-003

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3417 Lowell ST NW

Customer Sample Number:

Date / Time Collected: 1/22/2024 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-004

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-019

Sample Location: 1st Draw 3460 Dix ST NE

Customer Sample Number:

Date / Time Collected: 1/23/2024 5:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-019

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3460 Dix ST NE

Customer Sample Number:

Date / Time Collected: 1/23/2024 5:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-020

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-003

Sample Location: 1st Draw 3542 16th ST NW

Customer Sample Number:

Date / Time Collected: 1/5/2024 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-003

Date / Time Received: 1/23/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks

Sample Location: 2nd Draw 3542 16th ST NW

Customer Sample Number:

Date / Time Collected: 1/5/2024 7:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-004

Date / Time Received: 1/23/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-001

Sample Location: 1st Draw 3608 Park PI NW

Customer Sample Number:

Date / Time Collected: 1/16/2024 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-001

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3608 Park PI NW

Customer Sample Number:

Date / Time Collected: 1/16/2024 8:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-002

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-029

Sample Location: 1st Draw 3620 Norton PI NW

Customer Sample Number:

Date / Time Collected: 1/7/2024 10:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-029

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3620 Norton PI NW

Customer Sample Number:

Date / Time Collected: 1/7/2024 10:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-030

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-005

Sample Location: 1st Draw 3643 Tilden ST NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 6:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-005

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3643 Tilden ST NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 6:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-006

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-029

Sample Location: 1st Draw 3712 Manor PI NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 6:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-029

Date / Time Received: 1/23/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks

Sample Location: 2nd Draw 3712 Manor PI NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-030

Date / Time Received: 1/23/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-023

Sample Location: 1st Draw 3803 13th St NW

Customer Sample Number:

Date / Time Collected: 1/23/2024 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-023

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3803 13th St NW

Customer Sample Number:

Date / Time Collected: 1/23/2024 6:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-024

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-009

Sample Location: 1st Draw 3803 W St NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-009

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3803 W St NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-010

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-015

Sample Location: 1st Draw 414 Ava Way NE

Customer Sample Number:

Date / Time Collected: 1/14/2024 2:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-015

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-011

Sample Location: 1st Draw 4217 Van Ness St NW

Customer Sample Number:

Date / Time Collected: 1/9/2024 6:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-011

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 4217 Van Ness St NW

Customer Sample Number:

Date / Time Collected: 1/9/2024 6:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-012

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-033

Sample Location: 1st Draw 4321 37th ST NW

Customer Sample Number:

Date / Time Collected: 1/23/2024 5:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-033

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 4321 37th ST NW

Customer Sample Number:

Date / Time Collected: 1/23/2024 5:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-034

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-019

Sample Location: 1st Draw 4322 Argyle Terrace NW
Customer Sample Number:
Date / Time Collected: 1/9/2024 6:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-019
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 4322 Argyle Terrace NW
Customer Sample Number:
Date / Time Collected: 1/9/2024 6:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-020
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-017

Sample Location: 1st Draw 5066 MacArthur Blvd NW

Customer Sample Number:

Date / Time Collected: 1/17/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-017

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 5066 MacArthur Blvd NW

Customer Sample Number:

Date / Time Collected: 1/17/2024 7:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-018

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-013

Sample Location: 1st Draw 510 15th ST NE

Customer Sample Number:

Date / Time Collected: 1/18/2024 5:26 PM

Customer Program Code: DS

Laboratory Sample Number: 2401188-013

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 510 15th ST NE

Customer Sample Number:

Date / Time Collected: 1/18/2024 5:27 PM

Customer Program Code: DS

Laboratory Sample Number: 2401188-014

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-001

Sample Location: 1st Draw 515 9th St NE
Customer Sample Number:
Date / Time Collected: 1/6/2024 9:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-001
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 515 9th St NE
Customer Sample Number:
Date / Time Collected: 1/6/2024 9:02 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-002
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-019

Sample Location: 1st Draw 518 Quincy ST NW

Customer Sample Number:

Date / Time Collected: 1/12/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-019

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 518 Quincy ST NW

Customer Sample Number:

Date / Time Collected: 1/12/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-020

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-001

Sample Location: 1st Draw 5214 4th St NW

Customer Sample Number:

Date / Time Collected: 1/15/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-001

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 5214 4th St NW

Customer Sample Number:

Date / Time Collected: 1/15/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-002

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-021

Sample Location: 1st Draw 5239 Western Ave NW

Customer Sample Number:

Date / Time Collected: 1/5/2024 5:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-021

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 5239 Western Ave NW

Customer Sample Number:

Date / Time Collected: 1/5/2024 5:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-022

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-007

Sample Location: 1st Draw 54 S ST NW
Customer Sample Number:
Date / Time Collected: 1/9/2024 9:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-007
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 54 S ST NW
Customer Sample Number:
Date / Time Collected: 1/9/2024 9:37 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-008
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-033

Sample Location: 1st Draw 5514 13TH ST NW

Customer Sample Number:

Date / Time Collected: 1/17/2024 8:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-033

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 5514 13TH ST NW

Customer Sample Number:

Date / Time Collected: 1/17/2024 8:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-034

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-017

Sample Location: 1st Draw 612 Farragut PI NE

Customer Sample Number:

Date / Time Collected: 1/23/2024 7:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-017

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 612 Farragut PI NE

Customer Sample Number:

Date / Time Collected: 1/23/2024 7:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-018

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-057

Sample Location: 1st Draw 613 Rhode Island Ave NW

Customer Sample Number:

Date / Time Collected: 1/14/2024 7:59 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-057

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 613 Rhode Island Ave NW

Customer Sample Number:

Date / Time Collected: 1/14/2024 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-058

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401188-035

Sample Location: 1st Draw 620 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 1/20/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-035

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 620 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 1/20/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2401188-036

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-031

Sample Location: 1st Draw 647 Lexington PI NE

Customer Sample Number:

Date / Time Collected: 1/15/2024 6:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-031

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 647 Lexington PI NE

Customer Sample Number:

Date / Time Collected: 1/15/2024 6:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2401178-032

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401178-013

Sample Location: 1st Draw 709 17th ST SE

Customer Sample Number:

Date / Time Collected: 1/10/2024 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-013

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 709 17th ST SE

Customer Sample Number:

Date / Time Collected: 1/10/2024 6:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2401178-014

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-009

Sample Location: 1st Draw 71 Oglethorpe St NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 6:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-009

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 71 Oglethorpe St NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2401166-010

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2402011-001

Sample Location: 1st Draw 728 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 1/25/2024 7:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2402011-001

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 728 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 1/25/2024 7:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2402011-002

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS-2401166-031

Sample Location: 1st Draw 936 O ST NW
Customer Sample Number:
Date / Time Collected: 1/10/2024 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-031
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 936 O ST NW
Customer Sample Number:
Date / Time Collected: 1/10/2024 7:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2401166-032
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS250- 2401177-005

Sample Location: 1st Draw 102 - 1111 11th ST NW

Customer Sample Number:

Date / Time Collected: 1/6/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401177-005

Date / Time Received: 1/23/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	2/8/2024	SBrooks

Sample Location: 2nd Draw 102 - 1111 11th ST NW

Customer Sample Number:

Date / Time Collected: 1/6/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401177-006

Date / Time Received: 1/23/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS250- 2401177-001

Sample Location: 1st Draw 16 17th ST NE #113

Customer Sample Number:

Date / Time Collected: 1/16/2024 1:35 PM

Customer Program Code: DS250

Laboratory Sample Number: 2401177-001

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 16 17th ST NE #113

Customer Sample Number:

Date / Time Collected: 1/16/2024 1:35 PM

Customer Program Code: DS250

Laboratory Sample Number: 2401177-002

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS250- 2401165-001

Sample Location: 1st Draw 201 E ST SE Apt 4

Customer Sample Number:

Date / Time Collected: 1/9/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401165-001

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 201 E ST SE Apt 4

Customer Sample Number:

Date / Time Collected: 1/9/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401165-002

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-DS250- 2401177-003

Sample Location: 1st Draw 2122 Massachusetts Ave NW #734

Customer Sample Number:

Date / Time Collected: 1/15/2024 11:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401177-003

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 2122 Massachusetts Ave NW #734

Customer Sample Number:

Date / Time Collected: 1/15/2024 11:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2401177-004

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-017

Sample Location: 1st Draw 1006 Monroe St NW Unit 2

Customer Sample Number:

Date / Time Collected: 2/6/2024 9:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-017

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1006 Monroe St NW Unit 2

Customer Sample Number:

Date / Time Collected: 2/6/2024 9:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-018

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-043

Sample Location: 1st Draw 1010 Galloway ST NE

Customer Sample Number:

Date / Time Collected: 2/1/2024 9:52 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-043

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1010 Galloway ST NE

Customer Sample Number:

Date / Time Collected: 2/1/2024 9:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-044

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-023

Sample Location: 1st Draw 1011 MARYLAND AVE NE
Customer Sample Number:
Date / Time Collected: 2/12/2024 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2402127-023
Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1011 MARYLAND AVE NE
Customer Sample Number:
Date / Time Collected: 2/12/2024 6:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2402127-024
Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-041

Sample Location: 1st Draw 1117 Montello Ave NE

Customer Sample Number:

Date / Time Collected: 1/29/2024 5:42 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-041

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 1117 Montello Ave NE

Customer Sample Number:

Date / Time Collected: 1/29/2024 5:46 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-042

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-033

Sample Location: 1st Draw 1130 4th ST NE

Customer Sample Number:

Date / Time Collected: 2/3/2024 9:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-033

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1130 4th ST NE

Customer Sample Number:

Date / Time Collected: 2/3/2024 9:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-034

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402125-003

Sample Location: 1st Draw 114 Tennessee Ave.NE

Customer Sample Number:

Date / Time Collected: 2/2/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-003

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 114 Tennessee Ave.NE

Customer Sample Number:

Date / Time Collected: 2/2/2024 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-004

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-001

Sample Location: 1st Draw 1211 Duncan PI NE

Customer Sample Number:

Date / Time Collected: 2/13/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-001

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1211 Duncan PI NE

Customer Sample Number:

Date / Time Collected: 2/13/2024 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-002

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402056-007

Sample Location: 1st Draw 1212 5th St NE

Customer Sample Number:

Date / Time Collected: 1/27/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-007

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1212 5th St NE

Customer Sample Number:

Date / Time Collected: 1/27/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-008

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-035

Sample Location: 1st Draw 1248 Oates St NE

Customer Sample Number:

Date / Time Collected: 1/29/2024 7:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-035

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 1248 Oates St NE

Customer Sample Number:

Date / Time Collected: 1/29/2024 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-036

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-019

Sample Location: 1st Draw 14 T St NE #3

Customer Sample Number:

Date / Time Collected: 2/13/2024 4:01 PM

Customer Program Code: DS

Laboratory Sample Number: 2402127-019

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 14 T St NE #3

Customer Sample Number:

Date / Time Collected: 2/13/2024 4:03 PM

Customer Program Code: DS

Laboratory Sample Number: 2402127-020

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-021

Sample Location: 1st Draw 1404 Perry PI NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 9:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-021

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1404 Perry PI NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 9:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-022

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-025

Sample Location: 1st Draw 1410 D ST NE
Customer Sample Number:
Date / Time Collected: 2/5/2024 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2402118-025
Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1410 D ST NE
Customer Sample Number:
Date / Time Collected: 2/5/2024 6:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2402118-026
Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-007

Sample Location: 1st Draw 1520 19th ST SE

Customer Sample Number:

Date / Time Collected: 2/4/2024 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-007

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	105	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1520 19th ST SE

Customer Sample Number:

Date / Time Collected: 2/4/2024 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-008

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	12.6	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-013

Sample Location: 1st Draw 1532 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 2/4/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-013

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1532 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 2/4/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-014

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402056-023

Sample Location: 1st Draw 1716 Allison St NW

Customer Sample Number:

Date / Time Collected: 2/4/2024 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-023

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1716 Allison St NW

Customer Sample Number:

Date / Time Collected: 2/4/2024 6:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-024

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402125-005

Sample Location: 1st Draw 1834 Burke St SE

Customer Sample Number:

Date / Time Collected: 1/31/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-005

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 1834 Burke St SE

Customer Sample Number:

Date / Time Collected: 1/31/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-006

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402125-007

Sample Location: 1st Draw 1853 Ingleside Terrace NW

Customer Sample Number:

Date / Time Collected: 2/7/2024 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-007

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1853 Ingleside Terrace NW

Customer Sample Number:

Date / Time Collected: 2/7/2024 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-008

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402056-013

Sample Location: 1st Draw 1916 D St NE
Customer Sample Number:
Date / Time Collected: 1/30/2024 4:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2402056-013
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1916 D St NE
Customer Sample Number:
Date / Time Collected: 1/30/2024 4:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2402056-014
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-015

Sample Location: 1st Draw 2013 Perry ST NE

Customer Sample Number:

Date / Time Collected: 2/11/2024 5:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-015

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 2013 Perry ST NE

Customer Sample Number:

Date / Time Collected: 2/11/2024 5:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-016

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402056-009

Sample Location: 1st Draw 22 Hamilton St NE

Customer Sample Number:

Date / Time Collected: 1/29/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-009

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 22 Hamilton St NE

Customer Sample Number:

Date / Time Collected: 1/29/2024 6:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-010

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-005

Sample Location: 1st Draw 223 Peabody ST NW

Customer Sample Number:

Date / Time Collected: 2/5/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-005

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 223 Peabody ST NW

Customer Sample Number:

Date / Time Collected: 2/5/2024 6:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-006

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402125-001

Sample Location: 1st Draw 233 17th St SE

Customer Sample Number:

Date / Time Collected: 1/27/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-001

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 233 17th St SE

Customer Sample Number:

Date / Time Collected: 1/27/2024 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-002

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-027

Sample Location: 1st Draw 2431 39th PI NW

Customer Sample Number:

Date / Time Collected: 2/5/2024 5:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-027

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 2431 39th PI NW

Customer Sample Number:

Date / Time Collected: 2/5/2024 5:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-028

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-021

Sample Location: 1st Draw 2707 Fort Baker Dr SE #1

Customer Sample Number:

Date / Time Collected: 2/7/2024 3:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-021

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 2707 Fort Baker Dr SE #1

Customer Sample Number:

Date / Time Collected: 2/7/2024 3:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-022

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-031

Sample Location: 1st Draw 3005 Cleveland Ave NW

Customer Sample Number:

Date / Time Collected: 2/2/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-031

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 3005 Cleveland Ave NW

Customer Sample Number:

Date / Time Collected: 2/2/2024 6:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-032

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402125-011

Sample Location: 1st Draw 306 2nd St SE, Apt 1

Customer Sample Number:

Date / Time Collected: 2/4/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-011

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 306 2nd St SE, Apt 1

Customer Sample Number:

Date / Time Collected: 2/4/2024 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-012

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-019

Sample Location: 1st Draw 3100 Q ST NW

Customer Sample Number:

Date / Time Collected: 2/8/2024 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-019

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 3100 Q ST NW

Customer Sample Number:

Date / Time Collected: 2/8/2024 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-020

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-017

Sample Location: 1st Draw 3110 Chestnut ST NW

Customer Sample Number:

Date / Time Collected: 2/9/2024 5:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2402127-017

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 3110 Chestnut ST NW

Customer Sample Number:

Date / Time Collected: 2/9/2024 5:18 PM

Customer Program Code: DS

Laboratory Sample Number: 2402127-018

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402056-021

Sample Location: 1st Draw 315 18th St NE

Customer Sample Number:

Date / Time Collected: 1/27/2024 8:13 PM

Customer Program Code: DS

Laboratory Sample Number: 2402056-021

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 315 18th St NE

Customer Sample Number:

Date / Time Collected: 1/27/2024 8:17 PM

Customer Program Code: DS

Laboratory Sample Number: 2402056-022

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-009

Sample Location: 1st Draw 3343 18th ST NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-009

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 3343 18th ST NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-010

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-023

Sample Location: 1st Draw 3507 Alton PI NW

Customer Sample Number:

Date / Time Collected: 2/5/2024 5:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-023

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 3507 Alton PI NW

Customer Sample Number:

Date / Time Collected: 2/5/2024 5:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-024

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402056-017

Sample Location: 1st Draw 3552 Alton PI NW

Customer Sample Number:

Date / Time Collected: 1/14/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-017

Date / Time Received: 2/8/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 3552 Alton PI NW

Customer Sample Number:

Date / Time Collected: 1/14/2024 8:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-018

Date / Time Received: 2/8/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-003

Sample Location: 1st Draw 3727 Van Ness ST NW

Customer Sample Number:

Date / Time Collected: 2/7/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-003

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 3727 Van Ness ST NW

Customer Sample Number:

Date / Time Collected: 2/7/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-004

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402056-019

Sample Location: 1st Draw 4129 New Hampshire Ave NW

Customer Sample Number:

Date / Time Collected: 1/29/2024 9:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-019

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 4129 New Hampshire Ave NW

Customer Sample Number:

Date / Time Collected: 1/29/2024 9:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-020

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402056-015

Sample Location: 1st Draw 4625 Greene PI NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-015

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 4625 Greene PI NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 6:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2402056-016

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-003

Sample Location: 1st Draw 4902 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 2/4/2024 9:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-003

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 4902 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 2/4/2024 9:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-004

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-005

Sample Location: 1st Draw 4916 Brandywine St NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-005

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 4916 Brandywine St NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 6:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-006

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-001

Sample Location: 1st Draw 5308 1st ST NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 8:17 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-001

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 5308 1st ST NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 8:21 PM

Customer Program Code: DS

Laboratory Sample Number: 2402118-002

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-015

Sample Location: 1st Draw 5340 Drake PI SE

Customer Sample Number:

Date / Time Collected: 2/7/2024 8:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-015

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 5340 Drake PI SE

Customer Sample Number:

Date / Time Collected: 2/7/2024 8:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-016

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-013

Sample Location: 1st Draw 56 Girard St NE

Customer Sample Number:

Date / Time Collected: 2/5/2024 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-013

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 56 Girard St NE

Customer Sample Number:

Date / Time Collected: 2/5/2024 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-014

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-011

Sample Location: 1st Draw 5818 Sherier PI NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 1:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2402127-011

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 5818 Sherier PI NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 1:14 PM

Customer Program Code: DS

Laboratory Sample Number: 2402127-012

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-037

Sample Location: 1st Draw 5921 31st PI NW

Customer Sample Number:

Date / Time Collected: 1/29/2024 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-037

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 5921 31st PI NW

Customer Sample Number:

Date / Time Collected: 1/29/2024 8:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-038

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-029

Sample Location: 1st Draw 6110 Broad Branch Rd

Customer Sample Number:

Date / Time Collected: 2/7/2024 5:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-029

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 6110 Broad Branch Rd

Customer Sample Number:

Date / Time Collected: 2/7/2024 5:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2402118-030

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-039

Sample Location: 1st Draw 626 F St. NE
Customer Sample Number:
Date / Time Collected: 2/5/2024 8:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2402118-039
Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 626 F St. NE
Customer Sample Number:
Date / Time Collected: 2/5/2024 8:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2402118-040
Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402125-009

Sample Location: 1st Draw 635 Orleans PI NE

Customer Sample Number:

Date / Time Collected: 2/4/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-009

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 635 Orleans PI NE

Customer Sample Number:

Date / Time Collected: 2/4/2024 9:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2402125-010

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402056-011

Sample Location: 1st Draw 642 F St NE
Customer Sample Number:
Date / Time Collected: 1/30/2024 6:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2402056-011
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 642 F St NE
Customer Sample Number:
Date / Time Collected: 1/30/2024 6:52 AM

Customer Program Code: DS
Laboratory Sample Number: 2402056-012
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-009

Sample Location: 1st Draw 6824 32ND ST NW

Customer Sample Number:

Date / Time Collected: 2/12/2024 5:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-009

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 6824 32ND ST NW

Customer Sample Number:

Date / Time Collected: 2/12/2024 5:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-010

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402127-007

Sample Location: 1st Draw 707 10th ST SE

Customer Sample Number:

Date / Time Collected: 2/7/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-007

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 707 10th ST SE

Customer Sample Number:

Date / Time Collected: 2/7/2024 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2402127-008

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS-2402118-011

Sample Location: 1st Draw 800 K ST NE
Customer Sample Number:
Date / Time Collected: 1/31/2024 5:05 PM

Customer Program Code: DS
Laboratory Sample Number: 2402118-011
Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 800 K ST NE
Customer Sample Number:
Date / Time Collected: 1/31/2024 5:08 PM

Customer Program Code: DS
Laboratory Sample Number: 2402118-012
Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS250- 2402124-009

Sample Location: 1st Draw 1109 Rhode Island Ave NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 3:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-009

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 1109 Rhode Island Ave NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 3:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-010

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS250- 2402124-003

Sample Location: 1st Draw 1250 Half St SE Apt 823

Customer Sample Number:

Date / Time Collected: 1/28/2024 6:29 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-003

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 1250 Half St SE Apt 823

Customer Sample Number:

Date / Time Collected: 1/28/2024 6:29 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-004

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS250- 2402124-007

Sample Location: 1st Draw 1324 E St SE, Unit 206

Customer Sample Number:

Date / Time Collected: 2/6/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-007

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1324 E St SE, Unit 206

Customer Sample Number:

Date / Time Collected: 2/6/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-008

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS250- 2402117-001

Sample Location: 1st Draw 1614 17th St NW, Apt 606

Customer Sample Number:

Date / Time Collected: 2/8/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402117-001

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 1614 17th St NW, Apt 606

Customer Sample Number:

Date / Time Collected: 2/8/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402117-002

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS250- 2402124-011

Sample Location: 1st Draw 1823 Newton ST NW #105

Customer Sample Number:

Date / Time Collected: 1/28/2024 12:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-011

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 1823 Newton ST NW #105

Customer Sample Number:

Date / Time Collected: 1/28/2024 12:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-012

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS250- 2402124-001

Sample Location: 1st Draw 400 8th St NW Apt 1303

Customer Sample Number:

Date / Time Collected: 2/5/2024 6:44 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-001

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 400 8th St NW Apt 1303

Customer Sample Number:

Date / Time Collected: 2/5/2024 6:44 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-002

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-DS250- 2402124-005

Sample Location: 1st Draw 7044 Eastern Ave NW #10

Customer Sample Number:

Date / Time Collected: 2/2/2024 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-005

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 7044 Eastern Ave NW #10

Customer Sample Number:

Date / Time Collected: 2/2/2024 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402124-006

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-001

Sample Location: 1st Draw 1006 Lamont St NW

Customer Sample Number:

Date / Time Collected: 2/21/2024 8:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-001

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 1006 Lamont St NW

Customer Sample Number:

Date / Time Collected: 2/21/2024 8:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-002

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-013

Sample Location: 1st Draw 15 Oglethorpe St NW

Customer Sample Number:

Date / Time Collected: 2/27/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-013

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 15 Oglethorpe St NW

Customer Sample Number:

Date / Time Collected: 2/27/2024 6:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-014

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-005

Sample Location: 1st Draw 208 D ST SE
Customer Sample Number:
Date / Time Collected: 2/14/2024 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2402183-005
Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 208 D ST SE
Customer Sample Number:
Date / Time Collected: 2/14/2024 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2402183-006
Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-011

Sample Location: 1st Draw 215 T St NW
Customer Sample Number:
Date / Time Collected: 2/24/2024 7:03 AM

Customer Program Code: DS
Laboratory Sample Number: 2403063-011
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 215 T St NW
Customer Sample Number:
Date / Time Collected: 2/24/2024 7:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2403063-012
Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-005

Sample Location: 1st Draw 2410 17th PI SE

Customer Sample Number:

Date / Time Collected: 2/28/2024 7:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-005

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 2410 17th PI SE

Customer Sample Number:

Date / Time Collected: 2/28/2024 7:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-006

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-019

Sample Location: 1st Draw 25 Nicholson ST NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-019

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 25 Nicholson ST NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-020

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-007

Sample Location: 1st Draw 2909 Sherman Ave NW

Customer Sample Number:

Date / Time Collected: 2/27/2024 8:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-007

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 2909 Sherman Ave NW

Customer Sample Number:

Date / Time Collected: 2/27/2024 8:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-008

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-007

Sample Location: 1st Draw 2916 Stephenson PI NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 8:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-007

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 2916 Stephenson PI NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 8:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-008

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-019

Sample Location: 1st Draw 3036 RODMAN ST NW

Customer Sample Number:

Date / Time Collected: 2/29/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-019

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 3036 RODMAN ST NW

Customer Sample Number:

Date / Time Collected: 2/29/2024 6:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-020

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-003

Sample Location: 1st Draw 312 6th ST NE

Customer Sample Number:

Date / Time Collected: 2/25/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-003

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 312 6th ST NE

Customer Sample Number:

Date / Time Collected: 2/25/2024 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-004

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-015

Sample Location: 1st Draw 3310 35th ST NW

Customer Sample Number:

Date / Time Collected: 2/21/2024 6:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-015

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 3310 35th ST NW

Customer Sample Number:

Date / Time Collected: 2/21/2024 6:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-016

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-013

Sample Location: 1st Draw 3312 Porter St NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-013

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 3312 Porter St NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-014

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-017

Sample Location: 1st Draw 3922 13th St NE

Customer Sample Number:

Date / Time Collected: 2/19/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-017

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 3922 13th St NE

Customer Sample Number:

Date / Time Collected: 2/19/2024 6:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-018

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403006-001

Sample Location: 1st Draw 3941 Davis PI NW #4

Customer Sample Number:

Date / Time Collected: 2/16/2024 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2403006-001

Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 3941 Davis PI NW #4

Customer Sample Number:

Date / Time Collected: 2/16/2024 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2403006-002

Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-003

Sample Location: 1st Draw 4110 3rd ST NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-003

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 4110 3rd ST NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 7:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-004

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-009

Sample Location: 1st Draw 4331 Blagden Ave NW

Customer Sample Number:

Date / Time Collected: 2/29/2024 7:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-009

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 4331 Blagden Ave NW

Customer Sample Number:

Date / Time Collected: 2/29/2024 7:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-010

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-017

Sample Location: 1st Draw 5123 Tilden St NW

Customer Sample Number:

Date / Time Collected: 2/27/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-017

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 5123 Tilden St NW

Customer Sample Number:

Date / Time Collected: 2/27/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-018

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-011

Sample Location: 1st Draw 5140 Tilden ST NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 5:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2402183-011

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 5140 Tilden ST NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 5:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2402183-012

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-001

Sample Location: 1st Draw 6020 28th St NW

Customer Sample Number:

Date / Time Collected: 2/27/2024 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-001

Date / Time Received: 3/8/2024 3:41:22 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 6020 28th St NW

Customer Sample Number:

Date / Time Collected: 2/27/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-002

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-015

Sample Location: 1st Draw 607 Longfellow St. NW

Customer Sample Number:

Date / Time Collected: 2/29/2024 6:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-015

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 607 Longfellow St. NW

Customer Sample Number:

Date / Time Collected: 2/29/2024 6:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-016

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2403063-021

Sample Location: 1st Draw 6211 31st St NW

Customer Sample Number:

Date / Time Collected: 2/26/2024 5:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-021

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 6211 31st St NW

Customer Sample Number:

Date / Time Collected: 2/26/2024 5:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2403063-022

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS-2402183-009

Sample Location: 1st Draw 737 Hobart PI NW

Customer Sample Number:

Date / Time Collected: 2/16/2024 7:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-009

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 737 Hobart PI NW

Customer Sample Number:

Date / Time Collected: 2/16/2024 7:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2402183-010

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2402182-005

Sample Location: 1st Draw 1331 Q ST Apt 3

Customer Sample Number:

Date / Time Collected: 2/8/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-005

Date / Time Received: 2/26/2024 9:05:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/20/2024	Rlamsal

Sample Location: 2nd Draw 1331 Q ST Apt 3

Customer Sample Number:

Date / Time Collected: 2/8/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-006

Date / Time Received: 2/26/2024 9:05:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2403062-001

Sample Location: 1st Draw 1465 Columbia Rd NW Apt 401

Customer Sample Number:

Date / Time Collected: 2/22/2024 5:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2403062-001

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 1465 Columbia Rd NW Apt 401

Customer Sample Number:

Date / Time Collected: 2/22/2024 5:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2403062-002

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2402182-009

Sample Location: 1st Draw 149 W ST NW #21

Customer Sample Number:

Date / Time Collected: 2/17/2024 12:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-009

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 149 W ST NW #21

Customer Sample Number:

Date / Time Collected: 2/17/2024 12:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-010

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2402182-001

Sample Location: 1st Draw 1701 16th ST NW #615

Customer Sample Number:

Date / Time Collected: 2/13/2024 4:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-001

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 1701 16th ST NW #615

Customer Sample Number:

Date / Time Collected: 2/13/2024 4:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-002

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2402182-013

Sample Location: 1st Draw 1824 Phelps PI NW #1808

Customer Sample Number:

Date / Time Collected: 2/13/2024 11:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-013

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 1824 Phelps PI NW #1808

Customer Sample Number:

Date / Time Collected: 2/13/2024 11:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-014

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2403062-003

Sample Location: 1st Draw 1921 Kalorama Rd NW #301

Customer Sample Number:

Date / Time Collected: 2/26/2024 6:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403062-003

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 1921 Kalorama Rd NW #301

Customer Sample Number:

Date / Time Collected: 2/26/2024 6:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403062-004

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2402182-007

Sample Location: 1st Draw 2710 Macomb St NW Apt 109

Customer Sample Number:

Date / Time Collected: 2/10/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-007

Date / Time Received: 2/26/2024 9:05:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	3/20/2024	Rlamsal

Sample Location: 2nd Draw 2710 Macomb St NW Apt 109

Customer Sample Number:

Date / Time Collected: 2/10/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-008

Date / Time Received: 2/26/2024 9:05:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2402182-003

Sample Location: 1st Draw 2900 14th St. NW Apt 603

Customer Sample Number:

Date / Time Collected: 2/13/2024 10:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-003

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 2900 14th St. NW Apt 603

Customer Sample Number:

Date / Time Collected: 2/13/2024 10:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-004

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2402182-011

Sample Location: 1st Draw 5319 1st ST NW

Customer Sample Number:

Date / Time Collected: 2/17/2024 1:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-011

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 5319 1st ST NW

Customer Sample Number:

Date / Time Collected: 2/17/2024 1:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2402182-012

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-DS250- 2403062-005

Sample Location: 1st Draw 5333 Connecticut Ave NW Apt 320

Customer Sample Number:

Date / Time Collected: 2/22/2024 7:41 PM

Customer Program Code: DS250

Laboratory Sample Number: 2403062-005

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 5333 Connecticut Ave NW Apt 320

Customer Sample Number:

Date / Time Collected: 2/22/2024 7:41 PM

Customer Program Code: DS250

Laboratory Sample Number: 2403062-006

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-021

Sample Location: 1st Draw 125 Duddington PI SE

Customer Sample Number:

Date / Time Collected: 3/17/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-021

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 125 Duddington PI SE

Customer Sample Number:

Date / Time Collected: 3/17/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-022

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-045

Sample Location: 1st Draw 1309 Quincy St NW

Customer Sample Number:

Date / Time Collected: 3/9/2024 9:24 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-045

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 1309 Quincy St NW

Customer Sample Number:

Date / Time Collected: 3/9/2024 9:27 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-046

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-053

Sample Location: 1st Draw 1313 Corbin PI NE

Customer Sample Number:

Date / Time Collected: 3/5/2024 12:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-053

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 1313 Corbin PI NE

Customer Sample Number:

Date / Time Collected: 3/5/2024 12:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-054

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-025

Sample Location: 1st Draw 1408 35th St NW

Customer Sample Number:

Date / Time Collected: 3/4/2024 1:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-025

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 1408 35th St NW

Customer Sample Number:

Date / Time Collected: 3/4/2024 1:01 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-026

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-003

Sample Location: 1st Draw 1520 19th ST SE

Customer Sample Number:

Date / Time Collected: 3/17/2024 9:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2403189-003

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 1520 19th ST SE

Customer Sample Number:

Date / Time Collected: 3/17/2024 9:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2403189-004

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-027

Sample Location: 1st Draw 1526 Potomac Ave SE

Customer Sample Number:

Date / Time Collected: 3/14/2024 7:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-027

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 1526 Potomac Ave SE

Customer Sample Number:

Date / Time Collected: 3/14/2024 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-028

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-035

Sample Location: 1st Draw 1550 44th St NW

Customer Sample Number:

Date / Time Collected: 3/3/2024 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-035

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	3/29/2024	BPrakash

Sample Location: 2nd Draw 1550 44th St NW

Customer Sample Number:

Date / Time Collected: 3/3/2024 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-036

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403167-003

Sample Location: 1st Draw 1687 34th St NW

Customer Sample Number:

Date / Time Collected: 3/1/2024 8:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2403167-003

Date / Time Received: 3/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Sample Location: 2nd Draw 1687 34th St NW

Customer Sample Number:

Date / Time Collected: 3/1/2024 8:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2403167-004

Date / Time Received: 3/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-027

Sample Location: 1st Draw 1706 Massachusetts Ave SE

Customer Sample Number:

Date / Time Collected: 3/9/2024 7:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-027

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 1706 Massachusetts Ave SE

Customer Sample Number:

Date / Time Collected: 3/9/2024 7:39 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-028

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-041

Sample Location: 1st Draw 1724 D St SE

Customer Sample Number:

Date / Time Collected: 3/1/2024 5:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-041

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Sample Location: 2nd Draw 1724 D St SE

Customer Sample Number:

Date / Time Collected: 3/1/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-042

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-011

Sample Location: 1st Draw 1758 E St NE

Customer Sample Number:

Date / Time Collected: 3/15/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-011

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 1758 E St NE

Customer Sample Number:

Date / Time Collected: 3/15/2024 5:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-012

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-023

Sample Location: 1st Draw 1814 Ontario PI NW

Customer Sample Number:

Date / Time Collected: 3/11/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-023

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 1814 Ontario PI NW

Customer Sample Number:

Date / Time Collected: 3/11/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-024

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403167-001

Sample Location: 1st Draw 1819 Upshur St NE

Customer Sample Number:

Date / Time Collected: 3/5/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2403167-001

Date / Time Received: 3/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Sample Location: 2nd Draw 1819 Upshur St NE

Customer Sample Number:

Date / Time Collected: 3/5/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2403167-002

Date / Time Received: 3/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-019

Sample Location: 1st Draw 210 14th PI NE

Customer Sample Number:

Date / Time Collected: 3/14/2024 6:04 PM

Customer Program Code: DS

Laboratory Sample Number: 2403189-019

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 210 14th PI NE

Customer Sample Number:

Date / Time Collected: 3/14/2024 6:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2403189-020

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-029

Sample Location: 1st Draw 2252 12th PI NW

Customer Sample Number:

Date / Time Collected: 3/13/2024 6:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-029

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 2252 12th PI NW

Customer Sample Number:

Date / Time Collected: 3/13/2024 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-030

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-033

Sample Location: 1st Draw 2301 California St NW

Customer Sample Number:

Date / Time Collected: 3/3/2024 4:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-033

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Sample Location: 2nd Draw 2301 California St NW

Customer Sample Number:

Date / Time Collected: 3/3/2024 4:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-034

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-005

Sample Location: 1st Draw 2327 3rd St NE

Customer Sample Number:

Date / Time Collected: 3/18/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-005

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 2327 3rd St NE

Customer Sample Number:

Date / Time Collected: 3/18/2024 8:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-006

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-043

Sample Location: 1st Draw 2804 Channing St NE

Customer Sample Number:

Date / Time Collected: 3/6/2024 6:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-043

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 2804 Channing St NE

Customer Sample Number:

Date / Time Collected: 3/6/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-044

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-049

Sample Location: 1st Draw 2915 N. Capitol St NE

Customer Sample Number:

Date / Time Collected: 3/7/2024 3:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-049

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 2915 N. Capitol St NE

Customer Sample Number:

Date / Time Collected: 3/7/2024 3:08 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-050

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-057

Sample Location: 1st Draw 302 C St NE
Customer Sample Number:
Date / Time Collected: 3/6/2024 7:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2403154-057
Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 302 C St NE
Customer Sample Number:
Date / Time Collected: 3/6/2024 7:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2403154-058
Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-033

Sample Location: 1st Draw 3154 Patterson St NW

Customer Sample Number:

Date / Time Collected: 3/16/2024 7:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-033

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 3154 Patterson St NW

Customer Sample Number:

Date / Time Collected: 3/16/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-034

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-047

Sample Location: 1st Draw 3320 19th St NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-047

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 3320 19th St NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 6:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-048

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-055

Sample Location: 1st Draw 338 18th St NE

Customer Sample Number:

Date / Time Collected: 3/4/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-055

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 338 18th St NE

Customer Sample Number:

Date / Time Collected: 3/4/2024 5:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-056

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-037

Sample Location: 1st Draw 409 D St. NE

Customer Sample Number:

Date / Time Collected: 3/3/2024 7:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-037

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	3/29/2024	BPrakash

Sample Location: 2nd Draw 409 D St. NE

Customer Sample Number:

Date / Time Collected: 3/3/2024 7:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-038

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-039

Sample Location: 1st Draw 4404 46th St NW

Customer Sample Number:

Date / Time Collected: 3/11/2024 2:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-039

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 4404 46th St NW

Customer Sample Number:

Date / Time Collected: 3/11/2024 2:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-040

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-007

Sample Location: 1st Draw 4408 Volta PI NW

Customer Sample Number:

Date / Time Collected: 3/14/2024 6:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-007

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 4408 Volta PI NW

Customer Sample Number:

Date / Time Collected: 3/14/2024 7:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-008

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-019

Sample Location: 1st Draw 4417 Colorado Ave NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 9:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-019

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2	42.6	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 4417 Colorado Ave NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 9:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-020

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2	5.4	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-031

Sample Location: 1st Draw 4718 10th St. NE

Customer Sample Number:

Date / Time Collected: 3/9/2024 8:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-031

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 4718 10th St. NE

Customer Sample Number:

Date / Time Collected: 3/9/2024 8:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-032

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-051

Sample Location: 1st Draw 5015 Van Ness St NW

Customer Sample Number:

Date / Time Collected: 3/5/2024 6:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-051

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 5015 Van Ness St NW

Customer Sample Number:

Date / Time Collected: 3/5/2024 6:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-052

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-029

Sample Location: 1st Draw 5210 13th St NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 3:31 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-029

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 5210 13th St NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 3:31 PM

Customer Program Code: DS

Laboratory Sample Number: 2403154-030

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-001

Sample Location: 1st Draw 524 21st St NE

Customer Sample Number:

Date / Time Collected: 3/18/2024 10:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-001

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 524 21st St NE

Customer Sample Number:

Date / Time Collected: 3/18/2024 10:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-002

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-059

Sample Location: 1st Draw 5341 Sherier PI NW

Customer Sample Number:

Date / Time Collected: 3/5/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-059

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 5341 Sherier PI NW

Customer Sample Number:

Date / Time Collected: 3/5/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-060

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-017

Sample Location: 1st Draw 549 4TH ST SE

Customer Sample Number:

Date / Time Collected: 3/5/2024 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-017

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 549 4TH ST SE

Customer Sample Number:

Date / Time Collected: 3/5/2024 8:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-018

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-031

Sample Location: 1st Draw 558 Brummel CT NW

Customer Sample Number:

Date / Time Collected: 3/9/2024 2:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2403189-031

Date / Time Received: 3/25/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	4/2/2024	BPrakash

Sample Location: 2nd Draw 558 Brummel CT NW

Customer Sample Number:

Date / Time Collected: 3/9/2024 2:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2403189-032

Date / Time Received: 3/25/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-015

Sample Location: 1st Draw 614 4th St NE
Customer Sample Number:
Date / Time Collected: 3/16/2024 7:01 AM

Customer Program Code: DS
Laboratory Sample Number: 2403189-015
Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 614 4th St NE
Customer Sample Number:
Date / Time Collected: 3/16/2024 7:03 AM

Customer Program Code: DS
Laboratory Sample Number: 2403189-016
Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-017

Sample Location: 1st Draw 617 Lexington PI NE

Customer Sample Number:

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-017

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 617 Lexington PI NE

Customer Sample Number:

Date / Time Collected: 3/13/2024 8:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-018

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-021

Sample Location: 1st Draw 623 Keefer PI NW

Customer Sample Number:

Date / Time Collected: 3/9/2024 5:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-021

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 623 Keefer PI NW

Customer Sample Number:

Date / Time Collected: 3/9/2024 5:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-022

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-009

Sample Location: 1st Draw 664 Independence Ave SE

Customer Sample Number:

Date / Time Collected: 3/17/2024 9:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-009

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 664 Independence Ave SE

Customer Sample Number:

Date / Time Collected: 3/17/2024 9:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-010

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-013

Sample Location: 1st Draw 7547 9th St NW

Customer Sample Number:

Date / Time Collected: 3/17/2024 5:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2403189-013

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 7547 9th St NW

Customer Sample Number:

Date / Time Collected: 3/17/2024 5:14 PM

Customer Program Code: DS

Laboratory Sample Number: 2403189-014

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403154-015

Sample Location: 1st Draw 7624 9th St NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 6:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-015

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 7624 9th St NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2403154-016

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS-2403189-025

Sample Location: 1st Draw 824 Burns St SE

Customer Sample Number:

Date / Time Collected: 3/11/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-025

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 824 Burns St SE

Customer Sample Number:

Date / Time Collected: 3/11/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403189-026

Date / Time Received: 3/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS250- 2403153-005

Sample Location: 1st Draw 1220 12th St. NW Apt 1002

Customer Sample Number:

Date / Time Collected: 3/4/2024 6:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-005

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 1220 12th St. NW Apt 1002

Customer Sample Number:

Date / Time Collected: 3/4/2024 6:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-006

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS250- 2403153-001

Sample Location: 1st Draw 1700 15th St NW Apt 101

Customer Sample Number:

Date / Time Collected: 3/7/2024 4:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-001

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 1700 15th St NW Apt 101

Customer Sample Number:

Date / Time Collected: 3/7/2024 4:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-002

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS250- 2403153-009

Sample Location: 1st Draw 2630 Adams Mill Rd NW Unit #109

Customer Sample Number:

Date / Time Collected: 3/4/2024 7:35 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-009

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 2630 Adams Mill Rd NW Unit #109

Customer Sample Number:

Date / Time Collected: 3/4/2024 7:35 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-010

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS250- 2403153-003

Sample Location: 1st Draw 3700 9th St SE #331

Customer Sample Number:

Date / Time Collected: 3/8/2024 6:16 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-003

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 3700 9th St SE #331

Customer Sample Number:

Date / Time Collected: 3/8/2024 6:16 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-004

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-DS250- 2403153-007

Sample Location: 1st Draw 3700 9th St SE Apt 501

Customer Sample Number:

Date / Time Collected: 3/7/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-007

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Sample Location: 2nd Draw 3700 9th St SE Apt 501

Customer Sample Number:

Date / Time Collected: 3/7/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2403153-008

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-DS-2403195-001

Sample Location: 1st Draw 1206 Half St SW

Customer Sample Number:

Date / Time Collected: 3/23/2024 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-001

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Sample Location: 2nd Draw 1206 Half St SW

Customer Sample Number:

Date / Time Collected: 3/23/2024 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-002

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-DS-2403195-015

Sample Location: 1st Draw 1337 I St NE

Customer Sample Number:

Date / Time Collected: 3/9/2024 10:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-015

Date / Time Received: 3/27/2024 9:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	14.7	ug/L	H	4/5/2024	Bprakash

Sample Location: 2nd Draw 1337 I St NE

Customer Sample Number:

Date / Time Collected: 3/9/2024 10:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-016

Date / Time Received: 3/27/2024 9:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-DS-2403195-013

Sample Location: 1st Draw 1831 North Capitol St NE

Customer Sample Number:

Date / Time Collected: 3/25/2024 7:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-013

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/5/2024	Bprakash
Tin	EPA 200.8		0.2	0.2	ug/L		4/5/2024	Bprakash

Sample Location: 2nd Draw 1831 North Capitol St NE

Customer Sample Number:

Date / Time Collected: 3/25/2024 7:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-014

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/5/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-DS-2403195-011

Sample Location: 1st Draw 4025 Argyle Terrace NW

Customer Sample Number:

Date / Time Collected: 3/10/2024 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-011

Date / Time Received: 3/27/2024 9:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/5/2024	Bprakash

Sample Location: 2nd Draw 4025 Argyle Terrace NW

Customer Sample Number:

Date / Time Collected: 3/10/2024 8:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-012

Date / Time Received: 3/27/2024 9:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-DS-2403195-005

Sample Location: 1st Draw 4931 Fitch PI NE

Customer Sample Number:

Date / Time Collected: 3/13/2024 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2403195-005

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Sample Location: 2nd Draw 4931 Fitch PI NE

Customer Sample Number:

Date / Time Collected: 3/13/2024 6:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2403195-006

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-DS-2403195-003

Sample Location: 1st Draw 5019 42nd St NW

Customer Sample Number:

Date / Time Collected: 3/22/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-003

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Sample Location: 2nd Draw 5019 42nd St NW

Customer Sample Number:

Date / Time Collected: 3/22/2024 7:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-004

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-DS-2403195-007

Sample Location: 1st Draw 503 Seward Sq SE

Customer Sample Number:

Date / Time Collected: 3/14/2024 5:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-007

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Sample Location: 2nd Draw 503 Seward Sq SE

Customer Sample Number:

Date / Time Collected: 3/14/2024 5:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-008

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-DS-2403195-009

Sample Location: 1st Draw 5300 Dorsett PI

Customer Sample Number:

Date / Time Collected: 3/17/2024 8:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-009

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Sample Location: 2nd Draw 5300 Dorsett PI

Customer Sample Number:

Date / Time Collected: 3/17/2024 8:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-010

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-DS-2403195-017

Sample Location: 1st Draw 827 Florida Ave NE

Customer Sample Number:

Date / Time Collected: 3/25/2024 7:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-017

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.0	ug/L		4/5/2024	Bprakash

Sample Location: 2nd Draw 827 Florida Ave NE

Customer Sample Number:

Date / Time Collected: 3/25/2024 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2403195-018

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	30.0	ug/L		4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-031

Sample Location: 1st Draw 1020 Lamont ST NW

Customer Sample Number:

Date / Time Collected: 3/28/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-031

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1020 Lamont ST NW

Customer Sample Number:

Date / Time Collected: 3/28/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-032

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-047

Sample Location: 1st Draw 1530 D ST NE
Customer Sample Number:
Date / Time Collected: 4/1/2024 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2404095-047
Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1530 D ST NE
Customer Sample Number:
Date / Time Collected: 4/1/2024 7:03 AM

Customer Program Code: DS
Laboratory Sample Number: 2404095-048
Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-043

Sample Location: 1st Draw 1621 21st PI SE Apt 4

Customer Sample Number:

Date / Time Collected: 3/15/2024 4:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-043

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 1621 21st PI SE Apt 4

Customer Sample Number:

Date / Time Collected: 3/15/2024 4:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-044

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-049

Sample Location: 1st Draw 1717 37th ST NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 4:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-049

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1717 37th ST NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-050

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-051

Sample Location: 1st Draw 2809 5th St NE

Customer Sample Number:

Date / Time Collected: 3/20/2024 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-051

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 2809 5th St NE

Customer Sample Number:

Date / Time Collected: 3/20/2024 5:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-052

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-053

Sample Location: 1st Draw 2905 13th ST NW Apt 4

Customer Sample Number:

Date / Time Collected: 3/21/2024 7:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-053

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 2905 13th ST NW Apt 4

Customer Sample Number:

Date / Time Collected: 3/21/2024 7:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-054

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	56.6	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-029

Sample Location: 1st Draw 3028 RODMAN ST NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-029

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 3028 RODMAN ST NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 7:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-030

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-039

Sample Location: 1st Draw 3143 Oliver ST NW

Customer Sample Number:

Date / Time Collected: 3/20/2024 7:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-039

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 3143 Oliver ST NW

Customer Sample Number:

Date / Time Collected: 3/20/2024 7:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-040

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-045

Sample Location: 1st Draw 3318 Stephenson PI NW

Customer Sample Number:

Date / Time Collected: 3/20/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-045

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 3318 Stephenson PI NW

Customer Sample Number:

Date / Time Collected: 3/20/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-046

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-041

Sample Location: 1st Draw 3421 Brown ST NW

Customer Sample Number:

Date / Time Collected: 3/20/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-041

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 3421 Brown ST NW

Customer Sample Number:

Date / Time Collected: 3/20/2024 6:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-042

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-037

Sample Location: 1st Draw 4320 Yuma ST NW

Customer Sample Number:

Date / Time Collected: 3/27/2024 7:19 PM

Customer Program Code: DS

Laboratory Sample Number: 2404095-037

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 4320 Yuma ST NW

Customer Sample Number:

Date / Time Collected: 3/27/2024 7:22 PM

Customer Program Code: DS

Laboratory Sample Number: 2404095-038

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-035

Sample Location: 1st Draw 6132 32nd PI NW

Customer Sample Number:

Date / Time Collected: 3/31/2024 7:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2404095-035

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 6132 32nd PI NW

Customer Sample Number:

Date / Time Collected: 3/31/2024 7:53 PM

Customer Program Code: DS

Laboratory Sample Number: 2404095-036

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404095-033

Sample Location: 1st Draw 623 Keefer PI NW

Customer Sample Number:

Date / Time Collected: 3/20/2024 4:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-033

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 623 Keefer PI NW

Customer Sample Number:

Date / Time Collected: 3/20/2024 4:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2404095-034

Date / Time Received: 4/8/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS-2404106-045

Sample Location: 1st Draw 717 Madison St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 6:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-045

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 717 Madison St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-046

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS250- 2404101-003

Sample Location: 1st Draw 1245 13th St NW #212

Customer Sample Number:

Date / Time Collected: 3/22/2024 7:21 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404101-003

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 1245 13th St NW #212

Customer Sample Number:

Date / Time Collected: 3/22/2024 7:21 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404101-004

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS250- 2404101-001

Sample Location: 1st Draw 2707 Adams Mill Rd NW #108

Customer Sample Number:

Date / Time Collected: 3/27/2024 6:38 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404101-001

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 2707 Adams Mill Rd NW #108

Customer Sample Number:

Date / Time Collected: 3/27/2024 6:38 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404101-002

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-DS250- 2404144-001

Sample Location: 1st Draw 2737 Devonshire PI NW Unit #429

Customer Sample Number:

Date / Time Collected: 3/29/2024 9:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404144-001

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	4/17/2024	Lgallimore

Sample Location: 2nd Draw 2737 Devonshire PI NW Unit #429

Customer Sample Number:

Date / Time Collected: 3/29/2024 9:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404144-002

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-053

Sample Location: 1st Draw 1007 Fairmont St NW

Customer Sample Number:

Date / Time Collected: 4/4/2024 8:58 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-053

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1007 Fairmont St NW

Customer Sample Number:

Date / Time Collected: 4/4/2024 9:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-054

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404184-021

Sample Location: 1st Draw 1171 MORSE ST NE

Customer Sample Number:

Date / Time Collected: 4/8/2024 1:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2404184-021

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1171 MORSE ST NE

Customer Sample Number:

Date / Time Collected: 4/8/2024 1:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2404184-022

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-063

Sample Location: 1st Draw 1207 Talbert St SE

Customer Sample Number:

Date / Time Collected: 3/25/2024 8:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-063

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 1207 Talbert St SE

Customer Sample Number:

Date / Time Collected: 3/25/2024 8:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-064

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-025

Sample Location: 1st Draw 1217 Carrollsburg PI SW

Customer Sample Number:

Date / Time Collected: 4/11/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-025

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1217 Carrollsburg PI SW

Customer Sample Number:

Date / Time Collected: 4/11/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-026

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-021

Sample Location: 1st Draw 1236 C Street NE

Customer Sample Number:

Date / Time Collected: 3/27/2024 3:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2404200-021

Date / Time Received: 4/24/2024 8:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	5/3/2024	SBrooks

Sample Location: 2nd Draw 1236 C Street NE

Customer Sample Number:

Date / Time Collected: 3/27/2024 3:21 PM

Customer Program Code: DS

Laboratory Sample Number: 2404200-022

Date / Time Received: 4/24/2024 8:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-071

Sample Location: 1st Draw 1245 Walter St SE

Customer Sample Number:

Date / Time Collected: 4/7/2024 3:06 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-071

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1245 Walter St SE

Customer Sample Number:

Date / Time Collected: 4/7/2024 3:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-072

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404184-023

Sample Location: 1st Draw 1301 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 5:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2404184-023

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1301 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 5:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2404184-024

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-053

Sample Location: 1st Draw 1305 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/21/2024 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-053

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1305 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/21/2024 7:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-054

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-059

Sample Location: 1st Draw 1349 Branch Ave. SE

Customer Sample Number:

Date / Time Collected: 4/4/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-059

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1349 Branch Ave. SE

Customer Sample Number:

Date / Time Collected: 4/4/2024 6:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-060

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-051

Sample Location: 1st Draw 1353 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 4/7/2024 10:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-051

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1353 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 4/7/2024 10:42 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-052

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-061

Sample Location: 1st Draw 1375 F St NE
Customer Sample Number:
Date / Time Collected: 4/7/2024 3:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2404106-061
Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1375 F St NE
Customer Sample Number:
Date / Time Collected: 4/7/2024 3:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2404106-062
Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-059

Sample Location: 1st Draw 1502 E ST SE
Customer Sample Number:
Date / Time Collected: 4/22/2024 3:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2405018-059
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1502 E ST SE
Customer Sample Number:
Date / Time Collected: 4/22/2024 3:10 PM

Customer Program Code: DS
Laboratory Sample Number: 2405018-060
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-049

Sample Location: 1st Draw 16 8th St NE
Customer Sample Number:
Date / Time Collected: 3/26/2024 9:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2404160-049
Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 16 8th St NE
Customer Sample Number:
Date / Time Collected: 3/26/2024 9:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2404160-050
Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-029

Sample Location: 1st Draw 1604 Kearny ST NE

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2404200-029

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1604 Kearny ST NE

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2404200-030

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-043

Sample Location: 1st Draw 1606 Varnum St NW

Customer Sample Number:

Date / Time Collected: 3/29/2024 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-043

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 1606 Varnum St NW

Customer Sample Number:

Date / Time Collected: 3/29/2024 5:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-044

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-051

Sample Location: 1st Draw 1693 34th St NW

Customer Sample Number:

Date / Time Collected: 3/27/2024 5:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-051

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 1693 34th St NW

Customer Sample Number:

Date / Time Collected: 3/27/2024 5:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-052

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-019

Sample Location: 1st Draw 1729 Irving ST NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-019

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1729 Irving ST NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-020

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-065

Sample Location: 1st Draw 1757 Swann, Apt 1

Customer Sample Number:

Date / Time Collected: 4/5/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-065

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1757 Swann, Apt 1

Customer Sample Number:

Date / Time Collected: 4/5/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-066

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-069

Sample Location: 1st Draw 2032 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 4/5/2024 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-069

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 2032 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 4/5/2024 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-070

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-033

Sample Location: 1st Draw 2244 12th PI NW

Customer Sample Number:

Date / Time Collected: 4/12/2024 9:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-033

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 2244 12th PI NW

Customer Sample Number:

Date / Time Collected: 4/12/2024 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-034

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-003

Sample Location: 1st Draw 235 R.I. Ave NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 10:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-003

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 235 R.I. Ave NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 10:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-004

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-047

Sample Location: 1st Draw 2725 Woodley PI NW

Customer Sample Number:

Date / Time Collected: 4/20/2024 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-047

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 2725 Woodley PI NW

Customer Sample Number:

Date / Time Collected: 4/20/2024 7:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-048

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-039

Sample Location: 1st Draw 2820 Hurst Ter NW

Customer Sample Number:

Date / Time Collected: 3/16/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-039

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 2820 Hurst Ter NW

Customer Sample Number:

Date / Time Collected: 3/16/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-040

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-051

Sample Location: 1st Draw 3031 Sherman Ave NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 3:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-051

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3031 Sherman Ave NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 3:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-052

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-049

Sample Location: 1st Draw 310 3rd St SE

Customer Sample Number:

Date / Time Collected: 3/27/2024 4:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-049

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 310 3rd St SE

Customer Sample Number:

Date / Time Collected: 3/27/2024 4:12 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-050

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-027

Sample Location: 1st Draw 3110 33rd PI NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 8:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-027

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3110 33rd PI NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 8:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-028

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-059

Sample Location: 1st Draw 3121 18th ST NE

Customer Sample Number:

Date / Time Collected: 3/27/2024 7:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-059

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 3121 18th ST NE

Customer Sample Number:

Date / Time Collected: 3/27/2024 8:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-060

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-041

Sample Location: 1st Draw 320 15TH ST NE

Customer Sample Number:

Date / Time Collected: 4/3/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-041

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 320 15TH ST NE

Customer Sample Number:

Date / Time Collected: 4/3/2024 6:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-042

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-047

Sample Location: 1st Draw 3210 20th ST NE

Customer Sample Number:

Date / Time Collected: 4/14/2024 7:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-047

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3210 20th ST NE

Customer Sample Number:

Date / Time Collected: 4/14/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-048

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-067

Sample Location: 1st Draw 327 K St NE
Customer Sample Number:
Date / Time Collected: 3/26/2024 5:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2404106-067
Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 327 K St NE
Customer Sample Number:
Date / Time Collected: 3/26/2024 5:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2404106-068
Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-005

Sample Location: 1st Draw 3318 Reservoir Rd NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-005

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3318 Reservoir Rd NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 7:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-006

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-037

Sample Location: 1st Draw 3417 Porter ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 9:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-037

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3417 Porter ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 9:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-038

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-055

Sample Location: 1st Draw 3915 Benton St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 3:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-055

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 3915 Benton St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 3:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2404106-056

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-049

Sample Location: 1st Draw 3916 Mckinley ST NW

Customer Sample Number:

Date / Time Collected: 4/22/2024 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-049

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3916 Mckinley ST NW

Customer Sample Number:

Date / Time Collected: 4/22/2024 8:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-050

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-057

Sample Location: 1st Draw 404 8th St NE

Customer Sample Number:

Date / Time Collected: 3/26/2024 4:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-057

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 404 8th St NE

Customer Sample Number:

Date / Time Collected: 3/26/2024 4:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-058

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-063

Sample Location: 1st Draw 407 P ST NW
Customer Sample Number:
Date / Time Collected: 4/21/2024 10:06 AM

Customer Program Code: DS
Laboratory Sample Number: 2405018-063
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 407 P ST NW
Customer Sample Number:
Date / Time Collected: 4/21/2024 10:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2405018-064
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-023

Sample Location: 1st Draw 4103 38th St NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-023

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 4103 38th St NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-024

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404184-027

Sample Location: 1st Draw 4308 19th St NE

Customer Sample Number:

Date / Time Collected: 4/10/2024 9:36 PM

Customer Program Code: DS

Laboratory Sample Number: 2404184-027

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 4308 19th St NE

Customer Sample Number:

Date / Time Collected: 4/10/2024 9:36 PM

Customer Program Code: DS

Laboratory Sample Number: 2404184-028

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-013

Sample Location: 1st Draw 431 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 6:57 PM

Customer Program Code: DS

Laboratory Sample Number: 2404200-013

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 431 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 7:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2404200-014

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-007

Sample Location: 1st Draw 4400 47th ST NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 3:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-007

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 4400 47th ST NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 3:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-008

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-001

Sample Location: 1st Draw 4417 36th ST NW

Customer Sample Number:

Date / Time Collected: 4/13/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-001

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 4417 36th ST NW

Customer Sample Number:

Date / Time Collected: 4/13/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-002

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-057

Sample Location: 1st Draw 4504 Alton PI NW

Customer Sample Number:

Date / Time Collected: 4/7/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-057

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 4504 Alton PI NW

Customer Sample Number:

Date / Time Collected: 4/7/2024 7:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2404106-058

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-011

Sample Location: 1st Draw 4506 South Dakota Ave NE

Customer Sample Number:

Date / Time Collected: 4/9/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-011

Date / Time Received: 4/24/2024 8:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	5/3/2024	SBrooks

Sample Location: 2nd Draw 4506 South Dakota Ave NE

Customer Sample Number:

Date / Time Collected: 4/9/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-012

Date / Time Received: 4/24/2024 8:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-045

Sample Location: 1st Draw 454 Newcomb St SE

Customer Sample Number:

Date / Time Collected: 3/26/2024 8:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-045

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 454 Newcomb St SE

Customer Sample Number:

Date / Time Collected: 3/26/2024 8:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-046

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-031

Sample Location: 1st Draw 4719 4th St NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-031

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 4719 4th St NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-032

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-061

Sample Location: 1st Draw 5042 A ST SE
Customer Sample Number:
Date / Time Collected: 4/15/2024 7:04 AM

Customer Program Code: DS
Laboratory Sample Number: 2405018-061
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 5042 A ST SE
Customer Sample Number:
Date / Time Collected: 4/15/2024 7:06 AM

Customer Program Code: DS
Laboratory Sample Number: 2405018-062
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-053

Sample Location: 1st Draw 509 G St SW

Customer Sample Number:

Date / Time Collected: 3/27/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-053

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 509 G St SW

Customer Sample Number:

Date / Time Collected: 3/27/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-054

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-055

Sample Location: 1st Draw 517 7th St SE
Customer Sample Number:
Date / Time Collected: 4/8/2024 5:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2404160-055
Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 517 7th St SE
Customer Sample Number:
Date / Time Collected: 4/8/2024 5:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2404160-056
Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-047

Sample Location: 1st Draw 5441 32nd St NW

Customer Sample Number:

Date / Time Collected: 3/29/2024 7:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-047

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 5441 32nd St NW

Customer Sample Number:

Date / Time Collected: 3/29/2024 7:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2404160-048

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-015

Sample Location: 1st Draw 5743 5th ST NE

Customer Sample Number:

Date / Time Collected: 4/16/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-015

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 5743 5th ST NE

Customer Sample Number:

Date / Time Collected: 4/16/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-016

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-017

Sample Location: 1st Draw 606 F St NE
Customer Sample Number:
Date / Time Collected: 4/11/2024 2:58 PM

Customer Program Code: DS
Laboratory Sample Number: 2404200-017
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 606 F St NE
Customer Sample Number:
Date / Time Collected: 4/11/2024 3:01 PM

Customer Program Code: DS
Laboratory Sample Number: 2404200-018
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-057

Sample Location: 1st Draw 610 Morton PI NE

Customer Sample Number:

Date / Time Collected: 4/21/2024 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-057

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 610 Morton PI NE

Customer Sample Number:

Date / Time Collected: 4/21/2024 6:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-058

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-035

Sample Location: 1st Draw 615 Gresham PI NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 5:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-035

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 615 Gresham PI NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-036

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404184-019

Sample Location: 1st Draw 619 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 3/27/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2404184-019

Date / Time Received: 4/16/2024 9:05:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 619 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 3/27/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2404184-020

Date / Time Received: 4/16/2024 9:05:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404160-061

Sample Location: 1st Draw 629 7th St NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 9:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2404160-061

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 629 7th St NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 9:47 PM

Customer Program Code: DS

Laboratory Sample Number: 2404160-062

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-065

Sample Location: 1st Draw 6637 32nd ST NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 7:09 PM

Customer Program Code: DS

Laboratory Sample Number: 2405018-065

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 6637 32nd ST NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 7:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2405018-066

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2405018-055

Sample Location: 1st Draw 6948 33rd St NW

Customer Sample Number:

Date / Time Collected: 4/18/2024 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-055

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 6948 33rd St NW

Customer Sample Number:

Date / Time Collected: 4/18/2024 7:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2405018-056

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404184-025

Sample Location: 1st Draw 706 C St NE
Customer Sample Number:
Date / Time Collected: 4/7/2024 12:49 PM

Customer Program Code: DS
Laboratory Sample Number: 2404184-025
Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 706 C St NE
Customer Sample Number:
Date / Time Collected: 4/7/2024 12:52 PM

Customer Program Code: DS
Laboratory Sample Number: 2404184-026
Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404200-039

Sample Location: 1st Draw 833 11th ST NE

Customer Sample Number:

Date / Time Collected: 4/15/2024 3:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2404200-039

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 833 11th ST NE

Customer Sample Number:

Date / Time Collected: 4/15/2024 3:33 PM

Customer Program Code: DS

Laboratory Sample Number: 2404200-040

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS-2404106-047

Sample Location: 1st Draw 952 Westminster St NW
Customer Sample Number:
Date / Time Collected: 4/8/2024 6:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2404106-047
Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 952 Westminster St NW
Customer Sample Number:
Date / Time Collected: 4/8/2024 6:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2404106-048
Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2404199-011

Sample Location: 1st Draw 1201 N. St NW Apt E

Customer Sample Number:

Date / Time Collected: 4/10/2024 7:59 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-011

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1201 N. St NW Apt E

Customer Sample Number:

Date / Time Collected: 4/10/2024 7:59 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-012

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2404199-013

Sample Location: 1st Draw 1230 23rd ST NW Apt 809

Customer Sample Number:

Date / Time Collected: 4/12/2024 6:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-013

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1230 23rd ST NW Apt 809

Customer Sample Number:

Date / Time Collected: 4/12/2024 6:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-014

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2405015-001

Sample Location: 1st Draw 1523 Park Rd NW #101

Customer Sample Number:

Date / Time Collected: 4/17/2024 6:57 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405015-001

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1523 Park Rd NW #101

Customer Sample Number:

Date / Time Collected: 4/17/2024 6:57 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405015-002

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2404199-001

Sample Location: 1st Draw 1700 Harvard St NW Apt 412

Customer Sample Number:

Date / Time Collected: 4/10/2024 6:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-001

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1700 Harvard St NW Apt 412

Customer Sample Number:

Date / Time Collected: 4/10/2024 6:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-002

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2404199-003

Sample Location: 1st Draw 21 6th St NE
Customer Sample Number:
Date / Time Collected: 4/13/2024 10:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2404199-003
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 21 6th St NE
Customer Sample Number:
Date / Time Collected: 4/13/2024 10:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2404199-004
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2404159-001

Sample Location: 1st Draw 3511 13th St NW #205

Customer Sample Number:

Date / Time Collected: 4/5/2024 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404159-001

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 3511 13th St NW #205

Customer Sample Number:

Date / Time Collected: 4/5/2024 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404159-002

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2404199-009

Sample Location: 1st Draw 3618 Connecticut Ave NW, Apt 204

Customer Sample Number:

Date / Time Collected: 4/11/2024 8:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-009

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 3618 Connecticut Ave NW, Apt 204

Customer Sample Number:

Date / Time Collected: 4/11/2024 8:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-010

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2404199-007

Sample Location: 1st Draw 3807 Rodman St. NW, F12

Customer Sample Number:

Date / Time Collected: 4/14/2024 5:58 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-007

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 3807 Rodman St. NW, F12

Customer Sample Number:

Date / Time Collected: 4/14/2024 5:58 AM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-008

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2404199-005

Sample Location: 1st Draw 440 L St NW #802

Customer Sample Number:

Date / Time Collected: 4/14/2024 4:25 PM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-005

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 440 L St NW #802

Customer Sample Number:

Date / Time Collected: 4/14/2024 4:25 PM

Customer Program Code: DS250

Laboratory Sample Number: 2404199-006

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-DS250- 2404152-001

Sample Location: 1st Draw 4629 MacArthur Blvd NW Unit 1/2A

Customer Sample Number:

Date / Time Collected: 3/18/2024 7:15 PM

Customer Program Code: DS250

Laboratory Sample Number: 2404152-001

Date / Time Received: 4/18/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 4629 MacArthur Blvd NW Unit 1/2A

Customer Sample Number:

Date / Time Collected: 3/18/2024 7:15 PM

Customer Program Code: DS250

Laboratory Sample Number: 2404152-002

Date / Time Received: 4/18/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-013

Sample Location: 1st Draw 1203 Hamlin St NE

Customer Sample Number:

Date / Time Collected: 5/5/2024 10:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2405076-013

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1203 Hamlin St NE

Customer Sample Number:

Date / Time Collected: 5/5/2024 10:28 PM

Customer Program Code: DS

Laboratory Sample Number: 2405076-014

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-005

Sample Location: 1st Draw 1211 Florida Ave NE

Customer Sample Number:

Date / Time Collected: 5/1/2024 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-005

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1211 Florida Ave NE

Customer Sample Number:

Date / Time Collected: 5/1/2024 7:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-006

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-043

Sample Location: 1st Draw 1217 Quincy St. NE

Customer Sample Number:

Date / Time Collected: 4/27/2024 6:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-043

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1217 Quincy St. NE

Customer Sample Number:

Date / Time Collected: 4/27/2024 6:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-044

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405071-001

Sample Location: 1st Draw 125 D St SE
Customer Sample Number:
Date / Time Collected: 4/21/2024 7:08 PM

Customer Program Code: DS
Laboratory Sample Number: 2405071-001
Date / Time Received: 5/8/2024 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/14/2024	Rlamsal

Sample Location: 2nd Draw 125 D St SE
Customer Sample Number:
Date / Time Collected: 4/21/2024 7:09 PM

Customer Program Code: DS
Laboratory Sample Number: 2405071-002
Date / Time Received: 5/8/2024 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-007

Sample Location: 1st Draw 1325 Girard St NE

Customer Sample Number:

Date / Time Collected: 5/6/2024 4:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-007

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1325 Girard St NE

Customer Sample Number:

Date / Time Collected: 5/6/2024 4:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-008

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-017

Sample Location: 1st Draw 1325 Iris St, NW

Customer Sample Number:

Date / Time Collected: 5/7/2024 11:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-017

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1325 Iris St, NW

Customer Sample Number:

Date / Time Collected: 5/7/2024 11:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-018

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-009

Sample Location: 1st Draw 1326 22nd St NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 7:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-009

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1326 22nd St NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 7:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-010

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405071-005

Sample Location: 1st Draw 1443 Clifton St NW Apt A

Customer Sample Number:

Date / Time Collected: 4/29/2024 5:01 PM

Customer Program Code: DS

Laboratory Sample Number: 2405071-005

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1443 Clifton St NW Apt A

Customer Sample Number:

Date / Time Collected: 4/29/2024 5:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2405071-006

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-041

Sample Location: 1st Draw 1525 E St. SE

Customer Sample Number:

Date / Time Collected: 4/26/2024 1:32 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-041

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1525 E St. SE

Customer Sample Number:

Date / Time Collected: 4/26/2024 1:33 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-042

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-073

Sample Location: 1st Draw 1600 23rd St. SE

Customer Sample Number:

Date / Time Collected: 4/29/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-073

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-021

Sample Location: 1st Draw 1709 Stanton Terr. SE

Customer Sample Number:

Date / Time Collected: 4/24/2024 5:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-021

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1709 Stanton Terr. SE

Customer Sample Number:

Date / Time Collected: 4/24/2024 5:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-022

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-001

Sample Location: 1st Draw 1732 C St. NE

Customer Sample Number:

Date / Time Collected: 4/28/2024 8:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-001

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1732 C St. NE

Customer Sample Number:

Date / Time Collected: 4/28/2024 8:36 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-002

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-019

Sample Location: 1st Draw 1738 Potomac Ave SE

Customer Sample Number:

Date / Time Collected: 5/4/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-019

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1738 Potomac Ave SE

Customer Sample Number:

Date / Time Collected: 5/4/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-020

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-015

Sample Location: 1st Draw 1818 Vermont Ave NW

Customer Sample Number:

Date / Time Collected: 4/22/2024 3:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-015

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1818 Vermont Ave NW

Customer Sample Number:

Date / Time Collected: 4/22/2024 3:11 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-016

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-021

Sample Location: 1st Draw 2 Adams St NW

Customer Sample Number:

Date / Time Collected: 5/7/2024 6:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-021

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2 Adams St NW

Customer Sample Number:

Date / Time Collected: 5/7/2024 6:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-022

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-015

Sample Location: 1st Draw 2320 13th PI NE

Customer Sample Number:

Date / Time Collected: 5/4/2024 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-015

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2320 13th PI NE

Customer Sample Number:

Date / Time Collected: 5/4/2024 10:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-016

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-033

Sample Location: 1st Draw 2324 2nd St. NE

Customer Sample Number:

Date / Time Collected: 4/25/2024 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-033

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2324 2nd St. NE

Customer Sample Number:

Date / Time Collected: 4/25/2024 7:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-034

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-031

Sample Location: 1st Draw 2325 34th St. SE

Customer Sample Number:

Date / Time Collected: 4/25/2024 7:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-031

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2325 34th St. SE

Customer Sample Number:

Date / Time Collected: 4/25/2024 7:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-032

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-029

Sample Location: 1st Draw 26 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 4/25/2024 5:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-029

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 26 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 4/25/2024 5:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-030

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-027

Sample Location: 1st Draw 2735 Woodley PI NW

Customer Sample Number:

Date / Time Collected: 4/24/2024 9:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-027

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2735 Woodley PI NW

Customer Sample Number:

Date / Time Collected: 4/24/2024 10:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-028

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-055

Sample Location: 1st Draw 2828 McKinley PL NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 4:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-055

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2828 McKinley PL NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 4:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-056

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-019

Sample Location: 1st Draw 2942 M St. SE
Customer Sample Number:
Date / Time Collected: 4/23/2024 4:26 PM

Customer Program Code: DS
Laboratory Sample Number: 2405027-019
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2942 M St. SE
Customer Sample Number:
Date / Time Collected: 4/23/2024 4:28 PM

Customer Program Code: DS
Laboratory Sample Number: 2405027-020
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-013

Sample Location: 1st Draw 3048 R St NW
Customer Sample Number:
Date / Time Collected: 4/22/2024 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2405027-013
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3048 R St NW
Customer Sample Number:
Date / Time Collected: 4/22/2024 6:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2405027-014
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-025

Sample Location: 1st Draw 3345 Rittenhouse St NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-025

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3345 Rittenhouse St NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 6:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-026

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-071

Sample Location: 1st Draw 3446 23rd St. SE

Customer Sample Number:

Date / Time Collected: 4/28/2024 9:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-071

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3446 23rd St. SE

Customer Sample Number:

Date / Time Collected: 4/28/2024 9:17 PM

Customer Program Code: DS

Laboratory Sample Number: 2405027-072

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-023

Sample Location: 1st Draw 3939 Van Ness St. NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-023

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3939 Van Ness St. NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-024

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405071-003

Sample Location: 1st Draw 4401 Garrison St NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2405071-003

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 4401 Garrison St NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2405071-004

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-001

Sample Location: 1st Draw 4435 Garrison St NW

Customer Sample Number:

Date / Time Collected: 5/2/2024 6:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-001

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 4435 Garrison St NW

Customer Sample Number:

Date / Time Collected: 5/2/2024 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2405076-002

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-003

Sample Location: 1st Draw 516 K St NE
Customer Sample Number:
Date / Time Collected: 5/5/2024 5:45 PM

Customer Program Code: DS
Laboratory Sample Number: 2405076-003
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 516 K St NE
Customer Sample Number:
Date / Time Collected: 5/5/2024 5:50 PM

Customer Program Code: DS
Laboratory Sample Number: 2405076-004
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-007

Sample Location: 1st Draw 54 Q St. NE
Customer Sample Number:
Date / Time Collected: 4/19/2024 6:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2405027-007
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 54 Q St. NE
Customer Sample Number:
Date / Time Collected: 4/19/2024 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2405027-008
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-035

Sample Location: 1st Draw 630 NC Ave SE

Customer Sample Number:

Date / Time Collected: 4/25/2024 8:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-035

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 630 NC Ave SE

Customer Sample Number:

Date / Time Collected: 4/25/2024 8:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-036

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405076-011

Sample Location: 1st Draw 637 10th St NE

Customer Sample Number:

Date / Time Collected: 5/3/2024 7:52 PM

Customer Program Code: DS

Laboratory Sample Number: 2405076-011

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 637 10th St NE

Customer Sample Number:

Date / Time Collected: 5/3/2024 7:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2405076-012

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS-2405027-025

Sample Location: 1st Draw 815 Quakenbos St NW

Customer Sample Number:

Date / Time Collected: 4/24/2024 10:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-025

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 815 Quakenbos St NW

Customer Sample Number:

Date / Time Collected: 4/24/2024 10:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2405027-026

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS250- 2405028-005

Sample Location: 1st Draw 1410 12th St NW, #4

Customer Sample Number:

Date / Time Collected: 4/29/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-005

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1410 12th St NW, #4

Customer Sample Number:

Date / Time Collected: 4/29/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-006

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS250- 2405028-001

Sample Location: 1st Draw 1915 16th St NW, #303

Customer Sample Number:

Date / Time Collected: 4/22/2024 8:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-001

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1915 16th St NW, #303

Customer Sample Number:

Date / Time Collected: 4/22/2024 8:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-002

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS250- 2405028-009

Sample Location: 1st Draw 2070 Belmont Rd NW #604

Customer Sample Number:

Date / Time Collected: 4/20/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-009

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2070 Belmont Rd NW #604

Customer Sample Number:

Date / Time Collected: 4/20/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-010

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS250- 2405028-007

Sample Location: 1st Draw 21 8th St NE #4

Customer Sample Number:

Date / Time Collected: 4/29/2024 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-007

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 21 8th St NE #4

Customer Sample Number:

Date / Time Collected: 4/29/2024 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-008

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-DS250- 2405028-003

Sample Location: 1st Draw 700 7th St SW #704

Customer Sample Number:

Date / Time Collected: 4/29/2024 5:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-003

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 700 7th St SW #704

Customer Sample Number:

Date / Time Collected: 4/29/2024 5:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405028-004

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/10/2024

Report Number: L-DC-DS-2404200-009

Sample Location: 1st Draw 1927 U PI SE

Customer Sample Number:

Date / Time Collected: 4/16/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-009

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	111	ug/L		6/4/2024	SBrooks

Sample Location: 2nd Draw 1927 U PI SE

Customer Sample Number:

Date / Time Collected: 4/16/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2404200-010

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405199-005

Sample Location: 1st Draw 1130 Park ST NE

Customer Sample Number:

Date / Time Collected: 5/10/2024 9:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-005

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1130 Park ST NE

Customer Sample Number:

Date / Time Collected: 5/10/2024 9:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-006

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405199-015

Sample Location: 1st Draw 1221 Floral ST NW

Customer Sample Number:

Date / Time Collected: 5/10/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-015

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1221 Floral ST NW

Customer Sample Number:

Date / Time Collected: 5/10/2024 6:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-016

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405199-007

Sample Location: 1st Draw 1305 Riggs ST NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 2:57 PM

Customer Program Code: DS

Laboratory Sample Number: 2405199-007

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1305 Riggs ST NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 3:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2405199-008

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405199-013

Sample Location: 1st Draw 1418 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 5/21/2024 8:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-013

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1418 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 5/21/2024 8:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-014

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405199-009

Sample Location: 1st Draw 1516 Webster St NW

Customer Sample Number:

Date / Time Collected: 5/20/2024 4:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2405199-009

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1516 Webster St NW

Customer Sample Number:

Date / Time Collected: 5/20/2024 4:47 PM

Customer Program Code: DS

Laboratory Sample Number: 2405199-010

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405158-004

Sample Location: 1st Draw 1536 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 5/16/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2405158-004

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1536 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 5/16/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2405158-005

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405119-011

Sample Location: 1st Draw 1642 4th St NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 7:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2405119-011

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1642 4th St NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2405119-012

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405201-001

Sample Location: 1st Draw 1723 Allison St NE

Customer Sample Number:

Date / Time Collected: 5/10/2024 5:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2405201-001

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1723 Allison St NE

Customer Sample Number:

Date / Time Collected: 5/10/2024 5:34 PM

Customer Program Code: DS

Laboratory Sample Number: 2405201-002

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405199-003

Sample Location: 1st Draw 1745 Swann ST NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-003

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1745 Swann ST NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-004

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405119-003

Sample Location: 1st Draw 308 13TH ST SE Apt 1

Customer Sample Number:

Date / Time Collected: 5/8/2024 6:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2405119-003

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 308 13TH ST SE Apt 1

Customer Sample Number:

Date / Time Collected: 5/8/2024 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2405119-004

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405119-017

Sample Location: 1st Draw 313 10th St SE

Customer Sample Number:

Date / Time Collected: 5/2/2024 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2405119-017

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 313 10th St SE

Customer Sample Number:

Date / Time Collected: 5/2/2024 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2405119-018

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405201-009

Sample Location: 1st Draw 322 34th St NE

Customer Sample Number:

Date / Time Collected: 5/19/2024 8:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2405201-009

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 322 34th St NE

Customer Sample Number:

Date / Time Collected: 5/19/2024 8:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2405201-010

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405119-019

Sample Location: 1st Draw 4015 First PL SW

Customer Sample Number:

Date / Time Collected: 5/2/2024 5:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2405119-019

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 4015 First PL SW

Customer Sample Number:

Date / Time Collected: 5/2/2024 5:06 PM

Customer Program Code: DS

Laboratory Sample Number: 2405119-020

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405199-017

Sample Location: 1st Draw 408 Division Ave NE

Customer Sample Number:

Date / Time Collected: 5/15/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-017

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 408 Division Ave NE

Customer Sample Number:

Date / Time Collected: 5/15/2024 5:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-018

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405201-007

Sample Location: 1st Draw 44 Quincy PI NE #1

Customer Sample Number:

Date / Time Collected: 5/19/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2405201-007

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 44 Quincy PI NE #1

Customer Sample Number:

Date / Time Collected: 5/19/2024 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2405201-008

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405199-001

Sample Location: 1st Draw 4417 48 ST NW

Customer Sample Number:

Date / Time Collected: 5/18/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-001

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 4417 48 ST NW

Customer Sample Number:

Date / Time Collected: 5/18/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2405199-002

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405201-003

Sample Location: 1st Draw 4839 B ST SE
Customer Sample Number:
Date / Time Collected: 5/13/2024 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2405201-003
Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 4839 B ST SE
Customer Sample Number:
Date / Time Collected: 5/13/2024 7:37 AM

Customer Program Code: DS
Laboratory Sample Number: 2405201-004
Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405158-022

Sample Location: 1st Draw 4911 46th St. NW

Customer Sample Number:

Date / Time Collected: 5/16/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2405158-022

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 4911 46th St. NW

Customer Sample Number:

Date / Time Collected: 5/16/2024 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2405158-023

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405119-005

Sample Location: 1st Draw 503 21st St. NE

Customer Sample Number:

Date / Time Collected: 5/9/2024 6:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2405119-005

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 503 21st St. NE

Customer Sample Number:

Date / Time Collected: 5/9/2024 6:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2405119-006

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405130-001

Sample Location: 1st Draw 549 5th St SE
Customer Sample Number:
Date / Time Collected: 5/4/2024 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2405130-001
Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 549 5th St SE
Customer Sample Number:
Date / Time Collected: 5/4/2024 6:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2405130-002
Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405158-008

Sample Location: 1st Draw 602 Acker PL NE

Customer Sample Number:

Date / Time Collected: 5/14/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2405158-008

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 602 Acker PL NE

Customer Sample Number:

Date / Time Collected: 5/14/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2405158-009

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405201-005

Sample Location: 1st Draw 603 Quintana PI NW

Customer Sample Number:

Date / Time Collected: 5/5/2024 7:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2405201-005

Date / Time Received: 5/22/2024 12:10:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/31/2024	Bprakash

Sample Location: 2nd Draw 603 Quintana PI NW

Customer Sample Number:

Date / Time Collected: 5/5/2024 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2405201-006

Date / Time Received: 5/22/2024 12:10:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405158-016

Sample Location: 1st Draw 609 14TH ST NE

Customer Sample Number:

Date / Time Collected: 5/15/2024 10:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2405158-016

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 609 14TH ST NE

Customer Sample Number:

Date / Time Collected: 5/15/2024 10:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2405158-017

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS-2405199-011

Sample Location: 1st Draw 773 Hobart PL NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 4:59 PM

Customer Program Code: DS

Laboratory Sample Number: 2405199-011

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 773 Hobart PL NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 5:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2405199-012

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS250- 2405118-001

Sample Location: 1st Draw 1221 24th St. NW Apt. 106

Customer Sample Number:

Date / Time Collected: 5/7/2024 10:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-001

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1221 24th St. NW Apt. 106

Customer Sample Number:

Date / Time Collected: 5/7/2024 10:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-002

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS250- 2405118-005

Sample Location: 1st Draw 1651 Lamont St. NW #2E

Customer Sample Number:

Date / Time Collected: 5/8/2024 7:57 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-005

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1651 Lamont St. NW #2E

Customer Sample Number:

Date / Time Collected: 5/8/2024 7:57 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-006

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS250- 2405157-001

Sample Location: 1st Draw 1701 Kilbourne PL NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405157-001

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	BPrakash

Sample Location: 2nd Draw 1701 Kilbourne PL NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405157-002

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS250- 2405118-011

Sample Location: 1st Draw 1900 Lamont St NW Apt. 501

Customer Sample Number:

Date / Time Collected: 5/13/2024 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-011

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1900 Lamont St NW Apt. 501

Customer Sample Number:

Date / Time Collected: 5/13/2024 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-012

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS250- 2405118-003

Sample Location: 1st Draw 3071 Ontario Rd. NW #25

Customer Sample Number:

Date / Time Collected: 5/7/2024 6:42 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-003

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 3071 Ontario Rd. NW #25

Customer Sample Number:

Date / Time Collected: 5/7/2024 6:42 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-004

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS250- 2405118-009

Sample Location: 1st Draw 4000 Tunlaw Rd. NW Apt. 822

Customer Sample Number:

Date / Time Collected: 5/10/2024 6:48 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-009

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 4000 Tunlaw Rd. NW Apt. 822

Customer Sample Number:

Date / Time Collected: 5/10/2024 6:48 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-010

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-DS250- 2405118-007

Sample Location: 1st Draw 6425 14th St. NW, #201

Customer Sample Number:

Date / Time Collected: 5/8/2024 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-007

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 6425 14th St. NW, #201

Customer Sample Number:

Date / Time Collected: 5/8/2024 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2405118-008

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off approximately 4 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312111-031

Sample Location: 1st Draw 1343 Oak St. NW

Customer Sample Number:

Date / Time Collected: 12/5/2023 7:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-031

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1343 Oak St. NW

Customer Sample Number:

Date / Time Collected: 12/5/2023 7:58 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-032

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312060-035

Sample Location: 1st Draw 1535 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 12/1/2023 7:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-035

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1535 Upshur St. NW

Customer Sample Number:

Date / Time Collected: 12/1/2023 7:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-036

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312111-025

Sample Location: 1st Draw 1627 Webster St NW

Customer Sample Number:

Date / Time Collected: 12/6/2023 4:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-025

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 1627 Webster St NW

Customer Sample Number:

Date / Time Collected: 12/6/2023 4:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-026

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312048-009

Sample Location: 1st Draw 1724 5th St NW

Customer Sample Number:

Date / Time Collected: 11/21/2023 6:37 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312048-009

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Sample Location: 2nd Draw 1724 5th St NW

Customer Sample Number:

Date / Time Collected: 11/21/2023 6:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312048-010

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312111-029

Sample Location: 1st Draw 1821 Jackson St NE

Customer Sample Number:

Date / Time Collected: 11/25/2023 2:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-029

Date / Time Received: 12/14/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Sample Location: 2nd Draw 1821 Jackson St NE

Customer Sample Number:

Date / Time Collected: 11/25/2023 2:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-030

Date / Time Received: 12/14/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312060-005

Sample Location: 1st Draw 3558 13th St. NW

Customer Sample Number:

Date / Time Collected: 11/30/2023 6:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-005

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 3558 13th St. NW

Customer Sample Number:

Date / Time Collected: 11/30/2023 6:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-006

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312048-011

Sample Location: 1st Draw 4500 15th St. NW

Customer Sample Number:

Date / Time Collected: 11/27/2023 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312048-011

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 4500 15th St. NW

Customer Sample Number:

Date / Time Collected: 11/27/2023 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312048-012

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312111-027

Sample Location: 1st Draw 48 Madison St NW #4

Customer Sample Number:

Date / Time Collected: 11/20/2023 5:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-027

Date / Time Received: 12/14/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Sample Location: 2nd Draw 48 Madison St NW #4

Customer Sample Number:

Date / Time Collected: 11/20/2023 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-028

Date / Time Received: 12/14/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312060-007

Sample Location: 1st Draw 4825 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 12/3/2023 10:47 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-007

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 4825 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 12/3/2023 10:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-008

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312060-037

Sample Location: 1st Draw 5020 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 11/29/2023 6:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-037

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 5020 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 11/29/2023 6:34 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-038

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312060-003

Sample Location: 1st Draw 621 Upshur St NW

Customer Sample Number:

Date / Time Collected: 11/29/2023 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-003

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 621 Upshur St NW

Customer Sample Number:

Date / Time Collected: 11/29/2023 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312060-004

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312048-007

Sample Location: 1st Draw 765 Gresham PL NW

Customer Sample Number:

Date / Time Collected: 11/19/2023 11:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312048-007

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Sample Location: 2nd Draw 765 Gresham PL NW

Customer Sample Number:

Date / Time Collected: 11/19/2023 11:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312048-008

Date / Time Received: 12/7/2023 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312111-023

Sample Location: 1st Draw 800 Madison St NW

Customer Sample Number:

Date / Time Collected: 12/6/2023 8:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-023

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/21/2023	Lgallimore

Sample Location: 2nd Draw 800 Madison St NW

Customer Sample Number:

Date / Time Collected: 12/6/2023 8:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312111-024

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-Post-LSR- 2312005-041

Sample Location: 1st Draw 926 11th St. NW

Customer Sample Number:

Date / Time Collected: 11/28/2023 11:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312005-041

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	10	49.4	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 926 11th St. NW

Customer Sample Number:

Date / Time Collected: 11/28/2023 11:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312005-042

Date / Time Received: 12/1/2023 9:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/7/2023	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-003

Sample Location: 1st Draw 1057 5th St SE

Customer Sample Number:

Date / Time Collected: 12/13/2023 3:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-003

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 1057 5th St SE

Customer Sample Number:

Date / Time Collected: 12/13/2023 3:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-004

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-039

Sample Location: 1st Draw 1238 Ingraham St NW

Customer Sample Number:

Date / Time Collected: 12/6/2023 8:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-039

Date / Time Received: 12/22/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L	H	1/4/2024	SBrooks

Sample Location: 2nd Draw 1238 Ingraham St NW

Customer Sample Number:

Date / Time Collected: 12/6/2023 8:33 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-040

Date / Time Received: 12/22/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-035

Sample Location: 1st Draw 128 Bryant St NW

Customer Sample Number:

Date / Time Collected: 12/18/2023 7:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-035

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 128 Bryant St NW

Customer Sample Number:

Date / Time Collected: 12/18/2023 7:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-036

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-029

Sample Location: 1st Draw 1410 Kearny St. NE

Customer Sample Number:

Date / Time Collected: 12/17/2023 7:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-029

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 1410 Kearny St. NE

Customer Sample Number:

Date / Time Collected: 12/17/2023 7:57 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-030

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-009

Sample Location: 1st Draw 2416 Observatory PI NW

Customer Sample Number:

Date / Time Collected: 12/12/2023 12:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-009

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 2416 Observatory PI NW

Customer Sample Number:

Date / Time Collected: 12/12/2023 12:32 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-010

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-005

Sample Location: 1st Draw 242 Kentucky Ave SE

Customer Sample Number:

Date / Time Collected: 12/10/2023 2:18 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-005

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 242 Kentucky Ave SE

Customer Sample Number:

Date / Time Collected: 12/10/2023 2:21 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-006

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-007

Sample Location: 1st Draw 415 4th St. NE

Customer Sample Number:

Date / Time Collected: 12/17/2023 8:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-007

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 415 4th St. NE

Customer Sample Number:

Date / Time Collected: 12/17/2023 8:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-008

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-033

Sample Location: 1st Draw 4829 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 12/17/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-033

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 4829 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 12/17/2023 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-034

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-037

Sample Location: 1st Draw 539 11th St SE

Customer Sample Number:

Date / Time Collected: 12/12/2023 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-037

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 539 11th St SE

Customer Sample Number:

Date / Time Collected: 12/12/2023 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-038

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-031

Sample Location: 1st Draw 615 Gallatin St NW

Customer Sample Number:

Date / Time Collected: 12/13/2023 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-031

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		1/4/2024	SBrooks

Sample Location: 2nd Draw 615 Gallatin St NW

Customer Sample Number:

Date / Time Collected: 12/13/2023 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-032

Date / Time Received: 12/22/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-Post-LSR- 2312159-001

Sample Location: 1st Draw 705 18th St. NE

Customer Sample Number:

Date / Time Collected: 12/6/2023 8:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-001

Date / Time Received: 12/22/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/4/2024	SBrooks

Sample Location: 2nd Draw 705 18th St. NE

Customer Sample Number:

Date / Time Collected: 12/6/2023 8:14 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2312159-002

Date / Time Received: 12/22/2023 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-005

Sample Location: 1st Draw 2407 Irving St. NE

Customer Sample Number:

Date / Time Collected: 1/8/2024 5:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-005

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 2407 Irving St. NE

Customer Sample Number:

Date / Time Collected: 1/8/2024 5:58 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-006

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401043-037

Sample Location: 1st Draw 3010 Q St. NW

Customer Sample Number:

Date / Time Collected: 1/1/2024 5:02 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-037

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/2/2024	SBrooks

Sample Location: 2nd Draw 3010 Q St. NW

Customer Sample Number:

Date / Time Collected: 1/1/2024 5:04 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-038

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401043-005

Sample Location: 1st Draw 322 9th St SE
Customer Sample Number:
Date / Time Collected: 1/3/2024 6:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2401043-005
Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 322 9th St SE
Customer Sample Number:
Date / Time Collected: 1/3/2024 6:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2401043-006
Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-071

Sample Location: 1st Draw 3721 Jenifer St NW

Customer Sample Number:

Date / Time Collected: 1/2/2024 7:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-071

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 3721 Jenifer St NW

Customer Sample Number:

Date / Time Collected: 1/2/2024 7:33 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-072

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-059

Sample Location: 1st Draw 3833 T ST NW

Customer Sample Number:

Date / Time Collected: 1/7/2024 8:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-059

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 3833 T ST NW

Customer Sample Number:

Date / Time Collected: 1/7/2024 8:51 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-060

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401043-035

Sample Location: 1st Draw 3935 Livingston ST NW

Customer Sample Number:

Date / Time Collected: 1/1/2024 7:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-035

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 3935 Livingston ST NW

Customer Sample Number:

Date / Time Collected: 1/1/2024 7:33 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-036

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401043-003

Sample Location: 1st Draw 4222 3rd St NW

Customer Sample Number:

Date / Time Collected: 12/23/2023 10:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-003

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/11/2024	Rlamsal

Sample Location: 2nd Draw 4222 3rd St NW

Customer Sample Number:

Date / Time Collected: 12/23/2023 10:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-004

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-067

Sample Location: 1st Draw 4414 Lowell ST NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 7:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-067

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 4414 Lowell ST NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-068

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401043-001

Sample Location: 1st Draw 4508 15th St. NW

Customer Sample Number:

Date / Time Collected: 12/19/2023 5:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-001

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/11/2024	Rlamsal

Sample Location: 2nd Draw 4508 15th St. NW

Customer Sample Number:

Date / Time Collected: 12/19/2023 5:49 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-002

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-009

Sample Location: 1st Draw 4565 Grant Rd NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 7:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-009

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 4565 Grant Rd NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 7:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-010

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-033

Sample Location: 1st Draw 4606 Kane PI NE

Customer Sample Number:

Date / Time Collected: 1/8/2024 7:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-033

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 4606 Kane PI NE

Customer Sample Number:

Date / Time Collected: 1/8/2024 7:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-034

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401043-039

Sample Location: 1st Draw 4637 Q St NW

Customer Sample Number:

Date / Time Collected: 12/16/2023 5:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-039

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/31/2024	Rlamsal

Sample Location: 2nd Draw 4637 Q St NW

Customer Sample Number:

Date / Time Collected: 12/16/2023 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401043-040

Date / Time Received: 1/5/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-051

Sample Location: 1st Draw 4915 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 1/9/2024 8:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-051

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 4915 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 1/9/2024 8:13 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-052

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-063

Sample Location: 1st Draw 525 Decatur St NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 6:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-063

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 525 Decatur St NW

Customer Sample Number:

Date / Time Collected: 1/4/2024 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-064

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-021

Sample Location: 1st Draw 620 Emerson ST NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 2:10 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-021

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 620 Emerson ST NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 2:10 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-022

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-Post-LSR- 2401088-045

Sample Location: 1st Draw 906 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 1/3/2024 8:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-045

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		1/31/2024	Rlamsal

Sample Location: 2nd Draw 906 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 1/3/2024 8:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401088-046

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401166-035

Sample Location: 1st Draw 1425 West Virginia Ave NE

Customer Sample Number:

Date / Time Collected: 1/6/2024 10:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401166-035

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1425 West Virginia Ave NE

Customer Sample Number:

Date / Time Collected: 1/6/2024 10:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401166-036

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401178-045

Sample Location: 1st Draw 1602 A ST NE
Customer Sample Number:
Date / Time Collected: 1/11/2024 7:35 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2401178-045
Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1602 A ST NE
Customer Sample Number:
Date / Time Collected: 1/11/2024 7:38 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2401178-046
Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401188-045

Sample Location: 1st Draw 1635 Webster St NW

Customer Sample Number:

Date / Time Collected: 1/23/2024 7:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-045

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1635 Webster St NW

Customer Sample Number:

Date / Time Collected: 1/23/2024 7:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-046

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401178-039

Sample Location: 1st Draw 1853 Vernon ST NW

Customer Sample Number:

Date / Time Collected: 1/13/2024 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-039

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 1853 Vernon ST NW

Customer Sample Number:

Date / Time Collected: 1/13/2024 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-040

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401166-039

Sample Location: 1st Draw 2006 Kearny St NE

Customer Sample Number:

Date / Time Collected: 1/9/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401166-039

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 2006 Kearny St NE

Customer Sample Number:

Date / Time Collected: 1/9/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401166-040

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401188-039

Sample Location: 1st Draw 2132 37th St NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 6:50 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-039

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 2132 37th St NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 6:53 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-040

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401188-037

Sample Location: 1st Draw 2307 Park PI SE

Customer Sample Number:

Date / Time Collected: 1/24/2024 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-037

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 2307 Park PI SE

Customer Sample Number:

Date / Time Collected: 1/24/2024 6:23 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-038

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401178-041

Sample Location: 1st Draw 2402 I St NW
Customer Sample Number:
Date / Time Collected: 1/14/2024 8:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2401178-041
Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 2402 I St NW
Customer Sample Number:
Date / Time Collected: 1/14/2024 8:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2401178-042
Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401188-043

Sample Location: 1st Draw 306 12th ST NE

Customer Sample Number:

Date / Time Collected: 1/22/2024 7:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-043

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 306 12th ST NE

Customer Sample Number:

Date / Time Collected: 1/22/2024 7:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-044

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401166-037

Sample Location: 1st Draw 320 12th ST NE

Customer Sample Number:

Date / Time Collected: 1/10/2024 7:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401166-037

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 320 12th ST NE

Customer Sample Number:

Date / Time Collected: 1/10/2024 7:28 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401166-038

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401178-051

Sample Location: 1st Draw 3308 Park PI NW

Customer Sample Number:

Date / Time Collected: 1/12/2024 4:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-051

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3308 Park PI NW

Customer Sample Number:

Date / Time Collected: 1/12/2024 4:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-052

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401166-033

Sample Location: 1st Draw 3404 Norton ST NW

Customer Sample Number:

Date / Time Collected: 1/9/2024 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401166-033

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3404 Norton ST NW

Customer Sample Number:

Date / Time Collected: 1/9/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401166-034

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401178-037

Sample Location: 1st Draw 3722 35th St NW

Customer Sample Number:

Date / Time Collected: 1/11/2024 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-037

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 3722 35th St NW

Customer Sample Number:

Date / Time Collected: 1/11/2024 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-038

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401188-041

Sample Location: 1st Draw 4816 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 1/22/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-041

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 4816 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 1/22/2024 7:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401188-042

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401178-035

Sample Location: 1st Draw 50 Quincy PI NE

Customer Sample Number:

Date / Time Collected: 1/15/2024 1:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-035

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 50 Quincy PI NE

Customer Sample Number:

Date / Time Collected: 1/15/2024 1:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-036

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401178-047

Sample Location: 1st Draw 520 Oneida PI NW

Customer Sample Number:

Date / Time Collected: 1/14/2024 7:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-047

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 520 Oneida PI NW

Customer Sample Number:

Date / Time Collected: 1/14/2024 7:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-048

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401178-049

Sample Location: 1st Draw 624 Emerson St NW

Customer Sample Number:

Date / Time Collected: 1/12/2024 6:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-049

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 624 Emerson St NW

Customer Sample Number:

Date / Time Collected: 1/12/2024 6:33 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-050

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-Post-LSR- 2401178-043

Sample Location: 1st Draw 6501 3rd ST NW

Customer Sample Number:

Date / Time Collected: 1/10/2024 8:23 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-043

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 2nd Draw 6501 3rd ST NW

Customer Sample Number:

Date / Time Collected: 1/10/2024 8:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2401178-044

Date / Time Received: 1/23/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402118-051

Sample Location: 1st Draw 1508 Dumbarton Rock Ct NW

Customer Sample Number:

Date / Time Collected: 1/28/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-051

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 1508 Dumbarton Rock Ct NW

Customer Sample Number:

Date / Time Collected: 1/28/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-052

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402118-059

Sample Location: 1st Draw 1644 Newton St NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 9:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-059

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 1644 Newton St NW

Customer Sample Number:

Date / Time Collected: 1/21/2024 9:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-060

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402127-027

Sample Location: 1st Draw 217 Underwood St NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402127-027

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 217 Underwood St NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 6:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402127-028

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402125-013

Sample Location: 1st Draw 2405 North Capitol St NE

Customer Sample Number:

Date / Time Collected: 2/6/2024 7:01 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402125-013

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 2405 North Capitol St NE

Customer Sample Number:

Date / Time Collected: 2/6/2024 7:04 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402125-014

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402125-017

Sample Location: 1st Draw 2417 Observatory PI NW

Customer Sample Number:

Date / Time Collected: 2/8/2024 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402125-017

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 2417 Observatory PI NW

Customer Sample Number:

Date / Time Collected: 2/8/2024 8:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402125-018

Date / Time Received: 2/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402118-047

Sample Location: 1st Draw 2621 13th St NW

Customer Sample Number:

Date / Time Collected: 2/5/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-047

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 2621 13th St NW

Customer Sample Number:

Date / Time Collected: 2/5/2024 9:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-048

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402118-053

Sample Location: 1st Draw 3525 Alton PI NW

Customer Sample Number:

Date / Time Collected: 2/6/2024 2:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-053

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 3525 Alton PI NW

Customer Sample Number:

Date / Time Collected: 2/6/2024 2:47 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-054

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402127-029

Sample Location: 1st Draw 3812 T STREET NW

Customer Sample Number:

Date / Time Collected: 2/4/2024 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402127-029

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 3812 T STREET NW

Customer Sample Number:

Date / Time Collected: 2/4/2024 7:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402127-030

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402127-025

Sample Location: 1st Draw 3909 13th St. NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 7:59 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402127-025

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 3909 13th St. NW

Customer Sample Number:

Date / Time Collected: 2/11/2024 8:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402127-026

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402127-031

Sample Location: 1st Draw 4218 Jenifer St NW

Customer Sample Number:

Date / Time Collected: 2/13/2024 6:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402127-031

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 4218 Jenifer St NW

Customer Sample Number:

Date / Time Collected: 2/13/2024 6:28 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402127-032

Date / Time Received: 2/15/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402125-015

Sample Location: 1st Draw 4503 15th ST NW

Customer Sample Number:

Date / Time Collected: 1/25/2024 4:40 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402125-015

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 4503 15th ST NW

Customer Sample Number:

Date / Time Collected: 1/25/2024 4:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402125-016

Date / Time Received: 2/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402056-003

Sample Location: 1st Draw 503 Decatur St NW

Customer Sample Number:

Date / Time Collected: 1/26/2024 6:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402056-003

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 503 Decatur St NW

Customer Sample Number:

Date / Time Collected: 1/26/2024 6:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402056-004

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402056-001

Sample Location: 1st Draw 524 Decatur St NW

Customer Sample Number:

Date / Time Collected: 1/29/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402056-001

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 524 Decatur St NW

Customer Sample Number:

Date / Time Collected: 1/29/2024 9:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402056-002

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402118-049

Sample Location: 1st Draw 5401 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 8:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-049

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 5401 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 1/31/2024 8:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-050

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402118-045

Sample Location: 1st Draw 5403 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 2/6/2024 6:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-045

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 5403 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 2/6/2024 6:29 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-046

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402118-061

Sample Location: 1st Draw 609 Tuckerman St NW

Customer Sample Number:

Date / Time Collected: 1/30/2024 7:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-061

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 609 Tuckerman St NW

Customer Sample Number:

Date / Time Collected: 1/30/2024 7:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-062

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402118-055

Sample Location: 1st Draw 621 Tewkesbury PI NW

Customer Sample Number:

Date / Time Collected: 1/25/2024 6:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-055

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 621 Tewkesbury PI NW

Customer Sample Number:

Date / Time Collected: 1/25/2024 6:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-056

Date / Time Received: 2/13/2024 12:55:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402056-005

Sample Location: 1st Draw 6618 Harlan PI NW

Customer Sample Number:

Date / Time Collected: 1/14/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402056-005

Date / Time Received: 2/8/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	2/23/2024	SBrooks

Sample Location: 2nd Draw 6618 Harlan PI NW

Customer Sample Number:

Date / Time Collected: 1/14/2024 5:33 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402056-006

Date / Time Received: 2/8/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-Post-LSR- 2402118-057

Sample Location: 1st Draw 821 Madison St NW

Customer Sample Number:

Date / Time Collected: 1/30/2024 4:47 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-057

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/23/2024	SBrooks

Sample Location: 2nd Draw 821 Madison St NW

Customer Sample Number:

Date / Time Collected: 1/30/2024 4:49 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402118-058

Date / Time Received: 2/13/2024 12:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/13/2024

Report Number: L-DC-Post-LSR- 2403047-001

Sample Location: 1st Draw 812 C St. SE

Customer Sample Number:

Date / Time Collected: 12/8/2023 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403047-001

Date / Time Received: 2/29/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/11/2024	Rlamsal

Sample Location: 2nd Draw 812 C St. SE

Customer Sample Number:

Date / Time Collected: 12/8/2023 6:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403047-002

Date / Time Received: 2/29/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403006-003

Sample Location: 1st Draw 1121 S. Carolina Ave SE

Customer Sample Number:

Date / Time Collected: 2/17/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403006-003

Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 1121 S. Carolina Ave SE

Customer Sample Number:

Date / Time Collected: 2/17/2024 9:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403006-004

Date / Time Received: 3/1/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-029

Sample Location: 1st Draw 1403 Webster St NW

Customer Sample Number:

Date / Time Collected: 2/22/2024 8:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-029

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 1403 Webster St NW

Customer Sample Number:

Date / Time Collected: 2/22/2024 8:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-030

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-033

Sample Location: 1st Draw 1514 Webster St NW

Customer Sample Number:

Date / Time Collected: 2/28/2024 6:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-033

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 1514 Webster St NW

Customer Sample Number:

Date / Time Collected: 2/28/2024 6:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-034

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-025

Sample Location: 1st Draw 1742 D St NE

Customer Sample Number:

Date / Time Collected: 2/18/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-025

Date / Time Received: 3/7/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/20/2024	Rlamsal

Sample Location: 2nd Draw 1742 D St NE

Customer Sample Number:

Date / Time Collected: 2/18/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-026

Date / Time Received: 3/7/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-035

Sample Location: 1st Draw 2005 Kearny St NE

Customer Sample Number:

Date / Time Collected: 2/28/2024 5:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-035

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 2005 Kearny St NE

Customer Sample Number:

Date / Time Collected: 2/28/2024 5:33 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-036

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-039

Sample Location: 1st Draw 2211 38TH ST NW

Customer Sample Number:

Date / Time Collected: 2/24/2024 7:13 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-039

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 2211 38TH ST NW

Customer Sample Number:

Date / Time Collected: 2/24/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-040

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-031

Sample Location: 1st Draw 2224 38th St NW

Customer Sample Number:

Date / Time Collected: 2/24/2024 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-031

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 2224 38th St NW

Customer Sample Number:

Date / Time Collected: 2/24/2024 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-032

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2402183-029

Sample Location: 1st Draw 2420 Observatory PI NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 7:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-029

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 2420 Observatory PI NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 7:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-030

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2402183-031

Sample Location: 1st Draw 2828 28th St NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-031

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 2828 28th St NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-032

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2402183-027

Sample Location: 1st Draw 3722 T St. NW
Customer Sample Number:
Date / Time Collected: 2/18/2024 6:09 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2402183-027
Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 3722 T St. NW
Customer Sample Number:
Date / Time Collected: 2/18/2024 6:12 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2402183-028
Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-037

Sample Location: 1st Draw 3826 Beecher St NW

Customer Sample Number:

Date / Time Collected: 2/25/2024 6:47 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-037

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 3826 Beecher St NW

Customer Sample Number:

Date / Time Collected: 2/25/2024 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-038

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2402183-033

Sample Location: 1st Draw 3841 Beecher St NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 5:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-033

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 3841 Beecher St NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 5:23 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-034

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-023

Sample Location: 1st Draw 4604 4th St NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-023

Date / Time Received: 3/7/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	3/20/2024	Rlamsal

Sample Location: 2nd Draw 4604 4th St NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 7:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-024

Date / Time Received: 3/7/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2402183-025

Sample Location: 1st Draw 4621 5th ST NW

Customer Sample Number:

Date / Time Collected: 2/21/2024 8:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-025

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 4621 5th ST NW

Customer Sample Number:

Date / Time Collected: 2/21/2024 8:43 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-026

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2402183-021

Sample Location: 1st Draw 4624 5th St. NW

Customer Sample Number:

Date / Time Collected: 2/18/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-021

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 4624 5th St. NW

Customer Sample Number:

Date / Time Collected: 2/18/2024 7:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-022

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2402183-023

Sample Location: 1st Draw 4901 13th ST NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 8:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-023

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 4901 13th ST NW

Customer Sample Number:

Date / Time Collected: 2/20/2024 8:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2402183-024

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-041

Sample Location: 1st Draw 511 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 2/28/2024 6:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-041

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 511 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 2/28/2024 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-042

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-043

Sample Location: 1st Draw 6514 8th St NW

Customer Sample Number:

Date / Time Collected: 2/29/2024 7:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-043

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 6514 8th St NW

Customer Sample Number:

Date / Time Collected: 2/29/2024 7:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-044

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-Post-LSR- 2403063-027

Sample Location: 1st Draw 701 18th St NE

Customer Sample Number:

Date / Time Collected: 2/26/2024 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-027

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/20/2024	Rlamsal

Sample Location: 2nd Draw 701 18th St NE

Customer Sample Number:

Date / Time Collected: 2/26/2024 7:33 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403063-028

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	16.9	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403167-005

Sample Location: 1st Draw 110 4th St NE

Customer Sample Number:

Date / Time Collected: 3/6/2024 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403167-005

Date / Time Received: 3/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	3/29/2024	BPrakash

Sample Location: 2nd Draw 110 4th St NE

Customer Sample Number:

Date / Time Collected: 3/6/2024 6:59 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403167-006

Date / Time Received: 3/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403154-005

Sample Location: 1st Draw 1101 South Carolina Ave SE Units A/B

Customer Sample Number:

Date / Time Collected: 3/10/2024 7:49 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-005

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 1101 South Carolina Ave SE Units A/B

Customer Sample Number:

Date / Time Collected: 3/10/2024 7:51 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-006

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403189-023

Sample Location: 1st Draw 1271 Owen PI NE

Customer Sample Number:

Date / Time Collected: 3/8/2024 10:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403189-023

Date / Time Received: 3/25/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/2/2024	BPrakash

Sample Location: 2nd Draw 1271 Owen PI NE

Customer Sample Number:

Date / Time Collected: 3/8/2024 10:29 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403189-024

Date / Time Received: 3/25/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403154-011

Sample Location: 1st Draw 1317 D ST NE

Customer Sample Number:

Date / Time Collected: 3/4/2024 6:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-011

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 1317 D ST NE

Customer Sample Number:

Date / Time Collected: 3/4/2024 6:43 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-012

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403154-003

Sample Location: 1st Draw 1407 A St SE
Customer Sample Number:
Date / Time Collected: 3/11/2024 7:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2403154-003
Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 1407 A St SE
Customer Sample Number:
Date / Time Collected: 3/11/2024 7:35 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2403154-004
Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403154-001

Sample Location: 1st Draw 1704 Kilbourne PI NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 7:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-001

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 1704 Kilbourne PI NW

Customer Sample Number:

Date / Time Collected: 3/7/2024 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-002

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403189-035

Sample Location: 1st Draw 2326 39th St NW

Customer Sample Number:

Date / Time Collected: 3/10/2024 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403189-035

Date / Time Received: 3/25/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/2/2024	BPrakash

Sample Location: 2nd Draw 2326 39th St NW

Customer Sample Number:

Date / Time Collected: 3/10/2024 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403189-036

Date / Time Received: 3/25/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/2/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403154-009

Sample Location: 1st Draw 3528 Northampton St NW

Customer Sample Number:

Date / Time Collected: 3/2/2024 8:43 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-009

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Sample Location: 2nd Draw 3528 Northampton St NW

Customer Sample Number:

Date / Time Collected: 3/2/2024 8:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-010

Date / Time Received: 3/18/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403154-007

Sample Location: 1st Draw 3816 W St. NW

Customer Sample Number:

Date / Time Collected: 3/4/2024 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-007

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 3816 W St. NW

Customer Sample Number:

Date / Time Collected: 3/4/2024 6:57 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-008

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-Post-LSR- 2403154-013

Sample Location: 1st Draw 905 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 3/5/2024 4:04 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-013

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Sample Location: 2nd Draw 905 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 3/5/2024 4:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403154-014

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		3/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/11/2024

Report Number: L-DC-Post-LSR- 2403195-019

Sample Location: 1st Draw 2905 25TH ST NE

Customer Sample Number:

Date / Time Collected: 3/23/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403195-019

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/5/2024	Bprakash

Sample Location: 2nd Draw 2905 25TH ST NE

Customer Sample Number:

Date / Time Collected: 3/23/2024 7:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2403195-020

Date / Time Received: 3/27/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/5/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-009

Sample Location: 1st Draw 1303 Emerson ST NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-009

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1303 Emerson ST NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-010

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-021

Sample Location: 1st Draw 1330 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 2:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-021

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1330 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 2:26 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-022

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-003

Sample Location: 1st Draw 1410 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-003

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1410 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 8:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-004

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-027

Sample Location: 1st Draw 1426 Webster ST NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 8:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-027

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1426 Webster ST NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 8:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-028

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-017

Sample Location: 1st Draw 1432 Webster ST NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-017

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1432 Webster ST NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-018

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-015

Sample Location: 1st Draw 1707 D ST NE
Customer Sample Number:
Date / Time Collected: 3/29/2024 8:09 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404095-015
Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1707 D ST NE
Customer Sample Number:
Date / Time Collected: 3/29/2024 8:12 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404095-016
Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-007

Sample Location: 1st Draw 1815 Jackson St NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 5:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-007

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 1815 Jackson St NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 5:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-008

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-005

Sample Location: 1st Draw 213 13th ST SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 7:22 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-005

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 213 13th ST SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 7:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-006

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-019

Sample Location: 1st Draw 2315 33rd ST SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-019

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 2315 33rd ST SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 5:33 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-020

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-023

Sample Location: 1st Draw 2328 33rd ST SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 3:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-023

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 2328 33rd ST SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 3:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-024

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-025

Sample Location: 1st Draw 3302 24th St NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 6:23 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-025

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 3302 24th St NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 6:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-026

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-013

Sample Location: 1st Draw 3405 Holmead PI NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 6:59 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-013

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 3405 Holmead PI NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-014

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-001

Sample Location: 1st Draw 3813 W St NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-001

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 3813 W St NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-002

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-Post-LSR- 2404095-011

Sample Location: 1st Draw 727 Gresham PI NW

Customer Sample Number:

Date / Time Collected: 3/31/2024 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-011

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/17/2024	Lgallimore

Sample Location: 2nd Draw 727 Gresham PI NW

Customer Sample Number:

Date / Time Collected: 3/31/2024 8:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404095-012

Date / Time Received: 4/8/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-035

Sample Location: 1st Draw 1015 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-035

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1015 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-036

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-027

Sample Location: 1st Draw 1027 46th St NE

Customer Sample Number:

Date / Time Collected: 4/19/2024 4:29 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-027

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1027 46th St NE

Customer Sample Number:

Date / Time Collected: 4/19/2024 4:31 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-028

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-029

Sample Location: 1st Draw 1042 Argonne PI NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 7:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-029

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1042 Argonne PI NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-030

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404184-007

Sample Location: 1st Draw 1101 G St SE
Customer Sample Number:
Date / Time Collected: 4/7/2024 9:29 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404184-007
Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1101 G St SE
Customer Sample Number:
Date / Time Collected: 4/7/2024 9:29 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404184-008
Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-115

Sample Location: 1st Draw 1113 46th ST NE

Customer Sample Number:

Date / Time Collected: 4/13/2024 7:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-115

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1113 46th ST NE

Customer Sample Number:

Date / Time Collected: 4/13/2024 7:59 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-116

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404184-015

Sample Location: 1st Draw 1125 46th St NE

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-015

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1125 46th St NE

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-016

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-041

Sample Location: 1st Draw 1127 Allison ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-041

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1127 Allison ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-042

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-007

Sample Location: 1st Draw 120 Bryant Street NW

Customer Sample Number:

Date / Time Collected: 3/29/2024 6:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-007

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 120 Bryant Street NW

Customer Sample Number:

Date / Time Collected: 3/29/2024 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-008

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404184-013

Sample Location: 1st Draw 1217 Harvard St NW

Customer Sample Number:

Date / Time Collected: 4/9/2024 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-013

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1217 Harvard St NW

Customer Sample Number:

Date / Time Collected: 4/9/2024 8:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-014

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-007

Sample Location: 1st Draw 1273 OATES ST NE

Customer Sample Number:

Date / Time Collected: 4/19/2024 6:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-007

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1273 OATES ST NE

Customer Sample Number:

Date / Time Collected: 4/19/2024 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-008

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-027

Sample Location: 1st Draw 1304 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/5/2024 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-027

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1304 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/5/2024 6:37 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-028

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-023

Sample Location: 1st Draw 1308 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/6/2024 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-023

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1308 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/6/2024 8:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-024

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-013

Sample Location: 1st Draw 1326 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/2/2024 2:33 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-013

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1326 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/2/2024 2:34 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-014

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-077

Sample Location: 1st Draw 1340 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/12/2024 5:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-077

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1340 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/12/2024 5:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-078

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-101

Sample Location: 1st Draw 1359 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/16/2024 7:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-101

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1359 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/16/2024 7:13 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-102

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-091

Sample Location: 1st Draw 1363 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 7:29 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-091

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1363 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 7:33 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-092

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-113

Sample Location: 1st Draw 1369 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/10/2024 7:55 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-113

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1369 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/10/2024 7:56 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-114

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-097

Sample Location: 1st Draw 1371 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/13/2024 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-097

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1371 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/13/2024 6:49 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-098

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-065

Sample Location: 1st Draw 1375 Potomac Ave SE

Customer Sample Number:

Date / Time Collected: 4/15/2024 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-065

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1375 Potomac Ave SE

Customer Sample Number:

Date / Time Collected: 4/15/2024 8:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-066

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-105

Sample Location: 1st Draw 1377 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 3:08 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-105

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1377 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 3:12 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-106

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-063

Sample Location: 1st Draw 1391 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/12/2024 8:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-063

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1391 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/12/2024 8:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-064

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-111

Sample Location: 1st Draw 1397 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-111

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1397 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-112

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-051

Sample Location: 1st Draw 1403 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/14/2024 7:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-051

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1403 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/14/2024 7:04 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-052

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-005

Sample Location: 1st Draw 1403 Varnum St NW

Customer Sample Number:

Date / Time Collected: 4/4/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-005

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1403 Varnum St NW

Customer Sample Number:

Date / Time Collected: 4/4/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-006

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-021

Sample Location: 1st Draw 1407 Varnum St NW

Customer Sample Number:

Date / Time Collected: 4/8/2024 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-021

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1407 Varnum St NW

Customer Sample Number:

Date / Time Collected: 4/8/2024 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-022

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-071

Sample Location: 1st Draw 1411 Varnum ST NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 10:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-071

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1411 Varnum ST NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 10:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-072

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-019

Sample Location: 1st Draw 1414 Allison St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 7:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-019

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1414 Allison St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 7:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-020

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-019

Sample Location: 1st Draw 1416 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/23/2024 2:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-019

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1416 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/23/2024 2:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-020

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-003

Sample Location: 1st Draw 1417 Ives PL SE

Customer Sample Number:

Date / Time Collected: 3/31/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-003

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 1417 Ives PL SE

Customer Sample Number:

Date / Time Collected: 3/31/2024 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-004

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-017

Sample Location: 1st Draw 1418 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/3/2024 9:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-017

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1418 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 4/3/2024 9:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-018

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	12.4	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-001

Sample Location: 1st Draw 1418 Varnum St. NW

Customer Sample Number:

Date / Time Collected: 4/18/2024 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-001

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1418 Varnum St. NW

Customer Sample Number:

Date / Time Collected: 4/18/2024 6:43 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-002

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-041

Sample Location: 1st Draw 1419 Ives PI SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 8:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-041

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1419 Ives PI SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 8:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-042

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-025

Sample Location: 1st Draw 1419 West Virginia Ave NE

Customer Sample Number:

Date / Time Collected: 4/2/2024 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-025

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1419 West Virginia Ave NE

Customer Sample Number:

Date / Time Collected: 4/2/2024 6:44 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-026

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-017

Sample Location: 1st Draw 1420 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 3:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-017

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1420 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 3:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-018

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-059

Sample Location: 1st Draw 1421 Varnum ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 4:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-059

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1421 Varnum ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 4:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-060

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-005

Sample Location: 1st Draw 1427 Ives PL SE

Customer Sample Number:

Date / Time Collected: 4/17/2024 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-005

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1427 Ives PL SE

Customer Sample Number:

Date / Time Collected: 4/17/2024 7:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-006

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	29.6	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-011

Sample Location: 1st Draw 1429 Varnum St NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-011

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1429 Varnum St NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-012

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-009

Sample Location: 1st Draw 1430 Varnum St NW

Customer Sample Number:

Date / Time Collected: 3/29/2024 8:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-009

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 1430 Varnum St NW

Customer Sample Number:

Date / Time Collected: 3/29/2024 8:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-010

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-009

Sample Location: 1st Draw 1431 Ives PI SE

Customer Sample Number:

Date / Time Collected: 4/19/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-009

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1431 Ives PI SE

Customer Sample Number:

Date / Time Collected: 4/19/2024 7:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-010

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.5	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-043

Sample Location: 1st Draw 1507 West Virginia AVE NE

Customer Sample Number:

Date / Time Collected: 4/12/2024 8:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-043

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1507 West Virginia AVE NE

Customer Sample Number:

Date / Time Collected: 4/12/2024 8:29 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-044

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-017

Sample Location: 1st Draw 1516 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 5:14 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-017

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.2	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1516 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 5:17 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-018

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-023

Sample Location: 1st Draw 1519 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/8/2024 7:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-023

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1519 Webster St NW

Customer Sample Number:

Date / Time Collected: 4/8/2024 7:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-024

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-033

Sample Location: 1st Draw 1549 41st SE
Customer Sample Number:
Date / Time Collected: 4/1/2024 12:00 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404106-033
Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1549 41st SE
Customer Sample Number:
Date / Time Collected: 4/1/2024 12:04 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404106-034
Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-033

Sample Location: 1st Draw 1606 44TH St, NW

Customer Sample Number:

Date / Time Collected: 4/18/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-033

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1606 44TH St, NW

Customer Sample Number:

Date / Time Collected: 4/18/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-034

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-031

Sample Location: 1st Draw 1609 W Virginia Ave NE

Customer Sample Number:

Date / Time Collected: 4/3/2024 7:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-031

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1609 W Virginia Ave NE

Customer Sample Number:

Date / Time Collected: 4/3/2024 7:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-032

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.9	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-015

Sample Location: 1st Draw 1615 Massachusetts Ave SE

Customer Sample Number:

Date / Time Collected: 4/3/2024 6:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-015

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2	1590	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1615 Massachusetts Ave SE

Customer Sample Number:

Date / Time Collected: 4/3/2024 6:02 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-016

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	73.1	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-007

Sample Location: 1st Draw 1632 Nicholson St NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 6:02 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-007

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1632 Nicholson St NW

Customer Sample Number:

Date / Time Collected: 4/2/2024 6:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-008

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	14.7	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-045

Sample Location: 1st Draw 1634 Argonne PI NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 5:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-045

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1634 Argonne PI NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 5:10 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-046

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-061

Sample Location: 1st Draw 1700 D ST NE
Customer Sample Number:
Date / Time Collected: 4/15/2024 7:55 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404200-061
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1700 D ST NE
Customer Sample Number:
Date / Time Collected: 4/15/2024 8:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404200-062
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-021

Sample Location: 1st Draw 1712 D St NE
Customer Sample Number:
Date / Time Collected: 4/22/2024 6:41 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405018-021
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1712 D St NE
Customer Sample Number:
Date / Time Collected: 4/22/2024 6:43 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405018-022
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-035

Sample Location: 1st Draw 1730 D ST SE
Customer Sample Number:
Date / Time Collected: 4/21/2024 10:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405018-035
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1730 D ST SE
Customer Sample Number:
Date / Time Collected: 4/21/2024 10:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405018-036
Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-015

Sample Location: 1st Draw 1823 A Street SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-015

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 1823 A Street SE

Customer Sample Number:

Date / Time Collected: 4/2/2024 9:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-016

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-087

Sample Location: 1st Draw 1862 California ST NW #1

Customer Sample Number:

Date / Time Collected: 4/14/2024 5:36 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-087

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1862 California ST NW #1

Customer Sample Number:

Date / Time Collected: 4/14/2024 5:42 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-088

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-075

Sample Location: 1st Draw 1869 California ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 1:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-075

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 1869 California ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 1:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-076

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-029

Sample Location: 1st Draw 207 Douglas St NE

Customer Sample Number:

Date / Time Collected: 4/1/2024 8:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-029

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 207 Douglas St NE

Customer Sample Number:

Date / Time Collected: 4/1/2024 8:47 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-030

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-039

Sample Location: 1st Draw 219 Douglas St NE

Customer Sample Number:

Date / Time Collected: 3/28/2024 2:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-039

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 219 Douglas St NE

Customer Sample Number:

Date / Time Collected: 3/28/2024 2:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-040

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-073

Sample Location: 1st Draw 2211 Otis ST NE

Customer Sample Number:

Date / Time Collected: 4/12/2024 5:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-073

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 2211 Otis ST NE

Customer Sample Number:

Date / Time Collected: 4/12/2024 5:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-074

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-033

Sample Location: 1st Draw 2212 38th St NW

Customer Sample Number:

Date / Time Collected: 4/5/2024 5:58 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-033

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 2212 38th St NW

Customer Sample Number:

Date / Time Collected: 4/5/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-034

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-055

Sample Location: 1st Draw 2215 Kearney ST NE

Customer Sample Number:

Date / Time Collected: 4/12/2024 8:09 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-055

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 2215 Kearney ST NE

Customer Sample Number:

Date / Time Collected: 4/12/2024 8:14 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-056

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-103

Sample Location: 1st Draw 2218 38th St NW

Customer Sample Number:

Date / Time Collected: 4/13/2024 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-103

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 2218 38th St NW

Customer Sample Number:

Date / Time Collected: 4/13/2024 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-104

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404184-001

Sample Location: 1st Draw 2228 Kearny St NE

Customer Sample Number:

Date / Time Collected: 4/10/2024 5:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-001

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 2228 Kearny St NE

Customer Sample Number:

Date / Time Collected: 4/10/2024 5:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-002

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-049

Sample Location: 1st Draw 2230 Kearny St NE

Customer Sample Number:

Date / Time Collected: 4/9/2024 9:12 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-049

Date / Time Received: 4/24/2024 8:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	5/3/2024	SBrooks

Sample Location: 2nd Draw 2230 Kearny St NE

Customer Sample Number:

Date / Time Collected: 4/9/2024 9:16 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-050

Date / Time Received: 4/24/2024 8:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-043

Sample Location: 1st Draw 2316 39th ST NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 8:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-043

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 2316 39th ST NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 8:11 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-044

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-025

Sample Location: 1st Draw 2328 39th ST NW

Customer Sample Number:

Date / Time Collected: 4/19/2024 6:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-025

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 2328 39th ST NW

Customer Sample Number:

Date / Time Collected: 4/19/2024 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-026

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-067

Sample Location: 1st Draw 2414 Lawrence ST NE

Customer Sample Number:

Date / Time Collected: 4/17/2024 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-067

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 2414 Lawrence ST NE

Customer Sample Number:

Date / Time Collected: 4/17/2024 7:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-068

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404184-017

Sample Location: 1st Draw 2909 Otis St NE

Customer Sample Number:

Date / Time Collected: 4/11/2024 7:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-017

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 2909 Otis St NE

Customer Sample Number:

Date / Time Collected: 4/11/2024 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-018

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-021

Sample Location: 1st Draw 2914 25th St NE

Customer Sample Number:

Date / Time Collected: 4/7/2024 9:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-021

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 2914 25th St NE

Customer Sample Number:

Date / Time Collected: 4/7/2024 9:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-022

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-023

Sample Location: 1st Draw 304 12th ST NE

Customer Sample Number:

Date / Time Collected: 4/19/2024 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-023

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 304 12th ST NE

Customer Sample Number:

Date / Time Collected: 4/19/2024 6:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-024

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-015

Sample Location: 1st Draw 3421 24th St NE

Customer Sample Number:

Date / Time Collected: 4/19/2024 5:44 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-015

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3421 24th St NE

Customer Sample Number:

Date / Time Collected: 4/19/2024 5:48 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-016

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404184-009

Sample Location: 1st Draw 3504 24th St NE

Customer Sample Number:

Date / Time Collected: 4/8/2024 6:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-009

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 3504 24th St NE

Customer Sample Number:

Date / Time Collected: 4/8/2024 6:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-010

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-039

Sample Location: 1st Draw 3712 T ST NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-039

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3712 T ST NW

Customer Sample Number:

Date / Time Collected: 4/15/2024 8:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-040

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-003

Sample Location: 1st Draw 3731 T ST NW

Customer Sample Number:

Date / Time Collected: 4/18/2024 6:33 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-003

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3731 T ST NW

Customer Sample Number:

Date / Time Collected: 4/18/2024 6:39 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-004

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-083

Sample Location: 1st Draw 3766 W ST
Customer Sample Number:
Date / Time Collected: 4/14/2024 8:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404200-083
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3766 W ST
Customer Sample Number:
Date / Time Collected: 4/14/2024 8:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404200-084
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-037

Sample Location: 1st Draw 38 CHANNING ST NW

Customer Sample Number:

Date / Time Collected: 4/4/2024 8:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-037

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 38 CHANNING ST NW

Customer Sample Number:

Date / Time Collected: 4/4/2024 8:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-038

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-037

Sample Location: 1st Draw 3800 W ST NW

Customer Sample Number:

Date / Time Collected: 4/19/2024 7:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-037

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3800 W ST NW

Customer Sample Number:

Date / Time Collected: 4/19/2024 7:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-038

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-107

Sample Location: 1st Draw 3802 W ST NW
Customer Sample Number:
Date / Time Collected: 4/11/2024 6:11 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404200-107
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3802 W ST NW
Customer Sample Number:
Date / Time Collected: 4/11/2024 6:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404200-108
Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-031

Sample Location: 1st Draw 3805 Benton ST NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 2:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-031

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3805 Benton ST NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 2:35 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-032

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-081

Sample Location: 1st Draw 3811 Benton ST NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 8:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-081

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3811 Benton ST NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 8:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-082

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-037

Sample Location: 1st Draw 3832 Beecher St NW

Customer Sample Number:

Date / Time Collected: 4/5/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-037

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 3832 Beecher St NW

Customer Sample Number:

Date / Time Collected: 4/5/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-038

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-099

Sample Location: 1st Draw 3833 Beecher ST NW

Customer Sample Number:

Date / Time Collected: 4/10/2024 7:50 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-099

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3833 Beecher ST NW

Customer Sample Number:

Date / Time Collected: 4/10/2024 7:50 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-100

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-009

Sample Location: 1st Draw 3843 Becher St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 5:40 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-009

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 3843 Becher St NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 5:43 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-010

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-045

Sample Location: 1st Draw 3847 Beecher ST NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-045

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3847 Beecher ST NW

Customer Sample Number:

Date / Time Collected: 4/23/2024 6:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-046

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-005

Sample Location: 1st Draw 3848 Beecher St NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-005

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 3848 Beecher St NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 6:33 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-006

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-079

Sample Location: 1st Draw 3853 Beecher St NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 6:43 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-079

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3853 Beecher St NW

Customer Sample Number:

Date / Time Collected: 4/17/2024 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-080

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-085

Sample Location: 1st Draw 3863 Beecher St. NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 2:21 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-085

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3863 Beecher St. NW

Customer Sample Number:

Date / Time Collected: 4/11/2024 2:22 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-086

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-069

Sample Location: 1st Draw 3902 21st ST

Customer Sample Number:

Date / Time Collected: 4/11/2024 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-069

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 3902 21st ST

Customer Sample Number:

Date / Time Collected: 4/13/2024 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-070

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404184-003

Sample Location: 1st Draw 4224 37th St., NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 5:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-003

Date / Time Received: 4/16/2024 9:05:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. Results are considered biased low.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 4224 37th St., NW

Customer Sample Number:

Date / Time Collected: 1/8/2024 5:37 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-004

Date / Time Received: 4/16/2024 9:05:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. Results are considered biased low.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-001

Sample Location: 1st Draw 4515 5th ST NW

Customer Sample Number:

Date / Time Collected: 4/4/2024 6:04 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-001

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 4515 5th ST NW

Customer Sample Number:

Date / Time Collected: 4/4/2024 6:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-002

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-029

Sample Location: 1st Draw 4517 Arkansas Ave NW

Customer Sample Number:

Date / Time Collected: 4/22/2024 6:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-029

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 4517 Arkansas Ave NW

Customer Sample Number:

Date / Time Collected: 4/22/2024 6:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-030

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-109

Sample Location: 1st Draw 4603 13th ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 5:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-109

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 4603 13th ST NW

Customer Sample Number:

Date / Time Collected: 4/14/2024 5:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-110

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-011

Sample Location: 1st Draw 4618 4th St NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-011

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 4618 4th St NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-012

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-117

Sample Location: 1st Draw 5011 Ayers PI SE

Customer Sample Number:

Date / Time Collected: 4/15/2024 6:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-117

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 5011 Ayers PI SE

Customer Sample Number:

Date / Time Collected: 4/15/2024 6:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-118

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-089

Sample Location: 1st Draw 5027 Central Ave

Customer Sample Number:

Date / Time Collected: 4/15/2024 2:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-089

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	33.9	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 5027 Central Ave

Customer Sample Number:

Date / Time Collected: 4/15/2024 2:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-090

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-041

Sample Location: 1st Draw 533 11th St. SE

Customer Sample Number:

Date / Time Collected: 4/23/2024 8:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-041

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 533 11th St. SE

Customer Sample Number:

Date / Time Collected: 4/23/2024 8:20 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-042

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-035

Sample Location: 1st Draw 5403 13th NW

Customer Sample Number:

Date / Time Collected: 4/6/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-035

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 5403 13th NW

Customer Sample Number:

Date / Time Collected: 4/6/2024 6:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-036

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404184-011

Sample Location: 1st Draw 541 11 St SE
Customer Sample Number:
Date / Time Collected: 4/4/2024 9:00 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404184-011
Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	220	ug/L		5/2/2024	SBrooks

Sample Location: 2nd Draw 541 11 St SE
Customer Sample Number:
Date / Time Collected: 4/4/2024 9:15 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404184-012
Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	38.0	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-095

Sample Location: 1st Draw 5700 1st ST NW

Customer Sample Number:

Date / Time Collected: 4/12/2024 4:44 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-095

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 5700 1st ST NW

Customer Sample Number:

Date / Time Collected: 4/12/2024 4:48 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-096

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-003

Sample Location: 1st Draw 5702 Colorado Ave NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-003

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 5702 Colorado Ave NW

Customer Sample Number:

Date / Time Collected: 4/3/2024 7:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-004

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-011

Sample Location: 1st Draw 5711 Colorado Ave. NW
Customer Sample Number:
Date / Time Collected: 4/3/2024 7:03 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404160-011
Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 5711 Colorado Ave. NW
Customer Sample Number:
Date / Time Collected: 4/3/2024 7:05 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2404160-012
Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-043

Sample Location: 1st Draw 5927 Clay St. NE

Customer Sample Number:

Date / Time Collected: 3/27/2024 9:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-043

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 5927 Clay St. NE

Customer Sample Number:

Date / Time Collected: 3/27/2024 9:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-044

Date / Time Received: 4/12/2024 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-027

Sample Location: 1st Draw 6204 Utah Ave NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 8:24 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-027

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 6204 Utah Ave NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 8:27 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-028

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-093

Sample Location: 1st Draw 708 Adrian ST SE

Customer Sample Number:

Date / Time Collected: 4/14/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-093

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 708 Adrian ST SE

Customer Sample Number:

Date / Time Collected: 4/14/2024 6:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-094

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-053

Sample Location: 1st Draw 716 15th St SE

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-053

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 716 15th St SE

Customer Sample Number:

Date / Time Collected: 4/11/2024 6:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-054

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-019

Sample Location: 1st Draw 733 18th St NE

Customer Sample Number:

Date / Time Collected: 4/7/2024 2:35 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-019

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 733 18th St NE

Customer Sample Number:

Date / Time Collected: 4/7/2024 2:39 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-020

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-001

Sample Location: 1st Draw 781 19th St NE

Customer Sample Number:

Date / Time Collected: 4/2/2024 5:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-001

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 781 19th St NE

Customer Sample Number:

Date / Time Collected: 4/2/2024 5:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-002

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2405018-013

Sample Location: 1st Draw 830 Varnum ST NW

Customer Sample Number:

Date / Time Collected: 4/16/2024 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-013

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 830 Varnum ST NW

Customer Sample Number:

Date / Time Collected: 4/16/2024 8:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405018-014

Date / Time Received: 4/25/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404184-005

Sample Location: 1st Draw 834 50th PI NE

Customer Sample Number:

Date / Time Collected: 4/8/2024 1:22 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-005

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 834 50th PI NE

Customer Sample Number:

Date / Time Collected: 4/8/2024 1:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404184-006

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-013

Sample Location: 1st Draw 909 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 10:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-013

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 909 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 4/1/2024 10:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-014

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404160-031

Sample Location: 1st Draw 910 Massachusettes Ave NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-031

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	4/26/2024	SBrooks

Sample Location: 2nd Draw 910 Massachusettes Ave NE

Customer Sample Number:

Date / Time Collected: 3/31/2024 6:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404160-032

Date / Time Received: 4/15/2024 9:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404106-025

Sample Location: 1st Draw 923 Decatur St NW

Customer Sample Number:

Date / Time Collected: 3/31/2024 7:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-025

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2nd Draw 923 Decatur St NW

Customer Sample Number:

Date / Time Collected: 3/31/2024 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404106-026

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-Post-LSR- 2404200-057

Sample Location: 1st Draw 936 14th ST SE

Customer Sample Number:

Date / Time Collected: 4/13/2024 7:02 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-057

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		5/3/2024	SBrooks

Sample Location: 2nd Draw 936 14th ST SE

Customer Sample Number:

Date / Time Collected: 4/13/2024 7:07 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2404200-058

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405071-013

Sample Location: 1st Draw 1045 47th St NE

Customer Sample Number:

Date / Time Collected: 4/29/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-013

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.6	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1045 47th St NE

Customer Sample Number:

Date / Time Collected: 4/29/2024 9:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-014

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-085

Sample Location: 1st Draw 124 V St. NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-085

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 124 V St. NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-086

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-031

Sample Location: 1st Draw 1311 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 5/2/2024 6:39 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-031

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1311 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 5/2/2024 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-032

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-005

Sample Location: 1st Draw 1316 Randolph St. NE

Customer Sample Number:

Date / Time Collected: 4/18/2024 4:37 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-005

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1316 Randolph St. NE

Customer Sample Number:

Date / Time Collected: 4/18/2024 4:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-006

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-045

Sample Location: 1st Draw 1353 Sheridan St NW

Customer Sample Number:

Date / Time Collected: 5/1/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-045

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1353 Sheridan St NW

Customer Sample Number:

Date / Time Collected: 5/1/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-046

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-075

Sample Location: 1st Draw 1360 Meridian PL NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 6:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-075

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1360 Meridian PL NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 6:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-076

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-045

Sample Location: 1st Draw 1379 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-045

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1379 Sheridan ST NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-046

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-027

Sample Location: 1st Draw 1414 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 5/1/2024 9:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-027

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1414 Trinidad Ave NE

Customer Sample Number:

Date / Time Collected: 5/1/2024 9:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-028

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-017

Sample Location: 1st Draw 1429 West VA Ave. NE

Customer Sample Number:

Date / Time Collected: 4/22/2024 6:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-017

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1429 West VA Ave. NE

Customer Sample Number:

Date / Time Collected: 4/22/2024 6:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-018

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-011

Sample Location: 1st Draw 1437 Northgate Rd NW

Customer Sample Number:

Date / Time Collected: 4/20/2024 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-011

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1437 Northgate Rd NW

Customer Sample Number:

Date / Time Collected: 4/20/2024 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-012

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-039

Sample Location: 1st Draw 1516 44th St NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 5:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-039

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1516 44th St NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 5:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-040

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-051

Sample Location: 1st Draw 1624 Argonne PI NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 10:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-051

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1624 Argonne PI NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 10:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-052

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-081

Sample Location: 1st Draw 1738 Allison St NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 8:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-081

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1738 Allison St NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 8:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-082

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-069

Sample Location: 1st Draw 1825 W St. SE
Customer Sample Number:
Date / Time Collected: 4/28/2024 10:23 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405027-069
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 1825 W St. SE
Customer Sample Number:
Date / Time Collected: 4/28/2024 10:25 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405027-070
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-003

Sample Location: 1st Draw 1871 California St. NW #1

Customer Sample Number:

Date / Time Collected: 4/16/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-003

Date / Time Received: 5/2/2024 9:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	5/14/2024	Rlamsal

Sample Location: 2nd Draw 1871 California St. NW #1

Customer Sample Number:

Date / Time Collected: 4/16/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-004

Date / Time Received: 5/2/2024 9:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-059

Sample Location: 1st Draw 2027 Allen Pl. NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-059

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2027 Allen Pl. NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 7:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-060

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-023

Sample Location: 1st Draw 2220 Kearny St NE

Customer Sample Number:

Date / Time Collected: 4/24/2024 9:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-023

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2220 Kearny St NE

Customer Sample Number:

Date / Time Collected: 4/24/2024 9:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-024

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-061

Sample Location: 1st Draw 2417 Huidekoper PI NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 7:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-061

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2417 Huidekoper PI NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 7:11 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-062

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-053

Sample Location: 1st Draw 2826 27th Street NW

Customer Sample Number:

Date / Time Collected: 5/1/2024 6:51 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-053

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2826 27th Street NW

Customer Sample Number:

Date / Time Collected: 5/1/2024 6:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-054

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-029

Sample Location: 1st Draw 2901 Otis St NE

Customer Sample Number:

Date / Time Collected: 5/1/2024 9:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-029

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2901 Otis St NE

Customer Sample Number:

Date / Time Collected: 5/1/2024 9:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-030

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-077

Sample Location: 1st Draw 2949 Newark St NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-077

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 2949 Newark St NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-078

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-083

Sample Location: 1st Draw 3049 Foxhall Road NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-083

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3049 Foxhall Road NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 8:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-084

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-009

Sample Location: 1st Draw 31 W St. NW
Customer Sample Number:
Date / Time Collected: 4/29/2024 7:54 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405027-009
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 31 W St. NW
Customer Sample Number:
Date / Time Collected: 4/29/2024 7:56 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405027-010
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-089

Sample Location: 1st Draw 3103 11th St NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 7:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-089

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3103 11th St NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 7:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-090

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-047

Sample Location: 1st Draw 325 5th St SE
Customer Sample Number:
Date / Time Collected: 5/5/2024 8:40 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405076-047
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 325 5th St SE
Customer Sample Number:
Date / Time Collected: 5/5/2024 8:43 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405076-048
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-079

Sample Location: 1st Draw 3330 Alden PL NE

Customer Sample Number:

Date / Time Collected: 4/29/2024 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-079

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3330 Alden PL NE

Customer Sample Number:

Date / Time Collected: 4/29/2024 7:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-080

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405071-017

Sample Location: 1st Draw 3356 Runnymede PL NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-017

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3356 Runnymede PL NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-018

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405071-007

Sample Location: 1st Draw 3423 South Dakota Ave NE

Customer Sample Number:

Date / Time Collected: 4/24/2024 5:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-007

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3423 South Dakota Ave NE

Customer Sample Number:

Date / Time Collected: 4/24/2024 5:10 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-008

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-057

Sample Location: 1st Draw 3508 36TH ST NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-057

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3508 36TH ST NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 6:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-058

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405071-015

Sample Location: 1st Draw 3533 Hertford PI NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 5:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-015

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3533 Hertford PI NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 5:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-016

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-037

Sample Location: 1st Draw 3731 W St NW

Customer Sample Number:

Date / Time Collected: 4/25/2024 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-037

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3731 W St NW

Customer Sample Number:

Date / Time Collected: 4/25/2024 8:34 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-038

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-053

Sample Location: 1st Draw 3812 W St. NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 3:43 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-053

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3812 W St. NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 3:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-054

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-043

Sample Location: 1st Draw 3826 W St NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-043

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3826 W St NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-044

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-067

Sample Location: 1st Draw 3839 Beecher St. NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 9:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-067

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 3839 Beecher St. NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 9:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-068

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/6/2024

Report revised on 6/6/24 by MC.
Lab Sample Number 2405027-049, the result of "ND" was
changed to "60.1", the analysis date of "5/14/2024" was
changed to "6/4/2024", and the analyst was changed from
"Rlamsal" to "SBrooks".

Report Number: L-DC-Post-LSR- 2405027-049

Sample Location: 1st Draw 3902 Jocelyn St. NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 8:04 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-049

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	60.1	ug/L		6/4/2024	SBrooks

Sample Location: 2nd Draw 3902 Jocelyn St. NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 8:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-050

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-063

Sample Location: 1st Draw 4111 13th Place NE

Customer Sample Number:

Date / Time Collected: 4/28/2024 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-063

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 4111 13th Place NE

Customer Sample Number:

Date / Time Collected: 4/28/2024 7:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-064

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-065

Sample Location: 1st Draw 4217 39th St. NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 7:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-065

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 4217 39th St. NW

Customer Sample Number:

Date / Time Collected: 4/28/2024 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-066

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-039

Sample Location: 1st Draw 4424 Greenwich Pkwy, NW

Customer Sample Number:

Date / Time Collected: 4/26/2024 8:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-039

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 4424 Greenwich Pkwy, NW

Customer Sample Number:

Date / Time Collected: 4/26/2024 8:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-040

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-049

Sample Location: 1st Draw 48 Channing St. NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 7:11 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-049

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 48 Channing St. NW

Customer Sample Number:

Date / Time Collected: 4/29/2024 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-050

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-087

Sample Location: 1st Draw 5009 A St. SE
Customer Sample Number:
Date / Time Collected: 4/30/2024 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405027-087
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 5009 A St. SE
Customer Sample Number:
Date / Time Collected: 4/30/2024 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405027-088
Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-033

Sample Location: 1st Draw 515 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 2:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-033

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 515 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 5/6/2024 2:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-034

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-051

Sample Location: 1st Draw 517 KENYON ST NW

Customer Sample Number:

Date / Time Collected: 5/1/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-051

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 517 KENYON ST NW

Customer Sample Number:

Date / Time Collected: 5/1/2024 7:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-052

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405027-047

Sample Location: 1st Draw 5329 Reno Rd NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 7:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-047

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 5329 Reno Rd NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 7:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405027-048

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-037

Sample Location: 1st Draw 5600 Colorado Ave NW

Customer Sample Number:

Date / Time Collected: 5/4/2024 4:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-037

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 5600 Colorado Ave NW

Customer Sample Number:

Date / Time Collected: 5/4/2024 4:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-038

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-041

Sample Location: 1st Draw 645 Lexington PI NE

Customer Sample Number:

Date / Time Collected: 5/4/2024 9:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-041

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 645 Lexington PI NE

Customer Sample Number:

Date / Time Collected: 5/4/2024 9:11 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405076-042

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405071-009

Sample Location: 1st Draw 716 Adrian St SE

Customer Sample Number:

Date / Time Collected: 4/12/2024 7:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-009

Date / Time Received: 5/8/2024 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/14/2024	Rlamsal

Sample Location: 2nd Draw 716 Adrian St SE

Customer Sample Number:

Date / Time Collected: 4/12/2024 7:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-010

Date / Time Received: 5/8/2024 8:10:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405071-011

Sample Location: 1st Draw 743 Irving St NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-011

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 743 Irving St NW

Customer Sample Number:

Date / Time Collected: 4/30/2024 8:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405071-012

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-Post-LSR- 2405076-035

Sample Location: 1st Draw 87 V St NW
Customer Sample Number:
Date / Time Collected: 5/3/2024 6:12 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405076-035
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Sample Location: 2nd Draw 87 V St NW
Customer Sample Number:
Date / Time Collected: 5/3/2024 6:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405076-036
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-035

Sample Location: 1st Draw 1322 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 5/10/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-035

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1322 Emerson St. NW

Customer Sample Number:

Date / Time Collected: 5/10/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-036

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-043

Sample Location: 1st Draw 1336 31st St. NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 3:23 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-043

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1336 31st St. NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 3:27 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-044

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-027

Sample Location: 1st Draw 1345 Valley Place SE

Customer Sample Number:

Date / Time Collected: 5/8/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-027

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1345 Valley Place SE

Customer Sample Number:

Date / Time Collected: 5/8/2024 6:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-028

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-028

Sample Location: 1st Draw 1349 Montague St. NW

Customer Sample Number:

Date / Time Collected: 5/18/2024 5:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-028

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1349 Montague St. NW

Customer Sample Number:

Date / Time Collected: 5/18/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-029

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-023

Sample Location: 1st Draw 1358 Quincy St. NW

Customer Sample Number:

Date / Time Collected: 5/7/2024 5:25 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-023

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1358 Quincy St. NW

Customer Sample Number:

Date / Time Collected: 5/7/2024 5:26 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-024

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-024

Sample Location: 1st Draw 1403 Montague St. NW

Customer Sample Number:

Date / Time Collected: 5/16/2024 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-024

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1403 Montague St. NW

Customer Sample Number:

Date / Time Collected: 5/16/2024 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-025

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-029

Sample Location: 1st Draw 1430 Parkwood PI NW

Customer Sample Number:

Date / Time Collected: 5/20/2024 6:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-029

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1430 Parkwood PI NW

Customer Sample Number:

Date / Time Collected: 5/20/2024 6:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-030

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405130-007

Sample Location: 1st Draw 1433 Ives PI SE

Customer Sample Number:

Date / Time Collected: 4/30/2024 8:44 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-007

Date / Time Received: 5/17/2024 9:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	5/29/2024	Bprakash

Sample Location: 2nd Draw 1433 Ives PI SE

Customer Sample Number:

Date / Time Collected: 4/30/2024 8:47 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-008

Date / Time Received: 5/17/2024 9:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	16.2	ug/L	H	5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405130-003

Sample Location: 1st Draw 1435 Ives Place SE

Customer Sample Number:

Date / Time Collected: 5/6/2024 10:04 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-003

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1435 Ives Place SE

Customer Sample Number:

Date / Time Collected: 5/6/2024 10:04 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-004

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-039

Sample Location: 1st Draw 1614 T Street NW

Customer Sample Number:

Date / Time Collected: 5/11/2024 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-039

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1614 T Street NW

Customer Sample Number:

Date / Time Collected: 5/11/2024 7:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-040

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-033

Sample Location: 1st Draw 1617 A ST SE

Customer Sample Number:

Date / Time Collected: 5/21/2024 5:04 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-033

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1617 A ST SE

Customer Sample Number:

Date / Time Collected: 5/21/2024 5:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-034

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-006

Sample Location: 1st Draw 1650 Argonne PL NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 10:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-006

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1650 Argonne PL NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 10:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-007

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-017

Sample Location: 1st Draw 1701 D ST NE
Customer Sample Number:
Date / Time Collected: 5/12/2024 8:05 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405201-017
Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1701 D ST NE
Customer Sample Number:
Date / Time Collected: 5/12/2024 8:07 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405201-018
Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-001

Sample Location: 1st Draw 1702 D ST NE
Customer Sample Number:
Date / Time Collected: 5/7/2024 5:15 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405119-001
Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 1702 D ST NE
Customer Sample Number:
Date / Time Collected: 5/7/2024 5:17 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405119-002
Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405130-009

Sample Location: 1st Draw 1805 Kenyon St NW

Customer Sample Number:

Date / Time Collected: 5/1/2024 6:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-009

Date / Time Received: 5/17/2024 9:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L	H	5/29/2024	Bprakash

Sample Location: 2nd Draw 1805 Kenyon St NW

Customer Sample Number:

Date / Time Collected: 5/1/2024 6:13 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-010

Date / Time Received: 5/17/2024 9:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-043

Sample Location: 1st Draw 1834 Belmont RD NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-043

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1834 Belmont RD NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-044

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-037

Sample Location: 1st Draw 1847 California St NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-037

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 1847 California St NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 6:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-038

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-041

Sample Location: 1st Draw 2022 Jackson ST NE

Customer Sample Number:

Date / Time Collected: 5/20/2024 3:40 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-041

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 2022 Jackson ST NE

Customer Sample Number:

Date / Time Collected: 5/20/2024 3:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-042

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-023

Sample Location: 1st Draw 2031 Rosemont Ave NW

Customer Sample Number:

Date / Time Collected: 5/17/2024 6:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-023

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 2031 Rosemont Ave NW

Customer Sample Number:

Date / Time Collected: 5/17/2024 6:58 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-024

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-030

Sample Location: 1st Draw 2215 38th St. NW

Customer Sample Number:

Date / Time Collected: 5/18/2024 12:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-030

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 2215 38th St. NW

Customer Sample Number:

Date / Time Collected: 5/18/2024 12:05 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-031

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-039

Sample Location: 1st Draw 2215 39th ST NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-039

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 2215 39th ST NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-040

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-031

Sample Location: 1st Draw 226 Cromwell Ter NE

Customer Sample Number:

Date / Time Collected: 5/13/2024 7:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-031

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 226 Cromwell Ter NE

Customer Sample Number:

Date / Time Collected: 5/13/2024 7:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-032

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-013

Sample Location: 1st Draw 2301 39th St. NW

Customer Sample Number:

Date / Time Collected: 5/13/2024 6:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-013

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 2301 39th St. NW

Customer Sample Number:

Date / Time Collected: 5/13/2024 6:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-014

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-021

Sample Location: 1st Draw 2413 Observatory PL NW

Customer Sample Number:

Date / Time Collected: 5/5/2024 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-021

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 2413 Observatory PL NW

Customer Sample Number:

Date / Time Collected: 5/5/2024 6:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-022

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-023

Sample Location: 1st Draw 2418 Unit 8 Lenfant SQ SE

Customer Sample Number:

Date / Time Collected: 5/15/2024 7:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-023

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 2418 Unit 8 Lenfant SQ SE

Customer Sample Number:

Date / Time Collected: 5/15/2024 7:19 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-024

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-019

Sample Location: 1st Draw 2509 P ST NW

Customer Sample Number:

Date / Time Collected: 5/20/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-019

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 2509 P ST NW

Customer Sample Number:

Date / Time Collected: 5/20/2024 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-020

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-011

Sample Location: 1st Draw 2515 17th ST NE

Customer Sample Number:

Date / Time Collected: 5/16/2024 8:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-011

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 2515 17th ST NE

Customer Sample Number:

Date / Time Collected: 5/16/2024 8:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-012

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-007

Sample Location: 1st Draw 2632 10th St NE

Customer Sample Number:

Date / Time Collected: 5/9/2024 7:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-007

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 2632 10th St NE

Customer Sample Number:

Date / Time Collected: 5/9/2024 7:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-008

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-035

Sample Location: 1st Draw 2916 12TH ST NE

Customer Sample Number:

Date / Time Collected: 5/20/2024 3:37 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-035

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 2916 12TH ST NE

Customer Sample Number:

Date / Time Collected: 5/20/2024 3:42 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-036

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-001

Sample Location: 1st Draw 3015 25th St NE

Customer Sample Number:

Date / Time Collected: 5/5/2024 8:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-001

Date / Time Received: 5/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/29/2024	Bprakash

Sample Location: 2nd Draw 3015 25th St NE

Customer Sample Number:

Date / Time Collected: 5/5/2024 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-002

Date / Time Received: 5/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-021

Sample Location: 1st Draw 304 A ST SE
Customer Sample Number:
Date / Time Collected: 5/19/2024 5:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405201-021
Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 304 A ST SE
Customer Sample Number:
Date / Time Collected: 5/19/2024 5:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2405201-022
Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-021

Sample Location: 1st Draw 3116 W ST SE

Customer Sample Number:

Date / Time Collected: 5/20/2024 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-021

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 3116 W ST SE

Customer Sample Number:

Date / Time Collected: 5/20/2024 8:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-022

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-013

Sample Location: 1st Draw 3215 1/2 Sherman Ave NW

Customer Sample Number:

Date / Time Collected: 5/15/2024 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-013

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 3215 1/2 Sherman Ave NW

Customer Sample Number:

Date / Time Collected: 5/15/2024 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-014

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-025

Sample Location: 1st Draw 3318 Ames St NE

Customer Sample Number:

Date / Time Collected: 5/8/2024 5:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-025

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 3318 Ames St NE

Customer Sample Number:

Date / Time Collected: 5/8/2024 5:43 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-026

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405130-011

Sample Location: 1st Draw 3348 Brothers PI SE

Customer Sample Number:

Date / Time Collected: 5/11/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-011

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.2	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 3348 Brothers PI SE

Customer Sample Number:

Date / Time Collected: 5/11/2024 6:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-012

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-018

Sample Location: 1st Draw 3714 T St. NW

Customer Sample Number:

Date / Time Collected: 5/15/2024 6:36 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-018

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 3714 T St. NW

Customer Sample Number:

Date / Time Collected: 5/15/2024 6:37 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-019

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-019

Sample Location: 1st Draw 3737 Jocelyn St NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 8:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-019

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 3737 Jocelyn St NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 8:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-020

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-049

Sample Location: 1st Draw 3738 Benton St. NW

Customer Sample Number:

Date / Time Collected: 5/13/2024 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-049

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 3738 Benton St. NW

Customer Sample Number:

Date / Time Collected: 5/13/2024 8:39 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-050

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-047

Sample Location: 1st Draw 3740 Benton St. NW

Customer Sample Number:

Date / Time Collected: 5/13/2024 7:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-047

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 3740 Benton St. NW

Customer Sample Number:

Date / Time Collected: 5/13/2024 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-048

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-029

Sample Location: 1st Draw 3762 Benton St. NW

Customer Sample Number:

Date / Time Collected: 5/8/2024 6:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-029

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 3762 Benton St. NW

Customer Sample Number:

Date / Time Collected: 5/8/2024 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-030

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-015

Sample Location: 1st Draw 3824 Beecher St. NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-015

Date / Time Received: 5/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	5/29/2024	Bprakash

Sample Location: 2nd Draw 3824 Beecher St. NW

Customer Sample Number:

Date / Time Collected: 4/27/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-016

Date / Time Received: 5/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-037

Sample Location: 1st Draw 3849 Beecher St NW

Customer Sample Number:

Date / Time Collected: 5/10/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-037

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 3849 Beecher St NW

Customer Sample Number:

Date / Time Collected: 5/10/2024 7:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-038

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-025

Sample Location: 1st Draw 3937 Livingston ST NW

Customer Sample Number:

Date / Time Collected: 5/21/2024 6:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-025

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 3937 Livingston ST NW

Customer Sample Number:

Date / Time Collected: 5/21/2024 6:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-026

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-025

Sample Location: 1st Draw 410 10th ST SE

Customer Sample Number:

Date / Time Collected: 5/15/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-025

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 410 10th ST SE

Customer Sample Number:

Date / Time Collected: 5/15/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-026

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-027

Sample Location: 1st Draw 4107 13th PI NE

Customer Sample Number:

Date / Time Collected: 5/17/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-027

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 4107 13th PI NE

Customer Sample Number:

Date / Time Collected: 5/17/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-028

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-010

Sample Location: 1st Draw 414 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 5/14/2024 12:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-010

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 414 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 5/15/2024 12:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-011

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-041

Sample Location: 1st Draw 433 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 7:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-041

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	24.6	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 433 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 7:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-042

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.8	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-032

Sample Location: 1st Draw 446 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 6:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-032

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 446 Buchanan St. NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 6:34 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-033

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-012

Sample Location: 1st Draw 4507 Arkansas Ave NW

Customer Sample Number:

Date / Time Collected: 5/15/2024 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-012

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 4507 Arkansas Ave NW

Customer Sample Number:

Date / Time Collected: 5/15/2024 6:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-013

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-026

Sample Location: 1st Draw 4516 13th St. NW

Customer Sample Number:

Date / Time Collected: 5/17/2024 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-026

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 4516 13th St. NW

Customer Sample Number:

Date / Time Collected: 5/17/2024 6:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-027

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-033

Sample Location: 1st Draw 507 Decatur St. NW

Customer Sample Number:

Date / Time Collected: 5/10/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-033

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 507 Decatur St. NW

Customer Sample Number:

Date / Time Collected: 5/10/2024 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-034

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-031

Sample Location: 1st Draw 515 Rittenhouse ST NW

Customer Sample Number:

Date / Time Collected: 5/17/2024 3:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-031

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 515 Rittenhouse ST NW

Customer Sample Number:

Date / Time Collected: 5/17/2024 3:50 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-032

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-009

Sample Location: 1st Draw 5316 5th St. NW

Customer Sample Number:

Date / Time Collected: 5/11/2024 8:33 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-009

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 5316 5th St. NW

Customer Sample Number:

Date / Time Collected: 5/11/2024 8:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-010

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-029

Sample Location: 1st Draw 5322 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-029

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 5322 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 6:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-030

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405199-027

Sample Location: 1st Draw 5329 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 8:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-027

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 5329 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 8:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-028

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-031

Sample Location: 1st Draw 601 Rittenhouse St. NW

Customer Sample Number:

Date / Time Collected: 5/9/2024 6:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-031

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 601 Rittenhouse St. NW

Customer Sample Number:

Date / Time Collected: 5/9/2024 6:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-032

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405201-015

Sample Location: 1st Draw 6216 9th ST NW

Customer Sample Number:

Date / Time Collected: 5/17/2024 2:13 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-015

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		5/31/2024	Bprakash

Sample Location: 2nd Draw 6216 9th ST NW

Customer Sample Number:

Date / Time Collected: 5/17/2024 2:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405201-016

Date / Time Received: 5/22/2024 12:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		5/31/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-020

Sample Location: 1st Draw 708 15th St. SE

Customer Sample Number:

Date / Time Collected: 5/15/2024 7:50 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-020

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 708 15th St. SE

Customer Sample Number:

Date / Time Collected: 5/15/2024 7:52 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-021

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405130-013

Sample Location: 1st Draw 710 15TH ST SE

Customer Sample Number:

Date / Time Collected: 5/13/2024 5:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-013

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 710 15TH ST SE

Customer Sample Number:

Date / Time Collected: 5/13/2024 5:51 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-014

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-014

Sample Location: 1st Draw 721 15th St SE

Customer Sample Number:

Date / Time Collected: 5/15/2024 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-014

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 721 15th St SE

Customer Sample Number:

Date / Time Collected: 5/15/2024 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-015

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405130-005

Sample Location: 1st Draw 724 1/2 11th St SE

Customer Sample Number:

Date / Time Collected: 5/5/2024 5:08 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-005

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 724 1/2 11th St SE

Customer Sample Number:

Date / Time Collected: 5/5/2024 5:09 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405130-006

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405158-003

Sample Location: 1st Draw 739 18th St NE

Customer Sample Number:

Date / Time Collected: 5/14/2024 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405158-003

Date / Time Received: 5/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-Post-LSR- 2405119-045

Sample Location: 1st Draw 7607 13th St NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 6:35 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-045

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/29/2024	Bprakash

Sample Location: 2nd Draw 7607 13th St NW

Customer Sample Number:

Date / Time Collected: 5/12/2024 6:40 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405119-046

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/18/2024

Report Number: L-DC-Post-LSR- 2405199-045

Sample Location: 1st Draw 720 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 7:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-045

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/11/2024	Bprakash

Sample Location: 2nd Draw 720 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 5/19/2024 7:22 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2405199-046

Date / Time Received: 5/24/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/11/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Customer Collected Profiles

DC Water operates a program when customers request a lead sampling kit without knowledge of their service line material. The profile kit comes with ten bottles and instructions on how to collect samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: LT-DC-CCPF-2401187

Sample Location: 1 1414 Buchanan St NW
Date Collected: 1/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401187-001
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.4	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.3	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Sample Location: 2 1414 Buchanan St NW
Date Collected: 1/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401187-002
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.0	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.2	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Sample Location: 3 1414 Buchanan St NW
Date Collected: 1/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401187-003
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	45.4	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.6	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.4	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 1414 Buchanan St NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2401187-004		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.3	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.4	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.3	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Sample Location: 5 1414 Buchanan St NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2401187-005		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.2	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.4	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.3	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Sample Location: 6 1414 Buchanan St NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2401187-006		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.6	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.1	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.3	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Sample Location: 7 1414 Buchanan St NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2401187-007		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.5	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.8	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.2	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Sample Location: 8 1414 Buchanan St NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2401187-008		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.4	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.9	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.3	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 1414 Buchanan St NW
Date Collected: 1/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401187-009
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.4	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.7	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Sample Location: 10 1414 Buchanan St NW
Date Collected: 1/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401187-010
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	88.5	ug/L		2/1/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		2/1/2024	Bprakash
Manganese	EPA 200.8		0.2	1.8	ug/L		2/1/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/1/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: LT-DC-CCPF-2402060

Sample Location: 1 2214 Tunlaw Rd NW
Date Collected: 2/4/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402060-001
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.8	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2 2214 Tunlaw Rd NW
Date Collected: 2/4/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402060-002
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.2	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 3 2214 Tunlaw Rd NW
Date Collected: 2/4/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402060-003
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 2214 Tunlaw Rd NW						Customer Program Code: CCPF		
Date Collected: 2/4/2024						Laboratory Sample Number: 2402060-004		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.6	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 5 2214 Tunlaw Rd NW						Customer Program Code: CCPF		
Date Collected: 2/4/2024						Laboratory Sample Number: 2402060-005		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.0	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 6 2214 Tunlaw Rd NW						Customer Program Code: CCPF		
Date Collected: 2/4/2024						Laboratory Sample Number: 2402060-006		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.2	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	3.0	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 7 2214 Tunlaw Rd NW						Customer Program Code: CCPF		
Date Collected: 2/4/2024						Laboratory Sample Number: 2402060-007		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.4	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 8 2214 Tunlaw Rd NW						Customer Program Code: CCPF		
Date Collected: 2/4/2024						Laboratory Sample Number: 2402060-008		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.7	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 2214 Tunlaw Rd NW
Date Collected: 2/4/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402060-009
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.5	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	2.0	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 10 2214 Tunlaw Rd NW
Date Collected: 2/4/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402060-010
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.2	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: LT-DC-CCPF-2402061

Sample Location: 1 926 11th St. NW
Date Collected: 2/2/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402061-001
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	291	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.9	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2 926 11th St. NW
Date Collected: 2/2/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402061-002
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	292	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.8	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 3 926 11th St. NW
Date Collected: 2/2/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402061-003
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	295	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.7	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 926 11th St. NW						Customer Program Code: CCPF		
Date Collected: 2/2/2024						Laboratory Sample Number: 2402061-004		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	295	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.8	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 5 926 11th St. NW						Customer Program Code: CCPF		
Date Collected: 2/2/2024						Laboratory Sample Number: 2402061-005		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	283	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.7	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 6 926 11th St. NW						Customer Program Code: CCPF		
Date Collected: 2/2/2024						Laboratory Sample Number: 2402061-006		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	285	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.7	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 7 926 11th St. NW						Customer Program Code: CCPF		
Date Collected: 2/2/2024						Laboratory Sample Number: 2402061-007		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	291	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.7	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 8 926 11th St. NW						Customer Program Code: CCPF		
Date Collected: 2/2/2024						Laboratory Sample Number: 2402061-008		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	285	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.7	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 926 11th St. NW
Date Collected: 2/2/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402061-009
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	294	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.7	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 10 926 11th St. NW
Date Collected: 2/2/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402061-010
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	290	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	5.8	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: LT-DC-CCPF-2402062

Sample Location: 1 1415 S ST NW

Date Collected: 1/18/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2402062-001

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 2 1415 S ST NW

Date Collected: 1/18/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2402062-002

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 3 1415 S ST NW

Date Collected: 1/18/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2402062-003

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 1415 S ST NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2402062-004		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 5 1415 S ST NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2402062-005		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 6 1415 S ST NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2402062-006		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 7 1415 S ST NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2402062-007		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 8 1415 S ST NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2402062-008		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 1415 S ST NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2402062-009		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Sample Location: 10 1415 S ST NW						Customer Program Code: CCPF		
Date Collected: 1/18/2024						Laboratory Sample Number: 2402062-010		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L	H	2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: LT-DC-CCPF-2402063

Sample Location: 1 1305 G ST NE
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402063-001
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2 1305 G ST NE
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402063-002
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 3 1305 G ST NE
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402063-003
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Sample Location: 4 1305 G ST NE						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402063-004		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 5 1305 G ST NE						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402063-005		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 6 1305 G ST NE						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402063-006		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 7 1305 G ST NE						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402063-007		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 8 1305 G ST NE						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402063-008		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 1305 G ST NE
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402063-009
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 10 1305 G ST NE
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402063-010
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: LT-DC-CCPF-2402064

Sample Location: 1 1331 Park Rd. NW
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402064-001
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 2 1331 Park Rd. NW
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402064-002
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 3 1331 Park Rd. NW
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402064-003
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 1331 Park Rd. NW						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402064-004		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 5 1331 Park Rd. NW						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402064-005		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	0.4	ug/L		2/23/2024	SBrooks
Sample Location: 6 1331 Park Rd. NW						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402064-006		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 7 1331 Park Rd. NW						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402064-007		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks
Sample Location: 8 1331 Park Rd. NW						Customer Program Code: CCPF		
Date Collected: 2/1/2024						Laboratory Sample Number: 2402064-008		
						Date / Time Received: 2/8/2024 9:40:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 1331 Park Rd. NW
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402064-009
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 10 1331 Park Rd. NW
Date Collected: 2/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2402064-010
Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/23/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/23/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		2/23/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/7/2024

Report Number: LT-DC-CCPF-2401167

Sample Location: 1 4320 Kansas Ave NW

Date Collected: 12/24/2023

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2401167-001

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	138	ug/L	H	2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	5.2	ug/L	H	2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	18.6	ug/L	H	2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/9/2024	Bprakash

Sample Location: 2 4320 Kansas Ave NW

Date Collected: 12/24/2023

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2401167-002

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	136	ug/L	H	2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	6.7	ug/L	H	2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	17.1	ug/L	H	2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/9/2024	Bprakash

Sample Location: 3 4320 Kansas Ave NW

Date Collected: 12/24/2023

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2401167-003

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	175	ug/L	H	2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	7.9	ug/L	H	2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	18.9	ug/L	H	2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 4320 Kansas Ave NW						Customer Program Code: CCPF		
Date Collected: 12/24/2023						Laboratory Sample Number: 2401167-004		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	202	ug/L	H	2/1/2024	BPrakash
Lead	EPA 200.8	15	0.2	6.5	ug/L	H	2/1/2024	BPrakash
Manganese	EPA 200.8		0.2	19.3	ug/L	H	2/1/2024	BPrakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/1/2024	BPrakash

Sample Location: 5 4320 Kansas Ave NW						Customer Program Code: CCPF		
Date Collected: 12/24/2023						Laboratory Sample Number: 2401167-005		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	209	ug/L	H	2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	6.6	ug/L	H	2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	20.0	ug/L	H	2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/9/2024	Bprakash

Sample Location: 6 4320 Kansas Ave NW						Customer Program Code: CCPF		
Date Collected: 12/24/2023						Laboratory Sample Number: 2401167-006		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	207	ug/L	H	2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	4.2	ug/L	H	2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	20.1	ug/L	H	2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/9/2024	Bprakash

Sample Location: 7 4320 Kansas Ave NW						Customer Program Code: CCPF		
Date Collected: 12/24/2023						Laboratory Sample Number: 2401167-007		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	195	ug/L	H	2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	4.6	ug/L	H	2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	20.0	ug/L	H	2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/9/2024	Bprakash

Sample Location: 8 4320 Kansas Ave NW						Customer Program Code: CCPF		
Date Collected: 12/24/2023						Laboratory Sample Number: 2401167-008		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	198	ug/L	H	2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	3.6	ug/L	H	2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	20.0	ug/L	H	2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 4320 Kansas Ave NW						Customer Program Code: CCPF		
Date Collected: 12/24/2023						Laboratory Sample Number: 2401167-009		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	230	ug/L	H	2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	20.3	ug/L	H	2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/9/2024	Bprakash

Sample Location: 10 4320 Kansas Ave NW						Customer Program Code: CCPF		
Date Collected: 12/24/2023						Laboratory Sample Number: 2401167-010		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	225	ug/L	H	2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	20.2	ug/L	H	2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/7/2024

Report Number: LT-DC-CCPF-2401168

Sample Location: 1 1503 C ST SE
Date Collected: 1/9/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401168-001
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	79.6	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.0	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 2 1503 C ST SE
Date Collected: 1/9/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401168-002
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	83.6	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.7	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 3 1503 C ST SE
Date Collected: 1/9/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401168-003
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	186	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	2.0	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 1503 C ST SE						Customer Program Code: CCPF		
Date Collected: 1/9/2024						Laboratory Sample Number: 2401168-004		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	111	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	4.0	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	1.0	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 5 1503 C ST SE						Customer Program Code: CCPF		
Date Collected: 1/9/2024						Laboratory Sample Number: 2401168-005		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	74.5	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	4.4	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	1.1	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 6 1503 C ST SE						Customer Program Code: CCPF		
Date Collected: 1/9/2024						Laboratory Sample Number: 2401168-006		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	76.1	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	4.1	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	1.2	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 7 1503 C ST SE						Customer Program Code: CCPF		
Date Collected: 1/9/2024						Laboratory Sample Number: 2401168-007		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	73.8	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 8 1503 C ST SE						Customer Program Code: CCPF		
Date Collected: 1/9/2024						Laboratory Sample Number: 2401168-008		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	74.8	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 1503 C ST SE
Date Collected: 1/9/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401168-009
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	73.2	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 10 1503 C ST SE
Date Collected: 1/9/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401168-010
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	67.1	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/7/2024

Report Number: LT-DC-CCPF-2401169

Sample Location: 1 1614 New Jersey Ave NW
Date Collected: 1/10/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401169-001
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.2	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 2 1614 New Jersey Ave NW
Date Collected: 1/10/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401169-002
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.2	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 3 1614 New Jersey Ave NW
Date Collected: 1/10/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401169-003
Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.2	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Sample Location: 4 1614 New Jersey Ave NW						Customer Program Code: CCPF		
Date Collected: 1/10/2024						Laboratory Sample Number: 2401169-004		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.8	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.3	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 5 1614 New Jersey Ave NW						Customer Program Code: CCPF		
Date Collected: 1/10/2024						Laboratory Sample Number: 2401169-005		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.3	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 6 1614 New Jersey Ave NW						Customer Program Code: CCPF		
Date Collected: 1/10/2024						Laboratory Sample Number: 2401169-006		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.8	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.3	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 7 1614 New Jersey Ave NW						Customer Program Code: CCPF		
Date Collected: 1/10/2024						Laboratory Sample Number: 2401169-007		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.3	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 8 1614 New Jersey Ave NW						Customer Program Code: CCPF		
Date Collected: 1/10/2024						Laboratory Sample Number: 2401169-008		
						Date / Time Received: 1/18/2024 9:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.3	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 1614 New Jersey Ave NW

Date Collected: 1/10/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2401169-009

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	1.0	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 10 1614 New Jersey Ave NW

Date Collected: 1/10/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2401169-010

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.2	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.3	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/7/2024

Report Number: LT-DC-CCPF-2401186

Sample Location: 1 334 E ST NE
Date Collected: 1/16/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401186-001
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	2.8	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	1.0	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	0.2	ug/L		2/9/2024	Bprakash

Sample Location: 2 334 E ST NE
Date Collected: 1/16/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401186-002
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.6	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	1.3	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 3 334 E ST NE
Date Collected: 1/16/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2401186-003
Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Sample Location: 4 334 E ST NE						Customer Program Code: CCPF		
Date Collected: 1/16/2024						Laboratory Sample Number: 2401186-004		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash
Sample Location: 5 334 E ST NE						Customer Program Code: CCPF		
Date Collected: 1/16/2024						Laboratory Sample Number: 2401186-005		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.8	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	0.9	ug/L		2/9/2024	Bprakash
Sample Location: 6 334 E ST NE						Customer Program Code: CCPF		
Date Collected: 1/16/2024						Laboratory Sample Number: 2401186-006		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash
Sample Location: 7 334 E ST NE						Customer Program Code: CCPF		
Date Collected: 1/16/2024						Laboratory Sample Number: 2401186-007		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash
Sample Location: 8 334 E ST NE						Customer Program Code: CCPF		
Date Collected: 1/16/2024						Laboratory Sample Number: 2401186-008		
						Date / Time Received: 1/26/2024 8:30:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.3	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 334 E ST NE

Date Collected: 1/16/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2401186-009

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Sample Location: 10 334 E ST NE

Date Collected: 1/16/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2401186-010

Date / Time Received: 1/26/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.7	ug/L		2/9/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		2/9/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		2/9/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		2/9/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/15/2024

Report Number: LT-DC-CCPF-2403050

Sample Location: 1 1835 Burke St. SE
Date Collected: 2/25/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403050-001
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 2 1835 Burke St. SE
Date Collected: 2/25/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403050-002
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 3 1835 Burke St. SE
Date Collected: 2/25/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403050-003
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	0.9	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 1835 Burke St. SE						Customer Program Code: CCPF		
Date Collected: 2/25/2024						Laboratory Sample Number: 2403050-004		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 5 1835 Burke St. SE						Customer Program Code: CCPF		
Date Collected: 2/25/2024						Laboratory Sample Number: 2403050-005		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 6 1835 Burke St. SE						Customer Program Code: CCPF		
Date Collected: 2/25/2024						Laboratory Sample Number: 2403050-006		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.2	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 7 1835 Burke St. SE						Customer Program Code: CCPF		
Date Collected: 2/25/2024						Laboratory Sample Number: 2403050-007		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 8 1835 Burke St. SE						Customer Program Code: CCPF		
Date Collected: 2/25/2024						Laboratory Sample Number: 2403050-008		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 1835 Burke St. SE						Customer Program Code: CCPF		
Date Collected: 2/25/2024						Laboratory Sample Number: 2403050-009		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 10 1835 Burke St. SE						Customer Program Code: CCPF		
Date Collected: 2/25/2024						Laboratory Sample Number: 2403050-010		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/15/2024

Report Number: LT-DC-CCPF-2403051

Sample Location: 1 1224 29th St NW
Date Collected: 2/20/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403051-001
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.5	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 2 1224 29th St NW
Date Collected: 2/20/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403051-002
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.9	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 3 1224 29th St NW
Date Collected: 2/20/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403051-003
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 1224 29th St NW						Customer Program Code: CCPF		
Date Collected: 2/20/2024						Laboratory Sample Number: 2403051-004		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.0	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.9	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 5 1224 29th St NW						Customer Program Code: CCPF		
Date Collected: 2/20/2024						Laboratory Sample Number: 2403051-005		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.4	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 6 1224 29th St NW						Customer Program Code: CCPF		
Date Collected: 2/20/2024						Laboratory Sample Number: 2403051-006		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.8	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 7 1224 29th St NW						Customer Program Code: CCPF		
Date Collected: 2/20/2024						Laboratory Sample Number: 2403051-007		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.6	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 8 1224 29th St NW						Customer Program Code: CCPF		
Date Collected: 2/20/2024						Laboratory Sample Number: 2403051-008		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.6	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.2	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 1224 29th St NW						Customer Program Code: CCPF		
Date Collected: 2/20/2024						Laboratory Sample Number: 2403051-009		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.9	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 10 1224 29th St NW						Customer Program Code: CCPF		
Date Collected: 2/20/2024						Laboratory Sample Number: 2403051-010		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.4	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/15/2024

Report Number: LT-DC-CCPF-2403052

Sample Location: 1 3600 Porter St NW

Date Collected: 2/9/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2403052-001

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.8	ug/L	H	3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L	H	3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	3/11/2024	Rlamsal

Sample Location: 2 3600 Porter St NW

Date Collected: 2/9/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2403052-002

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	84.8	ug/L	H	3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.1	ug/L	H	3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	3/11/2024	Rlamsal

Sample Location: 3 3600 Porter St NW

Date Collected: 2/9/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2403052-003

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	138	ug/L	H	3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.9	ug/L	H	3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 3600 Porter St NW						Customer Program Code: CCPF		
Date Collected: 2/9/2024						Laboratory Sample Number: 2403052-004		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	82.6	ug/L	H	3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	2.5	ug/L	H	3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L	H	3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	0.2	ug/L	H	3/11/2024	Rlamsal

Sample Location: 5 3600 Porter St NW						Customer Program Code: CCPF		
Date Collected: 2/9/2024						Laboratory Sample Number: 2403052-005		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.2	ug/L	H	3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	2.8	ug/L	H	3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L	H	3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	3/11/2024	Rlamsal

Sample Location: 6 3600 Porter St NW						Customer Program Code: CCPF		
Date Collected: 2/9/2024						Laboratory Sample Number: 2403052-006		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.8	ug/L	H	3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L	H	3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	3/11/2024	Rlamsal

Sample Location: 7 3600 Porter St NW						Customer Program Code: CCPF		
Date Collected: 2/9/2024						Laboratory Sample Number: 2403052-007		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L	H	3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	0.2	ug/L	H	3/11/2024	Rlamsal

Sample Location: 8 3600 Porter St NW						Customer Program Code: CCPF		
Date Collected: 2/9/2024						Laboratory Sample Number: 2403052-008		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L	H	3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 3600 Porter St NW						Customer Program Code: CCPF			
Date Collected: 2/9/2024						Laboratory Sample Number: 2403052-009			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/29/2024 9:20:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	3/11/2024	Rlamsal	
Lead	EPA 200.8	15	0.2	1.8	ug/L	H	3/11/2024	Rlamsal	
Manganese	EPA 200.8		0.2	0.8	ug/L	H	3/11/2024	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	3/11/2024	Rlamsal	

Sample Location: 10 3600 Porter St NW						Customer Program Code: CCPF			
Date Collected: 2/9/2024						Laboratory Sample Number: 2403052-010			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 2/29/2024 9:20:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	3/11/2024	Rlamsal	
Lead	EPA 200.8	15	0.2	1.8	ug/L	H	3/11/2024	Rlamsal	
Manganese	EPA 200.8		0.2	0.9	ug/L	H	3/11/2024	Rlamsal	
Tin	EPA 200.8		0.2	0.2	ug/L	H	3/11/2024	Rlamsal	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/15/2024

Report Number: LT-DC-CCPF-2403053

Sample Location: 1 4818 Nebraska Ave NW
Date Collected: 2/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403053-001
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	171	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 2 4818 Nebraska Ave NW
Date Collected: 2/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403053-002
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	73.7	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.2	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 3 4818 Nebraska Ave NW
Date Collected: 2/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403053-003
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	88.3	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	2.2	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 4818 Nebraska Ave NW	Customer Program Code: CCPF
Date Collected: 2/18/2024	Laboratory Sample Number: 2403053-004
	Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	205	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	3.1	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 5 4818 Nebraska Ave NW	Customer Program Code: CCPF
Date Collected: 2/18/2024	Laboratory Sample Number: 2403053-005
	Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	229	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	3.5	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 6 4818 Nebraska Ave NW	Customer Program Code: CCPF
Date Collected: 2/18/2024	Laboratory Sample Number: 2403053-006
	Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	239	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	4.0	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 7 4818 Nebraska Ave NW	Customer Program Code: CCPF
Date Collected: 2/18/2024	Laboratory Sample Number: 2403053-007
	Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	371	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	5.3	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 8 4818 Nebraska Ave NW	Customer Program Code: CCPF
Date Collected: 2/18/2024	Laboratory Sample Number: 2403053-008
Sample is diluted to 2X and analyzed at 3/11/2024 11:06.	Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		20	535	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	6.8	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	6.0	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 4818 Nebraska Ave NW
Date Collected: 2/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403053-009
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	426	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	5.9	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	1.4	ug/L		3/11/2024	Rlamsal

Sample Location: 10 4818 Nebraska Ave NW
Date Collected: 2/18/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403053-010
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	361	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	6.3	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	1.1	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/15/2024

Report Number: LT-DC-CCPF-2403054

Sample Location: 1 3282 Aberfoyle PI NW
Date Collected: 2/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403054-001
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	166	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.2	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 2 3282 Aberfoyle PI NW
Date Collected: 2/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403054-002
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	154	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.1	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 3 3282 Aberfoyle PI NW
Date Collected: 2/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403054-003
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	158	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 3282 Aberfoyle PI NW						Customer Program Code: CCPF		
Date Collected: 2/21/2024						Laboratory Sample Number: 2403054-004		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	157	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 5 3282 Aberfoyle PI NW						Customer Program Code: CCPF		
Date Collected: 2/21/2024						Laboratory Sample Number: 2403054-005		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	145	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 6 3282 Aberfoyle PI NW						Customer Program Code: CCPF		
Date Collected: 2/21/2024						Laboratory Sample Number: 2403054-006		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	154	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 7 3282 Aberfoyle PI NW						Customer Program Code: CCPF		
Date Collected: 2/21/2024						Laboratory Sample Number: 2403054-007		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	145	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.3	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 8 3282 Aberfoyle PI NW						Customer Program Code: CCPF		
Date Collected: 2/21/2024						Laboratory Sample Number: 2403054-008		
						Date / Time Received: 2/29/2024 9:20:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	151	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.4	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 3282 Aberfoyle PI NW
Date Collected: 2/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403054-009
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	149	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	1.4	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Sample Location: 10 3282 Aberfoyle PI NW
Date Collected: 2/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403054-010
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	163	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	3.1	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/15/2024

Report Number: LT-DC-CCPF-2403055

Sample Location: 1 2815 Woodley Rd NW
Date Collected: 2/26/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403055-001
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.7	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	0.2	3.4	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	4.5	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	0.6	ug/L		3/11/2024	Rlamsal

Sample Location: 2 2815 Woodley Rd NW
Date Collected: 2/26/2024
Sample is diluted to 5X.

Customer Program Code: CCPF
Laboratory Sample Number: 2403055-002
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	539	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	1	3.4	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	16.1	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	4.4	ug/L		3/11/2024	Rlamsal

Sample Location: 3 2815 Woodley Rd NW
Date Collected: 2/26/2024
Sample is diluted to 5X.

Customer Program Code: CCPF
Laboratory Sample Number: 2403055-003
Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	1160	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	1	5.0	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	39.3	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	5.8	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 2815 Woodley Rd NW Date Collected: 2/26/2024 Sample is diluted to 5X.	Customer Program Code: CCPF Laboratory Sample Number: 2403055-004 Date / Time Received: 2/29/2024 9:20:00 AM
--	---

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	1280	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	1	6.6	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	46.3	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	6.5	ug/L		3/11/2024	Rlamsal

Sample Location: 5 2815 Woodley Rd NW Date Collected: 2/26/2024 Sample is diluted to 5X.	Customer Program Code: CCPF Laboratory Sample Number: 2403055-005 Date / Time Received: 2/29/2024 9:20:00 AM
--	---

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	748	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	1	10.9	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	21.2	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	12.4	ug/L		3/11/2024	Rlamsal

Sample Location: 6 2815 Woodley Rd NW Date Collected: 2/26/2024 Sample is diluted to 5X.	Customer Program Code: CCPF Laboratory Sample Number: 2403055-006 Date / Time Received: 2/29/2024 9:20:00 AM
--	---

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	473	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	1	9.2	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	12.0	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	8.9	ug/L		3/11/2024	Rlamsal

Sample Location: 7 2815 Woodley Rd NW Date Collected: 2/26/2024 Sample is diluted to 5X.	Customer Program Code: CCPF Laboratory Sample Number: 2403055-007 Date / Time Received: 2/29/2024 9:20:00 AM
--	---

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	512	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	1	5.5	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	12.7	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	2.3	ug/L		3/11/2024	Rlamsal

Sample Location: 8 2815 Woodley Rd NW Date Collected: 2/26/2024 Sample is diluted to 5X.	Customer Program Code: CCPF Laboratory Sample Number: 2403055-008 Date / Time Received: 2/29/2024 9:20:00 AM
--	---

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	566	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	1	5.6	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	14.0	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	0.8	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 2815 Woodley Rd NW

Date Collected: 2/26/2024

Sample is diluted to 5X.

Customer Program Code: CCPF

Laboratory Sample Number: 2403055-009

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	552	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	1	5.0	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	13.6	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	1.2	ug/L		3/11/2024	Rlamsal

Sample Location: 10 2815 Woodley Rd NW

Date Collected: 2/26/2024

Sample is diluted to 5X.

Customer Program Code: CCPF

Laboratory Sample Number: 2403055-010

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	621	ug/L		3/11/2024	Rlamsal
Lead	EPA 200.8	15	1	7.0	ug/L		3/11/2024	Rlamsal
Manganese	EPA 200.8		0.2	12.7	ug/L		3/11/2024	Rlamsal
Tin	EPA 200.8		0.2	3.4	ug/L		3/11/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: LT-DC-CCPF-2403159

Sample Location: 1 4125 8th St NW
Date Collected: 3/10/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403159-001
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.7	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 2 4125 8th St NW
Date Collected: 3/10/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403159-002
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.7	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	1.2	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 3 4125 8th St NW
Date Collected: 3/10/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403159-003
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	52.8	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	1.5	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Sample Location: 4 4125 8th St NW						Customer Program Code: CCPF		
Date Collected: 3/10/2024						Laboratory Sample Number: 2403159-004		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.9	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	1.3	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 5 4125 8th St NW						Customer Program Code: CCPF		
Date Collected: 3/10/2024						Laboratory Sample Number: 2403159-005		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.4	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	1.0	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 6 4125 8th St NW						Customer Program Code: CCPF		
Date Collected: 3/10/2024						Laboratory Sample Number: 2403159-006		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.7	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 7 4125 8th St NW						Customer Program Code: CCPF		
Date Collected: 3/10/2024						Laboratory Sample Number: 2403159-007		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.6	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 8 4125 8th St NW						Customer Program Code: CCPF		
Date Collected: 3/10/2024						Laboratory Sample Number: 2403159-008		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.5	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 4125 8th St NW
Date Collected: 3/10/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403159-009
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.9	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 10 4125 8th St NW
Date Collected: 3/10/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403159-010
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.0	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: LT-DC-CCPF-2403160

Sample Location: 1 4507 Foxhall Cres NW

Date Collected: 2/27/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2403160-001

Date / Time Received: 3/20/2024 9:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	137	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 2 4507 Foxhall Cres NW

Date Collected: 2/27/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2403160-002

Date / Time Received: 3/20/2024 9:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	94.7	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.6	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 3 4507 Foxhall Cres NW

Date Collected: 2/27/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2403160-003

Date / Time Received: 3/20/2024 9:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	82.2	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 4507 Foxhall Cres NW						Customer Program Code: CCPF		
Date Collected: 2/27/2024						Laboratory Sample Number: 2403160-004		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 PM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	99.8	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 5 4507 Foxhall Cres NW						Customer Program Code: CCPF		
Date Collected: 2/27/2024						Laboratory Sample Number: 2403160-005		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 PM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	91.1	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 6 4507 Foxhall Cres NW						Customer Program Code: CCPF		
Date Collected: 2/27/2024						Laboratory Sample Number: 2403160-006		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 PM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	85.9	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 7 4507 Foxhall Cres NW						Customer Program Code: CCPF		
Date Collected: 2/27/2024						Laboratory Sample Number: 2403160-007		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 PM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	84.7	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 8 4507 Foxhall Cres NW						Customer Program Code: CCPF		
Date Collected: 2/27/2024						Laboratory Sample Number: 2403160-008		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 PM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	91.9	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 4507 Foxhall Cres NW						Customer Program Code: CCPF			
Date Collected: 2/27/2024						Laboratory Sample Number: 2403160-009			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 PM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	91.7	ug/L	H	3/28/2024	Bprakash	
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	3/28/2024	Bprakash	
Manganese	EPA 200.8		0.2	1.0	ug/L	H	3/28/2024	Bprakash	
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash	

Sample Location: 10 4507 Foxhall Cres NW						Customer Program Code: CCPF			
Date Collected: 2/27/2024						Laboratory Sample Number: 2403160-010			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 PM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	97.6	ug/L	H	3/28/2024	Bprakash	
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	3/28/2024	Bprakash	
Manganese	EPA 200.8		0.2	0.9	ug/L	H	3/28/2024	Bprakash	
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: LT-DC-CCPF-2403161

Sample Location: 1 3241 38th St NW

Date Collected: 2/18/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2403161-001

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	102	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	1.3	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 2 3241 38th St NW

Date Collected: 2/18/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2403161-002

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.8	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	1.0	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 3 3241 38th St NW

Date Collected: 2/18/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2403161-003

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.0	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 3241 38th St NW						Customer Program Code: CCPF		
Date Collected: 2/18/2024						Laboratory Sample Number: 2403161-004		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.0	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 5 3241 38th St NW						Customer Program Code: CCPF		
Date Collected: 2/18/2024						Laboratory Sample Number: 2403161-005		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.5	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.6	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 6 3241 38th St NW						Customer Program Code: CCPF		
Date Collected: 2/18/2024						Laboratory Sample Number: 2403161-006		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.6	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.6	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 7 3241 38th St NW						Customer Program Code: CCPF		
Date Collected: 2/18/2024						Laboratory Sample Number: 2403161-007		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.8	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 8 3241 38th St NW						Customer Program Code: CCPF		
Date Collected: 2/18/2024						Laboratory Sample Number: 2403161-008		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.7	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.6	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 3241 38th St NW						Customer Program Code: CCPF		
Date Collected: 2/18/2024						Laboratory Sample Number: 2403161-009		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.8	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Sample Location: 10 3241 38th St NW						Customer Program Code: CCPF		
Date Collected: 2/18/2024						Laboratory Sample Number: 2403161-010		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.3	ug/L	H	3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L	H	3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	1.1	ug/L	H	3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L	H	3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: LT-DC-CCPF-2403162

Sample Location: 1 638 E St SE
Date Collected: 3/11/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403162-001
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.5	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 2 638 E St SE
Date Collected: 3/11/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403162-002
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.4	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 3 638 E St SE
Date Collected: 3/11/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403162-003
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Sample Location: 4 638 E St SE						Customer Program Code: CCPF		
Date Collected: 3/11/2024						Laboratory Sample Number: 2403162-004		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 5 638 E St SE						Customer Program Code: CCPF		
Date Collected: 3/11/2024						Laboratory Sample Number: 2403162-005		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 6 638 E St SE						Customer Program Code: CCPF		
Date Collected: 3/11/2024						Laboratory Sample Number: 2403162-006		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.2	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 7 638 E St SE						Customer Program Code: CCPF		
Date Collected: 3/11/2024						Laboratory Sample Number: 2403162-007		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.0	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.2	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 8 638 E St SE						Customer Program Code: CCPF		
Date Collected: 3/11/2024						Laboratory Sample Number: 2403162-008		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	1.0	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 638 E St SE

Date Collected: 3/11/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2403162-009

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 10 638 E St SE

Date Collected: 3/11/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2403162-010

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.4	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: LT-DC-CCPF-2403163

Sample Location: 1 426 Marietta PI NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403163-001
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 2 426 Marietta PI NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403163-002
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 3 426 Marietta PI NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403163-003
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Sample Location: 4 426 Marietta PI NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403163-004		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 5 426 Marietta PI NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403163-005		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 6 426 Marietta PI NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403163-006		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 7 426 Marietta PI NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403163-007		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 8 426 Marietta PI NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403163-008		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 426 Marietta PI NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403163-009
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 10 426 Marietta PI NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403163-010
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: LT-DC-CCPF-2403164

Sample Location: 1 1916 D St NE
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403164-001
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.6	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 2 1916 D St NE
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403164-002
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.0	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 3 1916 D St NE
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403164-003
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.7	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 1916 D St NE						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403164-004		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.0	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 5 1916 D St NE						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403164-005		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.5	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 6 1916 D St NE						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403164-006		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.9	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 7 1916 D St NE						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403164-007		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.5	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 8 1916 D St NE						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403164-008		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.5	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.6	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 1916 D St NE
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403164-009
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.2	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 10 1916 D St NE
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403164-010
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.9	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: LT-DC-CCPF-2403165

Sample Location: 1 5812 5th St NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403165-001
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.0	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.3	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 2 5812 5th St NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403165-002
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.5	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.3	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 3 5812 5th St NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403165-003
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.2	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 5812 5th St NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403165-004		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.4	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.4	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 5 5812 5th St NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403165-005		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.4	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 6 5812 5th St NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403165-006		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.1	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 7 5812 5th St NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403165-007		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.7	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	0.2	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.7	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash
Sample Location: 8 5812 5th St NW						Customer Program Code: CCPF		
Date Collected: 3/13/2024						Laboratory Sample Number: 2403165-008		
						Date / Time Received: 3/20/2024 9:25:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.2	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.9	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 5812 5th St NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403165-009
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.9	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.8	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Sample Location: 10 5812 5th St NW
Date Collected: 3/13/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2403165-010
Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.1	ug/L		3/28/2024	Bprakash
Lead	EPA 200.8	15	0.2	ND	ug/L		3/28/2024	Bprakash
Manganese	EPA 200.8		0.2	0.5	ug/L		3/28/2024	Bprakash
Tin	EPA 200.8		0.2	ND	ug/L		3/28/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: LT-DC-CCPF-2404036

Sample Location: 1 827 Allison St NW

Date Collected: 3/17/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2404036-001

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.0	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	0.5	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Sample Location: 2 827 Allison St NW

Date Collected: 3/17/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2404036-002

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.1	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	0.5	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Sample Location: 3 827 Allison St NW

Date Collected: 3/17/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2404036-003

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.1	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	1.3	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 827 Allison St NW						Customer Program Code: CCPF		
Date Collected: 3/17/2024						Laboratory Sample Number: 2404036-004		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Sample Location: 5 827 Allison St NW						Customer Program Code: CCPF		
Date Collected: 3/17/2024						Laboratory Sample Number: 2404036-005		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.6	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Sample Location: 6 827 Allison St NW						Customer Program Code: CCPF		
Date Collected: 3/17/2024						Laboratory Sample Number: 2404036-006		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.9	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Sample Location: 7 827 Allison St NW						Customer Program Code: CCPF		
Date Collected: 3/17/2024						Laboratory Sample Number: 2404036-007		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Sample Location: 8 827 Allison St NW						Customer Program Code: CCPF		
Date Collected: 3/17/2024						Laboratory Sample Number: 2404036-008		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	0.5	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 827 Allison St NW						Customer Program Code: CCPF		
Date Collected: 3/17/2024						Laboratory Sample Number: 2404036-009		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.1	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	1.6	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	0.7	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Sample Location: 10 827 Allison St NW						Customer Program Code: CCPF		
Date Collected: 3/17/2024						Laboratory Sample Number: 2404036-010		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.3	ug/L	H	4/15/2024	LGallimore
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	4/15/2024	LGallimore
Manganese	EPA 200.8		0.2	0.8	ug/L	H	4/15/2024	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: LT-DC-CCPF-2404037

Sample Location: 1 1329 I St NE
Date Collected: 3/28/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2404037-001
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.0	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Sample Location: 2 1329 I St NE
Date Collected: 3/28/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2404037-002
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.7	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.9	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Sample Location: 3 1329 I St NE
Date Collected: 3/28/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2404037-003
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.2	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.2	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Sample Location: 4 1329 I St NE						Customer Program Code: CCPF		
Date Collected: 3/28/2024						Laboratory Sample Number: 2404037-004		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.3	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.1	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore
Sample Location: 5 1329 I St NE						Customer Program Code: CCPF		
Date Collected: 3/28/2024						Laboratory Sample Number: 2404037-005		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.5	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.2	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore
Sample Location: 6 1329 I St NE						Customer Program Code: CCPF		
Date Collected: 3/28/2024						Laboratory Sample Number: 2404037-006		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.8	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore
Sample Location: 7 1329 I St NE						Customer Program Code: CCPF		
Date Collected: 3/28/2024						Laboratory Sample Number: 2404037-007		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.6	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore
Sample Location: 8 1329 I St NE						Customer Program Code: CCPF		
Date Collected: 3/28/2024						Laboratory Sample Number: 2404037-008		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.0	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.4	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 1329 I St NE						Customer Program Code: CCPF		
Date Collected: 3/28/2024						Laboratory Sample Number: 2404037-009		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	45.5	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	1.2	ug/L		4/15/2024	Lgallimore

Sample Location: 10 1329 I St NE						Customer Program Code: CCPF		
Date Collected: 3/28/2024						Laboratory Sample Number: 2404037-010		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	53.6	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	4.4	ug/L		4/15/2024	Lgallimore

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minumum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: LT-DC-CCPF-2404039

Sample Location: 1 3338 Croffut PI SE
Date Collected: 3/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2404039-001
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	58.6	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Sample Location: 2 3338 Croffut PI SE
Date Collected: 3/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2404039-002
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	55.7	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Sample Location: 3 3338 Croffut PI SE
Date Collected: 3/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2404039-003
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	52.8	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 3338 Croffut PI SE						Customer Program Code: CCPF		
Date Collected: 3/21/2024						Laboratory Sample Number: 2404039-004		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	57.0	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Sample Location: 5 3338 Croffut PI SE						Customer Program Code: CCPF		
Date Collected: 3/21/2024						Laboratory Sample Number: 2404039-005		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	58.0	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Sample Location: 6 3338 Croffut PI SE						Customer Program Code: CCPF		
Date Collected: 3/21/2024						Laboratory Sample Number: 2404039-006		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.0	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Sample Location: 7 3338 Croffut PI SE						Customer Program Code: CCPF		
Date Collected: 3/21/2024						Laboratory Sample Number: 2404039-007		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.6	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Sample Location: 8 3338 Croffut PI SE						Customer Program Code: CCPF		
Date Collected: 3/21/2024						Laboratory Sample Number: 2404039-008		
						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	53.9	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 3338 Croffut PI SE
Date Collected: 3/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2404039-009
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.5	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Sample Location: 10 3338 Croffut PI SE
Date Collected: 3/21/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2404039-010
Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	55.3	ug/L		4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		4/15/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/8/2024

Report Number: LT-DC-CCPF-2404038

Sample Location: 1 15 Rhode Island Ave NW

Date Collected: 3/16/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2404038-001

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	103	ug/L	H	5/2/2024	SBrooks
Lead	EPA 200.8	15	0.2	15.2	ug/L	H	5/2/2024	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L	H	5/2/2024	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L	H	5/2/2024	SBrooks

Sample Location: 2 15 Rhode Island Ave NW

Date Collected: 3/16/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2404038-002

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L	H	4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	Lgallimore

Sample Location: 3 15 Rhode Island Ave NW

Date Collected: 3/16/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2404038-003

Date / Time Received: 4/1/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 15 Rhode Island Ave NW						Customer Program Code: CCPF		
Date Collected: 3/16/2024						Laboratory Sample Number: 2404038-004		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	Lgallimore

Sample Location: 5 15 Rhode Island Ave NW						Customer Program Code: CCPF		
Date Collected: 3/16/2024						Laboratory Sample Number: 2404038-005		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	Lgallimore

Sample Location: 6 15 Rhode Island Ave NW						Customer Program Code: CCPF		
Date Collected: 3/16/2024						Laboratory Sample Number: 2404038-006		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	Lgallimore

Sample Location: 7 15 Rhode Island Ave NW						Customer Program Code: CCPF		
Date Collected: 3/16/2024						Laboratory Sample Number: 2404038-007		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	Lgallimore

Sample Location: 8 15 Rhode Island Ave NW						Customer Program Code: CCPF		
Date Collected: 3/16/2024						Laboratory Sample Number: 2404038-008		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 15 Rhode Island Ave NW						Customer Program Code: CCPF		
Date Collected: 3/16/2024						Laboratory Sample Number: 2404038-009		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L	H	4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	Lgallimore

Sample Location: 10 15 Rhode Island Ave NW						Customer Program Code: CCPF		
Date Collected: 3/16/2024						Laboratory Sample Number: 2404038-010		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/1/2024 9:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	4/15/2024	Lgallimore
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	4/15/2024	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L	H	4/15/2024	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L	H	4/15/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: LT-DC-CCPF-2404197

Sample Location: 1 730 Upshur St NW

Date Collected: 4/1/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2404197-001

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.4	ug/L	H	5/2/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	5/2/2024	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L	H	5/2/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks

Sample Location: 2 730 Upshur St NW

Date Collected: 4/1/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2404197-002

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.8	ug/L	H	5/2/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/2/2024	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L	H	5/2/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks

Sample Location: 3 730 Upshur St NW

Date Collected: 4/1/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2404197-003

Date / Time Received: 4/24/2024 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.2	ug/L	H	5/2/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/2/2024	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L	H	5/2/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 730 Upshur St NW						Customer Program Code: CCPF		
Date Collected: 4/1/2024						Laboratory Sample Number: 2404197-004		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/24/2024 8:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.9	ug/L	H	5/2/2024	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	5/2/2024	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L	H	5/2/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks

Sample Location: 5 730 Upshur St NW						Customer Program Code: CCPF		
Date Collected: 4/1/2024						Laboratory Sample Number: 2404197-005		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/24/2024 8:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.0	ug/L	H	5/2/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/2/2024	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L	H	5/2/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks

Sample Location: 6 730 Upshur St NW						Customer Program Code: CCPF		
Date Collected: 4/1/2024						Laboratory Sample Number: 2404197-006		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/24/2024 8:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.4	ug/L	H	5/2/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/2/2024	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L	H	5/2/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks

Sample Location: 7 730 Upshur St NW						Customer Program Code: CCPF		
Date Collected: 4/1/2024						Laboratory Sample Number: 2404197-007		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/24/2024 8:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.4	ug/L	H	5/2/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/2/2024	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L	H	5/2/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks

Sample Location: 8 730 Upshur St NW						Customer Program Code: CCPF		
Date Collected: 4/1/2024						Laboratory Sample Number: 2404197-008		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/24/2024 8:45:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.0	ug/L	H	5/2/2024	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/2/2024	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L	H	5/2/2024	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 730 Upshur St NW						Customer Program Code: CCPF			
Date Collected: 4/1/2024						Laboratory Sample Number: 2404197-009			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/24/2024 8:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	28.2	ug/L	H	5/2/2024	SBrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/2/2024	SBrooks	
Manganese	EPA 200.8		0.2	1.0	ug/L	H	5/2/2024	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks	

Sample Location: 10 730 Upshur St NW						Customer Program Code: CCPF			
Date Collected: 4/1/2024						Laboratory Sample Number: 2404197-010			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 4/24/2024 8:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	37.1	ug/L	H	5/2/2024	SBrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/2/2024	SBrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	5/2/2024	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	5/2/2024	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LT-DC-CCPF-2405070

Sample Location: 1 914 Sheridan St NW

Date Collected: 4/23/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2405070-001

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Sample Location: 2 914 Sheridan St NW

Date Collected: 4/23/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2405070-002

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Sample Location: 3 914 Sheridan St NW

Date Collected: 4/23/2024

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2405070-003

Date / Time Received: 5/8/2024 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 914 Sheridan St NW						Customer Program Code: CCPF		
Date Collected: 4/23/2024						Laboratory Sample Number: 2405070-004		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 5/8/2024 8:10:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Sample Location: 5 914 Sheridan St NW						Customer Program Code: CCPF		
Date Collected: 4/23/2024						Laboratory Sample Number: 2405070-005		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 5/8/2024 8:10:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Sample Location: 6 914 Sheridan St NW						Customer Program Code: CCPF		
Date Collected: 4/23/2024						Laboratory Sample Number: 2405070-006		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 5/8/2024 8:10:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Sample Location: 7 914 Sheridan St NW						Customer Program Code: CCPF		
Date Collected: 4/23/2024						Laboratory Sample Number: 2405070-007		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 5/8/2024 8:10:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Sample Location: 8 914 Sheridan St NW						Customer Program Code: CCPF		
Date Collected: 4/23/2024						Laboratory Sample Number: 2405070-008		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 5/8/2024 8:10:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 914 Sheridan St NW						Customer Program Code: CCPF		
Date Collected: 4/23/2024						Laboratory Sample Number: 2405070-009		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 5/8/2024 8:10:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	2.4	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Sample Location: 10 914 Sheridan St NW						Customer Program Code: CCPF		
Date Collected: 4/23/2024						Laboratory Sample Number: 2405070-010		
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 5/8/2024 8:10:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	2.5	ug/L	H	5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LT-DC-CCPF-2405074

Sample Location: 1 207 3rd St NE
Date Collected: 5/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2405074-001
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Sample Location: 2 207 3rd St NE
Date Collected: 5/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2405074-002
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Sample Location: 3 207 3rd St NE
Date Collected: 5/1/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2405074-003
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Sample Location: 4 207 3rd St NE						Customer Program Code: CCPF		
Date Collected: 5/1/2024						Laboratory Sample Number: 2405074-004		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Sample Location: 5 207 3rd St NE						Customer Program Code: CCPF		
Date Collected: 5/1/2024						Laboratory Sample Number: 2405074-005		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Sample Location: 6 207 3rd St NE						Customer Program Code: CCPF		
Date Collected: 5/1/2024						Laboratory Sample Number: 2405074-006		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Sample Location: 7 207 3rd St NE						Customer Program Code: CCPF		
Date Collected: 5/1/2024						Laboratory Sample Number: 2405074-007		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Sample Location: 8 207 3rd St NE						Customer Program Code: CCPF		
Date Collected: 5/1/2024						Laboratory Sample Number: 2405074-008		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Sample Location: 9 207 3rd St NE

Date Collected: 5/1/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2405074-009

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Sample Location: 10 207 3rd St NE

Date Collected: 5/1/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2405074-010

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: LT-DC-CCPF-2405075

Sample Location: 1 641 E St SE
Date Collected: 4/29/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2405075-001
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Sample Location: 2 641 E St SE
Date Collected: 4/29/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2405075-002
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Sample Location: 3 641 E St SE
Date Collected: 4/29/2024

Customer Program Code: CCPF
Laboratory Sample Number: 2405075-003
Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Sample Location: 4 641 E St SE						Customer Program Code: CCPF		
Date Collected: 4/29/2024						Laboratory Sample Number: 2405075-004		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Sample Location: 5 641 E St SE						Customer Program Code: CCPF		
Date Collected: 4/29/2024						Laboratory Sample Number: 2405075-005		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Sample Location: 6 641 E St SE						Customer Program Code: CCPF		
Date Collected: 4/29/2024						Laboratory Sample Number: 2405075-006		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	0.2	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Sample Location: 7 641 E St SE						Customer Program Code: CCPF		
Date Collected: 4/29/2024						Laboratory Sample Number: 2405075-007		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Sample Location: 8 641 E St SE						Customer Program Code: CCPF		
Date Collected: 4/29/2024						Laboratory Sample Number: 2405075-008		
						Date / Time Received: 5/10/2024 7:47:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 641 E St SE

Date Collected: 4/29/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2405075-009

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Sample Location: 10 641 E St SE

Date Collected: 4/29/2024

Customer Program Code: CCPF

Laboratory Sample Number: 2405075-010

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		5/16/2024	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/16/2024	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Customer Collected Filtered Samples

DC Water operates a program where customers request a lead sampling kit to test their in-line point-of-use filtered water. The test kit comes with a 1-L bottle and instructions on how to take a sample. Customers collect their own sample and contact DC Water to deliver the bottle to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-CUSTFILT- 2401090-001

Sample Location: 1421 E Street NE

Customer Sample Number:

Date / Time Collected: 1/4/2024 11:45 AM

Customer Program Code: CUSTFILT

Laboratory Sample Number: 2401090-001

Date / Time Received: 1/12/2024 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/1/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/14/2024

Report Number: L-DC-CUSTFILT- 2404161-001

Sample Location: 3909 13th St. NW

Customer Sample Number:

Date / Time Collected: 4/9/2024 7:14 AM

Customer Program Code: CUSTFILT

Laboratory Sample Number: 2404161-001

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-CUSTFILT- 2405117-001

Sample Location: 118 7th St SE

Customer Sample Number:

Date / Time Collected: 4/27/2024 7:30 AM

Customer Program Code: CUSTFILT

Laboratory Sample Number: 2405117-001

Date / Time Received: 5/15/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/29/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Pipe Loop Research

DC Water collected stagnated samples from lead pipe loops to simulate lead levels released in the distribution system. The Washington Aqueduct laboratory analyzed the samples for lead.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/9/2024

Report Number: L-DC-LLP- 09012024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-001

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/21/2023	Lgallimore

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-002

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		12/21/2023	Lgallimore

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-003

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		12/21/2023	Lgallimore

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-004

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/21/2023	Lgallimore

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-005

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/9/2024

Report Number: L-DC-LLP- 09012024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-006

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/21/2023	Lgallimore

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-007

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		12/21/2023	Lgallimore

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-008

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/21/2023	Lgallimore

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-009

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		12/21/2023	Lgallimore

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 12/6/2023 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312050-010

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/21/2023	Lgallimore

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-001

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/21/2023	Lgallimore

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-002

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		12/21/2023	Lgallimore

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-003

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/9/2024

Report Number: L-DC-LLP- 09012024

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-004

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/21/2023	Lgallimore

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-005

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/21/2023	Lgallimore

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-006

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		12/21/2023	Lgallimore

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-007

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/21/2023	Lgallimore

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-008

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/21/2023	Lgallimore

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-009

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		12/21/2023	Lgallimore

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 11/29/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312051-010

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		12/21/2023	Lgallimore

Sample Location: 3900 Donaldson Pl NW (Pipeloo 1)

Sample Collected By: TB

Date / Time Collected: 10/6/2023 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-001

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	20.8	ug/L	H	12/21/2023	Lgallimore

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/9/2024

Report Number: L-DC-LLP- 09012024

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: TB

Date / Time Collected: 10/6/2023 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-002

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	12/21/2023	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: CW

Date / Time Collected: 11/17/2023 7:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-003

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L	H	12/21/2023	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: CW

Date / Time Collected: 11/17/2023 7:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-004

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L	H	12/21/2023	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: RB

Date / Time Collected: 11/21/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-005

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	12/21/2023	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: RB

Date / Time Collected: 11/21/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-006

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L	H	12/21/2023	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: RB

Date / Time Collected: 11/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-007

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L	H	12/21/2023	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: RB

Date / Time Collected: 11/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-008

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L	H	12/21/2023	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/9/2024

Report Number: L-DC-LLP- 09012024

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: RB

Date / Time Collected: 11/28/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-009

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		12/21/2023	Lgallimore

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: RB

Date / Time Collected: 11/28/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312052-010

Date / Time Received: 12/7/2023 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		12/21/2023	Lgallimore

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-001

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		12/21/2023	Lgallimore

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-002

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/21/2023	Lgallimore

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-003

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/21/2023	Lgallimore

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-004

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/21/2023	Lgallimore

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-005

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/21/2023	Lgallimore

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-006

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/9/2024

Report Number: L-DC-LLP- 09012024

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-007

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/21/2023	LGallimore

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-008

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/21/2023	LGallimore

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-009

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		12/21/2023	LGallimore

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 12/8/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312059-010

Date / Time Received: 12/8/2023 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/21/2023	LGallimore

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-001

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/21/2023	Lgallimore

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-002

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/21/2023	Lgallimore

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-003

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		12/21/2023	Lgallimore

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-004

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/9/2024

Report Number: L-DC-LLP- 09012024

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-005

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/21/2023	Lgallimore

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-006

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		12/21/2023	Lgallimore

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-007

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		12/21/2023	Lgallimore

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-008

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		12/21/2023	Lgallimore

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-009

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		12/21/2023	Lgallimore

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 12/13/2023 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312109-010

Date / Time Received: 12/14/2023 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		12/21/2023	Lgallimore

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-001

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		12/21/2023	Lgallimore

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-002

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/9/2024

Report Number: L-DC-LLP- 09012024

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-003

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		12/21/2023	Lgallimore

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-004

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/21/2023	Lgallimore

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-005

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/21/2023	Lgallimore

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-006

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/21/2023	Lgallimore

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-007

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/21/2023	Lgallimore

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-008

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		12/21/2023	Lgallimore

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-009

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/21/2023	Lgallimore

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 12/15/2023 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312116-010

Date / Time Received: 12/15/2023 2:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		12/21/2023	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/17/2024

Report Number: L-DC-LLP- 17012024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-001

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		1/4/2024	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-002

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		1/4/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-003

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		1/4/2024	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-004

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		1/4/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-005

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Report Date: 1/17/2024

Report Number: L-DC-LLP- 17012024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-006

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		1/4/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-007

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		1/4/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-008

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		1/4/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-009

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		1/4/2024	SBrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 12/19/2023 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312157-010

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		1/4/2024	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-001

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		1/4/2024	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-002

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		1/4/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-003

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/17/2024

Report Number: L-DC-LLP- 17012024

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-004

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/4/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-005

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		1/4/2024	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-006

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		1/4/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-007

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		1/4/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-008

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		1/4/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-009

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		1/4/2024	SBrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 12/22/2023 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312158-010

Date / Time Received: 12/22/2023 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		1/4/2024	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-001

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/17/2024

Report Number: L-DC-LLP- 17012024

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-002

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		1/4/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-003

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		1/4/2024	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-004

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/4/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-005

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		1/4/2024	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-006

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		1/4/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-007

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/4/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-008

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		1/4/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-009

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/17/2024

Report Number: L-DC-LLP- 17012024

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 12/29/2023 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312193-010

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		1/4/2024	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-001

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		1/4/2024	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-002

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		1/4/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-003

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		1/4/2024	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-004

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		1/4/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-005

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		1/4/2024	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-006

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		1/4/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-007

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 1/17/2024

Report Number: L-DC-LLP- 17012024

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-008

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		1/4/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-009

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		1/4/2024	SBrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 12/27/2023 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2312194-010

Date / Time Received: 12/29/2023 9:29:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		1/4/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/13/2024

Report Number: L-DC-LLP- 13022024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 1/4/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401038-001

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		1/31/2024	Rlamsal

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 1/4/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401038-003

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		1/31/2024	Rlamsal

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 1/4/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401038-004

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/31/2024	Rlamsal

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 1/4/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401038-005

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		1/31/2024	Rlamsal

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 1/4/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401038-006

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Report Date: 2/13/2024

Report Number: L-DC-LLP- 13022024

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 1/4/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401038-007

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		1/31/2024	Rlamsal

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 1/4/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401038-008

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		1/31/2024	Rlamsal

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 1/4/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401038-009

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		1/31/2024	Rlamsal

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 1/4/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401038-010

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		1/31/2024	Rlamsal

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 1/5/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401039-001

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		1/31/2024	Rlamsal

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 1/5/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401039-003

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		1/31/2024	Rlamsal

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 1/5/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401039-004

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		1/31/2024	Rlamsal

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 1/5/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401039-005

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/13/2024

Report Number: L-DC-LLP- 13022024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 1/5/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401039-006

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		1/31/2024	Rlamsal

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 1/5/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401039-007

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		1/31/2024	Rlamsal

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 1/5/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401039-008

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		1/31/2024	Rlamsal

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 1/5/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401039-009

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		1/31/2024	Rlamsal

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 1/5/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401039-010

Date / Time Received: 1/5/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		1/31/2024	Rlamsal

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: HB

Date / Time Collected: 12/12/2023 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401042-001

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L	H	1/31/2024	Rlamsal

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 12/12/2023 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401042-002

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L	H	1/31/2024	Rlamsal

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/13/2024

Report Number: L-DC-LLP- 13022024

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: HB

Date / Time Collected: 12/20/2023 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401042-003

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	1/31/2024	Rlamsal
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 12/20/2023 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401042-004

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L	H	1/31/2024	Rlamsal
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 12/22/2023 11:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401042-005

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		1/31/2024	Rlamsal

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 12/22/2023 11:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401042-006

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		1/31/2024	Rlamsal

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 12/22/2023 12:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2401042-007

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		1/31/2024	Rlamsal

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-001

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		1/31/2024	Rlamsal

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-002

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/13/2024

Report Number: L-DC-LLP- 13022024

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-003

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		1/31/2024	Rlamsal

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-004

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		1/31/2024	Rlamsal

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-005

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		1/31/2024	Rlamsal

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-006

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		1/31/2024	Rlamsal

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-007

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		1/31/2024	Rlamsal

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-008

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		1/31/2024	Rlamsal

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-009

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		1/31/2024	Rlamsal

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 1/11/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401083-010

Date / Time Received: 1/11/2024 11:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/13/2024

Report Number: L-DC-LLP- 13022024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-001

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		1/31/2024	Rlamsal

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-002

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		1/31/2024	Rlamsal

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-003

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		1/31/2024	Rlamsal

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-004

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		1/31/2024	Rlamsal

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-005

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		1/31/2024	Rlamsal

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-006

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		1/31/2024	Rlamsal

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-007

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		1/31/2024	Rlamsal

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-008

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/13/2024

Report Number: L-DC-LLP- 13022024

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-009

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		1/31/2024	Rlamsal

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: RB

Date / Time Collected: 1/12/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401092-010

Date / Time Received: 1/12/2024 2:00:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		1/31/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 2/26/2024

Report Number: L-DC-LLP- 26022024

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: HB

Date / Time Collected: 12/1/2023 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401041-001

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	2/8/2024	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: HB

Date / Time Collected: 12/1/2023 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401041-002

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L	H	2/8/2024	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 12/1/2023 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401041-003

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: HB

Date / Time Collected: 12/5/2023 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401041-004

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	2/8/2024	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/26/2024

Report Number: L-DC-LLP- 26022024

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: HB

Date / Time Collected: 12/5/2023 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401041-005

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L	H	1/31/2024	Rlamsal
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: HB

Date / Time Collected: 12/8/2023 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401041-006

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L	H	1/31/2024	Rlamsal
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: HB

Date / Time Collected: 12/8/2023 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401041-007

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L	H	1/31/2024	Rlamsal
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 12/8/2023 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401041-008

Date / Time Received: 1/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	1/31/2024	Rlamsal
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: HB

Date / Time Collected: 1/9/2024 11:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401170-001

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		2/8/2024	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: HB

Date / Time Collected: 1/9/2024 11:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401170-002

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/8/2024	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: HB

Date / Time Collected: 1/12/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401170-003

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/26/2024

Report Number: L-DC-LLP- 26022024

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: HB

Date / Time Collected: 1/12/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401170-004

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		2/8/2024	SBrooks

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 1/12/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401170-005

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: HB

Date / Time Collected: 12/29/2023 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401171-001

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L	H	2/8/2024	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: HB

Date / Time Collected: 12/29/2023 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401171-002

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	2/8/2024	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 12/29/2023 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401171-003

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	2/8/2024	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: HB

Date / Time Collected: 1/4/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401171-004

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		2/8/2024	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: HB

Date / Time Collected: 1/4/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401171-005

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/26/2024

Report Number: L-DC-LLP- 26022024

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: HB

Date / Time Collected: 1/5/2024 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401171-006

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		2/8/2024	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 1/5/2024 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401171-007

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		2/8/2024	SBrooks

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 1/5/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401171-008

Date / Time Received: 1/18/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/8/2024	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-001

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		2/8/2024	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-002

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/8/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-003

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		2/8/2024	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-004

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/8/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-005

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/26/2024

Report Number: L-DC-LLP- 26022024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-006

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		2/8/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-007

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/8/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-008

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		2/8/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-009

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		2/8/2024	SBrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 1/26/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2401189-010

Date / Time Received: 1/26/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		2/8/2024	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-001

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		2/8/2024	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-002

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		2/8/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-003

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/26/2024

Report Number: L-DC-LLP- 26022024

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-004

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/8/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-005

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		2/8/2024	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-006

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		2/8/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-007

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		2/8/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-008

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		2/8/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-009

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.8	ug/L		2/8/2024	SBrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 1/31/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402009-010

Date / Time Received: 2/2/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		2/8/2024	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-001

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/26/2024

Report Number: L-DC-LLP- 26022024

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-002

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		2/8/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-003

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		2/8/2024	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-004

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/8/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-005

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		2/8/2024	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-006

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		2/8/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-007

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/8/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-008

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		2/8/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-009

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 2/26/2024

Report Number: L-DC-LLP- 26022024

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: RB

Date / Time Collected: 2/2/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402012-010

Date / Time Received: 2/2/2024 1:07:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		2/8/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 3/6/2024

Report Number: L-DC-LLP- 06032024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-001

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		2/23/2024	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-002

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		2/23/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-003

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-004

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		2/23/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-005

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 3/6/2024

Report Number: L-DC-LLP- 06032024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-006

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-007

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		2/23/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-008

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		2/23/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-009

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		2/23/2024	SBrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 2/7/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402058-010

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		2/23/2024	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 1/18/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402059-001

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	2/23/2024	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 1/18/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402059-002

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L	H	2/23/2024	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 3/6/2024

Report Number: L-DC-LLP- 06032024

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 1/26/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402059-003

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 1/26/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402059-004

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/23/2024	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 1/26/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402059-005

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		2/23/2024	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 1/30/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402059-006

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/23/2024	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 1/30/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402059-007

Date / Time Received: 2/8/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-001

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-002

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		2/23/2024	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-003

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 3/6/2024

Report Number: L-DC-LLP- 06032024

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-004

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		2/23/2024	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-005

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/23/2024	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-006

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		2/23/2024	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-007

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/23/2024	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-008

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		2/23/2024	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-009

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		2/23/2024	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: RB

Date / Time Collected: 2/9/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402069-010

Date / Time Received: 2/9/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		2/23/2024	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-001

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 3/6/2024

Report Number: L-DC-LLP- 06032024

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-002

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		2/23/2024	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-003

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-004

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		2/23/2024	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-005

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		2/23/2024	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-006

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		2/23/2024	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-007

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/23/2024	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-008

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		2/23/2024	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-009

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 3/6/2024

Report Number: L-DC-LLP- 06032024

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 2/14/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402123-010

Date / Time Received: 2/16/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		2/23/2024	SBrooks

Sample Location: 1 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: HB

Date / Time Collected: 2/2/2024 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-001

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/23/2024	SBrooks

Sample Location: 2 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 2/2/2024 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-002

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		2/23/2024	SBrooks

Sample Location: 3 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 2/2/2024 12:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-003

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 4 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: HB

Date / Time Collected: 2/6/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-004

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		2/23/2024	SBrooks

Sample Location: 5 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 2/6/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-005

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		2/23/2024	SBrooks

Sample Location: 6 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: HB

Date / Time Collected: 2/9/2024 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-006

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		2/23/2024	SBrooks

Sample Location: 7 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: HB

Date / Time Collected: 2/9/2024 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-007

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 3/6/2024

Report Number: L-DC-LLP- 06032024

Sample Location: 8 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 2/9/2024 11:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-008

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		2/23/2024	SBrooks

Sample Location: 9 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: LS

Date / Time Collected: 2/13/2024 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-009

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		2/23/2024	SBrooks

Sample Location: 10 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: LS

Date / Time Collected: 2/13/2024 9:51 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402126-010

Date / Time Received: 2/16/2024 10:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		2/23/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/1/2024

Report Number: L-DC-LLP- 01042024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-001

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		3/20/2024	Rlamsal

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-002

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		3/20/2024	Rlamsal

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-003

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		3/20/2024	Rlamsal

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-004

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/20/2024	Rlamsal

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-005

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Report Date: 4/1/2024

Report Number: L-DC-LLP- 01042024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-006

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/20/2024	Rlamsal

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-007

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		3/20/2024	Rlamsal

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-008

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		3/20/2024	Rlamsal

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-009

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		3/20/2024	Rlamsal

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: RB

Date / Time Collected: 2/23/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402162-010

Date / Time Received: 2/23/2024 11:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		3/20/2024	Rlamsal

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-001

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		3/20/2024	Rlamsal

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-002

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		3/20/2024	Rlamsal

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-003

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/1/2024

Report Number: L-DC-LLP- 01042024

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-004

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		3/20/2024	Rlamsal

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-005

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		3/20/2024	Rlamsal

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-006

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		3/20/2024	Rlamsal

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-007

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		3/20/2024	Rlamsal

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-008

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		3/20/2024	Rlamsal

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-009

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		3/20/2024	Rlamsal

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: RB

Date / Time Collected: 2/16/2024 7:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2402179-010

Date / Time Received: 2/26/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		3/20/2024	Rlamsal

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-001

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/1/2024

Report Number: L-DC-LLP- 01042024

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-002

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/20/2024	Rlamsal

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-003

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		3/20/2024	Rlamsal

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-004

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		3/20/2024	Rlamsal

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-005

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		3/20/2024	Rlamsal

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-006

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/20/2024	Rlamsal

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-007

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		3/20/2024	Rlamsal

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-008

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/20/2024	Rlamsal

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-009

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/1/2024

Report Number: L-DC-LLP- 01042024

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 3/1/2024 8:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403007-010

Date / Time Received: 3/1/2024 11:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		3/20/2024	Rlamsal

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-001

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		3/20/2024	Rlamsal

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-002

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		3/20/2024	Rlamsal

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-003

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		3/20/2024	Rlamsal

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-004

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/20/2024	Rlamsal

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-005

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		3/20/2024	Rlamsal

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-006

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		3/20/2024	Rlamsal

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-007

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/1/2024

Report Number: L-DC-LLP- 01042024

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-008

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		3/20/2024	Rlamsal

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-009

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		3/20/2024	Rlamsal

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 2/28/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403049-010

Date / Time Received: 2/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		3/20/2024	Rlamsal

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-001

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		3/20/2024	Rlamsal

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-002

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/20/2024	Rlamsal

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-003

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		3/20/2024	Rlamsal

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-004

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/20/2024	Rlamsal

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-005

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/1/2024

Report Number: L-DC-LLP- 01042024

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-006

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		3/20/2024	Rlamsal

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-007

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		3/20/2024	Rlamsal

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-008

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		3/20/2024	Rlamsal

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-009

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		3/20/2024	Rlamsal

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 3/6/2024 8:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403061-010

Date / Time Received: 3/7/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		3/20/2024	Rlamsal

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-001

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		3/20/2024	Rlamsal

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-002

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/20/2024	Rlamsal

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-003

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/1/2024

Report Number: L-DC-LLP- 01042024

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-004

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/20/2024	Rlamsal

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-005

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		3/20/2024	Rlamsal

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-006

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		3/20/2024	Rlamsal

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-007

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		3/20/2024	Rlamsal

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-008

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		3/20/2024	Rlamsal

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-009

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		3/20/2024	Rlamsal

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 3/8/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403064-010

Date / Time Received: 3/8/2024 1:33:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 4/9/2024

Report Number: L-DC-LLP- 09042024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-001

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		3/20/2024	Rlamsal

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-002

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		3/20/2024	Rlamsal

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-003

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		3/20/2024	Rlamsal

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-004

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		3/20/2024	Rlamsal

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-005

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		3/20/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Report Date: 4/9/2024

Report Number: L-DC-LLP- 09042024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-006

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		3/20/2024	Rlamsal

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-007

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		3/20/2024	Rlamsal

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-008

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		3/20/2024	Rlamsal

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-009

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		3/20/2024	Rlamsal

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 3/15/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403090-010

Date / Time Received: 3/15/2024 11:27:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		3/20/2024	Rlamsal

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 2/16/2024 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-001

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	4/2/2024	Bprakash

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 2/16/2024 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-002

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L	H	4/2/2024	Bprakash

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/9/2024

Report Number: L-DC-LLP- 09042024

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 2/16/2024 12:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-003

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/2/2024	Bprakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 2/21/2024 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-004

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	4/2/2024	Bprakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 2/21/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-005

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	4/2/2024	Bprakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: LS

Date / Time Collected: 2/27/2024 1:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-006

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	4/2/2024	Bprakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: LS

Date / Time Collected: 2/27/2024 1:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-007

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	4/2/2024	Bprakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 3/1/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-008

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	4/2/2024	Bprakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: LS

Date / Time Collected: 3/6/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-009

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		4/2/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/9/2024

Report Number: L-DC-LLP- 09042024

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: LS

Date / Time Collected: 3/6/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403145-010

Date / Time Received: 3/20/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		4/2/2024	Bprakash

Sample Location: 1 Bryant Street Pipeloop 1

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-001

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		4/2/2024	Bprakash

Sample Location: 2 Bryant Street Pipeloop 2

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-002

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		4/2/2024	Bprakash

Sample Location: 3 Bryant Street Pipeloop 3

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-003

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		4/2/2024	Bprakash

Sample Location: 4 Bryant Street Pipeloop 4

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-004

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		4/2/2024	Bprakash

Sample Location: 5 Bryant Street Pipeloop 5

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-005

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		4/2/2024	Bprakash

Sample Location: 6 Bryant Street Pipeloop 6

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-006

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		4/2/2024	Bprakash

Sample Location: 7 Bryant Street Pipeloop 7

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-007

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		4/2/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/9/2024

Report Number: L-DC-LLP- 09042024

Sample Location: 8 Bryant Street Pipeloop 8

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-008

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		4/2/2024	Bprakash

Sample Location: 9 Bryant Street Pipeloop 9

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-009

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		4/2/2024	Bprakash

Sample Location: 10 Bryant Street Pipeloop 10

Sample Collected By: KLC

Date / Time Collected: 3/13/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403152-010

Date / Time Received: 3/18/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		4/2/2024	Bprakash

Sample Location: 1 Bryant Street Pipeloop 1

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-001

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		4/2/2024	Bprakash

Sample Location: 2 Bryant Street Pipeloop 2

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-002

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/2/2024	Bprakash

Sample Location: 3 Bryant Street Pipeloop 3

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-003

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		4/2/2024	Bprakash

Sample Location: 4 Bryant Street Pipeloop 4

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-004

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/2/2024	Bprakash

Sample Location: 5 Bryant Street Pipeloop 5

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-005

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		4/2/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 4/9/2024

Report Number: L-DC-LLP- 09042024

Sample Location: 6 Bryant Street Pipeloop 6

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-006

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		4/2/2024	Bprakash

Sample Location: 7 Bryant Street Pipeloop 7

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-007

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		4/2/2024	Bprakash

Sample Location: 8 Bryant Street Pipeloop 8

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-008

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		4/2/2024	Bprakash

Sample Location: 9 Bryant Street Pipeloop 9

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-009

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		4/2/2024	Bprakash

Sample Location: 10 Bryant Street Pipeloop 10

Sample Collected By: IC

Date / Time Collected: 3/22/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403168-010

Date / Time Received: 3/22/2024 1:36:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		4/2/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/2/2024

Report Number: L-DC-LLP- 02052024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-001

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		4/17/2024	Lgallimore

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-002

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		4/17/2024	Lgallimore

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-003

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		4/17/2024	Lgallimore

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-004

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		4/17/2024	Lgallimore

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-005

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/2/2024

Report Number: L-DC-LLP- 02052024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-006

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		4/17/2024	Lgallimore

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-007

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		4/17/2024	Lgallimore

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-008

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		4/17/2024	Lgallimore

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-009

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		4/17/2024	Lgallimore

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: RB

Date / Time Collected: 3/29/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2403208-010

Date / Time Received: 3/29/2024 10:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		4/17/2024	Lgallimore

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-001

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/17/2024	Lgallimore

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-002

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/17/2024	Lgallimore

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-003

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/2/2024

Report Number: L-DC-LLP- 02052024

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-004

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/17/2024	Lgallimore

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-005

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		4/17/2024	Lgallimore

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-006

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/17/2024	Lgallimore

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-007

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		4/17/2024	Lgallimore

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-008

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		4/17/2024	Lgallimore

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-009

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		4/17/2024	Lgallimore

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 4/5/2024 8:35 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404050-010

Date / Time Received: 4/5/2024 11:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		4/17/2024	Lgallimore

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 3/8/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404102-001

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/2/2024

Report Number: L-DC-LLP- 02052024

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 3/8/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404102-002

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/17/2024	Lgallimore

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 3/8/2024 12:00 PM

Customer Program Code: LLP

Laboratory Sample Number: 2404102-003

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 3/15/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404102-004

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		4/17/2024	Lgallimore

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 3/15/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404102-005

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		4/17/2024	Lgallimore

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 3/26/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404103-001

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		4/17/2024	Lgallimore

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 3/26/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404103-002

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		4/17/2024	Lgallimore

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 3/29/2024 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404103-003

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		4/17/2024	Lgallimore

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 3/29/2024 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404103-004

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/2/2024

Report Number: L-DC-LLP- 02052024

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 3/29/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404103-005

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/17/2024	Lgallimore

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-001

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	4/17/2024	Lgallimore

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-002

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	4/17/2024	Lgallimore

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-003

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	4/17/2024	Lgallimore

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-004

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	4/17/2024	Lgallimore

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-005

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L	H	4/17/2024	Lgallimore

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-006

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L	H	4/17/2024	Lgallimore

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/2/2024

Report Number: L-DC-LLP- 02052024

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-007

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L	H	4/17/2024	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-008

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L	H	4/17/2024	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-009

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L	H	4/17/2024	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 3/27/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404104-010

Date / Time Received: 4/12/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L	H	4/17/2024	Lgallimore
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-001

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		4/17/2024	Lgallimore

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-002

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		4/17/2024	Lgallimore

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-003

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/2/2024

Report Number: L-DC-LLP- 02052024

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-004

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/17/2024	Lgallimore

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-005

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/17/2024	Lgallimore

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-006

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		4/17/2024	Lgallimore

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-007

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		4/17/2024	Lgallimore

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-008

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		4/17/2024	Lgallimore

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-009

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		4/17/2024	Lgallimore

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 4/12/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404105-010

Date / Time Received: 4/12/2024 10:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		4/17/2024	Lgallimore

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-001

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/2/2024

Report Number: L-DC-LLP- 02052024

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-002

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		4/17/2024	Lgallimore

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-003

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		4/17/2024	Lgallimore

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-004

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/17/2024	Lgallimore

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-005

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		4/17/2024	Lgallimore

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-006

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		4/17/2024	Lgallimore

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-007

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		4/17/2024	Lgallimore

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-008

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		4/17/2024	Lgallimore

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-009

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/2/2024

Report Number: L-DC-LLP- 02052024

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 4/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404143-010

Date / Time Received: 4/15/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		4/17/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/13/2024

Report Number: L-DC-LLP- 13052024

Sample Location: 1 Bryant Street - Lead Pipe Section 1
Sample Collected By: IC
Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2404158-001
Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/26/2024	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: IC
Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2404158-002
Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		4/26/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: IC
Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2404158-003
Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/26/2024	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: IC
Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2404158-004
Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		4/26/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5
Sample Collected By: IC
Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2404158-005
Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Report Date: 5/13/2024

Report Number: L-DC-LLP- 13052024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404158-006

Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		4/26/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404158-007

Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		4/26/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404158-008

Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		4/26/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404158-009

Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		4/26/2024	SBrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 4/19/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404158-010

Date / Time Received: 4/19/2024 1:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		4/26/2024	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-001

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		4/26/2024	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-002

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		4/26/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-003

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		4/26/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/13/2024

Report Number: L-DC-LLP- 13052024

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-004

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		4/26/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-005

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		4/26/2024	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-006

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		4/26/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-007

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		4/26/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-008

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		4/26/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-009

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		4/26/2024	SBrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 4/15/2024 8:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2404162-010

Date / Time Received: 4/16/2024 9:05:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		4/26/2024	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-001

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/13/2024

Report Number: L-DC-LLP- 13052024

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-002

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/3/2024	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-003

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		5/3/2024	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-004

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/3/2024	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-005

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		5/3/2024	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-006

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		5/3/2024	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-007

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		5/3/2024	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-008

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/3/2024	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-009

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/13/2024

Report Number: L-DC-LLP- 13052024

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 4/26/2024 8:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405017-010

Date / Time Received: 4/26/2024 1:55:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		5/3/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-LLP- 29052024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-001

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		5/14/2024	Rlamsal

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-002

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-003

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/14/2024	Rlamsal

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-004

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-005

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Report Date: 5/29/2024

Report Number: L-DC-LLP- 29052024

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-006

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		5/14/2024	Rlamsal

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-007

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		5/14/2024	Rlamsal

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-008

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		5/14/2024	Rlamsal

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-009

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		5/14/2024	Rlamsal

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 5/2/2024 8:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405025-010

Date / Time Received: 5/2/2024 1:50:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		5/14/2024	Rlamsal

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-001

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		5/14/2024	Rlamsal

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-002

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/14/2024	Rlamsal

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-003

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/29/2024

Report Number: L-DC-LLP- 29052024

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-004

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/14/2024	Rlamsal

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-005

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		5/14/2024	Rlamsal

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-006

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		5/14/2024	Rlamsal

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-007

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		5/14/2024	Rlamsal

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-008

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		5/14/2024	Rlamsal

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-009

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		5/14/2024	Rlamsal

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 5/1/2024 8:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405029-010

Date / Time Received: 5/2/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		5/14/2024	Rlamsal

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-001

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/29/2024

Report Number: L-DC-LLP- 29052024

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-002

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/14/2024	Rlamsal

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-003

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		5/14/2024	Rlamsal

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-004

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		5/14/2024	Rlamsal

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-005

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		5/14/2024	Rlamsal

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-006

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		5/14/2024	Rlamsal

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-007

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		5/14/2024	Rlamsal

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-008

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		5/14/2024	Rlamsal

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-009

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	14.9	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 5/29/2024

Report Number: L-DC-LLP- 29052024

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 5/8/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405073-010

Date / Time Received: 5/10/2024 7:47:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		5/14/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005


Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016


Robert P. Hoffa, Laboratory Manager

Report Date: 6/17/2024

Report Number: L-DC-LLP- 17062024

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2405115-001
Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/29/2024	Bprakash

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2405115-002
Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2405115-003
Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		5/29/2024	Bprakash

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2405115-004
Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/29/2024	Bprakash

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2405115-005
Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 6/17/2024

Report Number: L-DC-LLP- 17062024

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405115-006

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		5/29/2024	Bprakash

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405115-007

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		5/29/2024	Bprakash

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405115-008

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		5/29/2024	Bprakash

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405115-009

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		5/29/2024	Bprakash

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 5/14/2024 8:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405115-010

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		5/29/2024	Bprakash

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-001

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/29/2024	Bprakash

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-002

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/29/2024	Bprakash

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-003

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 6/17/2024

Report Number: L-DC-LLP- 17062024

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-004

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		5/29/2024	Bprakash

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-005

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		5/29/2024	Bprakash

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-006

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		5/29/2024	Bprakash

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-007

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		5/29/2024	Bprakash

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-008

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.3	ug/L		5/29/2024	Bprakash

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-009

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		5/29/2024	Bprakash

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: RB

Date / Time Collected: 5/10/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405116-010

Date / Time Received: 5/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		5/29/2024	Bprakash

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 4/5/2024 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405131-001

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L	H	5/29/2024	BPrakash

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 6/17/2024

Report Number: L-DC-LLP- 17062024

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 4/5/2024 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405131-002

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L	H	5/29/2024	BPrakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 4/5/2024 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405131-003

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/29/2024	BPrakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 4/19/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405131-004

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L	H	5/29/2024	BPrakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 4/19/2024 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405131-005

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L	H	5/29/2024	BPrakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 4/19/2024 10:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405131-006

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	5/29/2024	BPrakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 4/12/2024 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405131-007

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	5/29/2024	BPrakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 4/12/2024 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405131-008

Date / Time Received: 5/17/2024 9:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	5/29/2024	BPrakash
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 6/17/2024

Report Number: L-DC-LLP- 17062024

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-001

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		5/29/2024	Bprakash

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-002

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-003

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		5/29/2024	Bprakash

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-004

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-005

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		5/29/2024	Bprakash

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-006

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		5/29/2024	Bprakash

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-007

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		5/29/2024	Bprakash

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-008

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 6/17/2024

Report Number: L-DC-LLP- 17062024

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-009

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		5/29/2024	Bprakash

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: IC

Date / Time Collected: 5/17/2024 8:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2405132-010

Date / Time Received: 5/17/2024 1:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		5/29/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**

Customer Special Sampling

DC Water created special sampling profiles to determine the source of lead based on individual needs. DC Water collected samples at the customer's home. Samples were analyzed by the Washington Aqueduct.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 5/29/2024

Report Number: L-DC-SP- 2404198-001

Sample Location: 1st draw 1831 North Capitol St NE

Customer Sample Number:

Date / Time Collected: 4/1/2024 7:37 AM

Customer Program Code: SP

Laboratory Sample Number: 2404198-001

Date / Time Received: 4/24/2024 8:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	0.6	ug/L	H	5/16/2024	Rlamsal

Sample Location: 2nd draw 1831 North Capitol St NE

Customer Sample Number:

Date / Time Collected: 4/1/2024 7:38 AM

Customer Program Code: SP

Laboratory Sample Number: 2404198-002

Date / Time Received: 4/24/2024 8:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.3	ug/L	H	5/16/2024	Rlamsal
Tin	EPA 200.8		0.2	0.6	ug/L	H	5/16/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446