

Attachment 2

Other Addition Non-Regulated Monitoring Data

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406139-003

Sample Location: 1st Draw 109 Rhode Island Ave NE

Customer Sample Number:

Date / Time Collected: 5/30/2024 4:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406139-003

Date / Time Received: 6/7/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 109 Rhode Island Ave NE

Customer Sample Number:

Date / Time Collected: 5/30/2024 4:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2406139-004

Date / Time Received: 6/7/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406102-001

Sample Location: 1st Draw 1124 C St. NE

Customer Sample Number:

Date / Time Collected: 5/12/2024 6:04 PM

Customer Program Code: DS

Laboratory Sample Number: 2406102-001

Date / Time Received: 5/29/2024 2:30:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L	H	6/21/2024	Lgallimore

Sample Location: 2nd Draw 1124 C St. NE

Customer Sample Number:

Date / Time Collected: 5/12/2024 6:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2406102-002

Date / Time Received: 5/29/2024 2:30:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L	H	6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406102-003

Sample Location: 1st Draw 1224 Duncan PI NE

Customer Sample Number:

Date / Time Collected: 5/23/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2406102-003

Date / Time Received: 5/29/2024 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 1224 Duncan PI NE

Customer Sample Number:

Date / Time Collected: 5/23/2024 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2406102-004

Date / Time Received: 5/29/2024 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-017

Sample Location: 1st Draw 1225 Harvard St NW

Customer Sample Number:

Date / Time Collected: 6/3/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-017

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 1225 Harvard St NW

Customer Sample Number:

Date / Time Collected: 6/3/2024 9:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-018

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406119-007

Sample Location: 1st Draw 1252 Evarts St NE

Customer Sample Number:

Date / Time Collected: 5/26/2024 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2406119-007

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 1252 Evarts St NE

Customer Sample Number:

Date / Time Collected: 5/26/2024 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2406119-008

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-001

Sample Location: 1st Draw 1624 D St SE
Customer Sample Number:
Date / Time Collected: 6/5/2024 7:54 AM

Customer Program Code: DS
Laboratory Sample Number: 2406143-001
Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 1624 D St SE
Customer Sample Number:
Date / Time Collected: 6/5/2024 7:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2406143-002
Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406102-007

Sample Location: 1st Draw 1632 Nicholson St NW

Customer Sample Number:

Date / Time Collected: 5/24/2024 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2406102-007

Date / Time Received: 5/29/2024 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 1632 Nicholson St NW

Customer Sample Number:

Date / Time Collected: 5/24/2024 6:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2406102-008

Date / Time Received: 5/29/2024 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-019

Sample Location: 1st Draw 1633 35th St NW

Customer Sample Number:

Date / Time Collected: 6/9/2024 4:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2406143-019

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 1633 35th St NW

Customer Sample Number:

Date / Time Collected: 6/9/2024 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2406143-020

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-011

Sample Location: 1st Draw 1705 Euclid St. NW #1

Customer Sample Number:

Date / Time Collected: 6/9/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-011

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 1705 Euclid St. NW #1

Customer Sample Number:

Date / Time Collected: 6/9/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-012

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406119-003

Sample Location: 1st Draw 1830 Ingleside Ter NW

Customer Sample Number:

Date / Time Collected: 5/27/2024 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2406119-003

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 1830 Ingleside Ter NW

Customer Sample Number:

Date / Time Collected: 5/27/2024 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2406119-004

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-021

Sample Location: 1st Draw 22 7th St NE
Customer Sample Number:
Date / Time Collected: 6/10/2024 5:55 PM

Customer Program Code: DS
Laboratory Sample Number: 2406143-021
Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 22 7th St NE
Customer Sample Number:
Date / Time Collected: 6/10/2024 6:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2406143-022
Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-015

Sample Location: 1st Draw 2629 11th St NW

Customer Sample Number:

Date / Time Collected: 6/9/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-015

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 2629 11th St NW

Customer Sample Number:

Date / Time Collected: 6/9/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-016

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-003

Sample Location: 1st Draw 300 Kentucky Ave SE

Customer Sample Number:

Date / Time Collected: 6/9/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-003

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 300 Kentucky Ave SE

Customer Sample Number:

Date / Time Collected: 6/9/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-004

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-007

Sample Location: 1st Draw 3030 West Lane Keys NW

Customer Sample Number:

Date / Time Collected: 6/12/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-007

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 3030 West Lane Keys NW

Customer Sample Number:

Date / Time Collected: 6/12/2024 7:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-008

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406119-001

Sample Location: 1st Draw 3546 Albemarle St NW

Customer Sample Number:

Date / Time Collected: 5/26/2024 12:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2406119-001

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 3546 Albemarle St NW

Customer Sample Number:

Date / Time Collected: 5/26/2024 12:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2406119-002

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-005

Sample Location: 1st Draw 3551 Quesada St NW

Customer Sample Number:

Date / Time Collected: 6/3/2024 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-005

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 3551 Quesada St NW

Customer Sample Number:

Date / Time Collected: 6/3/2024 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-006

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406102-005

Sample Location: 1st Draw 3618 Military Rd NW

Customer Sample Number:

Date / Time Collected: 5/21/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2406102-005

Date / Time Received: 5/29/2024 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 3618 Military Rd NW

Customer Sample Number:

Date / Time Collected: 5/21/2024 5:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2406102-006

Date / Time Received: 5/29/2024 2:30:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-009

Sample Location: 1st Draw 3901 Livingston St NW

Customer Sample Number:

Date / Time Collected: 6/8/2024 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2406143-009

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 3901 Livingston St NW

Customer Sample Number:

Date / Time Collected: 6/8/2024 8:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2406143-010

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-013

Sample Location: 1st Draw 4106 38th St NW

Customer Sample Number:

Date / Time Collected: 6/11/2024 6:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-013

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 4106 38th St NW

Customer Sample Number:

Date / Time Collected: 6/11/2024 6:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-014

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406119-013

Sample Location: 1st Draw 441 Decatur Street NW

Customer Sample Number:

Date / Time Collected: 5/27/2024 10:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2406119-013

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 441 Decatur Street NW

Customer Sample Number:

Date / Time Collected: 5/27/2024 10:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2406119-014

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-007

Sample Location: 1st Draw 4914 Nannie Helen Burroughs Ave NE

Customer Sample Number:

Date / Time Collected: 6/2/2024 4:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2406137-007

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 4914 Nannie Helen Burroughs Ave NE

Customer Sample Number:

Date / Time Collected: 6/2/2024 4:38 PM

Customer Program Code: DS

Laboratory Sample Number: 2406137-008

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-021

Sample Location: 1st Draw 4915 9th St. NW

Customer Sample Number:

Date / Time Collected: 5/30/2024 7:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-021

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 4915 9th St. NW

Customer Sample Number:

Date / Time Collected: 5/30/2024 7:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-022

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-017

Sample Location: 1st Draw 4936 Butterworth

Customer Sample Number:

Date / Time Collected: 6/10/2024 4:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-017

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 4936 Butterworth

Customer Sample Number:

Date / Time Collected: 6/10/2024 4:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-018

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-019

Sample Location: 1st Draw 508 E St NE
Customer Sample Number:
Date / Time Collected: 6/5/2024 6:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2406137-019
Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 508 E St NE
Customer Sample Number:
Date / Time Collected: 6/5/2024 6:52 AM

Customer Program Code: DS
Laboratory Sample Number: 2406137-020
Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406119-009

Sample Location: 1st Draw 5208 13th St NW

Customer Sample Number:

Date / Time Collected: 5/23/2024 5:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2406119-009

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 5208 13th St NW

Customer Sample Number:

Date / Time Collected: 5/23/2024 5:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2406119-010

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406119-011

Sample Location: 1st Draw 537 Quincy St NW, Unit 1

Customer Sample Number:

Date / Time Collected: 5/21/2024 4:24 PM

Customer Program Code: DS

Laboratory Sample Number: 2406119-011

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 537 Quincy St NW, Unit 1

Customer Sample Number:

Date / Time Collected: 5/21/2024 4:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2406119-012

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406139-001

Sample Location: 1st Draw 5817 Foote St NE

Customer Sample Number:

Date / Time Collected: 6/5/2024 10:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2406139-001

Date / Time Received: 6/7/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 5817 Foote St NE

Customer Sample Number:

Date / Time Collected: 6/5/2024 10:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2406139-002

Date / Time Received: 6/7/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406119-005

Sample Location: 1st Draw 6648 Eastern Ave NW

Customer Sample Number:

Date / Time Collected: 5/22/2024 6:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2406119-005

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 6648 Eastern Ave NW

Customer Sample Number:

Date / Time Collected: 5/22/2024 6:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2406119-006

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-023

Sample Location: 1st Draw 6701 Piney Branch Rd NW

Customer Sample Number:

Date / Time Collected: 6/7/2024 5:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-023

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 6701 Piney Branch Rd NW

Customer Sample Number:

Date / Time Collected: 6/7/2024 5:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-024

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-011

Sample Location: 1st Draw 702 8th ST SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-011

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/25/2024	Lgallimore

Sample Location: 2nd Draw 702 8th ST SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-012

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-013

Sample Location: 1st Draw 704 8th ST SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-013

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/25/2024	Lgallimore

Sample Location: 2nd Draw 704 8th ST SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-014

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-003

Sample Location: 1st Draw 706 8th St SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-003

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/25/2024	Lgallimore

Sample Location: 2nd Draw 706 8th St SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 7:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-004

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-009

Sample Location: 1st Draw 708 8th St SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-009

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	6/25/2024	Lgallimore

Sample Location: 2nd Draw 708 8th St SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 5:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-010

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-015

Sample Location: 1st Draw 713 3rd St SW

Customer Sample Number:

Date / Time Collected: 5/30/2024 8:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2406137-015

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 713 3rd St SW

Customer Sample Number:

Date / Time Collected: 5/30/2024 8:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2406137-016

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406143-005

Sample Location: 1st Draw 761 Girard St NW

Customer Sample Number:

Date / Time Collected: 6/8/2024 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-005

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 761 Girard St NW

Customer Sample Number:

Date / Time Collected: 6/8/2024 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2406143-006

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS-2406137-001

Sample Location: 1st Draw 801 G ST SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-001

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	6/25/2024	Lgallimore

Sample Location: 2nd Draw 801 G ST SE

Customer Sample Number:

Date / Time Collected: 5/9/2024 5:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2406137-002

Date / Time Received: 6/6/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS250- 2406138-001

Sample Location: 1st Draw 1316 Spring Rd NW Apt 304

Customer Sample Number:

Date / Time Collected: 6/3/2024 7:10 PM

Customer Program Code: DS250

Laboratory Sample Number: 2406138-001

Date / Time Received: 6/7/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Sample Location: 2nd Draw 1316 Spring Rd NW Apt 304

Customer Sample Number:

Date / Time Collected: 6/3/2024 7:10 PM

Customer Program Code: DS250

Laboratory Sample Number: 2406138-002

Date / Time Received: 6/7/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/25/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS250- 2406103-001

Sample Location: 1st Draw 1661 Park RD NW #303
Customer Sample Number:
Date / Time Collected: 5/22/2024 7:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2406103-001
Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 1661 Park RD NW #303
Customer Sample Number:
Date / Time Collected: 5/22/2024 7:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2406103-002
Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS250- 2406103-003

Sample Location: 1st Draw 1669 Columbia Rd NW Apt 411

Customer Sample Number:

Date / Time Collected: 5/23/2024 9:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406103-003

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 1669 Columbia Rd NW Apt 411

Customer Sample Number:

Date / Time Collected: 5/23/2024 9:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406103-004

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS250- 2406136-001

Sample Location: 1st Draw 2100 New Hampshire Ave NW

Customer Sample Number:

Date / Time Collected: 6/2/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406136-001

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 2100 New Hampshire Ave NW

Customer Sample Number:

Date / Time Collected: 6/2/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406136-002

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS250- 2406142-001

Sample Location: 1st Draw 3101 New Mexico Ave. NW Apt 551

Customer Sample Number:

Date / Time Collected: 6/7/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406142-001

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 3101 New Mexico Ave. NW Apt 551

Customer Sample Number:

Date / Time Collected: 6/7/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406142-002

Date / Time Received: 6/14/2024 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS250- 2406136-003

Sample Location: 1st Draw 3241 N St NW Apt 6

Customer Sample Number:

Date / Time Collected: 6/2/2024 4:49 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406136-003

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 3241 N St NW Apt 6

Customer Sample Number:

Date / Time Collected: 6/2/2024 4:49 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406136-004

Date / Time Received: 6/6/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS250- 2406097-001

Sample Location: 1st Draw 4600 Connecticut Ave NW Apt 825

Customer Sample Number:

Date / Time Collected: 5/13/2024 3:04 PM

Customer Program Code: DS250

Laboratory Sample Number: 2406097-001

Date / Time Received: 5/29/2024 2:30:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	6/21/2024	LGallimore

Sample Location: 2nd Draw 4600 Connecticut Ave NW Apt 825

Customer Sample Number:

Date / Time Collected: 5/13/2024 3:04 PM

Customer Program Code: DS250

Laboratory Sample Number: 2406097-002

Date / Time Received: 5/29/2024 2:30:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	6/21/2024	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/16/2024

Report Number: L-DC-DS250- 2406103-005

Sample Location: 1st Draw 6645 Georgia Ave Apt 109

Customer Sample Number:

Date / Time Collected: 5/21/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406103-005

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/21/2024	Lgallimore

Sample Location: 2nd Draw 6645 Georgia Ave Apt 109

Customer Sample Number:

Date / Time Collected: 5/21/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406103-006

Date / Time Received: 6/3/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		6/21/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2406161-003

Sample Location: 1st Draw 1116 C St NE Apt 101

Customer Sample Number:

Date / Time Collected: 6/15/2024 8:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2406161-003

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 1116 C St NE Apt 101

Customer Sample Number:

Date / Time Collected: 6/15/2024 8:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2406161-004

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-019

Sample Location: 1st Draw 1159 3rd ST. NE

Customer Sample Number:

Date / Time Collected: 6/30/2024 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-019

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 1159 3rd ST. NE

Customer Sample Number:

Date / Time Collected: 6/30/2024 8:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-020

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2406161-005

Sample Location: 1st Draw 1161 Summit ST NE

Customer Sample Number:

Date / Time Collected: 6/16/2024 11:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2406161-005

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 1161 Summit ST NE

Customer Sample Number:

Date / Time Collected: 6/16/2024 11:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2406161-006

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2406161-001

Sample Location: 1st Draw 120 Duddington PI SE

Customer Sample Number:

Date / Time Collected: 6/14/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2406161-001

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 120 Duddington PI SE

Customer Sample Number:

Date / Time Collected: 6/14/2024 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2406161-002

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407093-021

Sample Location: 1st Draw 1209 Florida Ave NE

Customer Sample Number:

Date / Time Collected: 7/8/2024 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2407093-021

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1209 Florida Ave NE

Customer Sample Number:

Date / Time Collected: 7/8/2024 6:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2407093-022

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407160-001

Sample Location: 1st Draw 13 7th St. NE
Customer Sample Number:
Date / Time Collected: 7/11/2024 4:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2407160-001
Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 13 7th St. NE
Customer Sample Number:
Date / Time Collected: 7/11/2024 4:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2407160-002
Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407086-005

Sample Location: 1st Draw 1300 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 6/30/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407086-005

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1300 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 6/30/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407086-006

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-019

Sample Location: 1st Draw 1322 Roxanna Rd NW

Customer Sample Number:

Date / Time Collected: 7/7/2024 11:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-019

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 1322 Roxanna Rd NW

Customer Sample Number:

Date / Time Collected: 7/7/2024 11:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-020

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407088-011

Sample Location: 1st Draw 1415 Howard Rd SE

Customer Sample Number:

Date / Time Collected: 7/2/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-011

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1415 Howard Rd SE

Customer Sample Number:

Date / Time Collected: 7/2/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-012

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407088-003

Sample Location: 1st Draw 1416 Varnum St NW

Customer Sample Number:

Date / Time Collected: 7/3/2024 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-003

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1416 Varnum St NW

Customer Sample Number:

Date / Time Collected: 7/3/2024 8:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-004

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407093-019

Sample Location: 1st Draw 1431 MERIDIAN PL NW

Customer Sample Number:

Date / Time Collected: 7/9/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2407093-019

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1431 MERIDIAN PL NW

Customer Sample Number:

Date / Time Collected: 7/9/2024 7:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2407093-020

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-021

Sample Location: 1st Draw 1431 Whittier PL NW

Customer Sample Number:

Date / Time Collected: 7/1/2024 6:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-021

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 1431 Whittier PL NW

Customer Sample Number:

Date / Time Collected: 7/1/2024 6:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-022

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-001

Sample Location: 1st Draw 1442 T Street NW

Customer Sample Number:

Date / Time Collected: 6/12/2024 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-001

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 1442 T Street NW

Customer Sample Number:

Date / Time Collected: 6/12/2024 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-002

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407093-025

Sample Location: 1st Draw 151 11th ST NE

Customer Sample Number:

Date / Time Collected: 7/9/2024 5:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2407093-025

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 151 11th ST NE

Customer Sample Number:

Date / Time Collected: 7/9/2024 5:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2407093-026

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407160-013

Sample Location: 1st Draw 1514 Kearny St NE

Customer Sample Number:

Date / Time Collected: 7/12/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-013

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 1514 Kearny St NE

Customer Sample Number:

Date / Time Collected: 7/12/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-014

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407086-007

Sample Location: 1st Draw 1524 N. Carolina Ave NE

Customer Sample Number:

Date / Time Collected: 6/22/2024 12:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2407086-007

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1524 N. Carolina Ave NE

Customer Sample Number:

Date / Time Collected: 6/22/2024 12:31 PM

Customer Program Code: DS

Laboratory Sample Number: 2407086-008

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407093-023

Sample Location: 1st Draw 1532 A St NE
Customer Sample Number:
Date / Time Collected: 7/8/2024 8:07 AM

Customer Program Code: DS
Laboratory Sample Number: 2407093-023
Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1532 A St NE
Customer Sample Number:
Date / Time Collected: 7/8/2024 8:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2407093-024
Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407093-027

Sample Location: 1st Draw 1543 44th St NW

Customer Sample Number:

Date / Time Collected: 7/8/2024 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2407093-027

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1543 44th St NW

Customer Sample Number:

Date / Time Collected: 7/8/2024 8:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2407093-028

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-005

Sample Location: 1st Draw 1619 31st St NW

Customer Sample Number:

Date / Time Collected: 7/11/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-005

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 1619 31st St NW

Customer Sample Number:

Date / Time Collected: 7/11/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-006

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407088-005

Sample Location: 1st Draw 1623 Montague NW

Customer Sample Number:

Date / Time Collected: 7/4/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-005

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1623 Montague NW

Customer Sample Number:

Date / Time Collected: 7/4/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-006

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-007

Sample Location: 1st Draw 1810 Potomac Ave SE

Customer Sample Number:

Date / Time Collected: 5/10/2024 11:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2407035-007

Date / Time Received: 7/1/2024 12:20:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	7/6/2024	SBrooks

Sample Location: 2nd Draw 1810 Potomac Ave SE

Customer Sample Number:

Date / Time Collected: 5/10/2024 11:16 PM

Customer Program Code: DS

Laboratory Sample Number: 2407035-008

Date / Time Received: 7/1/2024 12:20:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L	H	7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-009

Sample Location: 1st Draw 1816 Rosedale St. NE

Customer Sample Number:

Date / Time Collected: 6/19/2024 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-009

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 1816 Rosedale St. NE

Customer Sample Number:

Date / Time Collected: 6/19/2024 7:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-010

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407160-009

Sample Location: 1st Draw 2015 37th St NW

Customer Sample Number:

Date / Time Collected: 7/15/2024 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-009

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 2015 37th St NW

Customer Sample Number:

Date / Time Collected: 7/15/2024 7:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-010

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407088-017

Sample Location: 1st Draw 208 Randolph PI NE

Customer Sample Number:

Date / Time Collected: 6/30/2024 7:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2407088-017

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 208 Randolph PI NE

Customer Sample Number:

Date / Time Collected: 6/30/2024 7:18 PM

Customer Program Code: DS

Laboratory Sample Number: 2407088-018

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407086-011

Sample Location: 1st Draw 214 F Street NE

Customer Sample Number:

Date / Time Collected: 6/25/2024 3:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2407086-011

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 214 F Street NE

Customer Sample Number:

Date / Time Collected: 6/25/2024 3:17 PM

Customer Program Code: DS

Laboratory Sample Number: 2407086-012

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-015

Sample Location: 1st Draw 227 Webster St NW

Customer Sample Number:

Date / Time Collected: 7/1/2024 5:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-015

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 227 Webster St NW

Customer Sample Number:

Date / Time Collected: 7/1/2024 5:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-016

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-003

Sample Location: 1st Draw 2406 17th PI SE

Customer Sample Number:

Date / Time Collected: 6/29/2024 2:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2407112-003

Date / Time Received: 7/15/2024 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/26/2024	Bprakash

Sample Location: 2nd Draw 2406 17th PI SE

Customer Sample Number:

Date / Time Collected: 6/29/2024 2:12 PM

Customer Program Code: DS

Laboratory Sample Number: 2407112-004

Date / Time Received: 7/15/2024 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-003

Sample Location: 1st Draw 2515 33 St SE

Customer Sample Number:

Date / Time Collected: 6/12/2024 2:03 PM

Customer Program Code: DS

Laboratory Sample Number: 2407027-003

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 2515 33 St SE

Customer Sample Number:

Date / Time Collected: 6/12/2024 2:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2407027-004

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-003

Sample Location: 1st Draw 2627 11th St NW

Customer Sample Number:

Date / Time Collected: 6/17/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-003

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 2627 11th St NW

Customer Sample Number:

Date / Time Collected: 6/17/2024 6:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-004

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-009

Sample Location: 1st Draw 2701 O St NW

Customer Sample Number:

Date / Time Collected: 7/10/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-009

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 2701 O St NW

Customer Sample Number:

Date / Time Collected: 7/10/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-010

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-021

Sample Location: 1st Draw 2755 Woodley PL NW

Customer Sample Number:

Date / Time Collected: 6/18/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-021

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 2755 Woodley PL NW

Customer Sample Number:

Date / Time Collected: 6/18/2024 6:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-022

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407088-009

Sample Location: 1st Draw 2840 Arizona Terrace

Customer Sample Number:

Date / Time Collected: 7/2/2024 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-009

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 2840 Arizona Terrace

Customer Sample Number:

Date / Time Collected: 7/2/2024 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-010

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407088-007

Sample Location: 1st Draw 2912 Cortland PI NW

Customer Sample Number:

Date / Time Collected: 7/8/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-007

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 2912 Cortland PI NW

Customer Sample Number:

Date / Time Collected: 7/8/2024 7:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-008

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-017

Sample Location: 1st Draw 3016 13th St. NW

Customer Sample Number:

Date / Time Collected: 6/14/2024 2:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2407027-017

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	50.6	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 3016 13th St. NW

Customer Sample Number:

Date / Time Collected: 6/14/2024 2:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2407027-018

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407086-003

Sample Location: 1st Draw 3033 Dent PI NW

Customer Sample Number:

Date / Time Collected: 6/24/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407086-003

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 3033 Dent PI NW

Customer Sample Number:

Date / Time Collected: 6/24/2024 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407086-004

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-013

Sample Location: 1st Draw 320 9th St SE
Customer Sample Number:
Date / Time Collected: 7/4/2024 6:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2407112-013
Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 320 9th St SE
Customer Sample Number:
Date / Time Collected: 7/4/2024 6:42 AM

Customer Program Code: DS
Laboratory Sample Number: 2407112-014
Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-011

Sample Location: 1st Draw 3202 Scott PL NW

Customer Sample Number:

Date / Time Collected: 6/16/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-011

Date / Time Received: 7/1/2024 12:20:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/6/2024	SBrooks

Sample Location: 2nd Draw 3202 Scott PL NW

Customer Sample Number:

Date / Time Collected: 6/16/2024 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-012

Date / Time Received: 7/1/2024 12:20:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407086-001

Sample Location: 1st Draw 3318 16th ST NE

Customer Sample Number:

Date / Time Collected: 6/28/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2407086-001

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 3318 16th ST NE

Customer Sample Number:

Date / Time Collected: 6/28/2024 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2407086-002

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-005

Sample Location: 1st Draw 3408 Oliver St. NW

Customer Sample Number:

Date / Time Collected: 6/21/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-005

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 3408 Oliver St. NW

Customer Sample Number:

Date / Time Collected: 6/21/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-006

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407160-011

Sample Location: 1st Draw 3612 Veazey St NW

Customer Sample Number:

Date / Time Collected: 7/16/2024 5:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-011

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 3612 Veazey St NW

Customer Sample Number:

Date / Time Collected: 7/16/2024 5:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-012

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-007

Sample Location: 1st Draw 3638 Veazey St NW

Customer Sample Number:

Date / Time Collected: 7/6/2024 5:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-007

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 3638 Veazey St NW

Customer Sample Number:

Date / Time Collected: 7/6/2024 5:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-008

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-023

Sample Location: 1st Draw 3728 VanNess St. NW

Customer Sample Number:

Date / Time Collected: 6/19/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-023

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 3728 VanNess St. NW

Customer Sample Number:

Date / Time Collected: 6/19/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-024

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407160-007

Sample Location: 1st Draw 3831 Military Rd NW

Customer Sample Number:

Date / Time Collected: 7/16/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-007

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 3831 Military Rd NW

Customer Sample Number:

Date / Time Collected: 7/16/2024 6:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-008

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-005

Sample Location: 1st Draw 3902 Jocelyn St. NW

Customer Sample Number:

Date / Time Collected: 6/13/2024 6:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-005

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 3902 Jocelyn St. NW

Customer Sample Number:

Date / Time Collected: 6/13/2024 6:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-006

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407088-001

Sample Location: 1st Draw 4417 Colorado Ave NW

Customer Sample Number:

Date / Time Collected: 7/3/2024 2:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2407088-001

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2	37.6	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 4417 Colorado Ave NW

Customer Sample Number:

Date / Time Collected: 7/3/2024 2:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2407088-002

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2	18.9	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-017

Sample Location: 1st Draw 4462 Reservoir Rd. NW

Customer Sample Number:

Date / Time Collected: 6/27/2024 9:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-017

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 4462 Reservoir Rd. NW

Customer Sample Number:

Date / Time Collected: 6/27/2024 9:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-018

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407086-013

Sample Location: 1st Draw 4504 Chesapeake St NW

Customer Sample Number:

Date / Time Collected: 6/20/2024 11:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2407086-013

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 4504 Chesapeake St NW

Customer Sample Number:

Date / Time Collected: 6/20/2024 11:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2407086-014

Date / Time Received: 7/3/2024 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-013

Sample Location: 1st Draw 4510 Q Place NW

Customer Sample Number:

Date / Time Collected: 6/24/2024 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-013

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 4510 Q Place NW

Customer Sample Number:

Date / Time Collected: 6/24/2024 6:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-014

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407088-013

Sample Location: 1st Draw 4529 Edison PI NE

Customer Sample Number:

Date / Time Collected: 7/6/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-013

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 4529 Edison PI NE

Customer Sample Number:

Date / Time Collected: 7/6/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-014

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-017

Sample Location: 1st Draw 5052 Just St NE

Customer Sample Number:

Date / Time Collected: 6/29/2024 3:47 PM

Customer Program Code: DS

Laboratory Sample Number: 2407112-017

Date / Time Received: 7/15/2024 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	7/26/2024	Bprakash

Sample Location: 2nd Draw 5052 Just St NE

Customer Sample Number:

Date / Time Collected: 6/29/2024 3:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2407112-018

Date / Time Received: 7/15/2024 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-015

Sample Location: 1st Draw 524 INGRAHAM ST NW

Customer Sample Number:

Date / Time Collected: 5/28/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-015

Date / Time Received: 6/26/2024 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/6/2024	SBrooks

Sample Location: 2nd Draw 524 INGRAHAM ST NW

Customer Sample Number:

Date / Time Collected: 5/28/2024 5:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2407027-016

Date / Time Received: 6/26/2024 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L	H	7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2406161-007

Sample Location: 1st Draw 532 4th ST NE
Customer Sample Number:
Date / Time Collected: 6/14/2024 6:42 AM

Customer Program Code: DS
Laboratory Sample Number: 2406161-007
Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 532 4th ST NE
Customer Sample Number:
Date / Time Collected: 6/14/2024 6:44 AM

Customer Program Code: DS
Laboratory Sample Number: 2406161-008
Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407093-017

Sample Location: 1st Draw 5413 13th St NW

Customer Sample Number:

Date / Time Collected: 7/4/2024 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2407093-017

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 5413 13th St NW

Customer Sample Number:

Date / Time Collected: 7/4/2024 6:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2407093-018

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-015

Sample Location: 1st Draw 55 S St. NW
Customer Sample Number:
Date / Time Collected: 6/22/2024 12:28 PM

Customer Program Code: DS
Laboratory Sample Number: 2407035-015
Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 55 S St. NW
Customer Sample Number:
Date / Time Collected: 6/22/2024 12:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2407035-016
Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-013

Sample Location: 1st Draw 5818 8th St NE

Customer Sample Number:

Date / Time Collected: 6/21/2024 5:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-013

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 5818 8th St NE

Customer Sample Number:

Date / Time Collected: 6/21/2024 5:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-014

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-025

Sample Location: 1st Draw 5918 4th St. NW

Customer Sample Number:

Date / Time Collected: 6/19/2024 5:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2407027-025

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 5918 4th St. NW

Customer Sample Number:

Date / Time Collected: 6/19/2024 5:03 PM

Customer Program Code: DS

Laboratory Sample Number: 2407027-026

Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407160-005

Sample Location: 1st Draw 6317 2nd St NW

Customer Sample Number:

Date / Time Collected: 7/11/2024 4:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2407160-005

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 6317 2nd St NW

Customer Sample Number:

Date / Time Collected: 7/11/2024 4:46 PM

Customer Program Code: DS

Laboratory Sample Number: 2407160-006

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-001

Sample Location: 1st Draw 649 Acker PI NE

Customer Sample Number:

Date / Time Collected: 7/10/2024 6:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-001

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 649 Acker PI NE

Customer Sample Number:

Date / Time Collected: 7/10/2024 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-002

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407035-009

Sample Location: 1st Draw 650 Acker PL NE

Customer Sample Number:

Date / Time Collected: 6/14/2024 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-009

Date / Time Received: 7/1/2024 12:20:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/6/2024	SBrooks

Sample Location: 2nd Draw 650 Acker PL NE

Customer Sample Number:

Date / Time Collected: 6/14/2024 6:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2407035-010

Date / Time Received: 7/1/2024 12:20:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-007

Sample Location: 1st Draw 700 4th St. NE
Customer Sample Number:
Date / Time Collected: 6/17/2024 6:33 AM

Customer Program Code: DS
Laboratory Sample Number: 2407027-007
Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 700 4th St. NE
Customer Sample Number:
Date / Time Collected: 6/17/2024 6:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2407027-008
Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407093-015

Sample Location: 1st Draw 7114 Alaska Ave NW

Customer Sample Number:

Date / Time Collected: 7/8/2024 6:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2407093-015

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 7114 Alaska Ave NW

Customer Sample Number:

Date / Time Collected: 7/8/2024 6:59 PM

Customer Program Code: DS

Laboratory Sample Number: 2407093-016

Date / Time Received: 7/10/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407027-019

Sample Location: 1st Draw 718 I St. NE
Customer Sample Number:
Date / Time Collected: 6/17/2024 5:02 AM

Customer Program Code: DS
Laboratory Sample Number: 2407027-019
Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 718 I St. NE
Customer Sample Number:
Date / Time Collected: 6/17/2024 5:04 AM

Customer Program Code: DS
Laboratory Sample Number: 2407027-020
Date / Time Received: 6/26/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407112-011

Sample Location: 1st Draw 732 51st St SE

Customer Sample Number:

Date / Time Collected: 7/2/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-011

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 732 51st St SE

Customer Sample Number:

Date / Time Collected: 7/2/2024 7:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2407112-012

Date / Time Received: 7/15/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407160-003

Sample Location: 1st Draw 774 Irving St NW

Customer Sample Number:

Date / Time Collected: 7/15/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-003

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 774 Irving St NW

Customer Sample Number:

Date / Time Collected: 7/15/2024 7:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-004

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407088-015

Sample Location: 1st Draw 814 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 7/3/2024 5:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-015

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 814 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 7/3/2024 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2407088-016

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS-2407160-015

Sample Location: 1st Draw 8169 E Beach Dr NW

Customer Sample Number:

Date / Time Collected: 7/13/2024 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-015

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 8169 E Beach Dr NW

Customer Sample Number:

Date / Time Collected: 7/13/2024 6:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2407160-016

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS250- 2407159-001

Sample Location: 1st Draw 1280 21st St NW Apt 906

Customer Sample Number:

Date / Time Collected: 7/10/2024 10:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407159-001

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 1280 21st St NW Apt 906

Customer Sample Number:

Date / Time Collected: 7/10/2024 10:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407159-002

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS250- 2407034-001

Sample Location: 1st Draw 1401 Columbia Rd. NW #406

Customer Sample Number:

Date / Time Collected: 6/20/2024 7:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407034-001

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 1401 Columbia Rd. NW #406

Customer Sample Number:

Date / Time Collected: 6/20/2024 7:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407034-002

Date / Time Received: 7/1/2024 12:20:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS250- 2407087-003

Sample Location: 1st Draw 1915 Kalorama Rd NW Apt 511

Customer Sample Number:

Date / Time Collected: 7/1/2024 8:23 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407087-003

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 1915 Kalorama Rd NW Apt 511

Customer Sample Number:

Date / Time Collected: 7/1/2024 8:23 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407087-004

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS250- 2407087-005

Sample Location: 1st Draw 2500 Pomeroy Rd SE Apt 404

Customer Sample Number:

Date / Time Collected: 6/29/2024 7:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407087-005

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 2500 Pomeroy Rd SE Apt 404

Customer Sample Number:

Date / Time Collected: 6/29/2024 7:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407087-006

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS250- 2407159-003

Sample Location: 1st Draw 2517 Mozart PI NW Apt F

Customer Sample Number:

Date / Time Collected: 7/15/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407159-003

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Sample Location: 2nd Draw 2517 Mozart PI NW Apt F

Customer Sample Number:

Date / Time Collected: 7/15/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407159-004

Date / Time Received: 7/18/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS250- 2406160-001

Sample Location: 1st Draw 3120 R ST NW #208

Customer Sample Number:

Date / Time Collected: 6/13/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406160-001

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 3120 R ST NW #208

Customer Sample Number:

Date / Time Collected: 6/13/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406160-002

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS250- 2406160-003

Sample Location: 1st Draw 4000 Massachusetts Ave Apt 1606

Customer Sample Number:

Date / Time Collected: 6/14/2024 6:46 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406160-003

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/6/2024	SBrooks

Sample Location: 2nd Draw 4000 Massachusetts Ave Apt 1606

Customer Sample Number:

Date / Time Collected: 6/14/2024 6:46 AM

Customer Program Code: DS250

Laboratory Sample Number: 2406160-004

Date / Time Received: 6/21/2024 12:25:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/5/2024

Report Number: L-DC-DS250- 2407087-001

Sample Location: 1st Draw 4501 Conn. Ave #808

Customer Sample Number:

Date / Time Collected: 7/1/2024 7:27 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407087-001

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/16/2024	Bprakash

Sample Location: 2nd Draw 4501 Conn. Ave #808

Customer Sample Number:

Date / Time Collected: 7/1/2024 7:27 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407087-002

Date / Time Received: 7/9/2024 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/16/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-023

Sample Location: 1st Draw 1027 30th ST NW

Customer Sample Number:

Date / Time Collected: 7/18/2024 8:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-023

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1027 30th ST NW

Customer Sample Number:

Date / Time Collected: 7/18/2024 8:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-024

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-041

Sample Location: 1st Draw 125 12th ST NE

Customer Sample Number:

Date / Time Collected: 7/16/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-041

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 125 12th ST NE

Customer Sample Number:

Date / Time Collected: 7/16/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-042

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-045

Sample Location: 1st Draw 1517 C St SE

Customer Sample Number:

Date / Time Collected: 7/23/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-045

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1517 C St SE

Customer Sample Number:

Date / Time Collected: 7/23/2024 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-046

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407216-005

Sample Location: 1st Draw 1518 Kearney St NE

Customer Sample Number:

Date / Time Collected: 7/17/2024 5:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2407216-005

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1518 Kearney St NE

Customer Sample Number:

Date / Time Collected: 7/17/2024 5:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2407216-006

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-025

Sample Location: 1st Draw 1605 45th St. NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 6:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-025

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1605 45th St. NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 6:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-026

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-029

Sample Location: 1st Draw 1802 8th St NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-029

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1802 8th St NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-030

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-027

Sample Location: 1st Draw 213 Webster St NW

Customer Sample Number:

Date / Time Collected: 7/22/2024 5:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-027

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	28.0	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 213 Webster St NW

Customer Sample Number:

Date / Time Collected: 7/22/2024 5:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-028

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	50.7	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-049

Sample Location: 1st Draw 2306 2nd St. NE

Customer Sample Number:

Date / Time Collected: 7/16/2024 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-049

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 2306 2nd St. NE

Customer Sample Number:

Date / Time Collected: 7/16/2024 9:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-050

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-039

Sample Location: 1st Draw 249 Hawaii Ave NE

Customer Sample Number:

Date / Time Collected: 7/18/2024 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-039

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 249 Hawaii Ave NE

Customer Sample Number:

Date / Time Collected: 7/18/2024 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-040

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-043

Sample Location: 1st Draw 2725 Poplar St NW

Customer Sample Number:

Date / Time Collected: 7/20/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-043

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 2725 Poplar St NW

Customer Sample Number:

Date / Time Collected: 7/20/2024 8:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-044

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-019

Sample Location: 1st Draw 340 12th ST SE

Customer Sample Number:

Date / Time Collected: 7/19/2024 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-019

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 340 12th ST SE

Customer Sample Number:

Date / Time Collected: 7/19/2024 8:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-020

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-031

Sample Location: 1st Draw 3409 Newark St NW

Customer Sample Number:

Date / Time Collected: 7/19/2024 6:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-031

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 3409 Newark St NW

Customer Sample Number:

Date / Time Collected: 7/19/2024 6:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-032

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407216-007

Sample Location: 1st Draw 3500 Highwood Dr SE

Customer Sample Number:

Date / Time Collected: 7/16/2024 7:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2407216-007

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 3500 Highwood Dr SE

Customer Sample Number:

Date / Time Collected: 7/16/2024 7:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2407216-008

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407216-003

Sample Location: 1st Draw 3901 Military Rd NW

Customer Sample Number:

Date / Time Collected: 7/18/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2407216-003

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 3901 Military Rd NW

Customer Sample Number:

Date / Time Collected: 7/18/2024 6:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2407216-004

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-051

Sample Location: 1st Draw 409 Randolph St NW

Customer Sample Number:

Date / Time Collected: 7/19/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-051

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 409 Randolph St NW

Customer Sample Number:

Date / Time Collected: 7/19/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-052

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-047

Sample Location: 1st Draw 4941 BUTTERWORTH PL NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 5:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-047

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 4941 BUTTERWORTH PL NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 5:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-048

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-035

Sample Location: 1st Draw 517 E St. NE
Customer Sample Number:
Date / Time Collected: 7/21/2024 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2407207-035
Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 517 E St. NE
Customer Sample Number:
Date / Time Collected: 7/21/2024 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2407207-036
Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407216-001

Sample Location: 1st Draw 5439 31ST STREET NW

Customer Sample Number:

Date / Time Collected: 7/15/2024 3:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2407216-001

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 5439 31ST STREET NW

Customer Sample Number:

Date / Time Collected: 7/15/2024 3:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2407216-002

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-033

Sample Location: 1st Draw 5714 6th St NW

Customer Sample Number:

Date / Time Collected: 7/21/2024 6:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-033

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 5714 6th St NW

Customer Sample Number:

Date / Time Collected: 7/21/2024 6:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-034

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407216-009

Sample Location: 1st Draw 5922 Eastern Ave. NE

Customer Sample Number:

Date / Time Collected: 7/16/2024 7:02 PM

Customer Program Code: DS

Laboratory Sample Number: 2407216-009

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 5922 Eastern Ave. NE

Customer Sample Number:

Date / Time Collected: 7/16/2024 7:08 PM

Customer Program Code: DS

Laboratory Sample Number: 2407216-010

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS-2407207-021

Sample Location: 1st Draw 6907 6th ST NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 5:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-021

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 6907 6th ST NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 5:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2407207-022

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS250- 2408012-005

Sample Location: 1st Draw 1117 NEW HAMPSHIRE AVE

Customer Sample Number:

Date / Time Collected: 7/22/2024 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408012-005

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1117 NEW HAMPSHIRE AVE

Customer Sample Number:

Date / Time Collected: 7/22/2024 10:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408012-006

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS250- 2407209-001

Sample Location: 1st Draw 1212 12th St NW B

Customer Sample Number:

Date / Time Collected: 7/17/2024 5:51 PM

Customer Program Code: DS250

Laboratory Sample Number: 2407209-001

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1212 12th St NW B

Customer Sample Number:

Date / Time Collected: 7/17/2024 5:51 PM

Customer Program Code: DS250

Laboratory Sample Number: 2407209-002

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS250- 2408012-001

Sample Location: 1st Draw 1344 Monroe St NW #A

Customer Sample Number:

Date / Time Collected: 7/30/2024 6:12 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408012-001

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1344 Monroe St NW #A

Customer Sample Number:

Date / Time Collected: 7/30/2024 6:12 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408012-002

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS250- 2407209-003

Sample Location: 1st Draw 1909 M St NE #4

Customer Sample Number:

Date / Time Collected: 7/17/2024 7:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407209-003

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1909 M St NE #4

Customer Sample Number:

Date / Time Collected: 7/17/2024 7:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407209-004

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS250- 2407209-005

Sample Location: 1st Draw 5300 43rd St NW #202

Customer Sample Number:

Date / Time Collected: 7/14/2024 4:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407209-005

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 5300 43rd St NW #202

Customer Sample Number:

Date / Time Collected: 7/14/2024 4:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2407209-006

Date / Time Received: 7/22/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/13/2024

Report Number: L-DC-DS250- 2408012-003

Sample Location: 1st Draw 950 24th St. NW Apt# 707

Customer Sample Number:

Date / Time Collected: 7/29/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408012-003

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 950 24th St. NW Apt# 707

Customer Sample Number:

Date / Time Collected: 7/29/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408012-004

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-043

Sample Location: 1st Draw 1119 Independence SE

Customer Sample Number:

Date / Time Collected: 7/31/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-043

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1119 Independence SE

Customer Sample Number:

Date / Time Collected: 7/31/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-044

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-057

Sample Location: 1st Draw 1325 Sheridan St NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-057

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1325 Sheridan St NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-058

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-027

Sample Location: 1st Draw 1355 Spring Rd NW

Customer Sample Number:

Date / Time Collected: 7/29/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-027

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1355 Spring Rd NW

Customer Sample Number:

Date / Time Collected: 7/29/2024 7:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-028

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-053

Sample Location: 1st Draw 1427 Ives PL SE

Customer Sample Number:

Date / Time Collected: 7/21/2024 8:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-053

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1427 Ives PL SE

Customer Sample Number:

Date / Time Collected: 7/21/2024 8:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-054

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-055

Sample Location: 1st Draw 1808 A St SE

Customer Sample Number:

Date / Time Collected: 7/26/2024 6:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-055

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1808 A St SE

Customer Sample Number:

Date / Time Collected: 7/26/2024 6:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-056

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-059

Sample Location: 1st Draw 1816 Varnum St NW

Customer Sample Number:

Date / Time Collected: 7/28/2024 7:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-059

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 1816 Varnum St NW

Customer Sample Number:

Date / Time Collected: 7/28/2024 7:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-060

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-071

Sample Location: 1st Draw 2030 F St NW Apt. 505

Customer Sample Number:

Date / Time Collected: 7/22/2024 11:39 PM

Customer Program Code: DS

Laboratory Sample Number: 2408015-071

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 2030 F St NW Apt. 505

Customer Sample Number:

Date / Time Collected: 7/22/2024 11:41 PM

Customer Program Code: DS

Laboratory Sample Number: 2408015-072

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-073

Sample Location: 1st Draw 2216 4 PI SE
Customer Sample Number:
Date / Time Collected: 7/24/2024 2:13 PM

Customer Program Code: DS
Laboratory Sample Number: 2408015-073
Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 2216 4 PI SE
Customer Sample Number:
Date / Time Collected: 7/24/2024 2:15 PM

Customer Program Code: DS
Laboratory Sample Number: 2408015-074
Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-037

Sample Location: 1st Draw 28 Crittenden ST NE

Customer Sample Number:

Date / Time Collected: 7/23/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-037

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 28 Crittenden ST NE

Customer Sample Number:

Date / Time Collected: 7/23/2024 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-038

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-063

Sample Location: 1st Draw 3 Pomander Walk NW

Customer Sample Number:

Date / Time Collected: 7/31/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-063

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 3 Pomander Walk NW

Customer Sample Number:

Date / Time Collected: 7/31/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-064

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-045

Sample Location: 1st Draw 3038 Cambridge PI NW

Customer Sample Number:

Date / Time Collected: 7/18/2024 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-045

Date / Time Received: 8/2/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	8/7/2024	Rlamsal

Sample Location: 2nd Draw 3038 Cambridge PI NW

Customer Sample Number:

Date / Time Collected: 7/18/2024 7:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-046

Date / Time Received: 8/2/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-029

Sample Location: 1st Draw 3039 M St NW A

Customer Sample Number:

Date / Time Collected: 7/28/2024 10:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-029

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 3039 M St NW A

Customer Sample Number:

Date / Time Collected: 7/28/2024 10:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-030

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-069

Sample Location: 1st Draw 330 9th ST NE

Customer Sample Number:

Date / Time Collected: 7/29/2024 5:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2408015-069

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 330 9th ST NE

Customer Sample Number:

Date / Time Collected: 7/29/2024 5:21 PM

Customer Program Code: DS

Laboratory Sample Number: 2408015-070

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-049

Sample Location: 1st Draw 3423 Oakwood Terrace NW

Customer Sample Number:

Date / Time Collected: 7/28/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-049

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 3423 Oakwood Terrace NW

Customer Sample Number:

Date / Time Collected: 7/28/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-050

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-039

Sample Location: 1st Draw 4117 Fessenden St NW

Customer Sample Number:

Date / Time Collected: 7/28/2024 9:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-039

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 4117 Fessenden St NW

Customer Sample Number:

Date / Time Collected: 7/28/2024 9:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-040

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-061

Sample Location: 1st Draw 4210 8th St NW

Customer Sample Number:

Date / Time Collected: 7/29/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-061

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 4210 8th St NW

Customer Sample Number:

Date / Time Collected: 7/29/2024 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-062

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-065

Sample Location: 1st Draw 4216 Grant St NE

Customer Sample Number:

Date / Time Collected: 7/28/2024 8:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-065

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 4216 Grant St NE

Customer Sample Number:

Date / Time Collected: 7/28/2024 8:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-066

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-041

Sample Location: 1st Draw 4619 Alton Place NW

Customer Sample Number:

Date / Time Collected: 7/28/2024 6:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2408015-041

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 4619 Alton Place NW

Customer Sample Number:

Date / Time Collected: 7/28/2024 6:18 PM

Customer Program Code: DS

Laboratory Sample Number: 2408015-042

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-047

Sample Location: 1st Draw 4820 B Street SE

Customer Sample Number:

Date / Time Collected: 7/22/2024 3:09 PM

Customer Program Code: DS

Laboratory Sample Number: 2408015-047

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 4820 B Street SE

Customer Sample Number:

Date / Time Collected: 7/22/2024 3:13 PM

Customer Program Code: DS

Laboratory Sample Number: 2408015-048

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-035

Sample Location: 1st Draw 5008 44th St NW

Customer Sample Number:

Date / Time Collected: 7/27/2024 8:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-035

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 5008 44th St NW

Customer Sample Number:

Date / Time Collected: 7/27/2024 8:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-036

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-023

Sample Location: 1st Draw 5108 Jay St NE

Customer Sample Number:

Date / Time Collected: 7/28/2024 11:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-023

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 5108 Jay St NE

Customer Sample Number:

Date / Time Collected: 7/28/2024 11:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-024

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-033

Sample Location: 1st Draw 5213 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 7/24/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-033

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 5213 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 7/24/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-034

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-031

Sample Location: 1st Draw 626 L Street NE

Customer Sample Number:

Date / Time Collected: 7/22/2024 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-031

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 626 L Street NE

Customer Sample Number:

Date / Time Collected: 7/22/2024 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-032

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-051

Sample Location: 1st Draw 6431 Utah Ave NW

Customer Sample Number:

Date / Time Collected: 7/29/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-051

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 6431 Utah Ave NW

Customer Sample Number:

Date / Time Collected: 7/29/2024 5:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-052

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-075

Sample Location: 1st Draw 708 13th ST NE Unit A

Customer Sample Number:

Date / Time Collected: 7/30/2024 6:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-075

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 708 13th ST NE Unit A

Customer Sample Number:

Date / Time Collected: 7/30/2024 6:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-076

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/19/2024

Report Number: L-DC-DS-2408015-067

Sample Location: 1st Draw 906 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 7/22/2024 7:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-067

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/7/2024	Rlamsal

Sample Location: 2nd Draw 906 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 7/22/2024 7:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-068

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/10/2024

Report Number: L-DC-DS- 2408015-025

Sample Location: 1st Draw 127 16th St NE

Customer Sample Number:

Date / Time Collected: 7/23/2024 8:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-025

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		9/4/2024	SBrooks

Sample Location: 2nd Draw 127 16th St NE

Customer Sample Number:

Date / Time Collected: 7/23/2024 8:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2408015-026

Date / Time Received: 8/2/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/10/2024

Report Number: L-DC-DS- 2407207-037

Sample Location: 1st Draw 2312 Shannon PI SE

Customer Sample Number:

Date / Time Collected: 7/19/2024 1:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2407207-037

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		9/4/2024	SBrooks

Sample Location: 2nd Draw 2312 Shannon PI SE

Customer Sample Number:

Date / Time Collected: 7/19/2024 1:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2407207-038

Date / Time Received: 7/29/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/7/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408199-001

Sample Location: 1st Draw 1 Gessford Ct
Customer Sample Number:
Date / Time Collected: 8/19/2024 7:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2408199-001
Date / Time Received: 8/22/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1 Gessford Ct
Customer Sample Number:
Date / Time Collected: 8/19/2024 7:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2408199-002
Date / Time Received: 8/22/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408200-025

Sample Location: 1st Draw 1002 K St. NE
Customer Sample Number:
Date / Time Collected: 8/10/2024 7:39 AM

Customer Program Code: DS
Laboratory Sample Number: 2408200-025
Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1002 K St. NE
Customer Sample Number:
Date / Time Collected: 8/10/2024 7:42 AM

Customer Program Code: DS
Laboratory Sample Number: 2408200-026
Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408198-011

Sample Location: 1st Draw 1109 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 8/12/2024 4:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2408198-011

Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1109 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 8/12/2024 4:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2408198-012

Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408200-013

Sample Location: 1st Draw 1128 4th St. NE

Customer Sample Number:

Date / Time Collected: 8/8/2024 7:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-013

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1128 4th St. NE

Customer Sample Number:

Date / Time Collected: 8/8/2024 7:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-014

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2409021-043

Sample Location: 1st Draw 1214 Euclid NW, #1

Customer Sample Number:

Date / Time Collected: 8/26/2024 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-043

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1214 Euclid NW, #1

Customer Sample Number:

Date / Time Collected: 8/26/2024 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-044

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408199-027

Sample Location: 1st Draw 1302 S St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2024 6:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2408199-027

Date / Time Received: 8/22/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1302 S St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2024 6:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2408199-028

Date / Time Received: 8/22/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408201-033

Sample Location: 1st Draw 1324 Corbin PL NE

Customer Sample Number:

Date / Time Collected: 8/12/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-033

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1324 Corbin PL NE

Customer Sample Number:

Date / Time Collected: 8/12/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-034

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408200-003

Sample Location: 1st Draw 1333 Madison St. NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 5:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-003

Date / Time Received: 8/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/6/2024	SBrooks

Sample Location: 2nd Draw 1333 Madison St. NW

Customer Sample Number:

Date / Time Collected: 7/23/2024 5:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-004

Date / Time Received: 8/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408056-025

Sample Location: 1st Draw 1340 31st St NW

Customer Sample Number:

Date / Time Collected: 7/30/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2408056-025

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/11/2024	SBrooks

Sample Location: 2nd Draw 1340 31st St NW

Customer Sample Number:

Date / Time Collected: 7/30/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2408056-026

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/11/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408198-003

Sample Location: 1st Draw 1360 East Captial St NE
Customer Sample Number:
Date / Time Collected: 8/15/2024 5:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2408198-003
Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1360 East Captial St NE
Customer Sample Number:
Date / Time Collected: 8/15/2024 5:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2408198-004
Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408056-031

Sample Location: 1st Draw 1415 1st St NW

Customer Sample Number:

Date / Time Collected: 7/29/2024 12:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2408056-031

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		9/11/2024	SBrooks

Sample Location: 2nd Draw 1415 1st St NW

Customer Sample Number:

Date / Time Collected: 7/29/2024 12:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2408056-032

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		9/11/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408056-021

Sample Location: 1st Draw 1437 R. St NW Unit 2A

Customer Sample Number:

Date / Time Collected: 8/1/2024 4:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2408056-021

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/11/2024	SBrooks

Sample Location: 2nd Draw 1437 R. St NW Unit 2A

Customer Sample Number:

Date / Time Collected: 8/1/2024 4:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2408056-022

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/11/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS- 2409021-051

Sample Location: 1st Draw 1451 S. Carolina Ave, SE

Customer Sample Number:

Date / Time Collected: 8/27/2024 8:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-051

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1451 S. Carolina Ave, SE

Customer Sample Number:

Date / Time Collected: 8/27/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-052

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS- 2409021-039

Sample Location: 1st Draw 1600 Otis St. NE

Customer Sample Number:

Date / Time Collected: 8/25/2024 6:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2409021-039

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1600 Otis St. NE

Customer Sample Number:

Date / Time Collected: 8/25/2024 6:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2409021-040

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408201-005

Sample Location: 1st Draw 1616 Allison St. NW

Customer Sample Number:

Date / Time Collected: 8/3/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-005

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	9/6/2024	SBrooks

Sample Location: 2nd Draw 1616 Allison St. NW

Customer Sample Number:

Date / Time Collected: 8/3/2024 6:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-006

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS- 2409021-035

Sample Location: 1st Draw 1623 45th St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2024 8:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-035

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1623 45th St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2024 8:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-036

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408201-009

Sample Location: 1st Draw 1849 3rd St. NW

Customer Sample Number:

Date / Time Collected: 8/5/2024 9:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-009

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/6/2024	SBrooks

Sample Location: 2nd Draw 1849 3rd St. NW

Customer Sample Number:

Date / Time Collected: 8/5/2024 9:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-010

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408056-023

Sample Location: 1st Draw 2145 Decatur PI NW

Customer Sample Number:

Date / Time Collected: 8/2/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2408056-023

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/11/2024	SBrooks

Sample Location: 2nd Draw 2145 Decatur PI NW

Customer Sample Number:

Date / Time Collected: 8/2/2024 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2408056-024

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/11/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408200-005

Sample Location: 1st Draw 2210 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 8/2/2024 11:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-005

Date / Time Received: 8/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L	H	9/6/2024	SBrooks

Sample Location: 2nd Draw 2210 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 8/2/2024 11:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-006

Date / Time Received: 8/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408198-001

Sample Location: 1st Draw 2216 Observatory Place NW

Customer Sample Number:

Date / Time Collected: 8/21/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2408198-001

Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 2216 Observatory Place NW

Customer Sample Number:

Date / Time Collected: 8/21/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2408198-002

Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408201-037

Sample Location: 1st Draw 2412 Chain Bridge Rd. NW

Customer Sample Number:

Date / Time Collected: 8/12/2024 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2408201-037

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 2412 Chain Bridge Rd. NW

Customer Sample Number:

Date / Time Collected: 8/12/2024 5:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2408201-038

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Report Date: 9/16/2024

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2408201-013

Sample Location: 1st Draw 249 16th St. SE

Customer Sample Number:

Date / Time Collected: 8/7/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-013

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 249 16th St. SE

Customer Sample Number:

Date / Time Collected: 8/7/2024 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-014

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408056-027

Sample Location: 1st Draw 3031 K St. SE
Customer Sample Number:
Date / Time Collected: 8/2/2024 5:27 AM

Customer Program Code: DS
Laboratory Sample Number: 2408056-027
Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/11/2024	SBrooks

Sample Location: 2nd Draw 3031 K St. SE
Customer Sample Number:
Date / Time Collected: 8/2/2024 5:28 AM

Customer Program Code: DS
Laboratory Sample Number: 2408056-028
Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/11/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408198-007

Sample Location: 1st Draw 3134 Ordway St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2024 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2408198-007

Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 3134 Ordway St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2024 6:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2408198-008

Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS- 2409021-037

Sample Location: 1st Draw 3305 O St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-037

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 3305 O St. NW

Customer Sample Number:

Date / Time Collected: 8/25/2024 8:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-038

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408198-009

Sample Location: 1st Draw 3532 S St NW

Customer Sample Number:

Date / Time Collected: 8/11/2024 8:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2408198-009

Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 3532 S St NW

Customer Sample Number:

Date / Time Collected: 8/11/2024 8:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2408198-010

Date / Time Received: 8/23/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408169-013

Sample Location: 1st Draw 3724 Jocelyn St. NW

Customer Sample Number:

Date / Time Collected: 8/14/2024 2:47 PM

Customer Program Code: DS

Laboratory Sample Number: 2408169-013

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/5/2024	SBrooks

Sample Location: 2nd Draw 3724 Jocelyn St. NW

Customer Sample Number:

Date / Time Collected: 8/14/2024 2:51 PM

Customer Program Code: DS

Laboratory Sample Number: 2408169-014

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408201-007

Sample Location: 1st Draw 3834 Calvert St

Customer Sample Number:

Date / Time Collected: 8/5/2024 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-007

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/6/2024	SBrooks

Sample Location: 2nd Draw 3834 Calvert St

Customer Sample Number:

Date / Time Collected: 8/5/2024 7:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-008

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408056-017

Sample Location: 1st Draw 3941 Legation St NW

Customer Sample Number:

Date / Time Collected: 8/2/2024 9:23 PM

Customer Program Code: DS

Laboratory Sample Number: 2408056-017

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/11/2024	SBrooks

Sample Location: 2nd Draw 3941 Legation St NW

Customer Sample Number:

Date / Time Collected: 8/2/2024 9:27 PM

Customer Program Code: DS

Laboratory Sample Number: 2408056-018

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/11/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2409021-023

Sample Location: 1st Draw 412 Webster St. NW

Customer Sample Number:

Date / Time Collected: 8/23/2024 6:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2409021-023

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/5/2024	SBrooks

Sample Location: 2nd Draw 412 Webster St. NW

Customer Sample Number:

Date / Time Collected: 8/23/2024 6:28 PM

Customer Program Code: DS

Laboratory Sample Number: 2409021-024

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408199-003

Sample Location: 1st Draw 4131 New Hampshire Ave. NW

Customer Sample Number:

Date / Time Collected: 8/17/2024 4:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2408199-003

Date / Time Received: 8/22/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 4131 New Hampshire Ave. NW

Customer Sample Number:

Date / Time Collected: 8/17/2024 4:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2408199-004

Date / Time Received: 8/22/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408200-037

Sample Location: 1st Draw 4341 Ellicott St, NW

Customer Sample Number:

Date / Time Collected: 8/12/2024 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-037

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 4341 Ellicott St, NW

Customer Sample Number:

Date / Time Collected: 8/12/2024 6:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-038

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408200-031

Sample Location: 1st Draw 4456 Q St NW

Customer Sample Number:

Date / Time Collected: 8/10/2024 9:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-031

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 4456 Q St NW

Customer Sample Number:

Date / Time Collected: 8/10/2024 9:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-032

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408201-021

Sample Location: 1st Draw 5020 Klinge St, NW

Customer Sample Number:

Date / Time Collected: 8/9/2024 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-021

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 5020 Klinge St, NW

Customer Sample Number:

Date / Time Collected: 8/9/2024 6:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-022

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS- 2408200-021

Sample Location: 1st Draw 511 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 8/9/2024 7:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-021

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 511 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 8/9/2024 7:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-022

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS- 2409021-027

Sample Location: 1st Draw 519 17th St. SE

Customer Sample Number:

Date / Time Collected: 8/24/2024 9:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-027

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 519 17th St. SE

Customer Sample Number:

Date / Time Collected: 8/24/2024 9:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-028

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408201-001

Sample Location: 1st Draw 5249 42nd St. NW

Customer Sample Number:

Date / Time Collected: 8/13/2024 7:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-001

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 5249 42nd St. NW

Customer Sample Number:

Date / Time Collected: 8/13/2024 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2408201-002

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2409021-003

Sample Location: 1st Draw 530 Foxhall PL SE

Customer Sample Number:

Date / Time Collected: 8/14/2024 11:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-003

Date / Time Received: 8/30/2024 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	9/5/2024	SBrooks

Sample Location: 2nd Draw 530 Foxhall PL SE

Customer Sample Number:

Date / Time Collected: 8/14/2024 11:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2409021-004

Date / Time Received: 8/30/2024 9:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408200-007

Sample Location: 1st Draw 5334 James PL NE

Customer Sample Number:

Date / Time Collected: 8/3/2024 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-007

Date / Time Received: 8/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/6/2024	SBrooks

Sample Location: 2nd Draw 5334 James PL NE

Customer Sample Number:

Date / Time Collected: 8/3/2024 7:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2408200-008

Date / Time Received: 8/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408056-019

Sample Location: 1st Draw 54 Allison St NE

Customer Sample Number:

Date / Time Collected: 8/2/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2408056-019

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/11/2024	SBrooks

Sample Location: 2nd Draw 54 Allison St NE

Customer Sample Number:

Date / Time Collected: 8/2/2024 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2408056-020

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/11/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS- 2409021-047

Sample Location: 1st Draw 5613 32nd St. NW

Customer Sample Number:

Date / Time Collected: 8/26/2024 1:18 PM

Customer Program Code: DS

Laboratory Sample Number: 2409021-047

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 5613 32nd St. NW

Customer Sample Number:

Date / Time Collected: 8/26/2024 1:21 PM

Customer Program Code: DS

Laboratory Sample Number: 2409021-048

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408201-003

Sample Location: 1st Draw 801 20th St. NE

Customer Sample Number:

Date / Time Collected: 8/3/2024 1:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2408201-003

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	9/6/2024	SBrooks

Sample Location: 2nd Draw 801 20th St. NE

Customer Sample Number:

Date / Time Collected: 8/3/2024 1:32 PM

Customer Program Code: DS

Laboratory Sample Number: 2408201-004

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS-2408056-029

Sample Location: 1st Draw 830 D St SE
Customer Sample Number:
Date / Time Collected: 7/28/2024 7:41 AM

Customer Program Code: DS
Laboratory Sample Number: 2408056-029
Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/11/2024	SBrooks

Sample Location: 2nd Draw 830 D St SE
Customer Sample Number:
Date / Time Collected: 7/28/2024 7:41 AM

Customer Program Code: DS
Laboratory Sample Number: 2408056-030
Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/11/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS250- 2408168-009

Sample Location: 1st Draw 1331 VERMONT AVE NW APT B

Customer Sample Number:

Date / Time Collected: 8/20/2024 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-009

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		9/5/2024	SBrooks

Sample Location: 2nd Draw 1331 VERMONT AVE NW APT B

Customer Sample Number:

Date / Time Collected: 8/20/2024 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-010

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS250- 2408055-001

Sample Location: 1st Draw 1448 Newton St NW Apt. B

Customer Sample Number:

Date / Time Collected: 8/1/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408055-001

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1448 Newton St NW Apt. B

Customer Sample Number:

Date / Time Collected: 8/1/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408055-002

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS250- 2408168-005

Sample Location: 1st Draw 1701 Massachusetts Ave NW, Apt 801

Customer Sample Number:

Date / Time Collected: 8/16/2024 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-005

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/5/2024	SBrooks

Sample Location: 2nd Draw 1701 Massachusetts Ave NW, Apt 801

Customer Sample Number:

Date / Time Collected: 8/16/2024 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-006

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS250- 2408171-003

Sample Location: 1st Draw 1730 New Hampshire Ave. NW #7

Customer Sample Number:

Date / Time Collected: 8/7/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408171-003

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/5/2024	SBrooks

Sample Location: 2nd Draw 1730 New Hampshire Ave. NW #7

Customer Sample Number:

Date / Time Collected: 8/7/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408171-004

Date / Time Received: 8/20/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS250- 2408171-001

Sample Location: 1st Draw 1744 U St. NW #K

Customer Sample Number:

Date / Time Collected: 8/2/2024 8:53 PM

Customer Program Code: DS250

Laboratory Sample Number: 2408171-001

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	9/5/2024	SBrooks

Sample Location: 2nd Draw 1744 U St. NW #K

Customer Sample Number:

Date / Time Collected: 8/2/2024 8:53 PM

Customer Program Code: DS250

Laboratory Sample Number: 2408171-002

Date / Time Received: 8/20/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS250- 2408055-005

Sample Location: 1st Draw 1791 Lanier PI NW Apt. 44

Customer Sample Number:

Date / Time Collected: 7/31/2024 9:09 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408055-005

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 1791 Lanier PI NW Apt. 44

Customer Sample Number:

Date / Time Collected: 7/31/2024 9:09 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408055-006

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Report Date: 9/16/2024

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2408172-003

Sample Location: 1st Draw 1930 Columbia Rd. NW, Apt. 712

Customer Sample Number:

Date / Time Collected: 8/8/2024 9:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408172-003

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/5/2024	SBrooks

Sample Location: 2nd Draw 1930 Columbia Rd. NW, Apt. 712

Customer Sample Number:

Date / Time Collected: 8/8/2024 9:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408172-004

Date / Time Received: 8/21/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS250- 2408172-001

Sample Location: 1st Draw 2330 Marion Barry Ave. SE, #316

Customer Sample Number:

Date / Time Collected: 8/5/2024 7:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2408172-001

Date / Time Received: 8/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/5/2024	SBrooks

Sample Location: 2nd Draw 2330 Marion Barry Ave. SE, #316

Customer Sample Number:

Date / Time Collected: 8/5/2024 7:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2408172-002

Date / Time Received: 8/21/2024 9:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Report Date: 9/16/2024

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2408168-003

Sample Location: 1st Draw 2410 20th St. NW, Apt. 2

Customer Sample Number:

Date / Time Collected: 8/14/2024 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-003

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/5/2024	SBrooks

Sample Location: 2nd Draw 2410 20th St. NW, Apt. 2

Customer Sample Number:

Date / Time Collected: 8/14/2024 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-004

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Report Date: 9/16/2024

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2408168-001

Sample Location: 1st Draw 3133 Connecticut Ave. NW Apt. 1019

Customer Sample Number:

Date / Time Collected: 8/13/2024 7:31 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-001

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/5/2024	SBrooks

Sample Location: 2nd Draw 3133 Connecticut Ave. NW Apt. 1019

Customer Sample Number:

Date / Time Collected: 8/13/2024 7:31 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-002

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS250- 2408055-003

Sample Location: 1st Draw 3801Conn. Ave NW, 714

Customer Sample Number:

Date / Time Collected: 8/4/2024 7:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408055-003

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/6/2024	SBrooks

Sample Location: 2nd Draw 3801Conn. Ave NW, 714

Customer Sample Number:

Date / Time Collected: 8/4/2024 7:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408055-004

Date / Time Received: 8/7/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/6/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2024

Report Number: L-DC-DS250- 2408168-007

Sample Location: 1st Draw 630 11th St. NE, Apt. 202

Customer Sample Number:

Date / Time Collected: 8/20/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-007

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/5/2024	SBrooks

Sample Location: 2nd Draw 630 11th St. NE, Apt. 202

Customer Sample Number:

Date / Time Collected: 8/20/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408168-008

Date / Time Received: 8/26/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/5/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-043

Sample Location: 1st Draw 115 Seaton PL NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 9:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-043

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 115 Seaton PL NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 9:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-044

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409065-005

Sample Location: 1st Draw 1203 Linden PL NE

Customer Sample Number:

Date / Time Collected: 8/24/2024 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-005

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 1203 Linden PL NE

Customer Sample Number:

Date / Time Collected: 8/24/2024 6:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-006

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-039

Sample Location: 1st Draw 1216 Shepherd St., NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-039

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 1216 Shepherd St., NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-040

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409094-044

Sample Location: 1st Draw 1229 Michigan Ave. NE

Customer Sample Number:

Date / Time Collected: 9/2/2024 7:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-044

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 1229 Michigan Ave. NE

Customer Sample Number:

Date / Time Collected: 9/2/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-045

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409094-019

Sample Location: 1st Draw 1239 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 8/28/2024 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-019

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 1239 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 8/28/2024 7:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-020

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-041

Sample Location: 1st Draw 1308 W St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-041

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 1308 W St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-042

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-023

Sample Location: 1st Draw 1438 W St SE
Customer Sample Number:
Date / Time Collected: 9/6/2024 10:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2409095-023
Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 1438 W St SE
Customer Sample Number:
Date / Time Collected: 9/6/2024 10:07 AM

Customer Program Code: DS
Laboratory Sample Number: 2409095-024
Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-047

Sample Location: 1st Draw 148 Wilmington PL SE

Customer Sample Number:

Date / Time Collected: 9/9/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-047

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 148 Wilmington PL SE

Customer Sample Number:

Date / Time Collected: 9/9/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-048

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-029

Sample Location: 1st Draw 1636 Roxanna Rd. NW

Customer Sample Number:

Date / Time Collected: 9/7/2024 6:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-029

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 1636 Roxanna Rd. NW

Customer Sample Number:

Date / Time Collected: 9/7/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-030

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-045

Sample Location: 1st Draw 2025 N St. NW

Customer Sample Number:

Date / Time Collected: 9/9/2024 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-045

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 2025 N St. NW

Customer Sample Number:

Date / Time Collected: 9/9/2024 6:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-046

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409065-001

Sample Location: 1st Draw 2200 Massachusetts Ave. NW

Customer Sample Number:

Date / Time Collected: 8/27/2024 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-001

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 2200 Massachusetts Ave. NW

Customer Sample Number:

Date / Time Collected: 8/27/2024 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-002

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409065-003

Sample Location: 1st Draw 3006 Ordway St NW

Customer Sample Number:

Date / Time Collected: 8/23/2024 8:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-003

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 3006 Ordway St NW

Customer Sample Number:

Date / Time Collected: 8/23/2024 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-004

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-019

Sample Location: 1st Draw 3317 16th ST NW, #1

Customer Sample Number:

Date / Time Collected: 9/6/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-019

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 3317 16th ST NW, #1

Customer Sample Number:

Date / Time Collected: 9/6/2024 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-020

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409095-063

Sample Location: 1st Draw 3508 Whitehaven Pkwy

Customer Sample Number:

Date / Time Collected: 9/11/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-063

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 3508 Whitehaven Pkwy

Customer Sample Number:

Date / Time Collected: 9/11/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-064

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409094-046

Sample Location: 1st Draw 3637 Appleton St. NW

Customer Sample Number:

Date / Time Collected: 9/2/2024 10:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-046

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 3637 Appleton St. NW

Customer Sample Number:

Date / Time Collected: 9/2/2024 10:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-047

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409094-027

Sample Location: 1st Draw 4102 38th St NW

Customer Sample Number:

Date / Time Collected: 8/29/2024 6:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-027

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 4102 38th St NW

Customer Sample Number:

Date / Time Collected: 8/29/2024 6:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-028

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409065-007

Sample Location: 1st Draw 4225 13th St NE

Customer Sample Number:

Date / Time Collected: 8/24/2024 7:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-007

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 4225 13th St NE

Customer Sample Number:

Date / Time Collected: 8/24/2024 7:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-008

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409094-041

Sample Location: 1st Draw 4311 Albemarle St. NW

Customer Sample Number:

Date / Time Collected: 9/2/2024 5:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-041

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.2	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409065-011

Sample Location: 1st Draw 5066 G St SE

Customer Sample Number:

Date / Time Collected: 8/26/2024 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-011

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 5066 G St SE

Customer Sample Number:

Date / Time Collected: 8/26/2024 6:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-012

Date / Time Received: 9/4/2024 9:22:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409095-051

Sample Location: 1st Draw 512 G St NE
Customer Sample Number:
Date / Time Collected: 9/9/2024 6:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2409095-051
Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 512 G St NE
Customer Sample Number:
Date / Time Collected: 9/9/2024 6:05 PM

Customer Program Code: DS
Laboratory Sample Number: 2409095-052
Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-037

Sample Location: 1st Draw 5235 Sherier PI NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-037

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 5235 Sherier PI NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-038

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409094-003

Sample Location: 1st Draw 5435 30th PL NW

Customer Sample Number:

Date / Time Collected: 9/2/2024 3:07 PM

Customer Program Code: DS

Laboratory Sample Number: 2409094-003

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 5435 30th PL NW

Customer Sample Number:

Date / Time Collected: 9/2/2024 3:09 PM

Customer Program Code: DS

Laboratory Sample Number: 2409094-004

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409094-017

Sample Location: 1st Draw 559 23rd PI NE

Customer Sample Number:

Date / Time Collected: 8/28/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-017

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 559 23rd PI NE

Customer Sample Number:

Date / Time Collected: 8/28/2024 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-018

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409065-009

Sample Location: 1st Draw 5747 13th St NW

Customer Sample Number:

Date / Time Collected: 8/20/2024 4:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-009

Date / Time Received: 9/4/2024 9:22:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	9/19/2024	Bprakash

Sample Location: 2nd Draw 5747 13th St NW

Customer Sample Number:

Date / Time Collected: 8/20/2024 4:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2409065-010

Date / Time Received: 9/4/2024 9:22:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L	H	9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS- 2409095-017

Sample Location: 1st Draw 613 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 9/5/2024 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2409095-017

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 613 Independence Ave. SE

Customer Sample Number:

Date / Time Collected: 9/5/2024 4:33 PM

Customer Program Code: DS

Laboratory Sample Number: 2409095-018

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409095-035

Sample Location: 1st Draw 6811 8th St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-035

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 6811 8th St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2024 6:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2409095-036

Date / Time Received: 9/12/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409094-001

Sample Location: 1st Draw 768 Harvard St NW

Customer Sample Number:

Date / Time Collected: 8/26/2024 7:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-001

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 768 Harvard St NW

Customer Sample Number:

Date / Time Collected: 8/26/2024 7:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-002

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS-2409094-021

Sample Location: 1st Draw 804 RITTENHOUSE ST NW

Customer Sample Number:

Date / Time Collected: 8/28/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-021

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 804 RITTENHOUSE ST NW

Customer Sample Number:

Date / Time Collected: 8/28/2024 9:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2409094-022

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS250- 2409088-001

Sample Location: 1st Draw 2550 17th St. NW #301

Customer Sample Number:

Date / Time Collected: 8/26/2024 9:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2409088-001

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 2550 17th St. NW #301

Customer Sample Number:

Date / Time Collected: 8/26/2024 9:56 AM

Customer Program Code: DS250

Laboratory Sample Number: 2409088-002

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS250- 2408207-001

Sample Location: 1st Draw 421 Constitution Ave. NE, Apt.1

Customer Sample Number:

Date / Time Collected: 8/26/2024 6:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408207-001

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	BPrakash

Sample Location: 2nd Draw 421 Constitution Ave. NE, Apt.1

Customer Sample Number:

Date / Time Collected: 8/26/2024 6:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2408207-002

Date / Time Received: 8/30/2024 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/30/2024

Report Number: L-DC-DS250- 2409088-003

Sample Location: 1st Draw 626 Independence Ave. SE Apt. 105

Customer Sample Number:

Date / Time Collected: 8/28/2024 6:54 AM

Customer Program Code: DS250

Laboratory Sample Number: 2409088-003

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Sample Location: 2nd Draw 626 Independence Ave. SE Apt. 105

Customer Sample Number:

Date / Time Collected: 8/28/2024 6:54 AM

Customer Program Code: DS250

Laboratory Sample Number: 2409088-004

Date / Time Received: 9/5/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/19/2024	Bprakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-017

Sample Location: 1st Draw 1015 Girard St. NE

Customer Sample Number:

Date / Time Collected: 9/21/2024 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-017

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1015 Girard St. NE

Customer Sample Number:

Date / Time Collected: 9/21/2024 6:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-018

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-013

Sample Location: 1st Draw 1315 Florida Ave. NW

Customer Sample Number:

Date / Time Collected: 9/20/2024 7:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-013

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1315 Florida Ave. NW

Customer Sample Number:

Date / Time Collected: 9/20/2024 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-014

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-015

Sample Location: 1st Draw 1364 W ST NE

Customer Sample Number:

Date / Time Collected: 9/20/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-015

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1364 W ST NE

Customer Sample Number:

Date / Time Collected: 9/20/2024 7:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-016

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-041

Sample Location: 1st Draw 1608 C St. NE
Customer Sample Number:
Date / Time Collected: 9/23/2024 7:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2410040-041
Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1608 C St. NE
Customer Sample Number:
Date / Time Collected: 9/23/2024 7:48 AM

Customer Program Code: DS
Laboratory Sample Number: 2410040-042
Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-011

Sample Location: 1st Draw 1610 Trinidad Ave. NE

Customer Sample Number:

Date / Time Collected: 9/19/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-011

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1610 Trinidad Ave. NE

Customer Sample Number:

Date / Time Collected: 9/19/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-012

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-001

Sample Location: 1st Draw 1639 Kalmia Rd NW

Customer Sample Number:

Date / Time Collected: 9/14/2024 11:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-001

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1639 Kalmia Rd NW

Customer Sample Number:

Date / Time Collected: 9/14/2024 11:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-002

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-009

Sample Location: 1st Draw 1714 Hobart St. NW

Customer Sample Number:

Date / Time Collected: 9/18/2024 7:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2410040-009

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1714 Hobart St. NW

Customer Sample Number:

Date / Time Collected: 9/18/2024 7:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2410040-010

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-005

Sample Location: 1st Draw 1775 Lang PL NE

Customer Sample Number:

Date / Time Collected: 9/17/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-005

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1775 Lang PL NE

Customer Sample Number:

Date / Time Collected: 9/17/2024 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-006

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-017

Sample Location: 1st Draw 227 14th Pl. NE

Customer Sample Number:

Date / Time Collected: 9/16/2024 7:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-017

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 227 14th Pl. NE

Customer Sample Number:

Date / Time Collected: 9/16/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-018

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-005

Sample Location: 1st Draw 2642 1/2 Woodley PI NW

Customer Sample Number:

Date / Time Collected: 9/15/2024 7:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-005

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 2642 1/2 Woodley PI NW

Customer Sample Number:

Date / Time Collected: 9/15/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-006

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-007

Sample Location: 1st Draw 2910 R St. NW

Customer Sample Number:

Date / Time Collected: 9/18/2024 8:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-007

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 2910 R St. NW

Customer Sample Number:

Date / Time Collected: 9/18/2024 8:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-008

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-009

Sample Location: 1st Draw 314 Bryant St. NE

Customer Sample Number:

Date / Time Collected: 9/9/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-009

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 314 Bryant St. NE

Customer Sample Number:

Date / Time Collected: 9/9/2024 9:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-010

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-015

Sample Location: 1st Draw 3227 Volta PI NW

Customer Sample Number:

Date / Time Collected: 9/15/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-015

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 3227 Volta PI NW

Customer Sample Number:

Date / Time Collected: 9/15/2024 6:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-016

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-003

Sample Location: 1st Draw 3309 Porter St NW

Customer Sample Number:

Date / Time Collected: 9/11/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-003

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 3309 Porter St NW

Customer Sample Number:

Date / Time Collected: 9/11/2024 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-004

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-069

Sample Location: 1st Draw 3501 17th St. NE

Customer Sample Number:

Date / Time Collected: 9/26/2024 7:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-069

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 3501 17th St. NE

Customer Sample Number:

Date / Time Collected: 9/26/2024 7:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-070

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-003

Sample Location: 1st Draw 3535 R St. NW

Customer Sample Number:

Date / Time Collected: 9/16/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-003

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 3535 R St. NW

Customer Sample Number:

Date / Time Collected: 9/16/2024 7:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-004

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-013

Sample Location: 1st Draw 3540 S St NW
Customer Sample Number:
Date / Time Collected: 9/11/2024 7:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2409200-013
Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 3540 S St NW
Customer Sample Number:
Date / Time Collected: 9/11/2024 7:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2409200-014
Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-019

Sample Location: 1st Draw 3933 Fordham Rd NW

Customer Sample Number:

Date / Time Collected: 9/12/2024 7:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-019

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 3933 Fordham Rd NW

Customer Sample Number:

Date / Time Collected: 9/12/2024 7:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-020

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-007

Sample Location: 1st Draw 4306 Alton Place NW

Customer Sample Number:

Date / Time Collected: 9/12/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-007

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 4306 Alton Place NW

Customer Sample Number:

Date / Time Collected: 9/12/2024 7:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-008

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-033

Sample Location: 1st Draw 4751 Berkeley Terrace NW

Customer Sample Number:

Date / Time Collected: 9/22/2024 5:08 PM

Customer Program Code: DS

Laboratory Sample Number: 2410040-033

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 4751 Berkeley Terrace NW

Customer Sample Number:

Date / Time Collected: 9/22/2024 5:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2410040-034

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-047

Sample Location: 1st Draw 5527 2nd St. NW

Customer Sample Number:

Date / Time Collected: 9/23/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-047

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 5527 2nd St. NW

Customer Sample Number:

Date / Time Collected: 9/23/2024 9:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-048

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2410040-053

Sample Location: 1st Draw 6024 N. Dakota Ave NW

Customer Sample Number:

Date / Time Collected: 9/24/2024 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-053

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 6024 N. Dakota Ave NW

Customer Sample Number:

Date / Time Collected: 9/24/2024 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2410040-054

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS-2409200-011

Sample Location: 1st Draw 7624 9th St NW

Customer Sample Number:

Date / Time Collected: 9/16/2024 8:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-011

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 7624 9th St NW

Customer Sample Number:

Date / Time Collected: 9/16/2024 8:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2409200-012

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2409199-005

Sample Location: 1st Draw 1101 3rd St SW Apt 402

Customer Sample Number:

Date / Time Collected: 9/10/2024 3:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2409199-005

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1101 3rd St SW Apt 402

Customer Sample Number:

Date / Time Collected: 9/10/2024 3:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2409199-006

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2410039-005

Sample Location: 1st Draw 1225 Fairmont St. NW

Customer Sample Number:

Date / Time Collected: 9/22/2024 5:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-005

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2024	Rlamsal

Sample Location: 2nd Draw 1225 Fairmont St. NW

Customer Sample Number:

Date / Time Collected: 9/22/2024 5:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-006

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2410039-009

Sample Location: 1st Draw 1320 Fairmont St. NW #105

Customer Sample Number:

Date / Time Collected: 9/23/2024 9:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-009

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2024	Rlamsal

Sample Location: 2nd Draw 1320 Fairmont St. NW #105

Customer Sample Number:

Date / Time Collected: 9/23/2024 9:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-010

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2410039-003

Sample Location: 1st Draw 1436 Meridian PL #203

Customer Sample Number:

Date / Time Collected: 9/19/2024 8:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-003

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2024	Rlamsal

Sample Location: 2nd Draw 1436 Meridian PL #203

Customer Sample Number:

Date / Time Collected: 9/19/2024 8:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-004

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/10/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2410039-011

Sample Location: 1st Draw 1660 Lanier PL NW Apt.119

Customer Sample Number:

Date / Time Collected: 9/24/2024 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-011

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/10/2024	Rlamsal

Sample Location: 2nd Draw 1660 Lanier PL NW Apt.119

Customer Sample Number:

Date / Time Collected: 9/24/2024 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-012

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/10/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2410039-007

Sample Location: 1st Draw 1756 Kilbourne Place NW Apt. 2

Customer Sample Number:

Date / Time Collected: 9/22/2024 8:39 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-007

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/10/2024	Rlamsal

Sample Location: 2nd Draw 1756 Kilbourne Place NW Apt. 2

Customer Sample Number:

Date / Time Collected: 9/22/2024 8:39 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-008

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/10/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2409199-003

Sample Location: 1st Draw 1831 California St NW Apt 1

Customer Sample Number:

Date / Time Collected: 9/14/2024 8:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2409199-003

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 1831 California St NW Apt 1

Customer Sample Number:

Date / Time Collected: 9/14/2024 8:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2409199-004

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2410039-001

Sample Location: 1st Draw 2216 Wisconsin Ave NW Unit B

Customer Sample Number:

Date / Time Collected: 9/18/2024 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-001

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/10/2024	Rlamsal

Sample Location: 2nd Draw 2216 Wisconsin Ave NW Unit B

Customer Sample Number:

Date / Time Collected: 9/18/2024 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-002

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/10/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2409199-001

Sample Location: 1st Draw 3020 Dent PI NW #14W

Customer Sample Number:

Date / Time Collected: 9/16/2024 7:05 AM

Customer Program Code: DS250

Laboratory Sample Number: 2409199-001

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 3020 Dent PI NW #14W

Customer Sample Number:

Date / Time Collected: 9/16/2024 7:05 AM

Customer Program Code: DS250

Laboratory Sample Number: 2409199-002

Date / Time Received: 9/20/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/22/2024

Report Number: L-DC-DS250- 2410039-013

Sample Location: 1st Draw 3851 Newark St. NW Apt. F462

Customer Sample Number:

Date / Time Collected: 9/25/2024 5:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-013

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/10/2024	Rlamsal

Sample Location: 2nd Draw 3851 Newark St. NW Apt. F462

Customer Sample Number:

Date / Time Collected: 9/25/2024 5:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410039-014

Date / Time Received: 9/30/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/10/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-011

Sample Location: 1st Draw 1110 Larmont St. NW

Customer Sample Number:

Date / Time Collected: 10/2/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-011

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 1110 Larmont St. NW

Customer Sample Number:

Date / Time Collected: 10/2/2024 7:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-012

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-035

Sample Location: 1st Draw 1549 33rd St. NW

Customer Sample Number:

Date / Time Collected: 10/7/2024 9:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-035

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 1549 33rd St. NW

Customer Sample Number:

Date / Time Collected: 10/7/2024 9:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-036

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410059-043

Sample Location: 1st Draw 1620 40th St. SE

Customer Sample Number:

Date / Time Collected: 9/28/2024 11:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2410059-043

Date / Time Received: 10/4/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-013

Sample Location: 1st Draw 19 6th St SE #B

Customer Sample Number:

Date / Time Collected: 10/3/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-013

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 19 6th St SE #B

Customer Sample Number:

Date / Time Collected: 10/3/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-014

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-021

Sample Location: 1st Draw 2021 Ridge Place, SE

Customer Sample Number:

Date / Time Collected: 10/6/2024 9:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-021

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 2021 Ridge Place, SE

Customer Sample Number:

Date / Time Collected: 10/6/2024 9:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-022

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-025

Sample Location: 1st Draw 3020 R St. NW #3

Customer Sample Number:

Date / Time Collected: 10/6/2024 9:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2410106-025

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 3020 R St. NW #3

Customer Sample Number:

Date / Time Collected: 10/6/2024 9:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2410106-026

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-029

Sample Location: 1st Draw 3122 Ordway St. NW

Customer Sample Number:

Date / Time Collected: 10/7/2024 7:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-029

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 3122 Ordway St. NW

Customer Sample Number:

Date / Time Collected: 10/7/2024 7:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-030

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410059-029

Sample Location: 1st Draw 315 L St. NE
Customer Sample Number:
Date / Time Collected: 9/28/2024 7:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2410059-029
Date / Time Received: 10/4/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 315 L St. NE
Customer Sample Number:
Date / Time Collected: 9/28/2024 7:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2410059-030
Date / Time Received: 10/4/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-031

Sample Location: 1st Draw 332 56th St. NE

Customer Sample Number:

Date / Time Collected: 10/7/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-031

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 332 56th St. NE

Customer Sample Number:

Date / Time Collected: 10/7/2024 8:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-032

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-027

Sample Location: 1st Draw 3519 PORTER ST NW

Customer Sample Number:

Date / Time Collected: 10/7/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-027

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 3519 PORTER ST NW

Customer Sample Number:

Date / Time Collected: 10/7/2024 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-028

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410076-001

Sample Location: 1st Draw 4432 Chesapeake St NW

Customer Sample Number:

Date / Time Collected: 9/30/2024 6:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2410076-001

Date / Time Received: 10/10/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 4432 Chesapeake St NW

Customer Sample Number:

Date / Time Collected: 9/30/2024 6:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2410076-002

Date / Time Received: 10/10/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-007

Sample Location: 1st Draw 4607 9th St. NW

Customer Sample Number:

Date / Time Collected: 10/1/2024 4:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2410106-007

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 4607 9th St. NW

Customer Sample Number:

Date / Time Collected: 10/1/2024 4:07 PM

Customer Program Code: DS

Laboratory Sample Number: 2410106-008

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-019

Sample Location: 1st Draw 4706 8th St. NW

Customer Sample Number:

Date / Time Collected: 10/5/2024 8:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-019

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 4706 8th St. NW

Customer Sample Number:

Date / Time Collected: 10/5/2024 8:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-020

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410059-027

Sample Location: 1st Draw 4722 Tilden St. NW

Customer Sample Number:

Date / Time Collected: 9/28/2024 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2410059-027

Date / Time Received: 10/4/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 4722 Tilden St. NW

Customer Sample Number:

Date / Time Collected: 9/28/2024 7:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2410059-028

Date / Time Received: 10/4/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410076-007

Sample Location: 1st Draw 5110 8th St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2024 8:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2410076-007

Date / Time Received: 10/10/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 5110 8th St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2024 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2410076-008

Date / Time Received: 10/10/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410056-011

Sample Location: 1st Draw 6960 33rd St NW

Customer Sample Number:

Date / Time Collected: 9/24/2024 6:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2410056-011

Date / Time Received: 10/3/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/23/2024	LGallimore

Sample Location: 2nd Draw 6960 33rd St NW

Customer Sample Number:

Date / Time Collected: 9/24/2024 6:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2410056-012

Date / Time Received: 10/3/2024 9:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-023

Sample Location: 1st Draw 7607 13th St NW

Customer Sample Number:

Date / Time Collected: 10/6/2024 5:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2410106-023

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 7607 13th St NW

Customer Sample Number:

Date / Time Collected: 10/6/2024 5:48 PM

Customer Program Code: DS

Laboratory Sample Number: 2410106-024

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS-2410106-003

Sample Location: 1st Draw 826 Otis PI NW

Customer Sample Number:

Date / Time Collected: 10/1/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-003

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 826 Otis PI NW

Customer Sample Number:

Date / Time Collected: 10/1/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410106-004

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS250- 2410075-005

Sample Location: 1st Draw 1455 Florida Ave. NW Apt. 3B

Customer Sample Number:

Date / Time Collected: 9/30/2024 6:17 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410075-005

Date / Time Received: 10/9/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 1455 Florida Ave. NW Apt. 3B

Customer Sample Number:

Date / Time Collected: 9/30/2024 6:28 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410075-006

Date / Time Received: 10/9/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS250- 2410075-003

Sample Location: 1st Draw 1619 1st St. NW, Apt. C

Customer Sample Number:

Date / Time Collected: 9/27/2024 9:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410075-003

Date / Time Received: 10/9/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 1619 1st St. NW, Apt. C

Customer Sample Number:

Date / Time Collected: 9/27/2024 9:40 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410075-004

Date / Time Received: 10/9/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS250- 2410075-001

Sample Location: 1st Draw 1774 U St. NW Apt.21

Customer Sample Number:

Date / Time Collected: 9/27/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410075-001

Date / Time Received: 10/9/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 1774 U St. NW Apt.21

Customer Sample Number:

Date / Time Collected: 9/27/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410075-002

Date / Time Received: 10/9/2024 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS250- 2410105-001

Sample Location: 1st Draw 3111 Sherman Ave NW #5

Customer Sample Number:

Date / Time Collected: 10/5/2024 10:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410105-001

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 3111 Sherman Ave NW #5

Customer Sample Number:

Date / Time Collected: 10/5/2024 10:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410105-002

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS250- 2410051-001

Sample Location: 1st Draw 3200 16th St. NW Apt. 709

Customer Sample Number:

Date / Time Collected: 9/24/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410051-001

Date / Time Received: 10/4/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/17/2024	Rlamsal

Sample Location: 2nd Draw 3200 16th St. NW Apt. 709

Customer Sample Number:

Date / Time Collected: 9/24/2024 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410051-002

Date / Time Received: 10/4/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/17/2024	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2024

Report Number: L-DC-DS250- 2410105-003

Sample Location: 1st Draw 4501 Connecticut Ave NW #707

Customer Sample Number:

Date / Time Collected: 10/7/2024 7:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410105-003

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/23/2024	Lgallimore

Sample Location: 2nd Draw 4501 Connecticut Ave NW #707

Customer Sample Number:

Date / Time Collected: 10/7/2024 7:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410105-004

Date / Time Received: 10/15/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/23/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410161-001

Sample Location: 1st Draw 1015 E. Capital St SE

Customer Sample Number:

Date / Time Collected: 10/13/2024 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2410161-001

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1015 E. Capital St SE

Customer Sample Number:

Date / Time Collected: 10/13/2024 8:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2410161-002

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410161-005

Sample Location: 1st Draw 1113 Chicago St SE

Customer Sample Number:

Date / Time Collected: 10/7/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410161-005

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1113 Chicago St SE

Customer Sample Number:

Date / Time Collected: 10/7/2024 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2410161-006

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-031

Sample Location: 1st Draw 1118 Chicago St SE

Customer Sample Number:

Date / Time Collected: 10/15/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-031

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1118 Chicago St SE

Customer Sample Number:

Date / Time Collected: 10/15/2024 6:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-032

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-037

Sample Location: 1st Draw 1207 HOLLY ST NW

Customer Sample Number:

Date / Time Collected: 10/21/2024 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-037

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1207 HOLLY ST NW

Customer Sample Number:

Date / Time Collected: 10/21/2024 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-038

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-005

Sample Location: 1st Draw 1225 18th St NE

Customer Sample Number:

Date / Time Collected: 10/19/2024 10:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-005

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1225 18th St NE

Customer Sample Number:

Date / Time Collected: 10/19/2024 10:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-006

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410217-001

Sample Location: 1st Draw 1254 Oates St NE

Customer Sample Number:

Date / Time Collected: 10/21/2024 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2410217-001

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1254 Oates St NE

Customer Sample Number:

Date / Time Collected: 10/21/2024 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2410217-002

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-007

Sample Location: 1st Draw 1301 MONTELLO AVE NE

Customer Sample Number:

Date / Time Collected: 10/20/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-007

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1301 MONTELLO AVE NE

Customer Sample Number:

Date / Time Collected: 10/20/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-008

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-027

Sample Location: 1st Draw 1312 Montello
Customer Sample Number:
Date / Time Collected: 10/15/2024 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2410208-027
Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1312 Montello
Customer Sample Number:
Date / Time Collected: 10/15/2024 8:31 AM

Customer Program Code: DS
Laboratory Sample Number: 2410208-028
Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-011

Sample Location: 1st Draw 1326 Downing PI NE

Customer Sample Number:

Date / Time Collected: 10/14/2024 5:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-011

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1326 Downing PI NE

Customer Sample Number:

Date / Time Collected: 10/14/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-012

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-033

Sample Location: 1st Draw 1331 Leegate Rd NW

Customer Sample Number:

Date / Time Collected: 10/9/2024 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-033

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1331 Leegate Rd NW

Customer Sample Number:

Date / Time Collected: 10/9/2024 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-034

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-015

Sample Location: 1st Draw 1336 Varnum St NE

Customer Sample Number:

Date / Time Collected: 10/15/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-015

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1336 Varnum St NE

Customer Sample Number:

Date / Time Collected: 10/15/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-016

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-009

Sample Location: 1st Draw 1364 Shepherd St NW

Customer Sample Number:

Date / Time Collected: 10/10/2024 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-009

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1364 Shepherd St NW

Customer Sample Number:

Date / Time Collected: 10/10/2024 7:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-010

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-021

Sample Location: 1st Draw 1428 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 10/17/2024 8:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-021

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1428 Longfellow St NW

Customer Sample Number:

Date / Time Collected: 10/17/2024 8:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-022

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-025

Sample Location: 1st Draw 1456 Sheridan St NW

Customer Sample Number:

Date / Time Collected: 10/6/2024 2:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2410195-025

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1456 Sheridan St NW

Customer Sample Number:

Date / Time Collected: 10/6/2024 2:34 PM

Customer Program Code: DS

Laboratory Sample Number: 2410195-026

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-037

Sample Location: 1st Draw 1622 Oak St NW

Customer Sample Number:

Date / Time Collected: 10/17/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-037

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1622 Oak St NW

Customer Sample Number:

Date / Time Collected: 10/17/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-038

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411049-003

Sample Location: 1st Draw 1667 34th St NW

Customer Sample Number:

Date / Time Collected: 10/29/2024 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411049-003

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1667 34th St NW

Customer Sample Number:

Date / Time Collected: 10/29/2024 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411049-004

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-029

Sample Location: 1st Draw 1721 Newton St NW

Customer Sample Number:

Date / Time Collected: 10/21/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-029

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1721 Newton St NW

Customer Sample Number:

Date / Time Collected: 10/21/2024 7:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-030

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411049-009

Sample Location: 1st Draw 1730 Lamont St NW

Customer Sample Number:

Date / Time Collected: 10/25/2024 4:39 PM

Customer Program Code: DS

Laboratory Sample Number: 2411049-009

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1730 Lamont St NW

Customer Sample Number:

Date / Time Collected: 10/25/2024 4:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2411049-010

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.8	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-025

Sample Location: 1st Draw 18 3rd St SE

Customer Sample Number:

Date / Time Collected: 10/9/2024 6:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-025

Date / Time Received: 10/29/2024 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 18 3rd St SE

Customer Sample Number:

Date / Time Collected: 10/9/2024 6:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-026

Date / Time Received: 10/29/2024 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411049-001

Sample Location: 1st Draw 1816 17th St SE

Customer Sample Number:

Date / Time Collected: 10/23/2024 6:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2411049-001

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1816 17th St SE

Customer Sample Number:

Date / Time Collected: 10/23/2024 6:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2411049-002

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-033

Sample Location: 1st Draw 219 Parker St NE

Customer Sample Number:

Date / Time Collected: 10/22/2024 8:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-033

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 219 Parker St NE

Customer Sample Number:

Date / Time Collected: 10/22/2024 8:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-034

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-019

Sample Location: 1st Draw 2214 16th St NE

Customer Sample Number:

Date / Time Collected: 10/26/2024 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-019

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 2214 16th St NE

Customer Sample Number:

Date / Time Collected: 10/26/2024 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-020

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-009

Sample Location: 1st Draw 2224 Decater PI NW

Customer Sample Number:

Date / Time Collected: 10/17/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-009

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 2224 Decater PI NW

Customer Sample Number:

Date / Time Collected: 10/17/2024 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-010

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-017

Sample Location: 1st Draw 2241 Bancroft PI NW

Customer Sample Number:

Date / Time Collected: 10/28/2024 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2411030-017

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 2241 Bancroft PI NW

Customer Sample Number:

Date / Time Collected: 10/28/2024 8:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2411030-018

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-003

Sample Location: 1st Draw 231 8th St SE
Customer Sample Number:
Date / Time Collected: 10/13/2024 6:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2410195-003
Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	76.1	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 231 8th St SE
Customer Sample Number:
Date / Time Collected: 10/13/2024 6:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2410195-004
Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	34.4	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411049-005

Sample Location: 1st Draw 2410 39th St NW

Customer Sample Number:

Date / Time Collected: 10/23/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2411049-005

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 2410 39th St NW

Customer Sample Number:

Date / Time Collected: 10/23/2024 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2411049-006

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410161-007

Sample Location: 1st Draw 2716 10th St. NE

Customer Sample Number:

Date / Time Collected: 10/14/2024 6:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2410161-007

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 2716 10th St. NE

Customer Sample Number:

Date / Time Collected: 10/14/2024 6:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2410161-008

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410217-003

Sample Location: 1st Draw 2930 Woodland Dr NW

Customer Sample Number:

Date / Time Collected: 10/22/2024 5:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2410217-003

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 2930 Woodland Dr NW

Customer Sample Number:

Date / Time Collected: 10/22/2024 5:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2410217-004

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410217-005

Sample Location: 1st Draw 3120 Patterson PI NW

Customer Sample Number:

Date / Time Collected: 10/15/2024 5:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2410217-005

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 3120 Patterson PI NW

Customer Sample Number:

Date / Time Collected: 10/15/2024 5:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2410217-006

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-005

Sample Location: 1st Draw 3129 P St NW

Customer Sample Number:

Date / Time Collected: 10/9/2024 6:39 PM

Customer Program Code: DS

Laboratory Sample Number: 2410195-005

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3129 P St NW

Customer Sample Number:

Date / Time Collected: 10/9/2024 6:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2410195-006

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-017

Sample Location: 1st Draw 3207 P St NW
Customer Sample Number:
Date / Time Collected: 10/18/2024 10:40 AM

Customer Program Code: DS
Laboratory Sample Number: 2410208-017
Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3207 P St NW
Customer Sample Number:
Date / Time Collected: 10/18/2024 10:42 AM

Customer Program Code: DS
Laboratory Sample Number: 2410208-018
Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-023

Sample Location: 1st Draw 3251 Van Hazen St NW

Customer Sample Number:

Date / Time Collected: 10/8/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-023

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3251 Van Hazen St NW

Customer Sample Number:

Date / Time Collected: 10/8/2024 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-024

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-031

Sample Location: 1st Draw 3329 Alden PI NE

Customer Sample Number:

Date / Time Collected: 10/8/2024 6:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-031

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3329 Alden PI NE

Customer Sample Number:

Date / Time Collected: 10/8/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-032

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-035

Sample Location: 1st Draw 3533 Cumberland St NW

Customer Sample Number:

Date / Time Collected: 10/25/2024 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-035

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3533 Cumberland St NW

Customer Sample Number:

Date / Time Collected: 10/25/2024 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-036

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-027

Sample Location: 1st Draw 3536 Park PI NW

Customer Sample Number:

Date / Time Collected: 10/12/2024 9:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-027

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3536 Park PI NW

Customer Sample Number:

Date / Time Collected: 10/12/2024 9:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-028

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411049-011

Sample Location: 1st Draw 3548 Warder St NW

Customer Sample Number:

Date / Time Collected: 10/22/2024 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2411049-011

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3548 Warder St NW

Customer Sample Number:

Date / Time Collected: 10/22/2024 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2411049-012

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-019

Sample Location: 1st Draw 3734 JENIFER ST NW

Customer Sample Number:

Date / Time Collected: 10/22/2024 6:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-019

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3734 JENIFER ST NW

Customer Sample Number:

Date / Time Collected: 10/22/2024 6:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-020

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-033

Sample Location: 1st Draw 3943 Military Rd

Customer Sample Number:

Date / Time Collected: 10/21/2024 4:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-033

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3943 Military Rd

Customer Sample Number:

Date / Time Collected: 10/21/2024 4:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-034

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-001

Sample Location: 1st Draw 40 T St NW
Customer Sample Number:
Date / Time Collected: 10/11/2024 8:16 AM

Customer Program Code: DS
Laboratory Sample Number: 2410195-001
Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 40 T St NW
Customer Sample Number:
Date / Time Collected: 10/11/2024 8:18 AM

Customer Program Code: DS
Laboratory Sample Number: 2410195-002
Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411049-007

Sample Location: 1st Draw 4008 5th St NW

Customer Sample Number:

Date / Time Collected: 10/27/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411049-007

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 4008 5th St NW

Customer Sample Number:

Date / Time Collected: 10/27/2024 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2411049-008

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410217-010

Sample Location: 2nd Draw 4019 5th St NW

Customer Sample Number:

Date / Time Collected: 10/20/2024 7:03 PM

Customer Program Code: DS

Laboratory Sample Number: 2410217-010

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-027

Sample Location: 1st Draw 4116 Jenifer St NW

Customer Sample Number:

Date / Time Collected: 10/22/2024 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-027

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 4116 Jenifer St NW

Customer Sample Number:

Date / Time Collected: 10/22/2024 9:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-028

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-035

Sample Location: 1st Draw 415 I St NE
Customer Sample Number:
Date / Time Collected: 10/10/2024 5:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2410195-035
Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 415 I St NE
Customer Sample Number:
Date / Time Collected: 10/10/2024 5:03 PM

Customer Program Code: DS
Laboratory Sample Number: 2410195-036
Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-015

Sample Location: 1st Draw 4323 12th PI NE

Customer Sample Number:

Date / Time Collected: 10/14/2024 1:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2410195-015

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 4323 12th PI NE

Customer Sample Number:

Date / Time Collected: 10/14/2024 1:57 PM

Customer Program Code: DS

Laboratory Sample Number: 2410195-016

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-031

Sample Location: 1st Draw 4343 Brandywine St NW

Customer Sample Number:

Date / Time Collected: 10/16/2024 5:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-031

Date / Time Received: 11/4/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 4343 Brandywine St NW

Customer Sample Number:

Date / Time Collected: 10/16/2024 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-032

Date / Time Received: 11/4/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-011

Sample Location: 1st Draw 4423 Albemarle St NW, Unit 2

Customer Sample Number:

Date / Time Collected: 10/16/2024 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-011

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 4423 Albemarle St NW, Unit 2

Customer Sample Number:

Date / Time Collected: 10/16/2024 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-012

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-003

Sample Location: 1st Draw 4425 14th St NE

Customer Sample Number:

Date / Time Collected: 10/2/2024 5:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-003

Date / Time Received: 10/29/2024 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 4425 14th St NE

Customer Sample Number:

Date / Time Collected: 10/2/2024 5:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-004

Date / Time Received: 10/29/2024 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-035

Sample Location: 1st Draw 4721 10th St NE

Customer Sample Number:

Date / Time Collected: 10/17/2024 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-035

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 4721 10th St NE

Customer Sample Number:

Date / Time Collected: 10/17/2024 7:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-036

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-017

Sample Location: 1st Draw 4722 Tilden St. NW

Customer Sample Number:

Date / Time Collected: 10/15/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-017

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 4722 Tilden St. NW

Customer Sample Number:

Date / Time Collected: 10/15/2024 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-018

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-025

Sample Location: 1st Draw 5 4th St NE
Customer Sample Number:
Date / Time Collected: 10/24/2024 12:32 PM

Customer Program Code: DS
Laboratory Sample Number: 2411030-025
Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 5 4th St NE
Customer Sample Number:
Date / Time Collected: 10/24/2024 12:33 PM

Customer Program Code: DS
Laboratory Sample Number: 2411030-026
Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-015

Sample Location: 1st Draw 5100 33rd St NW

Customer Sample Number:

Date / Time Collected: 10/27/2024 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-015

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 5100 33rd St NW

Customer Sample Number:

Date / Time Collected: 10/27/2024 6:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-016

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-007

Sample Location: 1st Draw 517 10th St SE

Customer Sample Number:

Date / Time Collected: 10/8/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-007

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 517 10th St SE

Customer Sample Number:

Date / Time Collected: 10/8/2024 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-008

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410161-003

Sample Location: 1st Draw 520 K St NE, #1

Customer Sample Number:

Date / Time Collected: 10/9/2024 8:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2410161-003

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 520 K St NE, #1

Customer Sample Number:

Date / Time Collected: 10/9/2024 8:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2410161-004

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-029

Sample Location: 1st Draw 5233 43rd ST NW

Customer Sample Number:

Date / Time Collected: 10/9/2024 12:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2410195-029

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 5233 43rd ST NW

Customer Sample Number:

Date / Time Collected: 10/9/2024 12:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2410195-030

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-037

Sample Location: 1st Draw 5330 5th ST NW

Customer Sample Number:

Date / Time Collected: 10/14/2024 8:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-037

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 5330 5th ST NW

Customer Sample Number:

Date / Time Collected: 10/14/2024 8:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-038

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-021

Sample Location: 1st Draw 5335 Jay St NE

Customer Sample Number:

Date / Time Collected: 10/8/2024 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-021

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 5335 Jay St NE

Customer Sample Number:

Date / Time Collected: 10/8/2024 7:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-022

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-023

Sample Location: 1st Draw 5510 2nd St NW

Customer Sample Number:

Date / Time Collected: 10/20/2024 7:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-023

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 5510 2nd St NW

Customer Sample Number:

Date / Time Collected: 10/20/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-024

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-001

Sample Location: 1st Draw 5849 Nebraska Ave NW

Customer Sample Number:

Date / Time Collected: 10/18/2024 5:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-001

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 5849 Nebraska Ave NW

Customer Sample Number:

Date / Time Collected: 10/18/2024 5:57 AM

Customer Program Code: DS

Laboratory Sample Number: 2410208-002

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410208-013

Sample Location: 1st Draw 6335 31st PL NW

Customer Sample Number:

Date / Time Collected: 10/21/2024 3:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2410208-013

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 6335 31st PL NW

Customer Sample Number:

Date / Time Collected: 10/21/2024 3:28 PM

Customer Program Code: DS

Laboratory Sample Number: 2410208-014

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-021

Sample Location: 1st Draw 645 E St SE
Customer Sample Number:
Date / Time Collected: 10/22/2024 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2411030-021
Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 645 E St SE
Customer Sample Number:
Date / Time Collected: 10/22/2024 6:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2411030-022
Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-029

Sample Location: 1st Draw 655 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 10/25/2024 8:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-029

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 655 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 10/25/2024 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-030

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-019

Sample Location: 1st Draw 728 Newton PI NW

Customer Sample Number:

Date / Time Collected: 10/7/2024 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-019

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 728 Newton PI NW

Customer Sample Number:

Date / Time Collected: 10/7/2024 9:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-020

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2411030-023

Sample Location: 1st Draw 734 Taylor St NW

Customer Sample Number:

Date / Time Collected: 10/28/2024 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-023

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 734 Taylor St NW

Customer Sample Number:

Date / Time Collected: 10/28/2024 5:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2411030-024

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS-2410195-013

Sample Location: 1st Draw 827 Tuckerman St NW

Customer Sample Number:

Date / Time Collected: 10/6/2024 7:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-013

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 827 Tuckerman St NW

Customer Sample Number:

Date / Time Collected: 10/6/2024 8:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2410195-014

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410216-017

Sample Location: 1st Draw 1275 25th St NW

Customer Sample Number:

Date / Time Collected: 10/9/2024 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-017

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 1275 25th St NW

Customer Sample Number:

Date / Time Collected: 10/9/2024 6:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-018

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2411029-001

Sample Location: 1st Draw 1525 Q St NW Apt. 5

Customer Sample Number:

Date / Time Collected: 10/22/2024 4:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411029-001

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1525 Q St NW Apt. 5

Customer Sample Number:

Date / Time Collected: 10/22/2024 4:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411029-002

Date / Time Received: 11/4/2024 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410216-011

Sample Location: 1st Draw 1631 Euclid St. NW #302

Customer Sample Number:

Date / Time Collected: 10/14/2024 11:02 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-011

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 1631 Euclid St. NW #302

Customer Sample Number:

Date / Time Collected: 10/14/2024 11:02 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-012

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410160-003

Sample Location: 1st Draw 1636 Irving St NW #3

Customer Sample Number:

Date / Time Collected: 10/10/2024 8:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410160-003

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	LGallimore

Sample Location: 2nd Draw 1636 Irving St NW #3

Customer Sample Number:

Date / Time Collected: 10/10/2024 8:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410160-004

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410194-005

Sample Location: 1st Draw 1701 19th St SE Apt 302

Customer Sample Number:

Date / Time Collected: 10/9/2024 9:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410194-005

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1701 19th St SE Apt 302

Customer Sample Number:

Date / Time Collected: 10/9/2024 9:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410194-006

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410207-001

Sample Location: 1st Draw 1718 P Street, #603

Customer Sample Number:

Date / Time Collected: 10/16/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410207-001

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 1718 P Street, #603

Customer Sample Number:

Date / Time Collected: 10/16/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410207-002

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410160-005

Sample Location: 1st Draw 1820 Swann St NW Apt #4

Customer Sample Number:

Date / Time Collected: 10/7/2024 7:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410160-005

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/14/2024	LGallimore

Sample Location: 2nd Draw 1820 Swann St NW Apt #4

Customer Sample Number:

Date / Time Collected: 10/7/2024 7:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410160-006

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/14/2024	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2411048-001

Sample Location: 1st Draw 2219 California St NW #41

Customer Sample Number:

Date / Time Collected: 10/23/2024 8:02 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411048-001

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 2219 California St NW #41

Customer Sample Number:

Date / Time Collected: 10/23/2024 8:03 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411048-002

Date / Time Received: 11/5/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410216-007

Sample Location: 1st Draw 242 G St SW

Customer Sample Number:

Date / Time Collected: 10/13/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-007

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 242 G St SW

Customer Sample Number:

Date / Time Collected: 10/13/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-008

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410194-001

Sample Location: 1st Draw 2422 17th St NW #301

Customer Sample Number:

Date / Time Collected: 10/6/2024 7:44 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410194-001

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 2422 17th St NW #301

Customer Sample Number:

Date / Time Collected: 10/6/2024 7:44 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410194-002

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410160-007

Sample Location: 1st Draw 2700 Calvert St NW

Customer Sample Number:

Date / Time Collected: 10/8/2024 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410160-007

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		11/14/2024	LGallimore

Sample Location: 2nd Draw 2700 Calvert St NW

Customer Sample Number:

Date / Time Collected: 10/8/2024 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410160-008

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/14/2024	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410216-001

Sample Location: 1st Draw 2700 Q St. NW Apt 317

Customer Sample Number:

Date / Time Collected: 10/13/2024 5:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-001

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 2700 Q St. NW Apt 317

Customer Sample Number:

Date / Time Collected: 10/13/2024 5:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-002

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410216-003

Sample Location: 1st Draw 2800 Connecticut Ave, 201

Customer Sample Number:

Date / Time Collected: 10/3/2024 5:25 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-003

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 2800 Connecticut Ave, 201

Customer Sample Number:

Date / Time Collected: 10/3/2024 5:25 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-004

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410216-013

Sample Location: 1st Draw 300 3rd St NE, Unit 2

Customer Sample Number:

Date / Time Collected: 10/21/2024 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-013

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 300 3rd St NE, Unit 2

Customer Sample Number:

Date / Time Collected: 10/21/2024 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-014

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410207-003

Sample Location: 1st Draw 3060 16th St NW Apt 313

Customer Sample Number:

Date / Time Collected: 10/17/2024 8:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410207-003

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 3060 16th St NW Apt 313

Customer Sample Number:

Date / Time Collected: 10/17/2024 8:10 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410207-004

Date / Time Received: 10/29/2024 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410216-015

Sample Location: 1st Draw 317 10th St, NE Apt 6

Customer Sample Number:

Date / Time Collected: 10/21/2024 7:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-015

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 317 10th St, NE Apt 6

Customer Sample Number:

Date / Time Collected: 10/21/2024 7:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-016

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410194-003

Sample Location: 1st Draw 3410 39TH St NW Apt F714

Customer Sample Number:

Date / Time Collected: 10/7/2024 4:29 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410194-003

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/1/2024	SBrooks

Sample Location: 2nd Draw 3410 39TH St NW Apt F714

Customer Sample Number:

Date / Time Collected: 10/7/2024 4:29 PM

Customer Program Code: DS250

Laboratory Sample Number: 2410194-004

Date / Time Received: 10/18/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410160-001

Sample Location: 1st Draw 4000 Cathedral Ave NW Apt 722B

Customer Sample Number:

Date / Time Collected: 10/10/2024 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410160-001

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	LGallimore

Sample Location: 2nd Draw 4000 Cathedral Ave NW Apt 722B

Customer Sample Number:

Date / Time Collected: 10/10/2024 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410160-002

Date / Time Received: 10/21/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2411029-003

Sample Location: 1st Draw 410 11th St NE Apt 15

Customer Sample Number:

Date / Time Collected: 10/20/2024 9:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411029-003

Date / Time Received: 11/4/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 410 11th St NE Apt 15

Customer Sample Number:

Date / Time Collected: 10/20/2024 9:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411029-004

Date / Time Received: 11/4/2024 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410207-005

Sample Location: 1st Draw 5402 Connecticut Ave NW Apt 502

Customer Sample Number:

Date / Time Collected: 10/12/2024 11:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410207-005

Date / Time Received: 10/29/2024 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 5402 Connecticut Ave NW Apt 502

Customer Sample Number:

Date / Time Collected: 10/12/2024 11:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410207-006

Date / Time Received: 10/29/2024 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410216-005

Sample Location: 1st draw 701 2nd St NE, Apt 444

Customer Sample Number:

Date / Time Collected: 10/19/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-005

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Sample Location: 2nd Draw 701 2nd St NE, Apt 444

Customer Sample Number:

Date / Time Collected: 10/19/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-006

Date / Time Received: 10/30/2024 9:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/10/2024

Report Number: L-DC-DS250- 2410216-009

Sample Location: 1st Draw 880 New Jersey Ave SE Apt. 317

Customer Sample Number:

Date / Time Collected: 10/14/2024 6:28 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-009

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Sample Location: 2nd Draw 880 New Jersey Ave SE Apt. 317

Customer Sample Number:

Date / Time Collected: 10/14/2024 6:28 AM

Customer Program Code: DS250

Laboratory Sample Number: 2410216-010

Date / Time Received: 10/30/2024 9:40:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/14/2024	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-047

Sample Location: 1st Draw 10 Underwood PI NE

Customer Sample Number:

Date / Time Collected: 11/12/2024 11:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-047

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 10 Underwood PI NE

Customer Sample Number:

Date / Time Collected: 11/12/2024 11:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-048

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411111-041

Sample Location: 1st Draw 1011 15th St SE

Customer Sample Number:

Date / Time Collected: 11/9/2024 8:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2411111-041

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1011 15th St SE

Customer Sample Number:

Date / Time Collected: 11/9/2024 8:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2411111-042

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-040

Sample Location: 1st Draw 1014 3rd St SE

Customer Sample Number:

Date / Time Collected: 11/15/2024 7:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-040

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 1014 3rd St SE

Customer Sample Number:

Date / Time Collected: 11/15/2024 7:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-041

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411111-035

Sample Location: 1st Draw 1031 47th PI
Customer Sample Number:
Date / Time Collected: 11/9/2024 1:46 PM

Customer Program Code: DS
Laboratory Sample Number: 2411111-035
Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1031 47th PI
Customer Sample Number:
Date / Time Collected: 11/9/2024 1:49 PM

Customer Program Code: DS
Laboratory Sample Number: 2411111-036
Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411159-019

Sample Location: 1st Draw 1037 5th St NE Apt. A

Customer Sample Number:

Date / Time Collected: 11/7/2024 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2411159-019

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1037 5th St NE Apt. A

Customer Sample Number:

Date / Time Collected: 11/7/2024 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2411159-020

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-005

Sample Location: 1st Draw 1317 1st St NW

Customer Sample Number:

Date / Time Collected: 11/3/2024 8:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-005

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1317 1st St NW

Customer Sample Number:

Date / Time Collected: 11/3/2024 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-006

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-027

Sample Location: 1st Draw 135 33rd St NE

Customer Sample Number:

Date / Time Collected: 11/5/2024 6:28 PM

Customer Program Code: DS

Laboratory Sample Number: 2411145-027

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 135 33rd St NE

Customer Sample Number:

Date / Time Collected: 11/5/2024 6:34 PM

Customer Program Code: DS

Laboratory Sample Number: 2411145-028

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-052

Sample Location: 1st Draw 135 Quincy Place NE #1

Customer Sample Number:

Date / Time Collected: 11/17/2024 9:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-052

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 135 Quincy Place NE #1

Customer Sample Number:

Date / Time Collected: 11/17/2024 9:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-053

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-041

Sample Location: 1st Draw 1367 E St SE
Customer Sample Number:
Date / Time Collected: 11/13/2024 4:55 PM

Customer Program Code: DS
Laboratory Sample Number: 2411145-041
Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 1367 E St SE
Customer Sample Number:
Date / Time Collected: 11/13/2024 4:55 PM

Customer Program Code: DS
Laboratory Sample Number: 2411145-042
Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-001

Sample Location: 1st Draw 1511 Allison St. NW

Customer Sample Number:

Date / Time Collected: 10/8/2024 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-001

Date / Time Received: 11/8/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	11/27/2024	SBrooks

Sample Location: 2nd Draw 1511 Allison St. NW

Customer Sample Number:

Date / Time Collected: 10/8/2024 7:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-002

Date / Time Received: 11/8/2024 10:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L	H	11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-031

Sample Location: 1st Draw 1527 Marion St NW

Customer Sample Number:

Date / Time Collected: 11/6/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-031

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 1527 Marion St NW

Customer Sample Number:

Date / Time Collected: 11/6/2024 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-032

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-039

Sample Location: 1st Draw 1530 Newton St NE

Customer Sample Number:

Date / Time Collected: 11/13/2024 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2411145-039

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 1530 Newton St NE

Customer Sample Number:

Date / Time Collected: 11/13/2024 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2411145-040

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2412030-023

Sample Location: 1st Draw 1634 44th St. NW

Customer Sample Number:

Date / Time Collected: 11/25/2024 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2412030-023

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 1634 44th St. NW

Customer Sample Number:

Date / Time Collected: 11/25/2024 6:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2412030-024

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-007

Sample Location: 1st Draw 1700 D ST SE

Customer Sample Number:

Date / Time Collected: 11/3/2024 5:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-007

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1700 D ST SE

Customer Sample Number:

Date / Time Collected: 11/3/2024 5:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-008

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-027

Sample Location: 1st Draw 1706 37th St NW

Customer Sample Number:

Date / Time Collected: 10/27/2024 11:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-027

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1706 37th St NW

Customer Sample Number:

Date / Time Collected: 10/27/2024 11:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-028

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-034

Sample Location: 1st Draw 1811 Newton St NW

Customer Sample Number:

Date / Time Collected: 11/17/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-034

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 1811 Newton St NW

Customer Sample Number:

Date / Time Collected: 11/17/2024 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-035

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-015

Sample Location: 1st Draw 1830 H St NE
Customer Sample Number:
Date / Time Collected: 11/4/2024 7:03 AM

Customer Program Code: DS
Laboratory Sample Number: 2411059-015
Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1830 H St NE
Customer Sample Number:
Date / Time Collected: 11/4/2024 7:06 AM

Customer Program Code: DS
Laboratory Sample Number: 2411059-016
Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-021

Sample Location: 1st Draw 1901 Spruce Drive

Customer Sample Number:

Date / Time Collected: 10/30/2024 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2411059-021

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1901 Spruce Drive

Customer Sample Number:

Date / Time Collected: 10/30/2024 4:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2411059-022

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411111-039

Sample Location: 1st Draw 1939 Vermont Ave NW

Customer Sample Number:

Date / Time Collected: 11/8/2024 8:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2411111-039

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1939 Vermont Ave NW

Customer Sample Number:

Date / Time Collected: 11/8/2024 8:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2411111-040

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-048

Sample Location: 1st Draw 2015 Gales St NE

Customer Sample Number:

Date / Time Collected: 11/18/2024 6:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2411195-048

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 2015 Gales St NE

Customer Sample Number:

Date / Time Collected: 11/18/2024 6:47 PM

Customer Program Code: DS

Laboratory Sample Number: 2411195-049

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.9	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-032

Sample Location: 1st Draw 28 53rd PI SE

Customer Sample Number:

Date / Time Collected: 11/17/2024 6:34 PM

Customer Program Code: DS

Laboratory Sample Number: 2411195-032

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 28 53rd PI SE

Customer Sample Number:

Date / Time Collected: 11/17/2024 6:36 PM

Customer Program Code: DS

Laboratory Sample Number: 2411195-033

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-009

Sample Location: 1st Draw 3103 19TH ST NW

Customer Sample Number:

Date / Time Collected: 11/2/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-009

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 3103 19TH ST NW

Customer Sample Number:

Date / Time Collected: 11/2/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-010

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411159-021

Sample Location: 1st Draw 319 Nicholson St. NE

Customer Sample Number:

Date / Time Collected: 11/12/2024 5:04 PM

Customer Program Code: DS

Laboratory Sample Number: 2411159-021

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 319 Nicholson St. NE

Customer Sample Number:

Date / Time Collected: 11/12/2024 5:06 PM

Customer Program Code: DS

Laboratory Sample Number: 2411159-022

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-011

Sample Location: 1st Draw 3225 Volta Pl. NW

Customer Sample Number:

Date / Time Collected: 11/5/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-011

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 3225 Volta Pl. NW

Customer Sample Number:

Date / Time Collected: 11/5/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-012

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-025

Sample Location: 1st Draw 3234 13th St NW, Unit 2

Customer Sample Number:

Date / Time Collected: 11/5/2024 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-025

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 3234 13th St NW, Unit 2

Customer Sample Number:

Date / Time Collected: 11/5/2024 6:26 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-026

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-051

Sample Location: 1st Draw 3320 Highland PI NW

Customer Sample Number:

Date / Time Collected: 11/14/2024 2:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2411145-051

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 3320 Highland PI NW

Customer Sample Number:

Date / Time Collected: 11/14/2024 2:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2411145-052

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-038

Sample Location: 1st Draw 3422 Q St NW
Customer Sample Number:
Date / Time Collected: 11/18/2024 7:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2411195-038
Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 3422 Q St NW
Customer Sample Number:
Date / Time Collected: 11/18/2024 7:07 AM

Customer Program Code: DS
Laboratory Sample Number: 2411195-039
Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-029

Sample Location: 1st Draw 3538 Whitehaven Parkway NW

Customer Sample Number:

Date / Time Collected: 11/7/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-029

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 3538 Whitehaven Parkway NW

Customer Sample Number:

Date / Time Collected: 11/7/2024 8:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-030

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-049

Sample Location: 1st Draw 3705 Porter St NW

Customer Sample Number:

Date / Time Collected: 11/8/2024 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-049

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 3705 Porter St NW

Customer Sample Number:

Date / Time Collected: 11/8/2024 6:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-050

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411111-033

Sample Location: 1st Draw 3829 Calvert St NW

Customer Sample Number:

Date / Time Collected: 11/10/2024 7:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2411111-033

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 3829 Calvert St NW

Customer Sample Number:

Date / Time Collected: 11/10/2024 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2411111-034

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411111-037

Sample Location: 1st Draw 3832 17th PI NE

Customer Sample Number:

Date / Time Collected: 11/7/2024 7:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2411111-037

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 3832 17th PI NE

Customer Sample Number:

Date / Time Collected: 11/7/2024 7:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2411111-038

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411111-043

Sample Location: 1st Draw 3834 McKinley St NW

Customer Sample Number:

Date / Time Collected: 11/12/2024 6:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2411111-043

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 3834 McKinley St NW

Customer Sample Number:

Date / Time Collected: 11/12/2024 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2411111-044

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-003

Sample Location: 1st Draw 421 21st St NE

Customer Sample Number:

Date / Time Collected: 10/28/2024 8:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-003

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 421 21st St NE

Customer Sample Number:

Date / Time Collected: 10/28/2024 8:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-004

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411159-015

Sample Location: 1st Draw 4213 37th St. NW

Customer Sample Number:

Date / Time Collected: 11/13/2024 5:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2411159-015

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 4213 37th St. NW

Customer Sample Number:

Date / Time Collected: 11/13/2024 5:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2411159-016

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-053

Sample Location: 1st Draw 4310 G St SE
Customer Sample Number:
Date / Time Collected: 11/11/2024 7:51 AM

Customer Program Code: DS
Laboratory Sample Number: 2411145-053
Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 4310 G St SE
Customer Sample Number:
Date / Time Collected: 11/11/2024 7:56 AM

Customer Program Code: DS
Laboratory Sample Number: 2411145-054
Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-013

Sample Location: 1st Draw 432 6th NE
Customer Sample Number:
Date / Time Collected: 11/5/2024 8:06 AM

Customer Program Code: DS
Laboratory Sample Number: 2411059-013
Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 432 6th NE
Customer Sample Number:
Date / Time Collected: 11/5/2024 8:08 AM

Customer Program Code: DS
Laboratory Sample Number: 2411059-014
Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-033

Sample Location: 1st Draw 4607 15th St NW

Customer Sample Number:

Date / Time Collected: 11/5/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-033

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 4607 15th St NW

Customer Sample Number:

Date / Time Collected: 11/5/2024 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-034

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-044

Sample Location: 1st Draw 4803 B St SE

Customer Sample Number:

Date / Time Collected: 11/19/2024 5:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-044

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 4803 B St SE

Customer Sample Number:

Date / Time Collected: 11/19/2024 5:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-045

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-037

Sample Location: 1st Draw 4825 Blagden Ave NW

Customer Sample Number:

Date / Time Collected: 11/11/2024 5:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-037

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 4825 Blagden Ave NW

Customer Sample Number:

Date / Time Collected: 11/11/2024 5:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-038

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-029

Sample Location: 1st Draw 49 U St NW
Customer Sample Number:
Date / Time Collected: 11/3/2024 9:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2411059-029
Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 49 U St NW
Customer Sample Number:
Date / Time Collected: 11/3/2024 9:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2411059-030
Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-023

Sample Location: 1st Draw 4930 Butterworth PI NW

Customer Sample Number:

Date / Time Collected: 10/26/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-023

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 4930 Butterworth PI NW

Customer Sample Number:

Date / Time Collected: 10/26/2024 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-024

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-043

Sample Location: 1st Draw 503 Rock Creek Church Rd NW

Customer Sample Number:

Date / Time Collected: 11/7/2024 4:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-043

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	2	8.7	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 503 Rock Creek Church Rd NW

Customer Sample Number:

Date / Time Collected: 11/7/2024 4:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-044

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.4	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-036

Sample Location: 1st Draw 5229 8th St NW

Customer Sample Number:

Date / Time Collected: 11/21/2024 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-036

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 5229 8th St NW

Customer Sample Number:

Date / Time Collected: 11/21/2024 7:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-037

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-019

Sample Location: 1st Draw 527 Longfellow St NW #2

Customer Sample Number:

Date / Time Collected: 10/30/2024 6:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-019

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 527 Longfellow St NW #2

Customer Sample Number:

Date / Time Collected: 10/30/2024 6:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2411059-020

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-017

Sample Location: 1st Draw 5310 New Hampshire Ave NW

Customer Sample Number:

Date / Time Collected: 10/29/2024 6:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2411059-017

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 5310 New Hampshire Ave NW

Customer Sample Number:

Date / Time Collected: 10/29/2024 6:08 PM

Customer Program Code: DS

Laboratory Sample Number: 2411059-018

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-045

Sample Location: 1st Draw 5329 42ND ST NW

Customer Sample Number:

Date / Time Collected: 11/9/2024 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-045

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 5329 42ND ST NW

Customer Sample Number:

Date / Time Collected: 11/9/2024 7:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2411145-046

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411159-017

Sample Location: 1st Draw 5330 Broad Rd NW

Customer Sample Number:

Date / Time Collected: 11/11/2024 5:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2411159-017

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 5330 Broad Rd NW

Customer Sample Number:

Date / Time Collected: 11/11/2024 5:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2411159-018

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-046

Sample Location: 1st Draw 5730 1st St NW

Customer Sample Number:

Date / Time Collected: 11/20/2024 4:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-046

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 5730 1st St NW

Customer Sample Number:

Date / Time Collected: 11/20/2024 4:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-047

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-042

Sample Location: 1st Draw 712 A St SE
Customer Sample Number:
Date / Time Collected: 11/19/2024 4:28 PM

Customer Program Code: DS
Laboratory Sample Number: 2411195-042
Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 712 A St SE
Customer Sample Number:
Date / Time Collected: 11/19/2024 4:33 PM

Customer Program Code: DS
Laboratory Sample Number: 2411195-043
Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411195-050

Sample Location: 1st Draw 746 Quebec Place NW

Customer Sample Number:

Date / Time Collected: 11/19/2024 7:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-050

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 746 Quebec Place NW

Customer Sample Number:

Date / Time Collected: 11/19/2024 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2411195-051

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411059-031

Sample Location: 1st Draw 772 Lamont St NW

Customer Sample Number:

Date / Time Collected: 11/3/2024 8:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2411059-031

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 772 Lamont St NW

Customer Sample Number:

Date / Time Collected: 11/3/2024 8:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2411059-032

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2412030-007

Sample Location: 1st Draw 930 Quincy St. NW

Customer Sample Number:

Date / Time Collected: 11/14/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2412030-007

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 930 Quincy St. NW

Customer Sample Number:

Date / Time Collected: 11/14/2024 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2412030-008

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS-2411145-035

Sample Location: 1st Draw 945 T St. NW
Customer Sample Number:
Date / Time Collected: 11/9/2024 5:40 PM

Customer Program Code: DS
Laboratory Sample Number: 2411145-035
Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 945 T St. NW
Customer Sample Number:
Date / Time Collected: 11/9/2024 5:45 PM

Customer Program Code: DS
Laboratory Sample Number: 2411145-036
Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411058-005

Sample Location: 1st Draw 1375 Monroe St NW

Customer Sample Number:

Date / Time Collected: 11/3/2024 9:29 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411058-005

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1375 Monroe St NW

Customer Sample Number:

Date / Time Collected: 11/3/2024 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411058-006

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411157-005

Sample Location: 1st Draw 1401 Columbia Rd. NW, Apt 410

Customer Sample Number:

Date / Time Collected: 11/10/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-005

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1401 Columbia Rd. NW, Apt 410

Customer Sample Number:

Date / Time Collected: 11/10/2024 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-006

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411110-001

Sample Location: 1st Draw 1464 Harvard St. Apt 7

Customer Sample Number:

Date / Time Collected: 11/11/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411110-001

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1464 Harvard St. Apt 7

Customer Sample Number:

Date / Time Collected: 11/11/2024 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411110-002

Date / Time Received: 11/14/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411194-001

Sample Location: 1st Draw 1620 Fuller St NW Apt 211

Customer Sample Number:

Date / Time Collected: 11/20/2024 7:46 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411194-001

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 1620 Fuller St NW Apt 211

Customer Sample Number:

Date / Time Collected: 11/20/2024 7:46 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411194-002

Date / Time Received: 11/26/2024 9:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411157-009

Sample Location: 1st Draw 1629 Columbia Rd NW Apt. 723

Customer Sample Number:

Date / Time Collected: 11/13/2024 9:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-009

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1629 Columbia Rd NW Apt. 723

Customer Sample Number:

Date / Time Collected: 11/13/2024 9:45 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-010

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411157-001

Sample Location: 1st Draw 1868 Columbia Rd NW, Apt. 612

Customer Sample Number:

Date / Time Collected: 11/7/2024 7:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-001

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 1868 Columbia Rd NW, Apt. 612

Customer Sample Number:

Date / Time Collected: 11/7/2024 7:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-002

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411157-007

Sample Location: 1st Draw 2 L St NW, 517

Customer Sample Number:

Date / Time Collected: 11/12/2024 5:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-007

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 2 L St NW, 517

Customer Sample Number:

Date / Time Collected: 11/12/2024 5:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-008

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2412029-003

Sample Location: 1st Draw 208 Farragut St. NW Apt 206

Customer Sample Number:

Date / Time Collected: 11/14/2024 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412029-003

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 208 Farragut St. NW Apt 206

Customer Sample Number:

Date / Time Collected: 11/14/2024 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412029-004

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2412029-005

Sample Location: 1st Draw 2141 I St. NW, #508

Customer Sample Number:

Date / Time Collected: 11/18/2024 7:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412029-005

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 2141 I St. NW, #508

Customer Sample Number:

Date / Time Collected: 11/18/2024 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412029-006

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2412050-005

Sample Location: 1st Draw 2510 41 ST NW #3

Customer Sample Number:

Date / Time Collected: 11/23/2024 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-005

Date / Time Received: 12/5/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 2510 41 ST NW #3

Customer Sample Number:

Date / Time Collected: 11/23/2024 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-006

Date / Time Received: 12/5/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411157-003

Sample Location: 1st Draw 2516 Q St NW Q201

Customer Sample Number:

Date / Time Collected: 11/10/2024 1:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-003

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 2516 Q St NW Q201

Customer Sample Number:

Date / Time Collected: 11/10/2024 1:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-004

Date / Time Received: 11/20/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411157-011

Sample Location: 1st Draw 2608 Sherman Ave NW Apt. 203

Customer Sample Number:

Date / Time Collected: 11/5/2024 8:08 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-011

Date / Time Received: 11/20/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/27/2024	SBrooks

Sample Location: 2nd Draw 2608 Sherman Ave NW Apt. 203

Customer Sample Number:

Date / Time Collected: 11/5/2024 8:08 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411157-012

Date / Time Received: 11/20/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411058-001

Sample Location: 1st Draw 2717 13th St NW

Customer Sample Number:

Date / Time Collected: 11/4/2024 8:42 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411058-001

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 2717 13th St NW

Customer Sample Number:

Date / Time Collected: 11/4/2024 8:42 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411058-002

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411058-003

Sample Location: 1st Draw 2939 Van Ness St NE #1203

Customer Sample Number:

Date / Time Collected: 10/30/2024 11:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411058-003

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Sample Location: 2nd Draw 2939 Van Ness St NE #1203

Customer Sample Number:

Date / Time Collected: 10/30/2024 11:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411058-004

Date / Time Received: 11/8/2024 10:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/27/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2412050-009

Sample Location: 1st Draw 3032 RODMAN ST NW #24

Customer Sample Number:

Date / Time Collected: 11/25/2024 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-009

Date / Time Received: 12/5/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 3032 RODMAN ST NW #24

Customer Sample Number:

Date / Time Collected: 11/25/2024 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-010

Date / Time Received: 12/5/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2412029-001

Sample Location: 1st Draw 305 C St. NE #108

Customer Sample Number:

Date / Time Collected: 11/13/2024 11:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412029-001

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 305 C St. NE #108

Customer Sample Number:

Date / Time Collected: 11/13/2024 11:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412029-002

Date / Time Received: 11/27/2024 9:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2412050-001

Sample Location: 1st Draw 3236 13TH ST NW

Customer Sample Number:

Date / Time Collected: 11/10/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-001

Date / Time Received: 12/5/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/10/2024	SBrooks

Sample Location: 2nd Draw 3236 13TH ST NW

Customer Sample Number:

Date / Time Collected: 11/10/2024 8:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-002

Date / Time Received: 12/5/2024 9:20:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2412050-003

Sample Location: 1st Draw 3831 Georgia Ave. NW #301

Customer Sample Number:

Date / Time Collected: 11/22/2024 7:04 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-003

Date / Time Received: 12/5/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 3831 Georgia Ave. NW #301

Customer Sample Number:

Date / Time Collected: 11/22/2024 7:04 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-004

Date / Time Received: 12/5/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2411144-001

Sample Location: 1st Draw 430 M St. SW Apt. N510

Customer Sample Number:

Date / Time Collected: 11/10/2024 3:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411144-001

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw 430 M St. SW Apt. N510

Customer Sample Number:

Date / Time Collected: 11/10/2024 3:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2411144-002

Date / Time Received: 11/19/2024 9:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/16/2024

Report Number: L-DC-DS250- 2412050-007

Sample Location: 1st Draw Kiley Apartments 600 4th St. SW Apt 738

Customer Sample Number:

Date / Time Collected: 11/25/2024 9:25 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-007

Date / Time Received: 12/5/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Sample Location: 2nd Draw Kiley Apartments 600 4th St. SW Apt 738

Customer Sample Number:

Date / Time Collected: 11/25/2024 9:25 AM

Customer Program Code: DS250

Laboratory Sample Number: 2412050-008

Date / Time Received: 12/5/2024 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/10/2024	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 1/8/2025

Report Number: L-DC-DS-2501010-017

Sample Location: 1st Draw 720 Harvard St NW

Customer Sample Number:

Date / Time Collected: 12/18/2024 6:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2501010-017

Date / Time Received: 1/2/2025 12:40:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	1/3/2025	BPrakash

Sample Location: 2nd Draw 720 Harvard St NW

Customer Sample Number:

Date / Time Collected: 12/18/2024 6:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2501010-018

Date / Time Received: 1/2/2025 12:40:00 PM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	1/3/2025	BPrakash

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**