

D.C. Mun. Regs., tit. 21, § 5400

21-5400 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5400. GENERAL PROVISIONS

5400.1 The purpose of this chapter is to establish procedures for the protection of the public health and safety and the potable water supply of the District of Columbia from contaminants and pollutants through cross-connections. The provisions of this chapter are designed to eliminate or control actual or potential cross-connection, to maintain a continuing program of cross connection control

5400.2 These regulations are promulgated to provide authority separate from and independent of other regulations, the Building Code and supplement authority exercised by the Department of Health and the Department of Consumer and Regulatory Affairs to regulate other activities that affect Cross-connections.

5400.3 The provisions of this chapter shall apply to all improved real property, appurtenances and fixtures thereto and all construction sites within the District of Columbia. Properties that have a private well or source of other private water source are not exempted from the requirements of this chapter.

5400.4 The General Manager shall have authority to develop, implement and enforce procedures and standards, which carry out the intent of this chapter.

D.C. Mun. Regs., tit. 21, § 5400, 21 DC ADC § 5400
21 DC ADC § 5400

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5401

21-5401 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5401. PROTECTION OF PUBLIC WATER SYSTEM

5401.1 An Owner shall maintain all interior plumbing to prevent contamination of the public water system from nonpotable liquids, solids, gasses or mixture of substances through cross connections.

5401.2 An Owner shall not permit the installation of a bypass around any backflow preventer unless a backflow preventer is installed on the bypass.

D.C. Mun. Regs., tit. 21, § 5401, 21 DC ADC § 5401
21 DC ADC § 5401

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5402

21-5402 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5402. INSPECTION AND ENTRY

5402.1 The General Manager, with prior written notice to the Owner of the date of entry, may enter any building, establishment, or other premises to identify potential cross connections and to determine whether it is practicable and necessary to install a backflow preventer to protect the public health and safety from contaminants.

5402.2 The General Manager may, after reasonable notice, enter any building, establishment, or other premises to inspect, install, retrofit, replace, or repair any device required to be installed pursuant to this chapter.

D.C. Mun. Regs., tit. 21, § 5402, 21 DC ADC § 5402
21 DC ADC § 5402

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5403

21-5403 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5403. IDENTIFICATION OF CROSS CONNECTIONS AND PRACTICABILITY DETERMINATION

5403.1 The General Manager may utilize all reasonable means to identify properties with cross connections and may determine whether installation of backflow prevention devices is practicable and necessary in order to prevent the introduction of pollutants or contaminants to the Potable Water System.

5403.2 In the event the General Manager determines that it is practicable and necessary to install backflow preventers, the General Manager shall give the Owner of the property identified written notification that the following will be required:

- (a) Installation of the number and type of backflow preventers determined to be necessary by the General Manager, at no cost to WASA, within sixty (60) days of the date of the notice;
- (b) Test and inspect the backflow preventers as directed by WASA, at no cost to WASA;
- (c) Report the test results to WASA as directed by WASA; and
- (d) Permit inspection or inspections as required by WASA.

5403.3 An Owner identified in a notice issued pursuant to §§ 5403.2 may petition the General Manager, in writing, for additional time to install the number and type of backflow preventers required by a notice issued pursuant to §§ 5403.2. This petition must be delivered to WASA no later than fifteen (15) days after the date of notice issued pursuant to §§ 5403.2. The General Manager may grant the request only upon a finding of good cause shown and shall advise the petitioning Owner of his or her decision in writing.

5403.4 An Owner identified in a notice issued pursuant to §§ 5403.2 may also submit an alternative proposal to eliminate existing or potential cross connections. The Owner's proposal shall be in writing, certified by professional engineer, registered with the District of Columbia, and must be delivered to WASA no later than fifteen (15) days after the date of the notice is-

sued pursuant to §§ 5403.2.

5403.5 The General Manager shall review the Owner's proposal made pursuant to §§ 5403.4, and after consideration of generally accepted engineering practices, in his or her sole discretion, either approve or deny, in whole or in part, the Owner's proposal in writing.

5403.6 If the Owner's proposal made pursuant to §§ 5403.4 is approved in whole or in part, the General Manager shall notify the Owner to:

- (a) Install the number and type of backflow preventers approved, at no cost to WASA, within thirty (30) days of the date of the approval or such other period of time determined reasonable by the General Manager, within his or her sole discretion;
- (b) Take any other action determined necessary by the General Manager as a result of the approval of the Owner's proposal;
- (c) Test and inspect the alternative backflow preventers as directed by WASA, at no cost to WASA;
- (d) Report the test results to WASA as directed by WASA; and
- (e) Permit inspection or inspections as required by WASA.

5403.7 If the Owner's proposal made pursuant to §§ 5403.4 is denied, in whole or in part, the Owner shall install the devices required in the §§ 5403.2 notice within thirty (30) days from the date of the General Manager's denial.

5403.8 An Owner, whose proposal made pursuant to §§ 5403.4 is denied in whole or in part, may also petition the General Manager for additional time to install the required devices. This petition must be delivered to WASA no later than fifteen (15) days after the date of the General Manager's notice of denial. The General Manager may grant or deny the Owner's request within the General Manager's sole discretion and shall advise the petitioning Owner of his or her decision in writing.

D.C. Mun. Regs., tit. 21, § 5403, 21 DC ADC § 5403
21 DC ADC § 5403

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5404

21-5404 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5404. DUTY OF OWNERS TO IDENTIFY CROSS CONNECTIONS

5404.1 An Owner shall, upon written request made by the General Manager, inspect all fixtures and appurtenant Interior Plumbing and inform the General Manager, in writing, of all cross connections on all properties that are the subject of General Manager's request.

D.C. Mun. Regs., tit. 21, § 5404, 21 DC ADC § 5404
21 DC ADC § 5404

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5405

21-5405 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5405. IMMINENT THREAT

5405.1 The General Manager shall terminate water service to any property that poses an imminent threat to the public health.

5405.2 The General Manager may also take any other action and require any person to take any action deemed necessary to protect the health of persons who are or may be users of the Potable Water Supply.

5405.3 Notwithstanding any other provision of this chapter, the General Manager, may upon receipt of information that a Contaminant is present in or is likely to enter the Potable Water Supply, and which may present an imminent and substantial endangerment to the health of persons, take such actions as the General Manager deems necessary in order to protect the health of such persons.

D.C. Mun. Regs., tit. 21, § 5405, 21 DC ADC § 5405
21 DC ADC § 5405

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, §5406

21-5406 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5406. MAINTENANCE AND TESTING OF BACKFLOW PREVENTERS

5406.1 An Owner shall inspect and test all backflow preventers annually or as otherwise directed by WASA at no charge to WASA. All test results shall be submitted to the General Manager within ten (10) days of test.

5406.2 An Owner shall repair or replace any backflow preventer that has failed within ten (10) days of the date the failure is made known to the Owner. In the event a device is replaced or repairs are made, an Owner shall test the device to insure correct operation.

5406.3 An Owner shall not permit the bypass of any backflow preventer unless a backflow preventer is installed on the bypass.

D.C. Mun. Regs., tit. 21, §5406, 21 DC ADC §5406
21 DC ADC §5406

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5407

21-5407 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5407. CERTIFICATION REQUIREMENTS

5407.1 No person shall engage in the testing of backflow preventers unless the person possesses a valid certification issued by the General Manager.

5407.2 Applications for certification to test backflow preventers shall be made to the General Manager on a form prescribed by the General Manager. Certification shall be for a three (3) year term.

5407.3 Each person applying for certification shall submit to the General Manager under oath, such information as the General Manager may require to assist in the determination whether the applicant has sufficient experience, training or education in testing backflow preventers.

5407.4 Application and certification fees shall be set by the General Manager, and shall be submitted with the application to the General Manager.

5407.5 If the General Manager finds that an applicant has the required qualifications, the General Manager shall issue the certification.

5407.6 Certifications issued pursuant to this chapter shall not be transferable.

D.C. Mun. Regs., tit. 21, § 5407, 21 DC ADC § 5407
21 DC ADC § 5407

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5407

21-5407 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5407. GROUNDS AND PROCEDURE FOR DENIAL, SUPENSION, OR REVOCATION OF
CERTIFICATION

5408.1 A backflow preventer tester certification shall be subject to denial, suspension, or revocation for the following causes:

- (a) Material misstatement in application for certification;
- (b) Willful failure or refusal to comply with any provision of statute or regulation relating to plumbing or water and sanitation;
- (c) Fraud;
- (d) Willful misrepresentation or concealment through any subterfuge or device of any matter or the nature of any matter required by the chapter to be stated or furnished;
- (e) Incompetence.

5408.2 Whenever the General Manager finds that an applicant for a certificate under this chapter is deficient in one or more of the certificate qualifications or whenever the General Manager has reasonable grounds to believe that there has been a violation of any statute or regulation applicable to plumbing or water and sanitation for which the tester is subject to suspension or revocation, the General Manager shall give written notice to the applicant or certificate holder in accordance with the provisions of this section.

5408.3 The notice required by §§ 5408.2 shall state with specificity the grounds for the suspension, revocation or denial.

5408.4 Any person who has received a notice of denial, suspension or revocation may file a written notice of appeal pursuant to chapter 400 of this Title. The notice of appeal shall be filed no later than fifteen (15) days after the date of the notice of denial.

D.C. Mun. Regs., tit. 21, § 5407, 21 DC ADC § 5407
21 DC ADC § 5407

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5409

21-5409 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5409. ENFORCEMENT

5409.1 In the event that an Owner fails to: allow inspections; comply with any requirement to install required devices; report test results; install, repair, maintain or test a backflow preventer; fails to maintain a private water system so as to prevent a cross connection; fails to maintain a private water system in accordance with regulations; or fails to comply with a notice, direction or order of the General Manager issued pursuant to these regulations, WASA may do the following:

- (a) Immediately terminate the water supply to the property;
- (b) Refuse to establish a water and sewer account for the property;
- (c) Refuse to supply water and sewer service to the property; or
- (d) Request that the building permit for the property be rescinded and not reinstated until the necessary backflow preventers are installed and inspected.

D.C. Mun. Regs., tit. 21, § 5409, 21 DC ADC § 5409
21 DC ADC § 5409

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5410

21-5410 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5410. RIGHT TO CHALLENGE PRACTICABILITY AND NECESSITY TO PROTECT PUBLIC HEALTH AND SAFETY, IMMINENT THREAT, AND PREVENTION DEVICE DETERMINATIONS

5410.1 The Owner of an identified property may contest any of the following determinations made by the General Manager:

- (a) Whether the installation of a backflow prevention device is practicable and necessary to protect the Portable Water System from contamination pursuant to §§ 5403.1 of this chapter;
- (b) Whether there is an imminent threat to the public health pursuant to §§ 5405.1 of this chapter; or
- (c) The type of preventive device determinations made by the General Manager pursuant to §§ 5403.2 of this chapter by following the procedures set forth in chapter 400 of this subtitle.

D.C. Mun. Regs., tit. 21, § 5410, 21 DC ADC § 5410
21 DC ADC § 5410

END OF DOCUMENT

D.C. Mun. Regs., tit. 21, § 5499

21-5499 CDCR

CODE OF DISTRICT OF COLUMBIA MUNICIPAL REGULATIONS
CDCR TITLE 21. WATER AND SANITATION
CHAPTER 54. CROSS CONNECTIONS

Copyright (c) 2009 by Matthew Bender & Company, Inc

Current through November 2009

5499. DEFINITIONS

When used in this chapter, the following words and phrases shall have the meanings ascribed:

Backflow - A reversal of the flow of water caused by a loss in water pressure. This reversal may allow other liquids, gasses or mixtures of substances to enter into the potable water supply.

Backflow Preventer - A device approved by the General Manager or his or her designee for a water supply pipe to prevent the backflow of water into the water supply system from the connections on its outlet end.

Contaminant - any substance in the Potable Water Supply that creates a hazard to human health when its level exceeds the standards established under the Safe Drinking Water Act, [42 U.S.C. §§300\(f\) et. seq.](#)

Cross-connection - an actual or potential link between any part of a potable water system and any other environment of liquid, gas, solid or mixture of substances in a manner that, under any circumstances, would allow such substances to enter the potable water system.

General Manager - the chief administrative officer of the District of Columbia Water and Sewer Authority or his or her designee.

Interior Plumbing - part of plumbing system that includes the water supply to the building and distribution pipes within the building or premises; plumbing fixtures and traps; soil, waste and vent pipes; and sanitary and storm sewers and building drains; including their respective connections, devices and appurtenances within a building or premises.

Owner - any individual, corporation, association or partnership listed as the legal titleholder of record or his or her agent, including where appropriate, agents and agencies of the government of the United States of America.

Pollutant - any substance in the water supply that renders it to be unsuitable or unacceptable for drinking.

Potable Water Supply - water distributed by WASA that meets the requirements of the Safe Drinking Water Act ([42 U.S.C. §§ 300\(f\)](#) et. seq.) and is otherwise suitable and acceptable for drinking.

Private Water System - the water service pipe, water distribution pipes, any necessary connection pipes, fittings, control valves, hydrants, and all appurtenances in or adjacent to the building(s) or premises.

WASA - the District of Columbia Water and Sewer Authority or its lawful agent, representative, successor in interest, assign or designee.

D.C. Mun. Regs., tit. 21, § 5499, 21 DC ADC § 5499
21 DC ADC § 5499

END OF DOCUMENT