



**DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY
DEPARTMENT OF WATER SERVICES
3900 Donaldson Pl, N.W. WASHINGTON DC 20016**

**Lead & Copper Compliance Report
July - December 2005
(REVISED 5-3-2006)**

- **Number of Samples Taken: 118**
- **Lead 90th% (First Draw): 0.015 mg/L or 15 ppb**
- **Lead 90th% (Second Draw): 0.018 mg/L or 18 ppb**
- **Copper 90th% (First Draw): 0.077 mg/L or 77 ppb**
- **Copper 90th% (Second Draw): 0.055 mg/L or 55 ppb**
- **Sampling Composite**
 - **Number of Samples Accepted for Compliance Monitoring: 102**
 - **Number of Routine Samples Taken: 100**
 - **Number of Repeat Samples Collected for Compliance Monitoring: 2**
 - **Number of Sampling Locations: 100**
 - **Percent Full Lead Service Line Samples: ~81%**
 - **Percent Partial Lead Service Line Samples: ~19%**
 - **Number of Samples Invalidated: 16**
 - **Number of Samples Invalidated by EPA on December 27, 2005: 3**
 - **Number of Samples Invalidated by EPA on February 12, 2006: 12**
 - **Number of Samples Invalidated by EPA on April 10, 2006: 3**
 - **Number of Samples Revalidated by EPA on April 10, 2006: 3**
 - **Number of Samples Invalidated by EPA on April 28, 2006: 1**
 - **Number of Replacement Samples Collected in 2006: 12**

The District of Columbia is **below** the Lead Action Level for a second consecutive semester at 0.015 mg/L or 15 ppb (first draw) and below the Copper action level at 0.077 mg/L or 77 ppb (first draw).

Orthophosphate addition was implemented on August 23, 2004. Since the addition, overall first draw lead levels have been on the decline. This semester ten (10) first draw samples were above the action level, however 7 of those samples were less than 26 ppb.

In November 2004, WASA implemented a door-to-door solicitation, educating customers on the importance of sampling, which was well received in most cases and increased the number of samples collected. This education program appeared to continue its success in 2005 as 98% of the sample pool was from the routine list. Samples were collected evenly throughout the monitoring period from July through December at approximately 20 samples per month.

For the monitoring period of July to December 2005, 196 sampling kits were dropped off to participants on the routine monitoring list, supplemental sites and customer requests. Of the 196

samples, 90 sampling kits were not returned. Those addresses are listed in Section 4. For the remainder, there were a total of 106 samples collected during the compliance monitoring period. An additional 12 samples were collected in February and March 2006 to replace the samples that were invalidated by EPA on February 12, 2006 and April 28, 2006. One-hundred, two (102) of all samples collected met the compliance monitoring criteria as described in the 2005 lead and copper monitoring plan (Section 5). One hundred (100) samples were from the routine list. The remaining two (2) samples were from locations where sampling kits were accidentally dropped off: 2850 28th St, NW and 1424 S St, NW. These two locations met the tier 1 criteria and were included in the compliance calculation.

There were two (2) locations of the one hundred, two (102) samples that were mistakenly sampled twice in the monitoring period. This occurred at the time the staff person in charge of sample assignments was out of the office and backup support staff accidentally dropped off bottles a second time at these locations. These samples met the tier 1 criteria and were both included in the compliance monitoring calculation.

Of the sixteen (16) samples that did not meet the compliance monitoring criteria, there were three (3) samples collected from two locations that were not be used for compliance monitoring. Analysis results are located in Section 2. The addresses of these locations are as follows:

- 1746 Kenyon Street, NW
 - Sample ID # 0511015-027
 - Analysis Date 11/1/2005
- 1502 Columbia Rd, NW
 - Sample ID # 0512018-001
 - Analysis Date 7/29/2005
 - Sample ID # 0511015-023
 - Analysis Date 11/1/2005

A detailed review of the chain of custody of 1746 Kenyon St, followed by a discussion with the resident, confirmed that the sample collected on 10/27/05 was actually taken from a filter. On December 2, 2005 WASA had the customer bypass the filter and recollect the sample. The sample collected on December 2, 2005 will be used for compliance purposes.

On November 28, 2005 WASA determined that 1502 Columbia Rd no longer met the tier 1 requirement. A full lead service line replacement occurred in August 2004. In addition, discussion with the customer on November 28, 2005 revealed major replumbing inside the home was recently conducted. According to WASA's most recent lead and copper monitoring plan (Section 5), if a home has had major indoor plumbing construction after 1986 and has a copper service line, the resident would NOT qualify as a Tier 1 site. There were two samples collected this semester from this home after the major plumbing had occurred. Therefore, these samples will also not be included in the compliance calculation.

On December 14, 2005, WASA requested the invalidation of these three (3) samples to be included in the July - December 2005 lead & copper monitoring report, but not include them towards the 90th percentile calculation. The chain of custody documents for these three (3)

samples are located in Section 7. EPA Region III approved WASA's request and invalidated these three (3) samples by email dated December 27, 2005 and by letter dated January 5, 2006.

On January 3, 2006, WASA submitted the Lead and Copper Compliance Report. In response to EPA's letter dated January 12, 2006, and electronic messages of January 27, 2006 and February 8, 2006, WASA provided additional documentation to EPA on February 3 and 10, 2006. Based on this information, on February 22, 2006, EPA invalidated twelve (12) samples listed below:

- 1250 Florida Ave. NE
- 1612 V St, NW
- 1626 19th St, NW
- 1803 Monroe St, NW
- 2003 Klingle Rd, NW
- 2017 Belmont Rd, NW
- 3250 Highland Pl, NW
- 4501 Yuma St, NW
- 4507 13th St, NW
- 1937 Summit Pl, NE
- 621 L St, NE
- 612 G St, NE

EPA's February 22, 2006 invalidation notice required WASA to collect samples at a minimum of eleven (11) additional tier 1 locations within 20 days of the receipt of that letter to reach the minimum number of samples required for the monitoring period, 100 samples. EPA noted that the replacement samples must meet the tier 1 criteria and be taken at eleven (11) locations other than those already used for sampling during the monitoring period.

At the time WASA received EPA's notice of invalidation, WASA had already submitted 22 samples to the lab for analysis. Prior to receiving the sampling results, WASA proceeded to screen these sample locations sampled on February 7, 8, and 9, 2006 to determine which of the 22 samples could qualify as replacements. Of the 22 samples, ten (10) sites had not been sampled during the July – December 2005 monitoring period and met the tier 1 criteria. WASA sent out another set of sample bottles to customers on March 5, 2006 and the first sample that met the replacement criteria was collected on March 6, 2006.

On March 27, 2006, WASA submitted the results and documentation for the eleven (11) samples to EPA for their review and approval. On April 10, 2006, EPA accepted all eleven (11) samples as replacements.

On March 27, 2006, WASA requested the invalidation of two (2) additional sample locations for not meeting the Tier 1 criteria and included a note regarding a third sample, which EPA had in conference indicated would not need to be invalidated. On April 5, 2006, WASA provided additional information to EPA in response to EPA's, March 31, 2006 request for additional documentation regarding the third sample. On April 10, 2006, EPA accepted WASA's request and invalidated the two (2) samples and invalidated the third based on the information provided.

- 1226 D St, NE – Test pitted as copper on August 30, 2005
- 714 8th St, NE – Test pitted as copper on September 29, 2005
- 406 9th St, NE – Test pitted as galvanized on November 17, 2005

In March 2006, WASA test pitted the following three (3) addresses that EPA had invalidated on February 12, 2006. WASA selected the invalidated sites to reevaluate based on: 1) prior participation in routine monitoring program, 2) prior water quality data, showing 2nd draw exceedances, 3) age of the home, and 4) no record of any public or private lead service line replacement. WASA found that the service lines at these addresses were in fact lead.

- 1612 V St, NW
- 2003 Klingle Rd, NW
- 4507 13th St, NW

On March 27, 2006, WASA requested revalidation of these three (3) samples, based on the test pit data. On April 10, 2006, EPA withdrew their invalidation determination for these three (3) samples. Consequently, WASA has incorporated the results for these three (3) samples into the 90th percentile calculation.

On April 25, 2006, WASA revised the Lead and Copper Compliance Report and submitted the revised report to EPA. During the preparation of the revised report, WASA learned of additional information pertaining to three (3) locations that were sampled during the July – December monitoring period: 4450 Volta Pl, NW, 1338 A St, SE, and 2448 Huidekoper Pl, NW. WASA provided this information to EPA, in the letter dated April 25, 2006. On April 28, 2006, EPA invalidated the sample collected at 4450 Volta Pl, NW, based on the information provided. EPA's invalidation notice required WASA, within twenty (20) days of receipt of the letter, to collect one (1) additional sample at a location that meets the tier 1 criteria and was not sampled during the July – December 2005 monitoring period.

EPA's invalidation notice acknowledged that WASA may have additional sample results taken earlier in 2006 that may be submitted as the replacement sample and that WASA sent a batch of samples to customers on March 5, 2006. EPA's notice encouraged WASA to respond as quickly as possible, but no later than 30 days from the date of the notice with a revised and certified 90th percentile calculation.

On April 28, 2006, WASA reviewed the batch of samples that were sent to customers on March 5, 2006 to identify the first sample that met the tier 1 criteria. As discussed above, the first sample from this batch was collected on March 6, 2006 and was included as a replacement sample in the March 27, 2006 correspondence. Therefore, WASA selected the second sample from this batch, which was collected on March 7, 2006 at 6:52 a.m. from 4325 Iowa Ave., NW. This location meets the tier 1 criteria and was not sampled during the July – December 2005 monitoring period. The sample results for this site have been included in the 90th percentile calculation. The documentation for this sample is included as an attachment to the cover letter for the transmittal of this revised report.

Detailed results of all samples including invalidated and revalidated samples are located in Section 2.

Summary of Sections

Section 1 - Summary of compliance results.

Section 2 – Detail report of all results collected under the compliance program

Section 3 – Summary of all samples collected under the customer service and Lead Service Line Replacement program

Section 4 – Summary of all locations where bottles were dropped off but no customer participation

Section 5 – July – December 2005 Lead and Copper Sampling Plan

Section 6 – Lab reports (hard copy only)

Section 7 – Chain of custody forms for the (3) samples invalidated by EPA letter dated 1/5/06

Section 1.
Summary of Lead Compliance Results

| Assigned No. | Location | Lead (mg/L) 1st Draw | Lead (mg/L) 2nd Draw |
|--------------|---------------------------|----------------------|----------------------|
| 1 | 1214 SHEPHERD ST NW | 0 ND | 0 ND |
| 2 | 1341 MASSACHUSETTS AVE SE | 0 ND | 0 ND |
| 3 | 2448 HUIDEKOPER PL NW | 0 ND | 0 ND |
| 4 | 2238 HALL PL NW | 0 ND | 0 ND |
| 5 | 2111 S ST NW | 0 ND | 0.006 |
| 6 | 202 11th St SE | 0<.5ppb | 0<.5ppb |
| 7 | 1262 COLUMBIA RD NW | 0<.5ppb | 0.001 |
| 8 | 1104 TRINIDAD AVE NE | 0<.5ppb | 0.001 |
| 9 | 3439 24TH ST SE | 0<.5ppb | 0 ND |
| 10 | 311 ELM ST NW | 0.001 | 0<.5ppb |
| 11 | 1332 VERMONT AVE NW | 0.001 | 0 ND |
| 12 | 3835 BEECHER ST NW | 0.001 | 0.001 |
| 13 | 3913 8TH ST NW | 0.001 | 0.001 |
| 14 | 4518 14TH ST NW | 0.001 | 0.001 |
| 15 | 1971 BILTMORE ST | 0.001 | 0.001 |
| 16 | 1338 A ST SE | 0.002 | 0 ND |
| 17 | 4332 BRANDYWINE ST NW | 0.002 | 0.003 |
| 18 | 1626 E ST SE | 0.002 | 0.002 |
| 19 | 1228 CARROLLSBURG PL SW | 0.002 | 0.001 |
| 20 | 3218 MORRISON ST NW | 0.002 | 0.003 |
| 21 | 1843 MONROE ST NW | 0.002 | 0.002 |
| 22 | 4818 ILLINOIS AVE NW | 0.002 | 0.003 |
| 23 | 3908 13TH ST NW | 0.0025 ³ | 0.003 |
| 24 | 4325 IOWA AVE NW | 0.003 | 0.003 |
| 25 | 205 TAYLOR ST NW | 0.003 | 0.006 |
| 26 | 5318 9TH ST NW | 0.003 | 0.003 |
| 27 | 331 RALEIGH ST SE | 0.003 | 0.003 |
| 28 | 1746 KENYON ST NW | 0.003 | 0.003 |
| 29 | 1815 MONROE ST NW | 0.003 | 0.002 |
| 30 | 2134 NEWPORT PL NW | 0.003 | 0.002 |
| 31 | 532 13TH ST SE | 0.0035 ³ | 0.004 |
| 32 | 119 16TH ST | 0.004 | 0.001 |
| 33 | 3601 WARREN ST NW | 0.004 | 0.002 |
| 34 | 5301 RENO RD NW | 0.004 | 0.020 |
| 35 | 1839 MONROE ST NW | 0.004 | 0.003 |

| Assigned No. | Location | Lead (mg/L) 1st Draw | Lead (mg/L) 2nd Draw |
|--------------|--------------------------------|-------------------------|-------------------------|
| 36 | 3618 PORTER ST NW | 0.004 | 0.016 |
| 37 | 1420 S ST SE | 0.004 | 0.007 |
| 38 | 1825 L ST NE | 0.004 | 0.004 |
| 39 | 1814 MONROE ST NW | 0.004 | 0.0045 ³ |
| 40 | 2823 28TH ST NW | 0.004 | 0.007 |
| 41 | 607 ATLANTIC ST SE | 0.0045 ³ | 0.002 |
| 42 | 3218 MACOMB ST NW ² | 0.005 | 0.007 |
| 43 | 3030 44TH ST NW ² | 0.005 | 0.007 |
| 44 | 1812 14TH ST SE | 0.005 | 0.004 |
| 45 | 2850 28th St NW | 0.005 | 0.008 |
| 46 | 2830 BRENTWOOD RD NE | 0.005 | 0.005 |
| 47 | 2702 P ST NW | 0.005 | 0<.5ppb |
| 48 | 2007 KLINGLE RD NW | 0.005 | 0.010 |
| 49 | 2435 33RD ST SE | 0.005 | 0.007 |
| 50 | 4111 INGOMAR ST NW | 0.005 | 0.007 |
| 51 | 3030 44TH ST NW ² | 0.005 | 0.003 |
| 52 | 143 UHLAND TER NE | 0.006 | 0.013 |
| 53 | 5324 COLORADO AVE NW | 0.006 | 0.002 |
| 54 | 3809 ALTON PL NW | 0.006 | 0.026 |
| 55 | 4609 30TH ST NW | 0.006 | 0.005 |
| 56 | 3424 PORTER ST NW | 0.007 | 0.004 |
| 57 | 4622 15TH ST NW | 0.007 | 0.005 |
| 58 | 4507 13TH ST NW | 0.007 | 0.003 |
| 59 | 1241 JACKSON ST NE | 0.007 | 0.012 |
| 60 | 1635 WEBSTER ST NW | 0.007 | 0.006 |
| 61 | 322 TENNESSEE AVE NE | 0.007 | 0.006 |
| 62 | 1400 FLORAL ST NW | 0.007 | 0.006 |
| 63 | 4413 GREENWICH PKWY NW | 0.007 | 0.010 |
| 64 | 1956 BILTMORE ST NW | 0.007 | 0.006 |
| 65 | 3550 ALBEMARLE ST NW | 0.007 | 0.008 |
| 66 | 349 TENNESSEE AVE NE | 0.008 | 0.011 |
| 67 | 2305 38TH ST NW | 0.008 | 0.006 |
| 68 | 312 14TH ST NE | 0.008 | 0.008 |
| 69 | 1863 MONROE ST NW | 0.009 | 0.007 |
| 70 | 1612 V ST NW | 0.009 | 0.013 |
| 71 | 1324 N. CAROLINA AVE NE | 0.009 | 0.008 |
| 72 | 4307 CHESAPEAKE ST NW | 0.009 | 0.004 |
| 73 | 1405 21ST ST NW | 0.010 | 0.0085 ³ |

| Assigned No. | Location | Lead (mg/L) 1st Draw | Lead (mg/L) 2nd Draw |
|--------------|--|----------------------|----------------------|
| 74 | 4818 8TH ST NW | 0.010 | 0.008 |
| 75 | 3827 VEAZEY ST NW | 0.010 | 0.010 |
| 76 | 3815 JOCELYN ST NW | 0.010 | 0.0055 ³ |
| 77 | 2003 KLINGLE RD NW | 0.010 | 0.006 |
| 78 | 5134 NEBRASKA AVE NW | 0.010 | 0.004 |
| 79 | 4327 IOWA AVE NW | 0.011 | 0.032 |
| 80 | 3408 LOWELL ST NW | 0.011 | 0.005 |
| 81 | 514 13th St SE | 0.011 | 0.009 |
| 82 | 821 BUCHANAN ST NW | 0.012 | 0.005 |
| 83 | 3218 MACOMB ST NW ² | 0.012 | 0.008 |
| 84 | 3720 NORTHAMPTON ST NW | 0.012 | 0.013 |
| 85 | 5229 7TH ST NW | 0.012 | 0.016 |
| 86 | 1353 JEFFERSON ST NW | 0.013 | 0.017 |
| 87 | 1407 MONTAGUE ST NW | 0.013 | 0.016 |
| 88 | 3973 HARRISON ST NW | 0.013 | 0.018 |
| 89 | 4305 38TH ST NW | 0.013 | 0.0215 ³ |
| 90 | 4326 FOREST LN NW | 0.013 | 0.016 |
| 91 | 4306 CHESAPEAKE ST NW | 0.014 | 0.013 |
| 92 | 1649 HARVARD ST NW ¹ | 0.015 | 0.015 |
| 93 | 1240 D ST SE | 0.016 | 0.002 |
| 94 | 2846 VISTA ST NE | 0.016 | 0.005 |
| 95 | 1340 V ST SE | 0.017 | 0.008 |
| 96 | 302 RITTENHOUSE ST NW | 0.017 | 0.039 |
| 97 | 4331 BRANDYWINE ST NW | 0.024 | 0.023 |
| 98 | 4401 5TH ST NW | 0.024 | 0.018 |
| 99 | 3412 GARRISON ST NW | 0.025 | 0.021 |
| 100 | 1334 HEMLOCK ST NW | 0.028 | 0.008 |
| 101 | 1424 S ST NW | 0.030 | 0.030 |
| 102 | 1424 S ST SE | 0.051 | 0.037 |

Footnotes:

ND = Result listed as ND or Non Detect on lab report form

<.5ppb = Result listed as <0.0005 mg/L on lab report form

1. Indicates 90th percentile for lead first draw = 102 samples x 0.9 = 91.8 rounded to 92nd sample

2. Indicates samples taken twice in same semester at the same location

3. Indicates this result was not rounded to 3 decimal places because the lab result rounded the numerical results to 4 decimal places and rounding this result to will cause a double rounding error.

Section 1.
Summary of Copper Compliance Results

| Assigned No. | Location | Copper (mg/L) 1st Draw | Copper (mg/L) 2nd Draw |
|--------------|-------------------------------|---------------------------|---------------------------|
| 1 | 4818 ILLINOIS AVE NW | 0.003 | 0.008 |
| 2 | 5229 7TH ST NW | 0.005 | 0.006 |
| 3 | 1262 COLUMBIA RD NW | 0.006 | 0.008 |
| 4 | 1104 TRINIDAD AVE NE | 0.007 | 0.011 |
| 5 | 302 RITTENHOUSE ST NW | 0.007 | 0.011 |
| 6 | 4325 IOWA AVE NW | 0.008 | 0.008 |
| 7 | 1971 BILTMORE ST NW | 0.008 | 0.007 |
| 8 | 1626 E ST SE | 0.008 | 0.011 |
| 9 | 4111 INGOMAR ST NW | 0.009 | 0.024 |
| 10 | 3412 GARRISON ST NW | 0.009 | 0.010 |
| 11 | 3815 JOCELYN ST. NW | 0.010 | 0.011 |
| 12 | 2134 NEWPORT PL NW | 0.011 | 0.008 |
| 13 | 3913 8TH ST NW | 0.012 | 0.012 |
| 14 | 4609 30TH ST NW | 0.012 | 0.009 |
| 15 | 5134 NEBRASKA AVE NW | 0.012 | 0.007 |
| 16 | 3835 BEECHER ST NW | 0.013 | 0.006 |
| 17 | 4518 14TH ST NW | 0.013 | 0.013 |
| 18 | 514 13th St SE | 0.013 | 0.008 |
| 19 | 3973 HARRISON ST NW | 0.013 | 0.009 |
| 20 | 4326 FOREST LN NW | 0.015 | 0.007 |
| 21 | 3908 13TH ST NW | 0.016 | 0.016 |
| 22 | 607 ATLANTIC ST SE | 0.016 | 0.016 |
| 23 | 3030 44TH ST. NW ² | 0.016 | 0.005 |
| 24 | 4331 BRANDYWINE ST NW | 0.016 | 0.009 |
| 25 | 3720 NORTHAMPTON ST NW | 0.017 | 0.031 |
| 26 | 3439 24 ST SE | 0.018 | 0.013 |
| 27 | 5324 COLORADO AVE NW | 0.018 | 0.008 |
| 28 | 4622 15TH ST. NW | 0.018 | 0.006 |
| 29 | 1324 N. CAROLINA AVE NE | 0.018 | 0.009 |
| 30 | 1815 MONROE ST NW | 0.019 | 0.015 |
| 31 | 2007 KLINGLE ST NW | 0.019 | 0.055 |
| 32 | 311 ELM ST NW | 0.020 | 0.017 |
| 33 | 1825 L ST NE | 0.020 | 0.057 |
| 34 | 4305 38TH ST NW | 0.020 | 0.017 |
| 35 | 1341 Massachusetts Ave SE | 0.021 | 0.010 |
| 36 | 5301 RENO RD. NW | 0.021 | 0.013 |

| Assigned No. | Location | Copper (mg/L) 1st Draw | Copper (mg/L) 2nd Draw |
|--------------|-------------------------------|---------------------------|---------------------------|
| 37 | 2702 P ST. NW | 0.021 | 0.006 |
| 38 | 4507 13 TH ST NW | 0.021 | 0.013 |
| 39 | 1340 V ST. SE | 0.021 | 0.023 |
| 40 | 2435 33RD ST SE | 0.022 | 0.010 |
| 41 | 1635 WEBSTER ST NW | 0.022 | 0.007 |
| 42 | 322 TENNESSEE AVE NE | 0.022 | 0.018 |
| 43 | 2830 BRENTWOOD RD NE | 0.024 | 0.017 |
| 44 | 4401 5TH ST NW | 0.024 | 0.040 |
| 45 | 1332 VERMONT AVE NW | 0.025 | 0.018 |
| 46 | 821 BUCHANAN ST NW | 0.025 | 0.015 |
| 47 | 1814 MONROE ST NW | 0.026 | 0.025 |
| 48 | 2238 HALL PL NW | 0.028 | 0.009 |
| 49 | 1812 14TH ST SE | 0.028 | 0.026 |
| 50 | 3424 PORTER ST NW | 0.028 | 0.004 |
| 51 | 3550 ALBEMARLE ST. NW | 0.030 | 0.010 |
| 52 | 349 TENNESSEE AVE NE | 0.030 | 0.018 |
| 53 | 1240 D ST SE | 0.030 | 0.011 |
| 54 | 3601 WARREN ST. NW | 0.031 | 0.008 |
| 55 | 2850 28th Street NW | 0.031 | 0.006 |
| 56 | 331 RALEIGH ST SE | 0.032 | 0.014 |
| 57 | 1839 MONROE ST NW | 0.032 | 0.030 |
| 58 | 1420 S ST SE | 0.032 | 0.009 |
| 59 | 1649 HARVARD ST NW | 0.032 | 0.026 |
| 60 | 143 UHLAND TERRACE NE | 0.033 | 0.031 |
| 61 | 312 14TH ST NE | 0.033 | 0.036 |
| 62 | 3827 VEAZEY ST NW | 0.033 | 0.006 |
| 63 | 3809 ALTON PL. NW | 0.034 | 0.006 |
| 64 | 3408 LOWELL ST NW | 0.034 | 0.005 |
| 65 | 1843 MONROE ST NW | 0.035 | 0.024 |
| 66 | 4307 CHESAPEAKE ST NW | 0.035 | 0.005 |
| 67 | 1214 SHEPHERD ST. NW | 0.036 | 0.011 |
| 68 | 4413 GREENWICH PKWY NW | 0.036 | 0.039 |
| 69 | 1241 JACKSON ST NE | 0.038 | 0.015 |
| 70 | 1956 BILTMORE ST NW | 0.038 | 0.021 |
| 71 | 4327 IOWA AVE NW | 0.038 | 0.103 |
| 72 | 3218 MORRISON ST NW | 0.040 | 0.027 |
| 73 | 3030 44TH ST. NW ² | 0.040 | 0.015 |
| 74 | 2305 38TH ST NW | 0.040 | 0.013 |
| 75 | 1353 JEFFERSON ST NW | 0.044 | 0.033 |

| Assigned No. | Location | Copper (mg/L) 1st Draw | Copper (mg/L) 2nd Draw |
|--------------|--|---------------------------|---------------------------|
| 76 | 2846 VISTA ST NE | 0.044 | 0.021 |
| 77 | 1746 KENYON ST NW | 0.047 | 0.074 |
| 78 | 1863 MONROE ST NW | 0.048 | 0.064 |
| 79 | 4332 BRANDYWINE ST NW | 0.050 | 0.027 |
| 80 | 3618 PORTER ST NW | 0.053 | 0.009 |
| 81 | 2448 HUIDEKOPER PL NW | 0.055 | 0.016 |
| 82 | 4818 8TH ST NW | 0.055 | 0.012 |
| 83 | 1405 21ST. NW | 0.055 | 0.032 |
| 84 | 4306 CHESAPEAKE ST NW | 0.058 | 0.031 |
| 85 | 1338 A ST SE | 0.059 | 0.022 |
| 86 | 1612 V ST NW | 0.059 | 0.020 |
| 87 | 205 TAYLOR ST. NW | 0.060 | 0.053 |
| 88 | 2111 S ST. NW | 0.063 | 0.017 |
| 89 | 1334 HEMLOCK ST. NW | 0.063 | 0.049 |
| 90 | 119 16 TH ST NE | 0.064 | 0.007 |
| 91 | 532 13TH ST SE | 0.067 | 0.048 |
| 92 | 1400 FLORAL ST. NW ¹ | 0.077 | 0.015 |
| 93 | 2003 KLINGLE RD NW | 0.077 | 0.017 |
| 94 | 202 11th St SE | 0.079 | 0.020 |
| 95 | 1424 S ST NW | 0.088 | 0.013 |
| 96 | 5318 9TH ST NW | 0.093 | 0.074 |
| 97 | 3218 MACOMB ST NW ² | 0.098 | 0.061 |
| 98 | 2823 28TH ST NW | 0.104 | 0.045 |
| 99 | 3218 MACOMB ST NW ² | 0.114 | 0.013 |
| 100 | 1424 S ST SE | 0.126 | 0.033 |
| 101 | 1407 MONTAGUE ST NW | 0.197 | 0.090 |
| 102 | 1228 CARROLLSBURG PL SW | 0.219 | 0.280 |

Footnotes:

1. Indicates 90th percentile for Copper first draw = 102 samples x 0.9 = 91.8 rounded to 92nd sample
2. Indicates samples taken twice in same semester at the same location

Section 2
Detail report of all results collected under the compliance program
Compliance Samples – Tier 1

| <i>Address</i> | <i>Pipe</i> | <i>Routine</i> | <i>Sampling</i> | <i>Date</i> |
|--|-----------------|------------------------|------------------|-------------|
| | <i>Material</i> | <i>Discontinued</i> | <i>Requested</i> | |
| <u>1214 SHEPHERD ST NW Washington, DC 20011; LESLIE GRIFFIN</u> | Lead | X | No | |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0 ND | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0 ND | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.036 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.011 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0.014 | |
| <u>1228 CARROLLSBURG PL SW Washington, DC 20024; EMMA WARD</u> 215-8757 | Partial Lead | X | No | |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | 0.002 | |
| Collection | 10/27/2005 | Lead (ppm) 2nd Draw: | 0.001 | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.219 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.280 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1241 JACKSON ST NE Washington, DC 20017; MELODIE KATE</u> 518-7983 | Partial Lead | X | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.007 | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | 0.012 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.038 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.015 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0.020 | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0.015 | |
| <u>1332 VERMONT AVE NW Washington, DC 20005; 1332 VERMONT AVE PRTSHP</u> 675-2409 | Lead | X | No | |
| Bottle Drop OffDate: | 10/26/2005 | Lead (ppm) 1st Draw: | 0.001 | |
| Collection | 10/28/2005 | Lead (ppm) 2nd Draw: | 0 ND | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.025 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.018 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|---|----------------------|------------------------|------------------------------|-----------------------|
| <u>1334 HEMLOCK ST NW Washington, DC 20012; JACK PIORKO</u> 829-6144 | Lead | X | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.028 | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.008 | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.063 | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.049 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0<10 ppb | |
| <u>1338 A ST SE Washington, DC 20016; CAROL GRISSON</u> | Partial Lead | X | No | |
| Bottle Drop OffDate: | 11/1/2005 | Lead (ppm) 1st Draw: | 0.002 | |
| Collection | 11/2/2005 | Lead (ppm) 2nd Draw: | 0 ND | |
| Received at | 11/8/2005 | Copper (ppm) 1st Draw: | 0.059 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.022 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0.023 | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0<10 ppb | |
| <u>1340 V ST SE Washington, DC 20009; Nancy Small</u> | Lead | X | Yes | 3/6/2006 |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.017 | |
| Collection | 7/26/2005 | Lead (ppm) 2nd Draw: | 0.008 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.021 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.023 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0.166 | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0.032 | |
| <u>1341 Massachusetts Ave SE Washington, DC 20003; CARMEN</u> <u>COMIN</u> 547-8303 | Partial Lead | X | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0 ND | |
| Collection | 9/30/2005 | Lead (ppm) 2nd Draw: | 0 ND | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.021 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.010 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0 ND | |

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|--|----------------------|------------------------|------------------------------|-----------------------|
| <u>1353 JEFFERSON ST NW Washington, DC 20011; ROSSELYN ABITBOL</u> 545-0639 | Lead | X | | No |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.013 | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | 0.017 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.044 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.033 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1400 FLORAL ST NW Washington, DC 20012; RUTH JOHNSON</u> | Lead | X | | No |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.007 | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.006 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.077 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.015 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1405 21ST ST NW Washington, DC 20036; NATALIE HOPKINS</u> | Partial Lead | X | | No |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.010 | |
| Collection | 7/26/2005 | Lead (ppm) 2nd Draw: | 0.0085 ¹ | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.055 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.032 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1407 MONTAGUE ST NW Washington, DC 20011; RODERICK DAVIS</u> | Lead | X | | No |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | 0.013 | |
| Collection | 10/27/2005 | Lead (ppm) 2nd Draw: | 0.016 | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.197 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.090 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0.667 | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0.751 | |
| <u>1424 S ST SE Washington, DC 20020; ROSE COBBLER</u> 889-5928 | Lead | X | | No |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | 0.051 | |
| Collection | 10/26/2005 | Lead (ppm) 2nd Draw: | 0.037 | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.126 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.033 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0.102 | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|---|----------------------|------------------------|------------------------------|-----------------------|
| <u>143 UHLAND TER NE Washington, DC 20002; IDA JACKSON</u> 832-5337 | Lead | X | | No |
| Bottle Drop OffDate: | 11/1/2005 | Lead (ppm) 1st Draw: | 0.006 | |
| Collection | 11/2/2005 | Lead (ppm) 2nd Draw: | 0.013 | |
| Received at | 11/8/2005 | Copper (ppm) 1st Draw: | 0.033 | |
| Analysis Date: | 11/17/2005 | Copper (ppm) 2nd Draw: | 0.031 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1612 V ST NW Washington, DC 20009; ROBERT & STACY</u> <u>KREGER</u> | Lead | X | | No |
| Bottle Drop OffDate: | 11/1/2005 | Lead (ppm) 1st Draw: | 0.009 | |
| Collection | 11/2/2005 | Lead (ppm) 2nd Draw: | 0.013 | |
| Received at | 11/8/2005 | Copper (ppm) 1st Draw: | 0.059 | |
| Analysis Date: | 11/17/2005 | Copper (ppm) 2nd Draw: | 0.020 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1649 HARVARD ST NW Washington, DC 20016; WILLIAM</u> <u>GORDON</u> | Lead | X | | No |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.015 | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.015 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.032 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.026 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0.017 | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0.034 | |
| <u>1746 KENYON ST NW Washington, DC 20010; JAMES YEAGER</u> 787-1986 | Lead | X | | No |
| Bottle Drop OffDate: | 12/1/2005 | Lead (ppm) 1st Draw: | 0.003 | |
| Collection | 12/2/2005 | Lead (ppm) 2nd Draw: | 0.003 | |
| Received at | 12/2/2005 | Copper (ppm) 1st Draw: | 0.047 | |
| Analysis Date: | 12/6/2005 | Copper (ppm) 2nd Draw: | 0.074 | |
| Date received from Aqueduct: | 12/7/2005 | Iron (ppm) 1st Draw: | 0.018 | |
| Date Letter Sent to Customer: | 12/07/05 | Iron (ppm) 2nd Draw: | 0¹⁰ ppb | |
| <u>1812 14TH ST SE Washington, DC 20020; MICHAEL SULLIVAN</u> 678-5353 | Lead | X | | No |
| Bottle Drop OffDate: | 10/26/2005 | Lead (ppm) 1st Draw: | 0.005 | |
| Collection | 10/28/2005 | Lead (ppm) 2nd Draw: | 0.004 | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.028 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.026 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|---|----------------------|------------------------|------------------------------|-----------------------|
| <u>1814 MONROE ST NW Washington, DC 20011; BAEHRENS</u> 460-3340 | Partial Lead | X | | No |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.004 | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.004 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.026 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.025 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1815 MONROE ST NW Washington, DC 20016; ROBERT POHLMAN</u> 387-7273 | Partial Lead | X | | No |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.003 | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.002 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.019 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.015 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0.017 | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0<10 ppb | |
| <u>1825 L ST NE Washington, DC 20002; SAINTA HAYWOOD</u> 491-6841 | Partial Lead | X | | No |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.004 | |
| Collection | 9/29/2005 | Lead (ppm) 2nd Draw: | 0.0045 ¹ | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.020 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.057 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0.07 | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0<10 ppb | |
| <u>1839 MONROE ST NW Washington, DC 20020; F HAGGARD</u> 328-9675 | Partial Lead | X | | No |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.004 | |
| Collection | 7/28/2005 | Lead (ppm) 2nd Draw: | 0.003 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.032 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.030 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1843 MONROE ST NW Washington, DC 20017; INORID EVERS</u> | Partial Lead | X | | No |
| Bottle Drop OffDate: | 11/2/2005 | Lead (ppm) 1st Draw: | 0.002 | |
| Collection | 11/3/2005 | Lead (ppm) 2nd Draw: | 0.002 | |
| Received at | 11/4/2005 | Copper (ppm) 1st Draw: | 0.035 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.024 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |

| <i>Address</i> | <i>Pipe</i> | <i>Sampling</i> | <i>Date</i> |
|----------------|-----------------|-----------------|---------------------|
| | <i>Material</i> | <i>Routine</i> | <i>Discontinued</i> |
| | | | <i>Requested</i> |

1863 MONROE ST NW Washington, DC 20010; ALBERTA EDWARDS
332-7464

Partial Lead **X** No

| | | | |
|-------------------------------|-----------|------------------------|-------|
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.009 |
| Collection | 7/26/2005 | Lead (ppm) 2nd Draw: | 0.007 |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.048 |
| Analysis Date: | 8/11/2005 | Copper (ppm) 2nd Draw: | 0.064 |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0.017 |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0.021 |

1956 BILTMORE ST NW Washington, DC 20009; MICHAEL TESTA
462-1176

Lead **X** No

| | | | |
|-------------------------------|-----------|------------------------|----------|
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.007 |
| Collection | 7/26/2005 | Lead (ppm) 2nd Draw: | 0.006 |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.038 |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.021 |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0.142 |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0<10 ppb |

2003 KLINGLE RD NW Washington, DC 20010; PETER KLAPPERT
483-3822

Lead **X** No

| | | | |
|-------------------------------|-----------|------------------------|----------|
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.010 |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.006 |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.077 |
| Analysis Date: | 8/11/2005 | Copper (ppm) 2nd Draw: | 0.017 |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0<10 ppb |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0.018 |

2007 KLINGLE RD NW Washington, DC 20016; MEG BUSSE

Lead **X** No

| | | | |
|-------------------------------|-----------|------------------------|-----------------|
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.005 |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.010 |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.019 |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.055 |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0.010 |

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|---|----------------------|------------------------|------------------------------|-----------------------|
| <u>202 11th St SE Washington, DC 20011; MONK TOPPING</u> 544-7036 | Lead | X | | No |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0 <.5 ppb | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0 <.5 ppb | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.079 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.020 | |
| Date received from Aqueduct: | 8/25/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/26/05 | Iron (ppm) 2nd Draw: | 0<10 ppb | |
| <u>205 TAYLOR ST NW Washington, DC 20011; JOAN OLIVER</u> | Partial Lead | X | | No |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | 0.003 | |
| Collection | 10/27/2005 | Lead (ppm) 2nd Draw: | 0.006 | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.060 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.053 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>2111 S ST NW Washington, DC 20008; SIEGENTHALER</u> | Lead | X | | No |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0 ND | |
| Collection | 7/29/2005 | Lead (ppm) 2nd Draw: | 0.006 | |
| Received at | 8/1/2005 | Copper (ppm) 1st Draw: | 0.063 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.017 | |
| Date received from Aqueduct: | 8/25/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>2134 NEWPORT PL NW Washington, DC 20037; RANDALL</u> <u>SHERMAN</u> | Lead | X | | No |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.003 | |
| Collection | 9/27/2005 | Lead (ppm) 2nd Draw: | 0.002 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.011 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.008 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0<10 ppb | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0 ND | |

| <i>Address</i> | <i>Pipe</i> | <i>Material</i> | <i>Routine</i> | <i>Sampling</i> | <i>Date</i> |
|--|--------------|------------------------|----------------|---------------------|------------------|
| | | | | <i>Discontinued</i> | <i>Requested</i> |
| <u>2238 HALL PL NW Washington, DC 20007; ELIZABETH EGGLESTON</u> 337-0488 | Lead | | X | No | |
| Bottle Drop OffDate: | 11/1/2005 | Lead (ppm) 1st Draw: | | 0 ND | |
| Collection | 11/2/2005 | Lead (ppm) 2nd Draw: | | 0 ND | |
| Received at | 11/8/2005 | Copper (ppm) 1st Draw: | | 0.028 | |
| Analysis Date: | 11/17/2005 | Copper (ppm) 2nd Draw: | | 0.009 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | | 0 ND | |
| <u>2305 38TH ST NW Washington, DC 20007; MATT RIERZO</u> 338-6521 | Partial Lead | | X | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | | 0.008 | |
| Collection | 9/29/2005 | Lead (ppm) 2nd Draw: | | 0.006 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | | 0.040 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | | 0.013 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | | 0 ND | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | | 0 ND | |
| <u>2435 33RD ST SE Washington, DC 20020; JOSEPH GRIFFITH</u> 584-2101 | Lead | | X | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | | 0.005 | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | | 0.007 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | | 0.022 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | | 0.010 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | | 0 ND | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | | 0 ND | |
| <u>2702 P ST NW Washington, DC 20007; CHRIS DIETRICH</u> | Lead | | X | No | |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | | 0.005 | |
| Collection | 7/26/2005 | Lead (ppm) 2nd Draw: | | 0 <.5 ppb | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | | 0.021 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | | 0.006 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | | 0.316 | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | | 0<10 ppb | |
| <u>2823 28TH ST NW Washington, DC 20008; OLIVIA MORGAN</u> | Partial Lead | | X | No | |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | | 0.004 | |
| Collection | 7/28/2005 | Lead (ppm) 2nd Draw: | | 0.007 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | | 0.104 | |
| Analysis Date: | | Copper (ppm) 2nd Draw: | | 0.045 | |
| Date received from Aqueduct: | 8/25/2005 | Iron (ppm) 1st Draw: | | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | | 0 ND | |

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|--|----------------------|------------------------|------------------------------|-----------------------|
| <u>2830 BRENTWOOD RD NE Washington, DC 20018; PAUL BAKER</u> 635-0413 | Lead | X | | No |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.005 | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | 0.005 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.024 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.017 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0<10 ppb | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0<10 ppb | |
| <u>2846 VISTA ST NE Washington, DC 20018; DEWANA HORTON</u> 636-1083 | Lead | X | | No |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | 0.016 | |
| Collection | 10/26/2005 | Lead (ppm) 2nd Draw: | 0.005 | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.044 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.021 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>302 RITTENHOUSE ST NW Washington, DC 20011; GLYNN LEWIS</u> 291-3309 | Lead | X | | No |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.017 | |
| Collection | 9/29/2005 | Lead (ppm) 2nd Draw: | 0.039 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.007 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.011 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0.137 | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0.130 | |
| <u>3030 44TH ST NW Washington, DC 20016; ELYSA GRAMAGLIA</u> | Lead | X | | No |
| Bottle Drop OffDate: | 11/1/2005 | Lead (ppm) 1st Draw: | 0.005 | |
| Collection | 11/2/2005 | Lead (ppm) 2nd Draw: | 0.003 | |
| Received at | 11/8/2005 | Copper (ppm) 1st Draw: | 0.040 | |
| Analysis Date: | 11/17/2005 | Copper (ppm) 2nd Draw: | 0.015 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.005 | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.007 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.016 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.005 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0<10 ppb | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | |

| <i>Address</i> | <i>Pipe</i> | | <i>Sampling</i> | | <i>Date Requested</i> |
|--|-----------------|------------------------|---------------------|----|-----------------------|
| | <i>Material</i> | <i>Routine</i> | <i>Discontinued</i> | | |
| <u>311 ELM ST NW Washington, DC 20001; ALICE PRATT</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.001 | | |
| Collection | 7/26/2005 | Lead (ppm) 2nd Draw: | 0 <.5 ppb | | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.020 | | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.017 | | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| <u>312 14TH ST NE Washington, DC 20002; MEGAN MADDEN</u> 546-4124 | Partial Lead | X | | No | |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | 0.008 | | |
| Collection | 10/27/2005 | Lead (ppm) 2nd Draw: | 0.008 | | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.033 | | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.036 | | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| <u>3218 MACOMB ST NW Washington, DC 20008; JOHN BUNTIN</u> 363-9609 | Lead | X | | No | |
| Bottle Drop OffDate: | 11/1/2005 | Lead (ppm) 1st Draw: | 0.005 | | |
| Collection | 11/2/2005 | Lead (ppm) 2nd Draw: | 0.007 | | |
| Received at | 11/8/2005 | Copper (ppm) 1st Draw: | 0.114 | | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.013 | | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.012 | | |
| Collection | 7/28/2005 | Lead (ppm) 2nd Draw: | 0.008 | | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.098 | | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.061 | | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| <u>3218 MORRISON ST NW Washington, DC 20015; WILLIAM</u> <u>SOLLEE JR</u> 397-1212 | Lead | X | | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.002 | | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | 0.003 | | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.040 | | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.027 | | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0 ND | | |

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|---|----------------------|------------------------|------------------------------|-----------------------|
| <u>322 TENNESSEE AVE NE Washington, DC 20002; DISTRICT RESIDENT</u> 547-3659 | Lead | X | | No |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.007 | |
| Collection | 7/28/2005 | Lead (ppm) 2nd Draw: | 0.006 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.022 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.018 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0.020 | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0.010 | |
| <u>331 RALEIGH ST SE Washington, DC 20032; FORREST MILLER</u> 561-2502 | Lead | X | | No |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.003 | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | 0.003 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.032 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.014 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>3408 LOWELL ST NW Washington, DC 20011; ALBERT STURTEVANT</u> | Lead | X | | No |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.011 | |
| Collection | 8/5/2005 | Lead (ppm) 2nd Draw: | 0.005 | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.034 | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.005 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.01 | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.012 | |
| <u>3412 GARRISON ST NW Washington, DC 20015; FRANCIS TOLAND</u> 363-4343 | Lead | X | | No |
| Bottle Drop OffDate: | 8/30/2005 | Lead (ppm) 1st Draw: | 0.025 | |
| Collection | 9/1/2005 | Lead (ppm) 2nd Draw: | 0.021 | |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | 0.009 | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.010 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.617 | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.062 | |

| <i>Address</i> | <i>Pipe</i> | | <i>Sampling</i> | | <i>Date Requested</i> |
|---|-----------------|------------------------|---------------------|----|-----------------------|
| | <i>Material</i> | <i>Routine</i> | <i>Discontinued</i> | | |
| <u>3424 PORTER ST NW Washington, DC 20016: ANTHONY QUANTON</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.007 | | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.004 | | |
| Received at | 9/9/2005 | Copper (ppm) 1st Draw: | 0.028 | | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.004 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.060 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0<10 ppb | | |
| <u>3439 24TH ST SE Washington, DC 20020: SHIRLEY ROSEBORO 678-4991</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0<.5 ppb | | |
| Collection | 9/27/2005 | Lead (ppm) 2nd Draw: | 0 ND | | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.018 | | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.013 | | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0.043 | | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| <u>349 TENNESSEE AVE NE Washington, DC 20002: JOSH & HEATHER EDELMAN 547-5445</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.008 | | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | 0.011 | | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.030 | | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.018 | | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0.019 | | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0<10 ppb | | |
| <u>3550 ALBEMARLE ST NW Washington, DC 20016: DOROTHY LEVY</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.007 | | |
| Collection | 8/4/2005 | Lead (ppm) 2nd Draw: | 0.008 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.030 | | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.010 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.016 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.066 | | |

| <i>Address</i> | <i>Pipe</i> | | <i>Sampling</i> | | <i>Date Requested</i> |
|--|-----------------|------------------------|---------------------|---------------------|-----------------------|
| | <i>Material</i> | <i>Routine</i> | <i>Discontinued</i> | | |
| <u>3601 WARREN ST NW Washington, DC 20008: JANICE RAHIMI</u> | Lead | | X | | No |
| Bottle Drop OffDate: | 8/30/2005 | Lead (ppm) 1st Draw: | | 0.004 | |
| Collection | 9/1/2005 | Lead (ppm) 2nd Draw: | | 0.002 | |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | | 0.031 | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | | 0.008 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | | 0.042 | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | | 0.030 | |
| <u>3618 PORTER ST NW Washington, DC 20016: R C & PHILIP F. CRONIN JR</u> 966-4823 | Lead | | X | | No |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | | 0.004 | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | | 0.016 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | | 0.053 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | | 0.009 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | | 0 ND | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | | 0 ND | |
| <u>3720 NORTHAMPTON ST NW Washington, DC 20015: JANE BERNOT</u> 362-0854 | Lead | | X | | No |
| Bottle Drop OffDate: | 8/30/2005 | Lead (ppm) 1st Draw: | | 0.012 | |
| Collection | 9/1/2005 | Lead (ppm) 2nd Draw: | | 0.013 | |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | | 0.017 | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | | 0.031 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | | 0.011 | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | | 0.012 | |
| <u>3809 ALTON PL NW Washington, DC 20008: THOMAS</u> 537-5045 | Lead | | X | | No |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | | 0.006 | |
| Collection | 8/2/2005 | Lead (ppm) 2nd Draw: | | 0.026 | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | | 0.034 | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | | 0.006 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | | 0 ND | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | | 0 ND | |
| <u>3815 JOCELYN ST NW Washington, DC 20015: LETITIA GARDNER</u> | Partial Lead | | X | | No |
| Bottle Drop OffDate: | 8/30/2005 | Lead (ppm) 1st Draw: | | 0.010 | |
| Collection | 8/31/2005 | Lead (ppm) 2nd Draw: | | 0.0055 ¹ | |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | | 0.010 | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | | 0.011 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | | 0.043 | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | | 0.015 | |

| <i>Address</i> | <i>Pipe</i> | | <i>Sampling</i> | | <i>Date Requested</i> |
|--|-----------------|------------------------|-------------------------|----|-----------------------|
| | <i>Material</i> | <i>Routine</i> | <i>Discontinued</i> | | |
| <u>3827 VEAZEY ST NW Washington, DC 20016; GERALD</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.010 | | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.010 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.033 | | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.006 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| <u>3835 BEECHER ST NW Washington, DC 20007; PHILIP GIORDANO</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.001 | | |
| Collection | 8/4/2005 | Lead (ppm) 2nd Draw: | 0.001 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.013 | | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.006 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.079 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.098 | | |
| <u>3908 13TH ST NW Washington, DC 20011; JENNIFER 251-9080</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.0025 ¹ | | |
| Collection | 9/29/2005 | Lead (ppm) 2nd Draw: | 0.003 | | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.016 | | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.016 | | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0.09 | | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0.063 | | |
| <u>3913 8TH ST NW Washington, DC 20011; LESTINA WALLACE 545-9448</u> | Partial Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.001 | | |
| Collection | 9/2/2005 | Lead (ppm) 2nd Draw: | 0.001 | | |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | 0.012 | | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.012 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.012 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0 ^{<10} ppb | | |

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|----------------|--------------------------|----------------|----------------------------------|---------------------------|
|----------------|--------------------------|----------------|----------------------------------|---------------------------|

| | | | | |
|---|------|----------|--|----|
| <u>3973 HARRISON ST NW Washington, DC 20015: MARY WHITMAN</u> | Lead | X | | No |
|---|------|----------|--|----|

| | | | |
|-------------------------------|-----------|------------------------|-------|
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.013 |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.018 |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.013 |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.009 |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.229 |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.138 |

| | | | | |
|--|------|----------|--|----|
| <u>4111 INGOMAR ST NW Washington, DC 20015: JONATHON MOORE</u> 362-4633 | Lead | X | | No |
|--|------|----------|--|----|

| | | | |
|-------------------------------|-----------|------------------------|-----------------|
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.005 |
| Collection | 8/2/2005 | Lead (ppm) 2nd Draw: | 0.007 |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.009 |
| Analysis Date: | 9/7/2005 | Copper (ppm) 2nd Draw: | 0.024 |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0 ND |

| | | | | |
|---|------|----------|--|----|
| <u>4305 38TH ST NW Washington, DC 20016: RICHARD ABBOTT</u> 244-5267 | Lead | X | | No |
|---|------|----------|--|----|

| | | | |
|-------------------------------|-----------|------------------------|---------------------|
| Bottle Drop OffDate: | 8/30/2005 | Lead (ppm) 1st Draw: | 0.013 |
| Collection | 8/31/2005 | Lead (ppm) 2nd Draw: | 0.0215 ¹ |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | 0.020 |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.017 |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.385 |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.037 |

| | | | | |
|--|------|----------|--|----|
| <u>4306 CHESAPEAKE ST NW Washington, DC 20016: RICHARD RIZIO</u> 363-0556 | Lead | X | | No |
|--|------|----------|--|----|

| | | | |
|-------------------------------|-----------|------------------------|-------|
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.014 |
| Collection | 8/2/2005 | Lead (ppm) 2nd Draw: | 0.013 |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.058 |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.031 |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.046 |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.027 |

| <i>Address</i> | <i>Pipe</i> | | <i>Sampling</i> | | <i>Date Requested</i> |
|--|-----------------|------------------------|----------------------|----|-----------------------|
| | <i>Material</i> | <i>Routine</i> | <i>Discontinued</i> | | |
| <u>4307 CHESAPEAKE ST NW Washington, DC 20016; HEGY</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.009 | | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.004 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.035 | | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.005 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.020 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.024 | | |
| <u>4326 FOREST LN NW Washington, DC 20007; WILLIAM & SUSAN GRIDLEY</u> 686-4186 | Lead | X | | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.013 | | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | 0.016 | | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.015 | | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.007 | | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0< ¹⁰ ppb | | |
| <u>4327 IOWA AVE NW Washington, DC 20016; MARY BUCKMAN</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/30/2005 | Lead (ppm) 1st Draw: | 0.011 | | |
| Collection | 9/1/2005 | Lead (ppm) 2nd Draw: | 0.032 | | |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | 0.038 | | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.103 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.021 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 1.030 | | |
| <u>4331 BRANDYWINE ST NW Washington, DC 20008; EMILY ATTWELL</u> 364-2646 | Lead | X | | No | |
| Bottle Drop OffDate: | 8/30/2005 | Lead (ppm) 1st Draw: | 0.024 | | |
| Collection | 9/1/2005 | Lead (ppm) 2nd Draw: | 0.023 | | |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | 0.016 | | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.009 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.111 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.050 | | |
| <u>4332 BRANDYWINE ST NW Washington, DC 20016; GEORGE SELIM</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.002 | | |
| Collection | 8/4/2005 | Lead (ppm) 2nd Draw: | 0.003 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.050 | | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.027 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0< ¹⁰ ppb | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.015 | | |

| <i>Address</i> | <i>Pipe</i> | | <i>Sampling</i> | | <i>Date Requested</i> |
|---|-----------------|------------------------|---------------------|------------------|-----------------------|
| | <i>Material</i> | <i>Routine</i> | <i>Discontinued</i> | <i>Requested</i> | |
| <u>4401 5TH ST NW Washington, DC 20011; KENNETH EYE</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.024 | | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.018 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.024 | | |
| Analysis Date: | 9/7/2005 | Copper (ppm) 2nd Draw: | 0.040 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.151 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.255 | | |
| <u>4413 GREENWICH PKWY NW Washington, DC 20007; DEBORAH BUTTERWORTH</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/30/2005 | Lead (ppm) 1st Draw: | 0.007 | | |
| Collection | 9/1/2005 | Lead (ppm) 2nd Draw: | 0.010 | | |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | 0.036 | | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.039 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| <u>4507 13TH ST NW Washington, DC 20011; ROSA DOUGLAS</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/30/2005 | Lead (ppm) 1st Draw: | 0.007 | | |
| Collection | 9/1/2005 | Lead (ppm) 2nd Draw: | 0.003 | | |
| Received at | 9/2/2005 | Copper (ppm) 1st Draw: | 0.021 | | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.013 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.044 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.043 | | |
| <u>4518 14TH ST NW Washington, DC 20011; LEROY ALBERTINI 249-9756</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.001 | | |
| Collection | 9/29/2005 | Lead (ppm) 2nd Draw: | 0.001 | | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.013 | | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.013 | | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0 ND | | |

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|---|----------------------|------------------------|------------------------------|-----------------------|
| <u>4609 30TH ST NW Washington, DC 20008; ARNOLD & VERA MAYER 363-6347</u> | Lead | X | | No |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.006 | |
| Collection | 9/27/2005 | Lead (ppm) 2nd Draw: | 0.005 | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.012 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.009 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>4622 15TH ST NW Washington, DC 20011; JACK BOBO 398-5525</u> | Lead | X | | No |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.007 | |
| Collection | 8/4/2005 | Lead (ppm) 2nd Draw: | 0.005 | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.018 | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.006 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>4818 8TH ST NW Washington, DC 20011; ELLSTON HOLMAN 213-9949</u> | Lead | X | | No |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.010 | |
| Collection | 8/2/2005 | Lead (ppm) 2nd Draw: | 0.008 | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.055 | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.012 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>4818 ILLINOIS AVE NW Washington, DC 20020; E. JENKINS</u> | Lead | X | | No |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.002 | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.003 | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.003 | |
| Analysis Date: | | Copper (ppm) 2nd Draw: | 0.008 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.011 | |
| <u>5134 NEBRASKA AVE NW Washington, DC 20008; KOSKELO</u> | Lead | X | | No |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.010 | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.004 | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.012 | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.007 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.219 | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.027 | |

| <i>Address</i> | <i>Pipe</i> | | <i>Sampling</i> | | <i>Date Requested</i> |
|--|-----------------|------------------------|---------------------|----|-----------------------|
| | <i>Material</i> | <i>Routine</i> | <i>Discontinued</i> | | |
| <u>514 13th St SE Washington, DC 20003; KEVIN TALLEY</u> 546-1867 | Lead | X | | No | |
| Bottle Drop OffDate: | 9/25/2005 | Lead (ppm) 1st Draw: | 0.011 | | |
| Collection | 9/28/2005 | Lead (ppm) 2nd Draw: | 0.009 | | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.013 | | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.008 | | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| <u>5229 7TH ST NW Washington, DC 20011; MARIA NELSON</u> 291-0661 | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.012 | | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.016 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.005 | | |
| Analysis Date: | 9/6/2005 | Copper (ppm) 2nd Draw: | 0.006 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.347 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.015 | | |
| <u>5301 RENO RD NW Washington, DC 20015; JEAN THOMAS</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.004 | | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.020 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.021 | | |
| Analysis Date: | 9/7/2005 | Copper (ppm) 2nd Draw: | 0.013 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.014 | | |
| <u>5318 9TH ST NW Washington, DC 20011; ANNIE WILLIAMS</u> 726-8071 | Lead | X | | No | |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.003 | | |
| Collection | 8/4/2005 | Lead (ppm) 2nd Draw: | 0.003 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.093 | | |
| Analysis Date: | | Copper (ppm) 2nd Draw: | 0.074 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| <u>532 13TH ST SE Washington, DC 20003; MICHELLE GREANIAS</u> | Lead | X | | No | |
| Bottle Drop OffDate: | 10/26/2005 | Lead (ppm) 1st Draw: | 0.0035 ¹ | | |
| Collection | 10/27/2005 | Lead (ppm) 2nd Draw: | 0.004 | | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.067 | | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.048 | | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | | |

Non Tier 1 Samples Invalidated

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|---|----------------------|------------------------|------------------------------|-----------------------|
| <u>1226 D ST NE Washington, DC 20002; DIANA BERMUDEZ</u> 543-4585 | Copper | | No | |
| Bottle Drop OffDate: | 9/28/2005 | Lead (ppm) 1st Draw: | 0 ND | |
| Collection | 9/30/2005 | Lead (ppm) 2nd Draw: | 0 ND | |
| Received at | 10/4/2005 | Copper (ppm) 1st Draw: | 0.020 | |
| Analysis Date: | 10/17/2005 | Copper (ppm) 2nd Draw: | 0.010 | |
| Date received from Aqueduct: | 10/21/2005 | Iron (ppm) 1st Draw: | 0.019 | |
| Date Letter Sent to Customer: | 10/21/05 | Iron (ppm) 2nd Draw: | 0.014 | |
| <u>1250 FLORIDA AVE NE Washington, DC 20002; STACY MILLER</u> 397-8206 | Full Copper | | No | |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | 0.001 | |
| Collection | 10/26/2005 | Lead (ppm) 2nd Draw: | 0 ND | |
| Received at | 11/8/2005 | Copper (ppm) 1st Draw: | 0.050 | |
| Analysis Date: | 11/17/2005 | Copper (ppm) 2nd Draw: | 0.023 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1502 COLUMBIA RD NW Washington, DC 20009; MICHAEL O'SULLIVAN</u> | Full Copper | | Yes | 12/8/2005 |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.001 | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.001 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.066 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.031 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0<10 ppb | |
| Bottle Drop OffDate: | 10/24/2005 | Lead (ppm) 1st Draw: | 0.001 | |
| Collection | 10/26/2005 | Lead (ppm) 2nd Draw: | 0<.5 ppb | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.093 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.086 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1626 19TH ST NW Washington, DC 20006; GREGORY MOUNTS</u> | Copper | | No | |
| Bottle Drop OffDate: | 11/1/2005 | Lead (ppm) 1st Draw: | 0.002 | |
| Collection | 11/2/2005 | Lead (ppm) 2nd Draw: | 0<.5 ppb | |
| Received at | 11/8/2005 | Copper (ppm) 1st Draw: | 0.050 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.053 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0.184 | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0.013 | |

| <i>Address</i> | <i>Pipe Material</i> | <i>Sampling Routine</i> | <i>Discontinued</i> | <i>Date Requested</i> |
|---|----------------------|-------------------------|---------------------|-----------------------|
| <u>1803 MONROE ST NW Washington, DC 20011; GLEN PARKER</u> 483-5376 | Full Copper | | No | |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.002 | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.002 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.027 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.020 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>1937 SUMMIT PL NE Washington, DC 20002; ANDREA WALKER</u> 832-8698 | Unknown | | No | |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | 0.001 | |
| Collection | 10/25/2005 | Lead (ppm) 2nd Draw: | 0.001 | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.094 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.031 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 11/17/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>2017 BELMONT RD NW Washington, DC 20020; BOSE MONICA</u> | Full Copper | | No | |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.002 | |
| Collection | 7/27/2005 | Lead (ppm) 2nd Draw: | 0.001 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.048 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.071 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>3250 HIGHLAND PL NW Washington, DC 20008; ROBERT</u> <u>MATHIAS</u> | Full Copper | | No | |
| Bottle Drop OffDate: | 7/25/2005 | Lead (ppm) 1st Draw: | 0.003 | |
| Collection | 7/28/2005 | Lead (ppm) 2nd Draw: | 0.001 | |
| Received at | 7/29/2005 | Copper (ppm) 1st Draw: | 0.029 | |
| Analysis Date: | 8/10/2005 | Copper (ppm) 2nd Draw: | 0.080 | |
| Date received from Aqueduct: | 8/26/2005 | Iron (ppm) 1st Draw: | 0 ND | |
| Date Letter Sent to Customer: | 08/29/05 | Iron (ppm) 2nd Draw: | 0 ND | |
| <u>406 9TH ST NE Washington, DC 20002; ELIZABETH WHITNEY</u> | Copper/Galvanized | | Yes | 3/3/2006 |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.001 | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.001 | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.012 | |
| Analysis Date: | 9/7/2005 | Copper (ppm) 2nd Draw: | 0.011 | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.019 | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0 ND | |

| <i>Address</i> | <i>Pipe</i> | | <i>Sampling</i> | | <i>Date Requested</i> |
|--|-------------------|------------------------|---------------------|--|-----------------------|
| | <i>Material</i> | <i>Routine</i> | <i>Discontinued</i> | | |
| <u>4450 VOLTA PL NW Washington, DC 20007; RICHARDS JEWETT</u> | Lead | X | | | No |
| Bottle Drop OffDate: | 8/1/2005 | Lead (ppm) 1st Draw: | 0.015 | | |
| Collection | 8/3/2005 | Lead (ppm) 2nd Draw: | 0.006 | | |
| Received at | 8/9/2005 | Copper (ppm) 1st Draw: | 0.051 | | |
| Analysis Date: | 9/7/2005 | Copper (ppm) 2nd Draw: | 0.155 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0.411 | | |
| Date Letter Sent to Customer: | 09/19/05 | Iron (ppm) 2nd Draw: | 0.073 | | |
| <u>4501 YUMA ST NW Washington, DC 20016; JENNIFER GAUM</u> 387-3110 | Copper | | | | No |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | 0.001 | | |
| Collection | 10/25/2005 | Lead (ppm) 2nd Draw: | 0.001 | | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.021 | | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.014 | | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0.025 | | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0.017 | | |
| <u>612 G ST NE Washington, DC 20002; JEFF MARTIN</u> | Copper/Galvanized | | | | No |
| Bottle Drop OffDate: | 11/29/2005 | Lead (ppm) 1st Draw: | 0.004 | | |
| Collection | 11/30/2005 | Lead (ppm) 2nd Draw: | 0.003 | | |
| Received at | 12/5/2005 | Copper (ppm) 1st Draw: | 0.035 | | |
| Analysis Date: | 12/6/2005 | Copper (ppm) 2nd Draw: | 0.031 | | |
| Date received from Aqueduct: | 12/7/2005 | Iron (ppm) 1st Draw: | 0.038 | | |
| Date Letter Sent to Customer: | 12/07/05 | Iron (ppm) 2nd Draw: | 0.027 | | |
| <u>621 L ST NE Washington, DC ; NIKOL MCCOMBS</u> 544-6779 | Unknown | | | | No |
| Bottle Drop OffDate: | 7/20/2005 | Lead (ppm) 1st Draw: | 0 <.5 ppb | | |
| Collection | 7/19/2005 | Lead (ppm) 2nd Draw: | 0.001 | | |
| Received at | 7/28/2005 | Copper (ppm) 1st Draw: | 0.142 | | |
| Analysis Date: | 9/15/2005 | Copper (ppm) 2nd Draw: | 0.111 | | |
| Date received from Aqueduct: | 9/16/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 11/30/05 | Iron (ppm) 2nd Draw: | 0 ND | | |
| <u>714 8TH ST NE Washington, DC 20002; DAVID KLAUITTER</u> 547-5745 | Copper | | | | No |
| Bottle Drop OffDate: | 10/26/2005 | Lead (ppm) 1st Draw: | 0 <.5 ppb | | |
| Collection | 10/27/2005 | Lead (ppm) 2nd Draw: | 0 <.5 ppb | | |
| Received at | 11/1/2005 | Copper (ppm) 1st Draw: | 0.040 | | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | 0.018 | | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | 0 ND | | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | 0 ND | | |

Invalidated Results – Did not bypass filter

| <i>Address</i> | | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|--|------------|--------------------------|----------------|----------------------------------|---------------------------|
| <u>1746 KENYON ST NW Washington, DC 20010; JAMES YEAGER 787-1986</u> | | Lead | X | No | |
| Bottle Drop OffDate: | 10/25/2005 | Lead (ppm) 1st Draw: | | 0.003 | |
| Collection Date: | 10/27/2005 | Lead (ppm) 2nd Draw: | | 0.001 | |
| Received at WAD: | 11/1/2005 | Copper (ppm) 1st Draw: | | 0.047 | |
| Analysis Date: | 11/16/2005 | Copper (ppm) 2nd Draw: | | 0.067 | |
| Date received from Aqueduct: | 11/17/2005 | Iron (ppm) 1st Draw: | | 0.105 | |
| Date Letter Sent to Customer: | 11/18/05 | Iron (ppm) 2nd Draw: | | 0 ND | |

Replacement Samples Taken in 2006

| <i>Address</i> | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|--|----------------------|------------------------|------------------------------|-----------------------|
| <u>1104 TRINIDAD AVE NE Washington, DC 20002; ROBERT FAULKER</u> 399-3525 | Lead | X | No | |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | 0 <.5 ppb | |
| Collection | 2/9/2006 | Lead (ppm) 2nd Draw: | 0.001 | |
| Received at WAD: | 2/10/2006 | Copper (ppm) 1st Draw | 0.007 | |
| Analysis Date: | 2/15/2006 | Copper (ppm) 2nd Draw: | 0.011 | |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | 0 <10 ppb | |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | 0.021 | |
| <u>119 16TH ST NE Washington, DC 20002; ROCHELLE DORNATT</u> 225-2861 | Lead | X | No | |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | 0.004 | |
| Collection | 2/8/2006 | Lead (ppm) 2nd Draw: | 0.001 | |
| Received at WAD: | 2/10/2006 | Copper (ppm) 1st Draw | 0.064 | |
| Analysis Date: | 2/15/2006 | Copper (ppm) 2nd Draw: | 0.007 | |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | 0 <10 ppb | |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | 0.021 | |
| <u>1240 D ST SE Washington, DC 20011; ED REISKEN</u> 547-4007 | Partial Lead | X | No | |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | 0.016 | |
| Collection | 2/8/2006 | Lead (ppm) 2nd Draw: | 0.002 | |
| Received at WAD: | 2/10/2006 | Copper (ppm) 1st Draw | 0.030 | |
| Analysis Date: | 2/15/2006 | Copper (ppm) 2nd Draw: | 0.011 | |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | 0.029 | |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | 0.033 | |
| <u>1262 COLUMBIA RD NW Washington, DC 20009; MS. JOHNSON</u> 234-0339 | Lead | X | No | |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | 0 <.5 ppb | |
| Collection | 2/8/2006 | Lead (ppm) 2nd Draw: | 0.001 | |
| Received at WAD: | 2/10/2006 | Copper (ppm) 1st Draw | 0.006 | |
| Analysis Date: | 2/15/2006 | Copper (ppm) 2nd Draw: | 0.008 | |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | 0.042 | |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | 0.060 | |

| <i>Address</i> | | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|--|-----------|------------------------|----------------|------------------------------|-----------------------|
| <u>1324 N. CAROLINA AVE NE Washington, DC 20002; TOM HARDY</u> 544-5659 | | Lead | | <i>X</i> | No |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | | | 0.009 |
| Collection | 2/9/2006 | Lead (ppm) 2nd Draw: | | | 0.008 |
| Received at WAD: | 2/10/2006 | Copper (ppm) 1st Draw | | | 0.018 |
| Analysis Date: | 2/15/2006 | Copper (ppm) 2nd Draw: | | | 0.009 |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | | | 0.125 |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | | | 0.029 |
| <u>1420 S ST SE Washington, DC 20020; TIMOTHY FERRALL</u> 889-8795 | | Lead | | <i>X</i> | No |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | | | 0.004 |
| Collection | 2/8/2006 | Lead (ppm) 2nd Draw: | | | 0.007 |
| Received at WAD: | 2/10/2006 | Copper (ppm) 1st Draw | | | 0.032 |
| Analysis Date: | 2/15/2006 | Copper (ppm) 2nd Draw: | | | 0.009 |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | | | 0.010 |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | | | 0.010 |
| <u>1424 S ST. NW Washington, DC 20009; Kee Hiani Looi</u> 462-4338 | | Lead | | | No |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | | | 0.030 |
| Collection | 2/7/2006 | Lead (ppm) 2nd Draw: | | | 0.030 |
| Received at WAD: | 2/10/2006 | Copper (ppm) 1st Draw | | | 0.088 |
| Analysis Date: | 2/15/2006 | Copper (ppm) 2nd Draw: | | | 0.013 |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | | | 0.118 |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | | | 0.031 |
| <u>1626 E ST SE Washington, DC 20003; CASANDRA SMTH</u> | | Lead | | <i>X</i> | No |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | | | 0.002 |
| Collection | 2/8/2006 | Lead (ppm) 2nd Draw: | | | 0.002 |
| Received at WAD: | 2/10/2006 | Copper (ppm) 1st Draw | | | 0.008 |
| Analysis Date: | 2/15/2006 | Copper (ppm) 2nd Draw: | | | 0.011 |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | | | 0.015 |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | | | 0.011 |

| <i>Address</i> | | <i>Pipe Material</i> | <i>Routine</i> | <i>Sampling Discontinued</i> | <i>Date Requested</i> |
|---|-----------|------------------------|----------------|------------------------------|-----------------------|
| <u>1635 WEBSTER ST. NW Washington, DC 20011; CARL MODIG</u> 726-5414 | | Lead | X | | No |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | | 0.007 | |
| Collection | 2/9/2006 | Lead (ppm) 2nd Draw: | | 0.001 | |
| Received at WAD: | 2/16/2006 | Copper (ppm) 1st Draw | | 0.022 | |
| Analysis Date: | 2/23/2006 | Copper (ppm) 2nd Draw: | | 0.007 | |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | | 0.416 | |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | | 0.028 | |
| <u>1971 BILTMORE ST NW Washington, DC 20009; RICHARD FITZ</u> 841-0459 | | Lead | X | | No |
| Bottle Drop | 2/7/2006 | Lead (ppm) 1st Draw | | 0.001 | |
| Collection | 2/8/2006 | Lead (ppm) 2nd Draw: | | 0.001 | |
| Received at WAD: | 2/10/2006 | Copper (ppm) 1st Draw | | 0.008 | |
| Analysis Date: | 2/15/2006 | Copper (ppm) 2nd Draw: | | 0.007 | |
| Date received from Aqueduct: | 3/2/2006 | Iron (ppm) 1st Draw: | | 0.025 | |
| Date Letter Sent to Customer: | 03/07/06 | Iron (ppm) 2nd Draw: | | 0.021 | |
| <u>2448 HUIDEKOPER PL NW Washington, DC 20007; SOPHIA HENRY</u> 965-8800 | | Lead | X | | No |
| Bottle Drop | 3/5/2006 | Lead (ppm) 1st Draw | | 0 ND | |
| Collection | 3/6/2006 | Lead (ppm) 2nd Draw: | | 0 ND | |
| Received at WAD: | 3/8/2006 | Copper (ppm) 1st Draw | | 0.055 | |
| Analysis Date: | 3/9/2006 | Copper (ppm) 2nd Draw: | | 0.016 | |
| Date received from Aqueduct: | 3/9/2006 | Iron (ppm) 1st Draw: | | 0 ND | |
| Date Letter Sent to Customer: | 03/13/06 | Iron (ppm) 2nd Draw: | | 0 ND | |
| <u>4325 IOWA AVE NW Washington, DC 20011; WILLIAM DIAL</u> 723-2927 | | Lead | X | | No |
| Bottle Drop | 3/5/2006 | Lead (ppm) 1st Draw | | 0.003 | |
| Collection | 3/7/2006 | Lead (ppm) 2nd Draw: | | 0.003 | |
| Received at WAD: | 3/13/2006 | Copper (ppm) 1st Draw | | 0.008 | |
| Analysis Date: | 3/15/2006 | Copper (ppm) 2nd Draw: | | 0.008 | |
| Date received from Aqueduct: | 4/6/2006 | Iron (ppm) 1st Draw: | | 0.063 | |
| Date Letter Sent to Customer: | 04/10/06 | Iron (ppm) 2nd Draw: | | 0.071 | |

Section 3.

Summary of all Samples Collected Under the Customer Service Program

| | Address | Collection Date | Draw 1 | Draw 2 | Service Pipe |
|----|-------------------------|-----------------|--------|--------|--------------|
| 1 | 3930 Morrison Street NW | 7/7/2005 | 0 | 0 | UNKNOWN |
| 2 | 4102 38th St NW | 8/12/2005 | 0 | 0 | BRASS |
| 3 | 4425 45th St NW | 11/2/2005 | 0 | 1 | COPPER |
| 4 | 7321 Georgia Ave NW | 9/30/2005 | 0 | 0 | COPPER |
| 5 | 220 35th St NE | 7/18/2005 | 0 | 1 | COPPER |
| 6 | 2017 O St NW | 7/31/2005 | 0 | 0 | LEAD |
| 7 | 114 R St NE | 8/25/2005 | 0 | 1 | UNKNOWN |
| 8 | 4400 20th St NE | 11/6/2005 | 0 | 0 | COPPER |
| 9 | 4441 Westover Pl NW | 10/2/2005 | 0 | 2 | UNKNOWN |
| 10 | 3301 Nebraska Ave NW | 10/19/2005 | 0 | 0 | COPPER |
| 11 | 2017 O St NW | 10/23/2005 | 0 | 0 | LEAD |
| 12 | 4950 Hillbrook Ln NW | 7/12/2005 | 0 | 1 | COPPER |
| 13 | 3102 Cathedral Ave NW | 7/7/2005 | 0 | 0 | LEAD |
| 14 | 1543 41st St SE | 7/4/2005 | 0 | 0 | BRASS |
| 15 | 4035 Benning Rd NE | 7/29/2005 | 0 | 0 | COPPER |
| 16 | 1533 P St NW | 10/25/2005 | 0 | 0 | COPPER |
| 17 | 1748 Swann St NW | 10/6/2005 | 0 | 0 | LEAD |
| 18 | 1221 Kenyon St NW | 9/19/2005 | 0 | 0 | COPPER |
| 19 | 120 1/2 Rumsey Ct SE | 10/24/2005 | 0 | 0 | UNKNOWN |
| 20 | 4830 Rockwood Pkwy NW | 9/25/2005 | 0 | 1 | COPPER |
| 21 | 1108 C St SE | 11/13/2005 | 0 | 0 | COPPER |
| 22 | 1884 Newton St NW | 10/22/2005 | 0 | 0 | COPPER |
| 23 | 3666 Upton St NW | 9/24/2005 | 0 | 0 | COPPER |
| 24 | 2941 Mills Ave NE | 9/5/2005 | 0 | 0 | NLD |
| 25 | 1601 16th St NW | 11/15/2005 | 0 | 0 | COPPER |
| 26 | 5904 Utah Ave NW | 10/31/2005 | 0 | 0 | COPPER |
| 27 | 4607 River Rd NW | 8/24/2005 | 0 | 0 | COPPER |
| 28 | 3732 Benton St NW | 10/23/2005 | 0 | 0 | LEAD |
| 29 | 1024 Wisconsin Ave NW | 10/21/2005 | 0 | 0 | COPPER |
| 30 | 4214 Lenore Ln NW | 9/28/2005 | 0 | 0 | NLD |
| 31 | 1226 R St NW | 8/9/2005 | 0 | 1 | LEAD |
| 32 | 315 C St SE | 9/29/2005 | 0 | 0 | COPPER |
| 33 | 3023 Cambridge Pl NW | 8/10/2005 | 0 | 0 | UNKNOWN |
| 34 | 2805 28th St NW | 9/29/2005 | 0 | 0 | COPPER |
| 35 | 630 Acker Pl NE | 8/15/2005 | 0 | 0 | COPPER |
| 36 | 4642 Warren St NW | 8/5/2005 | 0 | 0 | COPPER |
| 37 | 3956 Garrison St NW | 9/14/2005 | 0 | 0 | COPPER |
| 38 | 6423 Barnaby St NW | 7/25/2005 | 0 | 1 | BRASS |
| 39 | 1115 N St NW | 9/19/2005 | 0 | 0 | COPPER |
| 40 | 1523 Ridge Pl SE | 7/25/2005 | 0 | 1 | BRASS |
| 41 | 255 14th Pl NE | 10/3/2005 | 1 | 3 | LEAD |
| 42 | 1360 L St SE | 9/15/2005 | 1 | 0 | BRASS |

| | Address | Collection Date | Draw 1 | Draw 2 | Service Pipe |
|----|---------------------------|-----------------|--------|--------|--------------|
| 43 | 2225 Branch Ave SE | 7/2/2005 | 1 | 1 | BRASS |
| 44 | 205 10th St NE | 8/25/2005 | 1 | 3 | COPPER |
| 45 | 5500 16th St NW | 10/21/2005 | 1 | 6 | COPPER |
| 46 | 658 12th St NE | 11/1/2005 | 1 | 1 | LEAD |
| 47 | 3728 Jenifer St NW | 10/20/2005 | 1 | 0 | COPPER |
| 48 | 4627 44th St NW | 9/24/2005 | 1 | 0 | LEAD |
| 49 | 1722 Corcoran St NW | 7/25/2005 | 1 | 0 | COPPER |
| 50 | 4513 Davenport St NW | 10/4/2005 | 1 | 1 | BRASS |
| 51 | 2728 34th St NW | 10/26/2005 | 1 | 1 | COPPER |
| 52 | 1343 S.Caroline Ave SE | 7/18/2005 | 1 | 1 | COPPER |
| 53 | 3121 P St NW | 7/12/2005 | 1 | 1 | LEAD |
| 54 | 533 21st St NE | 7/15/2005 | 1 | 0 | NLD |
| 55 | 5111 45th St NW | 8/15/2005 | 1 | 0 | BRASS |
| 56 | 839 Xenia St SE | 7/24/2005 | 1 | 2 | COPPER |
| 57 | 4631 Massachusetts Ave NW | 7/18/2005 | 1 | 0 | COPPER |
| 58 | 4610 Chesapeake St NW | 9/16/2005 | 1 | 0 | BRASS |
| 59 | 123 Tennessee Ave NE | 7/6/2005 | 1 | 1 | LEAD |
| 60 | 2449 39th PI NW | 7/14/2005 | 1 | 1 | COPPER |
| 61 | 1133 Kalmia Rd NW | 10/2/2005 | 1 | 0 | COPPER |
| 62 | 2314 39th St NW | 7/7/2005 | 1 | 0 | COPPER |
| 63 | 1315 Naylor Ct NW | 10/25/2005 | 1 | 0 | LEAD |
| 64 | 4926 43rd St NW | 7/27/2005 | 1 | 0 | COPPER |
| 65 | 5011 Sedgwick St NW | 7/12/2005 | 1 | 1 | COPPER |
| 66 | 3565 Brandywine St NW | 9/20/2005 | 1 | 0 | COPPER |
| 67 | 650 A St NE | 7/15/2005 | 1 | 0 | COPPER |
| 68 | 1413 1st St NW | 8/10/2005 | 1 | 0 | LEAD |
| 69 | 59 N ST NW | 7/5/2005 | 1 | 2 | COPPER |
| 70 | 3901 Ivy Terrace Ct NW | 8/4/2005 | 1 | 0 | UNKNOWN |
| 71 | 2935 Garfield St NW | 9/18/2005 | 1 | 0 | COPPER |
| 72 | 1946 3rd St NW | 10/4/2005 | 1 | 0 | COPPER |
| 73 | 418 E Capitol St NE | 7/11/2005 | 1 | 2 | COPPER |
| 74 | 516 T ST NW | 7/12/2005 | 1 | 1 | COPPER |
| 75 | 2623 GARFIELD ST NW | 9/15/2005 | 1 | 0 | COPPER |
| 76 | 6660 32nd PI NW | 7/10/2005 | 1 | 1 | COPPER |
| 77 | 2306 Minnesota Ave SE | 10/13/2005 | 1 | 0 | BRASS |
| 78 | 3171 Porter St NW | 8/9/2005 | 1 | 0 | BRASS |
| 79 | 2029 Savannah PI SE | 11/9/2005 | 1 | 0 | COPPER |
| 80 | 3650 Texas Ave SE | 10/6/2005 | 1 | 1 | COPPER |
| 81 | 6960 33rd St NW | 9/3/2005 | 1 | 1 | COPPER |
| 82 | 5124 Drake PI SE | 7/26/2005 | 1 | 6 | COPPER |
| 83 | 5070 Macomb St NW | 8/5/2005 | 1 | 0 | COPPER |
| 84 | 4805 Blagden Ave NW | 11/7/2005 | 1 | 2 | UNKNOWN |
| 85 | 1801 Taylor St NW | 7/17/2005 | 1 | 0 | BRASS |
| 86 | 1319 Dexter Ter SE | 10/31/2005 | 1 | 0 | COPPER |
| 87 | 220 Peabody St NW | 9/29/2005 | 1 | 0 | BRASS |

| | Address | Collection Date | Draw 1 | Draw 2 | Service Pipe |
|-----|-----------------------|-----------------|--------|--------|--------------|
| 88 | 1300 Emerald St NE | 9/23/2005 | 1 | 0 | COPPER |
| 89 | 1208 D Street SE | 7/14/2005 | 1 | 0 | LEAD |
| 90 | 404 Aspen St NW | 7/6/2005 | 1 | 0 | COPPER |
| 91 | 1613 S St NW | 8/22/2005 | 1 | 1 | LEAD |
| 92 | 1414 A St SE | 7/12/2005 | 1 | 0 | BRASS |
| 93 | 3536 Winfield Lane NW | 9/19/2005 | 1 | 0 | UNKNOWN |
| 94 | 2300 39th St NW | 7/12/2005 | 1 | 0 | COPPER |
| 95 | 301 Allison St NW | 7/12/2005 | 1 | 1 | BRASS |
| 96 | 1609 Buchanan St NE | 10/11/2005 | 1 | 0 | COPPER |
| 97 | 4515 43rd St NW | 7/22/2005 | 1 | 1 | COPPER |
| 98 | 2116 Kearney St NE | 10/5/2005 | 1 | 0 | BRASS |
| 99 | 5112 Watson St NW | 7/20/2005 | 1 | 0 | COPPER |
| 100 | 2907 P St NW | 7/12/2005 | 1 | 0 | BRASS |
| 101 | 5149 Sherier Pl NW | 7/9/2005 | 1 | 1 | COPPER |
| 102 | 546 14th St SE | 8/26/2005 | 1 | 2 | LEAD |
| 103 | 33 N St NW | 7/6/2005 | 2 | 1 | LEAD |
| 104 | 4317 22nd St NE | 7/9/2005 | 2 | 1 | COPPER |
| 105 | 1727 KILBOURNE PL NW | 8/27/2005 | 2 | 2 | COPPER |
| 106 | 1723 Swann St NW | 7/14/2005 | 2 | 1 | LEAD |
| 107 | 1318 D St SE | 11/12/2005 | 2 | 3 | LEAD |
| 108 | 2936 Garfield Ter NW | 7/27/2005 | 2 | 0 | COPPER |
| 109 | 803 25th St NW | 9/6/2005 | 2 | 2 | LEAD |
| 110 | 1314 8th St NW | 9/2/2005 | 2 | 7 | LEAD |
| 111 | 2845 28th St SE | 10/12/2005 | 2 | 33 | LEAD |
| 112 | 256 9th St NE | 10/5/2005 | 2 | 1 | COPPER |
| 113 | 304 9th St NE | 9/6/2005 | 2 | 0 | COPPER |
| 114 | 1733 U St NW | 9/25/2005 | 2 | 3 | COPPER |
| 115 | 722 Kenyon St NW | 10/10/2005 | 2 | 3 | COPPER |
| 116 | 2200 16th St NE | 10/4/2005 | 2 | 2 | COPPER |
| 117 | 658 G St NE | 8/10/2005 | 2 | 1 | UNKNOWN |
| 118 | 4443 Harrison St NW | 10/3/2005 | 2 | 0 | UNKNOWN |
| 119 | 600 H St SW | 10/15/2005 | 2 | 0 | COPPER |
| 120 | 1752 S St NW | 9/30/2005 | 2 | 0 | BRASS |
| 121 | 1444 Taylor St NW | 10/4/2005 | 2 | 0 | COPPER |
| 122 | 1725 U St NW | 9/9/2005 | 2 | 1 | COPPER |
| 123 | 1209 D St NE | 8/26/2005 | 2 | 1 | LEAD |
| 124 | 2231 16th St NE | 10/25/2005 | 2 | 5 | COPPER |
| 125 | 2490 Tracy Pl NW | 10/13/2005 | 2 | 1 | COPPER |
| 126 | 5714 3rd Pl NW | 7/25/2005 | 2 | 1 | COPPER |
| 127 | 7600 17th St NW | 10/20/2005 | 2 | 0 | COPPER |
| 128 | 710 A St SE | 11/9/2005 | 2 | 3 | LEAD |
| 129 | 3308 Carpenter St SE | 11/7/2005 | 2 | 3 | COPPER |
| 130 | 2321 32nd St SE | 7/14/2005 | 2 | 0 | COPPER |
| 131 | 40 Farragut Pl NW | 8/3/2005 | 2 | 0 | COPPER |
| 132 | 3909 Morrison St NW | 8/14/2005 | 2 | 0 | COPPER |

| | Address | Collection Date | Draw 1 | Draw 2 | Service Pipe |
|-----|-------------------------|-----------------|--------|--------|--------------|
| 133 | 4007 14th St NW | 11/12/2005 | 2 | 1 | LEAD |
| 134 | 4200 37th St NW | 8/22/2005 | 2 | 2 | LEAD |
| 135 | 518 Peabody St NW | 8/20/2005 | 3 | 2 | LEAD |
| 136 | 1434 C St NE | 10/18/2005 | 3 | 4 | COPPER |
| 137 | 140 N Carolina Ave SE | 10/25/2005 | 3 | 3 | LEAD |
| 138 | 1213 29th Street NW | 8/2/2005 | 3 | 3 | LEAD |
| 139 | 1505 33rd St NW | 8/22/2005 | 3 | 8 | LEAD |
| 140 | 805 A St SE | 8/2/2005 | 3 | 4 | LEAD |
| 141 | 3612 Martin Luther | 9/21/2005 | 3 | 1 | LEAD |
| 142 | 1603 S St NW | 7/13/2005 | 3 | 1 | LEAD |
| 143 | 3036 Cambridge Pl NW | 10/27/2005 | 3 | 0 | UNKNOWN |
| 144 | 4520 Texas Ave SE | 8/16/2005 | 3 | 0 | COPPER |
| 145 | 1508 Gales St NE | 10/12/2005 | 3 | 3 | UNKNOWN |
| 146 | 5222 Illinois Ave NW | 10/4/2005 | 4 | 2 | UNKNOWN |
| 147 | 5107 45th St NW | 10/1/2005 | 4 | 2 | BRASS |
| 148 | 1313 K St SE | 8/1/2005 | 4 | 5 | LEAD |
| 149 | 1605 Foxhall Rd NW | 11/2/2005 | 4 | 4 | LEAD |
| 150 | 5360 MacArthur Blvd NW | 9/11/2005 | 4 | 7 | UNKNOWN |
| 151 | 1121 Staples St NE | 9/22/2005 | 4 | 4 | LEAD |
| 152 | 3628 12th St NE | 8/12/2005 | 4 | 4 | LEAD |
| 153 | 68 Observatory Cir NW | 11/5/2005 | 4 | 6 | LEAD |
| 154 | 4218 Edson Pl NE | 9/19/2005 | 4 | 5 | LEAD |
| 155 | 308 G St NE | 9/26/2005 | 4 | 2 | COPPER |
| 156 | 145 Rhode Island Ave NW | 8/11/2005 | 4 | 4 | COPPER |
| 157 | 3219 Warder St NW | 8/29/2005 | 4 | 6 | UNKNOWN |
| 158 | 901 Aspen St NW | 10/11/2005 | 4 | 7 | LEAD |
| 159 | 515 F St NE | 8/31/2005 | 4 | 1 | COPPER |
| 160 | 210 11th St SE | 9/1/2005 | 4 | 1 | LEAD |
| 161 | 2724 34th St NW | 10/6/2005 | 4 | 2 | BRASS |
| 162 | 1112 K St SE | 8/22/2005 | 4 | 7 | UNKNOWN |
| 163 | 1140 Sixth Street NE | 7/15/2005 | 4 | 2 | COPPER |
| 164 | 522 Nicholson St NE | 10/19/2005 | 4 | 1 | COPPER |
| 165 | 712 E St NE | 11/3/2005 | 4 | 14 | LEAD |
| 166 | 715 Dahlia St NW | 9/16/2005 | 4 | 3 | COPPER |
| 167 | 4719 44th St NW | 7/16/2005 | 4 | 0 | COPPER |
| 168 | 4414 6th Pl NE | 10/21/2005 | 4 | 0 | NLD |
| 169 | 3635 Winfield Lane NW | 8/13/2005 | 4 | 3 | UNKNOWN |
| 170 | 3303 22ND St NE | 9/30/2005 | 5 | 8 | COPPER |
| 171 | 138 RANDOLPH Pl NW | 7/2/2005 | 5 | 5 | COPPER |
| 172 | 519 F St NE | 7/8/2005 | 5 | 2 | COPPER |
| 173 | 338 8TH St SE | 10/3/2005 | 5 | 6 | GALVANIZED |
| 174 | 2912 13th St NW | 8/10/2005 | 5 | 8 | LEAD |
| 175 | 1334 Shepherd St NW | 7/10/2005 | 5 | 11 | LEAD |
| 176 | 3409 O St NW | 8/15/2005 | 5 | 4 | LEAD |
| 177 | 5132 Nebraska Ave NW | 8/4/2005 | 5 | 4 | LEAD |

| | Address | Collection Date | Draw 1 | Draw 2 | Service Pipe |
|-----|---------------------------|-----------------|--------|--------|--------------|
| 178 | 2215 38th St NW | 9/10/2005 | 6 | 3 | LEAD |
| 179 | 4515 Brooks St NE | 9/29/2005 | 6 | 4 | LEAD |
| 180 | 1031 Kearney St NE | 9/5/2005 | 6 | 2 | COPPER |
| 181 | 1530 32nd St NW | 9/18/2005 | 6 | 6 | UNKNOWN |
| 182 | 3726 Brandywine St NW | 8/15/2005 | 6 | 13 | LEAD |
| 183 | 1412 Massachusetts Ave SE | 9/16/2005 | 6 | 8 | LEAD |
| 184 | 1727 S St NW | 8/16/2005 | 6 | 5 | UNKNOWN |
| 185 | 1404 Massachusetts Ave SE | 9/9/2005 | 6 | 9 | LEAD |
| 186 | 4713 Queens Chapel Ter NE | 9/3/2005 | 6 | 2 | COPPER |
| 187 | 3411 Q St NW | 9/12/2005 | 6 | 13 | COPPER |
| 188 | 324 17th St SE | 7/7/2005 | 7 | 10 | LEAD |
| 189 | 4312 Brandywine St NW | 10/16/2005 | 7 | 29 | LEAD |
| 190 | 2618 32nd St SE | 10/17/2005 | 7 | 1 | BRASS |
| 191 | 701 3rd St NE | 7/26/2005 | 7 | 7 | LEAD |
| 192 | 1829 Riggs Pl NW | 7/28/2005 | 7 | 5 | LEAD |
| 193 | 601 K St NE | 7/27/2005 | 7 | 29 | COPPER |
| 194 | 3802 Yuma St NW | 7/31/2005 | 7 | 6 | LEAD |
| 195 | 2224 Cathedral Ave NW | 9/8/2005 | 7 | 26 | LEAD |
| 196 | 7541 14th St NW | 8/23/2005 | 7 | 4 | COPPER |
| 197 | 3745 W St NW | 7/8/2005 | 7 | 21 | LEAD |
| 198 | 1340 D St NE | 8/12/2005 | 7 | 1 | UNKNOWN |
| 199 | 740 Quebec Pl NW | 7/26/2005 | 7 | 9 | COPPER |
| 200 | 38 CHANNING ST NW | 9/9/2005 | 7 | 3 | LEAD |
| 201 | 624 C St SE | 7/13/2005 | 8 | 10 | UNKNOWN |
| 202 | 4306 Brandywine St NW | 7/18/2005 | 8 | 12 | UNKNOWN |
| 203 | 3410 Quesada St NW | 7/13/2005 | 8 | 16 | UNKNOWN |
| 204 | 1522 Potomac Ave SE | 7/27/2005 | 8 | 5 | LEAD |
| 205 | 513 13th St SE | 10/2/2005 | 8 | 29 | LEAD |
| 206 | 1407 A St SE | 10/20/2005 | 8 | 15 | LEAD |
| 207 | 4424 Greenwich Pkwy NW | 9/23/2005 | 8 | 5 | LEAD |
| 208 | 1410 D St SE | 9/2/2005 | 8 | 3 | LEAD |
| 209 | 1240 Randolph St NE | 8/12/2005 | 8 | 1 | BRASS |
| 210 | 2307 Ontario Rd NW | 9/17/2005 | 8 | 19 | UNKNOWN |
| 211 | 1726 Seaton St NW | 11/8/2005 | 8 | 7 | LEAD |
| 212 | 3116 Warder St NW | 9/6/2005 | 8 | 9 | LEAD |
| 213 | 610 Harvard St NW | 9/27/2005 | 8 | 5 | UNKNOWN |
| 214 | 3622 Ordway St NW | 7/24/2005 | 8 | 18 | LEAD |
| 215 | 1406 Massachusetts Ave SE | 9/9/2005 | 8 | 11 | LEAD |
| 216 | 1875 NEWTON ST NW | 9/11/2005 | 9 | 22 | COPPER |
| 217 | 3013 15th St NE | 7/26/2005 | 9 | 1 | LEAD |
| 218 | 3807 S ST NW | 7/9/2005 | 9 | 7 | COPPER |
| 219 | 5343 43rd St NW | 10/15/2005 | 9 | 5 | BRASS |
| 220 | 4213 16th St NW | 10/2/2005 | 9 | 53 | LEAD |
| 221 | 2920 Porter St NW | 9/18/2005 | 9 | 6 | UNKNOWN |
| 222 | 4119 3rd St NW | 7/19/2005 | 9 | 7 | COPPER |

| | Address | Collection Date | Draw 1 | Draw 2 | Service Pipe |
|------------|---------------------------|------------------|-----------|-----------|--------------|
| 223 | 6110 Broad Branch Rd NW | 7/27/2005 | 9 | 7 | COPPER |
| 224 | 645 Morton PI NE | 7/10/2005 | 9 | 9 | LEAD |
| 225 | 4306 NH BURROUGHS AVE NE | 10/6/2005 | 9 | 2 | COPPER |
| 226 | 320 Bryant St NE | 10/3/2005 | 9 | 8 | LEAD |
| 227 | 509 G St NE | 8/16/2005 | 10 | 11 | LEAD |
| 228 | 3312 Alabama Ave SE | 7/3/2005 | 10 | 20 | BRASS |
| 229 | 702 Longfellow St NW | 7/11/2005 | 10 | 12 | UNKNOWN |
| 230 | 4020 14th St NW | 10/14/2005 | 10 | 1 | LEAD |
| 231 | 1877 NEWTON ST NW | 7/12/2005 | 10 | 13 | COPPER |
| 232 | 3244 38th St NW | 9/23/2005 | 10 | 8 | LEAD |
| 233 | 3551 6th St NW | 7/13/2005 | 10 | 8 | LEAD |
| 234 | 1018 Irving St NE | 7/29/2005 | 10 | 5 | UNKNOWN |
| 235 | 3805 Gramercy St NW | 10/16/2005 | 10 | 12 | LEAD |
| 236 | 6810 Laurel St NW | 7/5/2005 | 10 | 14 | UNKNOWN |
| 237 | 2219 2nd St NW | 8/27/2005 | 10 | 30 | LEAD |
| 238 | 3525 Porter St NW | 10/17/2005 | 11 | 21 | LEAD |
| 239 | 238 10th St SE | 10/2/2005 | 11 | 15 | LEAD |
| 240 | 3052 Monroe St NE | 9/29/2005 | 11 | 14 | COPPER |
| 241 | 3736 Huntington St NW | 10/17/2005 | 11 | 12 | COPPER |
| 242 | 311 Rock Crk Church Rd NW | 10/6/2005 | 11 | 3 | LEAD |
| 243 | 2005 Kalorama Rd NW | 7/5/2005 | 11 | 14 | UNKNOWN |
| 244 | 322 14th PI NE | 9/5/2005 | 12 | 42 | UNKNOWN |
| 245 | 215 10th St NE | 9/8/2005 | 12 | 49 | LEAD |
| 246 | 3723 Reservoir Rd NW | 9/6/2005 | 12 | 3 | LEAD |
| 247 | 207 Randolph PI NE | 8/11/2005 | 13 | 8 | LEAD |
| 248 | 1101 Clifton St NW | 10/22/2005 | 13 | 4 | LEAD |
| 249 | 216 R St NE | 7/1/2005 | 13 | 5 | LEAD |
| 250 | 5511 39th St NW | 10/26/2005 | 14 | 11 | LEAD |
| 251 | 25 16th St SE | 9/13/2005 | 14 | 5 | LEAD |
| 252 | 3022 Macomb St NW | 7/2/2005 | 14 | 11 | UNKNOWN |
| 253 | 1414 Massachusetts Ave SE | 9/15/2005 | 14 | 14 | LEAD |
| 254 | 1626 33rd St NW | 9/18/2005 | 14 | 12 | COPPER |
| 255 | 1725 Seaton St NW | 8/10/2005 | 15 | 5 | LEAD |
| 256 | 1717 37th St NW | 9/3/2005 | 16 | 25 | COPPER |
| 257 | 540 Newton PI NW | 9/3/2005 | 16 | 11 | LEAD |
| 258 | 2032 Douglas St NE | 8/30/2005 | 16 | 33 | LEAD |
| 259 | 806 Alabama Ave SE | 10/21/2005 | 17 | 6 | LEAD |
| 260 | 1118 Staples St NE | 8/18/2005 | 17 | 12 | LEAD |
| 261 | 4521 Lowell St NW | 10/18/2005 | 18 | 16 | LEAD |
| 262 | 4208 8TH ST NW | 9/10/2005 | 18 | 5 | LEAD |
| 263 | 1423 Varnum St NW | 9/13/2005 | 19 | 21 | UNKNOWN |
| 264 | 1701 Newton St NW | 10/22/2005 | 20 | 27 | COPPER |
| 265 | 2037 37th St NW | 8/17/2005 | 20 | 29 | LEAD |
| 266 | 3211 Oliver St NW | 8/4/2005 | 20 | 9 | LEAD |
| 267 | 12 14th St SE | 8/26/2005 | 20 | 41 | LEAD |

| | Address | Collection Date | Draw 1 | Draw 2 | Service Pipe |
|-----|---------------------------|-----------------|--------|--------|--------------|
| 268 | 1920 35th PI NW | 9/11/2005 | 21 | 21 | COPPER |
| 269 | 4341 Forest Ln NW | 7/6/2005 | 21 | 11 | BRASS |
| 270 | 1318 Randolph St NE | 8/13/2005 | 23 | 23 | LEAD |
| 271 | 5520 Hawthorne PI NW | 8/17/2005 | 24 | 30 | LEAD |
| 272 | 151 Rhode Island Ave NW | 7/6/2005 | 25 | 252 | COPPER |
| 273 | 16 16th St NE | 10/19/2005 | 25 | 21 | LEAD |
| 274 | 3814 47th St NW | 9/29/2005 | 34 | 15 | LEAD |
| 275 | 612 G St SE | 9/7/2005 | 37 | 9 | LEAD |
| 276 | 4115 Garrison St NW | 7/29/2005 | 39 | 29 | UNKNOWN |
| 277 | 2729 Sherman Ave NW | 8/3/2005 | 41 | 11 | COPPER |
| 278 | 820 Allison St NW | 9/8/2005 | 45 | 34 | LEAD |
| 279 | 3101 Massachusetts Ave NW | 10/7/2005 | 55 | 1 | UNKNOWN |
| 280 | 3623 T St NW | 7/2/2005 | 67 | 60 | COPPER |
| 281 | 814 4th St NE | 10/23/2005 | 80 | 19 | COPPER |
| 282 | 103 14th St NE | 8/17/2005 | 97 | 63 | LEAD |
| 283 | 1892 ONTARIO PL NW | 7/29/2005 | 99 | 14 | COPPER |
| 284 | 1724 V St NW | 7/4/2005 | 128 | 63 | LEAD |
| 285 | 1424 S St NW | 8/1/2005 | 144 | 21 | LEAD |
| 286 | 5609 NH BURROUGHS AVE NE | 8/8/2005 | 217 | 2 | UNKNOWN |
| 287 | 145 Rhode Island Ave NW | 7/6/2005 | 4600 | 263 | COPPER |

90th percentile (First draw) is indicated in green.

Section 4.
Summary of all locations where bottles were dropped off but no customer participation

| | Address | Quadrant | Routine | | Address | Quadrant | Routine |
|----|-------------------------|----------|---------|----|----------------------|----------|---------|
| 1 | 1008 MARYLAND AVE | NE | TRUE | 46 | 2858 28TH ST | NW | TRUE |
| 2 | 1016 DOUGLAS ST | NE | TRUE | 47 | 3009 7TH ST | SE | TRUE |
| 3 | 1104 TRINIDAD AVE | NE | TRUE | 48 | 3035 15TH ST | NW | TRUE |
| 4 | 1110 45TH PL. | SE | TRUE | 49 | 3202 38TH ST | NW | TRUE |
| 5 | 1115 PARK ST | NE | TRUE | 50 | 3301 BROWN St. | NW | TRUE |
| 6 | 112 4TH ST. | SE | TRUE | 51 | 3342 18TH ST | NW | TRUE |
| 7 | 1145 OATES ST | NE | TRUE | 52 | 335 17TH PL | NE | TRUE |
| 8 | 119 16TH ST | NE | TRUE | 53 | 3519 PORTER ST | NW | TRUE |
| 9 | 1222 HAMILTON ST | NW | TRUE | 54 | 3634 WARDER ST | NW | TRUE |
| 10 | 1240 D ST | SE | TRUE | 55 | 4131 YUMA ST | NW | TRUE |
| 11 | 1262 COL RD | NW | TRUE | 56 | 4230 FESSENDEN ST. | NW | TRUE |
| 12 | 1319 21st ST | NW | TRUE | 57 | 4325 IOWA AVE | NW | TRUE |
| 13 | 1319 POTOMAC AVE | SE | TRUE | 58 | 434 15TH ST | SE | TRUE |
| 14 | 1324 N. CAROLINA AVE | NE | TRUE | 59 | 440 3RD ST | NE | TRUE |
| 15 | 1326 A ST | SE | TRUE | 60 | 4616 HUNT PL | NE | TRUE |
| 16 | 1326 NORTH CAROLINA AVE | NE | TRUE | 61 | 4828 7TH ST | NW | TRUE |
| 17 | 1419 SPRING RD | NW | TRUE | 62 | 4912 44TH ST | NW | TRUE |
| 18 | 1420 S ST | SE | TRUE | 63 | 501 UPSHUR ST | NW | TRUE |
| 19 | 1451 S ST | NW | TRUE | 64 | 5121 ILLINOIS AVE | NW | TRUE |
| 20 | 1527 33RD ST | NW | TRUE | 65 | 5324 COLORADO AVE | NW | TRUE |
| 21 | 1626 E ST. SE | SE | TRUE | 66 | 5404 39TH ST. | NW | TRUE |
| 22 | 1635 WEBSTER ST. | NW | TRUE | 67 | 5405 39TH ST | NW | TRUE |
| 23 | 1701 INDEPENDENCE AVE | SE | TRUE | 68 | 5407 41ST ST | NW | TRUE |
| 24 | 1802 35TH ST | NW | TRUE | 69 | 545 PARK RD | NW | TRUE |
| 25 | 1808 KEARNEY ST | NE | TRUE | 70 | 5717 SHERIER PL | NW | TRUE |
| 26 | 1850 2ND ST. | NW | TRUE | 71 | 608 Gallatin St | NW | TRUE |
| 27 | 1929 SUMMIT PL | NE | TRUE | 72 | 618 OTIS PL | NW | TRUE |
| 28 | 1931 SUMMIT PL. | NE | TRUE | 73 | 6213 7TH ST | NW | TRUE |
| 29 | 1937 BILTMORE ST | NW | TRUE | 74 | 6413 KANSAS AVE. | NE | TRUE |
| 30 | 1971 BILTMORE ST | NW | TRUE | 75 | 661 MARYLAND AVE | NE | TRUE |
| 31 | 2007 37TH ST | NW | TRUE | 76 | 704 ALABAMA AVE | SE | TRUE |
| 32 | 2016 4TH ST | NE | TRUE | 77 | 712 JEFFERSON ST | NW | TRUE |
| 33 | 208 5TH ST | SE | TRUE | 78 | 720 ALABAMA AVE | SE | TRUE |
| 34 | 211 RANDOLPH PL | NE | TRUE | 79 | 720 PARK RD | NW | TRUE |
| 35 | 2136 NEWPORT PL | NW | TRUE | 80 | 720 RHODE ISLAND AVE | NE | TRUE |
| 36 | 220 8TH ST | SE | TRUE | 81 | 729 11TH ST | NE | TRUE |
| 37 | 2208 12TH ST | NW | TRUE | 82 | 747 GIRARD ST | NW | TRUE |
| 38 | 2211 39TH ST | NW | TRUE | 83 | 765 GIRARD ST | NW | TRUE |
| 39 | 2237 CHESTER ST | SE | TRUE | 84 | 805 LONGFELLOW ST. | NW | TRUE |
| 40 | 225 MISSISSIPPI AVE | SE | TRUE | 85 | 811 BUTTERNUT ST | NW | TRUE |
| 41 | 228 V ST | NE | TRUE | 86 | 817 DECATUR ST. | NW | TRUE |
| 42 | 2418 3RD ST | NE | TRUE | 87 | 833 DECATUR ST. | NW | TRUE |
| 43 | 2448 HUIDEKOPER PL | NW | TRUE | 88 | 835 3RD ST | NE | TRUE |
| 44 | 2634 GEORGIA AVE | NW | TRUE | 89 | 909 HAMLIN ST | NE | TRUE |
| 45 | 2823 5TH ST | NE | TRUE | 90 | 926 14TH ST | SE | TRUE |

Section 5.
July – December 2005 Lead and Copper Sampling Plan



July – December 2005 Sampling Plan
DCWASA
Department of Water Services
Division of Water Quality
(Revised 9-20-2005)
Lead and Copper Site Selection Criteria

The lead and copper rule for the DCWASA system requires a minimum of 100 sample sites with at least ½ of the sites with full lead service lines (Tier 1 sites). The sample sites will comply with this requirement (i.e. ½ of the Tier 1 sites will be full lead service lines) as indicated in Table 2. The District currently performs lead and copper compliance monitoring twice per year (two sampling periods per year) due to lead action level exceedances. The sampling is evenly distributed over the course of the monitoring period. The homeowner, using the form and instructions located in Appendix A, will collect the samples. First and second draw samples will be collected and analyzed for lead, copper and iron using EPA Method 200.8 at a certified lab (Washington Aqueduct). DCWASA will mail results to the homeowner along with lead advisory information (written in the letter) once lab reports are received from the certified lab. *DCWASA will exercise best efforts to provide sampling results within 30 days of sample collection, although laboratory response time is outside of WASA's control. WASA will provide the sampling results to customers within three business days from the receipt of the results from the laboratory.*

There are four standard letters located in Appendix B, one that will be mailed to the homeowner depending on the following conditions:

- Letter 1 – First and second draw below action level with a non-lead service line
- Letter 2 – First and/or second draw above action level with a non-lead service line
- Letter 3 – First and second draw below action level with lead, brass or unknown service line
- Letter 4 – First or second draw above action level with lead, brass or unknown service line

DCWASA has never obtained a first or second draw copper sample above the action level. Should this situation arise, DCWASA will notify the customer in writing on an individual basis.

Routine Monitoring List

Research conducted in 2004 indicated that customer lead service lines were the major contributor of lead concentrations in DCWASA's tap water. In order to accurately assess lead reduction for compliance monitoring, the revised routine monitoring list (Table 2) will contain at least 50% residential locations with full lead service lines. The remaining 50% will need to meet one of the following criteria:

- A residential location that has had a partial lead service line replacement
- A residential location that has either unknown or brass service lines and the 2nd draw sample has previously exceeded the lead action level.

- A residential location that has a copper service line and was built before 1986 with no major plumbing work conducted prior to 1986.

Table 3 in Appendix C lists the residential homes that were removed from the list either because the customer requested to cease sampling, the location no longer meets the above criteria or the location has been established as a consecutive system.

Supplemental Monitoring List

There are 186 locations in the revised routine monitoring list. During the new monitoring period, DCWASA's Water Quality Division may be requested to collect lead and copper samples from concerned customers. Should any of these customers meet the criteria listed in the Routine monitoring list, their results will be included in the compliance calculation.

Monitoring Strategy for July 2005 through December 2005

Past experience indicates that as much as 50 % of the customers will choose not to participate in any given monitoring period due to circumstances such as: the customer is out of town, there is a new owner of the residence, lack of interest, etc. DCWASA will attempt to sample all of the sites listed in Table 2 during a given monitoring period and a given site will not be sampled only if the customer elects not to participate. All sites will remain on the list until such time that the customer notifies DCWASA that they wish to be removed from the list at which time DCWASA will notify EPA.

If DCWASA does not have at least 100 sample sites during a given monitoring period due to the conditions noted above, DCWASA will solicit residences that have known lead services from the database. Specific locations will be determined using a random generated computer program.

It is estimated that approximately 90 of the homeowners on the new "routine list" will participate in the upcoming monitoring period, therefore it is expected that approximately 10 "supplemental" Tier 1 locations will be used.

Reduced monitoring

This plan is specifically designed to address lead and copper monitoring during the periods that DCWASA exceeds the action level as well as for 2 consecutive 6-month periods when lead and copper levels fall below the action level. An addendum to this plan will follow once optimal corrosion control has been achieved and reduced monitoring has been authorized by USEPA.

Reporting Format

The lead and copper routine monitoring will be submitted in electronic format. The report format will be in an access database report and also an Excel spreadsheet.



Appendix A Lead and Copper Monitoring Sample Collection Form (Revised 9-20-2005)

PLEASE READ ENTIRE FORM BEFORE COLLECTING SAMPLES

Thank you for participating in the LEAD AND COPPER MONITORING PROGRAM. These samples are being collected to determine the contribution of faucet fixtures and household pipes and/or solder to the lead and copper levels in your tap water. This sampling effort is required by the Environmental Protection Agency, and is being accomplished through the cooperation of homeowners and residents.

Run your cold water for a minimum of 10 minutes out of the kitchen tap. Close the tap and do not use the water in your entire home for a period of 6 to 8 hours. Collect the samples immediately after the 6-8 hour period of NO water use as instructed below. The best time to collect the samples is early morning or evening upon returning home. The following describes the sample collection procedure:

1. Use a kitchen cold-water faucet for sampling. The 1st and 2nd draw samples must be collected from the same cold water faucet and within a few minutes of each other.

Notes:

***PLEASE DO NOT REMOVE AERATOR FROM FAUCETS BEFORE SAMPLING.**

***If you have a water treatment unit or filter attached to your plumbing system or faucet, please bypass the unit or remove the filter before sampling.**

2. Uncap a sample bottle. Place the sample bottle under the faucet. Gently open the cold water faucet and fill the sample bottle to the top.
3. When the bottle is full to the top, tightly cap the sample bottle. On the bottle label, fill out **Collect Date, Collect Time, Collector** (your name), **Address**, and circle **1st Draw**. Leave **Sample #** blank.
4. Note the Date and Time of the sampling on this form in the designated area on the next page.
5. Once 1st draw sample is taken, immediately uncap the unused plastic bottle to take the 2nd draw sample. Run the cold water faucet at a slow to moderate pace until the water turns cold. Then fill the bottle to the top.
6. When the bottle is full to the top, tightly cap the sample bottle. On the bottle label, fill out **Collect Date, Collect Time, Collector** (your name), **Address**, and circle **2nd Draw**. Leave **Sample #** blank. Note the Date and Time of the sampling on this form in the designated area on the next page.

7. For pick-up, place both bottles together with this completed and signed form in the same place where the kit was dropped off. The date of sample pick-up is listed on the next page. If you have questions regarding the instructions or the lead and copper monitoring program, please call our Water Quality Office at 202-612-3440.



| CUSTOMER INFORMATION | LABORATORY USE ONLY |
|----------------------|--|
| Name _____ | Sample ID# _____ |
| Address _____ | Flush Sample ID# _____ |
| City _____ | Sample Type: <u>D</u> System: WASA FC AC |
| Telephone # _____ | Date/Time/Received By: _____ |

PLEASE VERIFY THE FOLLOWING AND MARK THE APPROPRIATE BOX:

- Was your home built before 1986? YES NO
- Has there been any major plumbing changes within the premises after 1986? YES NO
- ARE THERE ANY LEAKING PLUMBING, FAUCETS OR TOILETS? YES NO OTHER _____
- IS YOUR ICE MAKER OFF? YES NO
- IS YOUR HUMIDIFIER OFF? YES NO
- ARE YOUR BASEBOARD/RADIATOR HEATING SYSTEMS OFF? YES NO
- WAS THERE ANY OTHER HOUSEHOLD USAGE DURING 6-8 HR. PERIOD? YES NO
- SPRINKLER SYSTEM OFF? YES NO
- DO YOU HAVE A WATER TREATMENT UNIT OR FILTER ATTACHED TO YOUR PLUMBING SYSTEM OR FAUCET? YES NO
 - IF YES, WHAT TYPE OF TREATMENT _____
 - IF YES, WAS IT BYPASSED BEFORE SAMPLING? YES NO

PLEASE COMPLETE:

Water last used: Date: _____ Time: _____

1st Draw Sample collection: Date: _____ Time: _____

2nd Draw Sample collection: Date: _____ Time: _____

I have read the above directions and taken both tap samples in accordance with these directions.

Signature: _____ Date: _____

SAMPLE PICK-UP DATE March 31, 2005

IF YOU HAVE ANY QUESTIONS REGARDING THESE INSTRUCTIONS CALL (202) 612-3440 OR Email us at WQP2003@DCWASA.COM OR WRITE TO D.C. WATER AND SEWER AUTHORITY – DEPARTMENT OF WATER SERVICES, WATER QUALITY DIVISION, 3900 DONALDSON PLACE, NW, WASHINGTON, D.C. 20016.

Appendix B
Lead and Copper Monitoring
Participant Results – Letter

LETTER #1

Resident
Washington, DC, NE 20002

Dear Resident,

Thank you for participating in the Lead and Copper Tap Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DCWASA). The analysis of the samples collected during the monitoring period of July 2004 through December 2004, is now complete.

Participant selection was made according to Environmental Protection Agency guidelines. Each participant selected was required to collect and provide two samples of water to DCWASA, within the sampling period. These samples were collected to determine how faucet fixtures, household pipes, service lines and solder contribute to the lead and copper levels in tap water. First draw samples are required by EPA and are designed to determine lead levels originating from your fixtures and in-house plumbing, while second draw samples (not required by EPA) indicate concentrations coming from your service line (the line from the main to the house). Our records indicate that your home does not contain a lead service line. If this is not correct, please contact WASA at the telephone number listed below.

The test results listed below indicate that the lead and copper concentrations of the tap water in your home are below the EPA action levels. The EPA action levels (AL) for lead and copper are 15 parts per billion (ppb) and 1300 ppb, respectively.

| Sample Site | QUADRANT | Concentration Of Lead in ppb | Concentration Of Copper in ppb |
|------------------|----------|------------------------------|--------------------------------|
| 1107 PARK ST. | NE | 2ppb (1 st draw) | 39ppb (1 st draw) |
| | | 1ppb (2 nd draw) | 7ppb (2 nd draw) |
| EPA Action Level | | 15 ppb | 1300 ppb |

Although samples indicate lead and copper concentrations are below the action level, WASA, at this time, is recommending that you use cold water for drinking or cooking, as hot water could contain higher levels of lead. Cold water should be heated on the stove for hot beverages or cooking. Flush water lines by running the cold water for 60 seconds prior to using the water from a faucet for drinking or cooking. Periodically, remove and clean the strainer/aerator device on your faucet to remove debris.

We appreciate your participation in the Lead and Copper Tap Water Monitoring Program. WASA is committed to making continuous improvements in our service to District residents and businesses. We look forward to your continued support of our monitoring and testing programs.

If you have additional questions or concerns, please call **202 612-3440** DCWASA, Water Quality Division or write to DCWASA, Water Quality Division, 3900 Donaldson Pl. NW, Washington, D.C. 20016.

Sincerely,



Richard Gian
Manager
Water Quality Division

LETTER #2

Resident
Washington, DC, NE 20002

Dear Resident,

Thank you for participating in the Lead and Copper Tap Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DCWASA). The analysis of the samples collected during the monitoring period of July 2004 through December 2004, is now complete.

Participant selection was made according to Environmental Protection Agency guidelines. Each participant selected was required to collect and provide two samples of water to DCWASA, within the sampling period. These samples were collected to determine how faucet fixtures, household pipes, service lines and solder contribute to the lead and copper levels in tap water. First draw samples are required by EPA and are designed to determine lead levels originating from your fixtures and in-house plumbing, while second draw samples (not required by EPA) indicate concentrations coming from your service line (the line from the main to the house).

The monitoring tests reveal that the lead concentration of the tap water in your home is above the EPA action level. The EPA action level (AL) for lead in the drinking water is 15 parts per billion (ppb). However, test results of the copper samples collected from your home are below the EPA action level for copper of 1300 ppb. The test results for the samples collected from your home are as follows:

| Sample Site | QUADRANT | Concentration Of Lead in ppb | Concentration Of Copper in ppb |
|------------------|----------|------------------------------|--------------------------------|
| 1107 PARK ST. | NE | 22ppb (1 st draw) | 9ppb (1 st draw) |
| | | 21ppb (2 nd draw) | 7ppb (2 nd draw) |
| EPA Action Level | | 15 ppb | 1300 ppb |

According to our records, your home does not have a lead service line. If this is not correct, please contact DCWASA at the number listed below. DCWASA is currently working with EPA and the Washington Aqueduct to determine the cause of the elevated lead levels and to find a solution. Until a treatment can be found, DCWASA is recommending for homes that do not have a lead service line to use cold water for drinking or cooking, as hot water could contain higher levels of lead. Cold water should be heated on the stove for hot beverages or cooking. Flush water lines by running the cold water for 60 seconds prior to using the water from a faucet for drinking or cooking. Periodically, remove and clean the strainer/aerator device on your faucet to remove debris.

Note: Boiling water does not reduce lead levels.

We appreciate your participation in the Lead and Copper Tap Water Monitoring Program. WASA is committed to making continuous improvements in our service to District residents and businesses. We look forward to your continued support of our monitoring and testing programs.

If you have additional questions or concerns, please call **202 612-3440** DCWASA, Water Quality Division or write to DCWASA, Water Quality Division, 3900 Donaldson Pl. NW, Washington, D.C. 20016.

Sincerely,



Richard Gian
Manager
Water Quality Division

LETTER #3

Resident
Washington, DC, NE 20002

Dear Resident,

Thank you for participating in the Lead and Copper Tap Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DCWASA). The analysis of the samples collected during the monitoring period of July 2004 through December 2004, are now complete.

Participant selection was made according to Environmental Protection Agency guidelines. Each participant selected was required to collect and provide two samples of water to DCWASA, within the sampling period. These samples were collected to determine how faucet fixtures, household pipes, service lines and solder contribute to the lead and copper levels in tap water. First draw samples are required by EPA and are designed to determine lead levels originating from your fixtures and in-house plumbing, while second draw samples indicate concentrations coming from your service line (the line from the main to the house).

The test results listed below indicate that the lead and copper concentrations of the tap water in your home are below the EPA action levels. The EPA action levels (AL) for lead and copper are 15 parts per billion (ppb) and 1300 ppb, respectively.

| Sample Site | QUADRANT | Concentration Of Lead in ppb | Concentration Of Copper in ppb |
|------------------|----------|-------------------------------|--------------------------------|
| 909 HAMLIN ST | NE | 12 ppb (1 st draw) | 107ppb (1 st draw) |
| | | 5 ppb (2 nd draw) | 1ppb (2 nd draw) |
| EPA Action Level | | 15 ppb | 1300 ppb |

According to our records, your home has a lead service line. If this is not correct, please contact DCWASA at the telephone number listed below. DCWASA is currently working with EPA and the Washington Aqueduct to determine the cause of the elevated lead levels and to find a solution. Although samples from your home indicate your lead and copper concentrations are below the action level, until a treatment can be found, DCWASA is recommending that you:

- **Use cold water for drinking or cooking, as hot water could contain higher levels of lead. Cold water should be heated on the stove for hot beverages or cooking.**
- **Draw water for drinking or cooking purposes immediately after another high water use activity, such as bathing or washing your clothes, so that a total of at least 10 minutes of flushing has occurred. (The large amount of water used will flush significant amounts of water, which might contain dissolved lead, from your home’s pipes.)**
- **Once flushing is complete, run the tap that you intend to use for drinking and cooking, for another 60 seconds before use. It is highly recommended at this time to collect water in several clean containers and place them in your refrigerator for daily drinking and cooking purposes.**
- **Periodically, remove and clean the strainer/aerator device on your faucet to remove debris.**

Note: Boiling water does not reduce lead levels.

The DC Department of Health (DOH) has issued very specific advice to residents of the District that have been identified in WASA records as having a lead water service pipe or for which WASA records do not identify the material of the water service pipe. According to DOH, in homes which may have a lead service pipe, children under

six years and women who are pregnant or breast feeding should not drink unfiltered water or use it to prepare infant formula or concentrated juices until concerns regarding the lead levels in the water have been resolved.

The District of Columbia Department of Health (DC DOH) provides information on how to have children and pregnant women screened for blood lead levels. The DC DOH can be reached by calling (202) 535-2626 or by visiting its Web site www.dchealth.dc.gov If you have additional concerns about a child's health, please contact his or her pediatrician.

If you are flushing your water lines but still have concerns about lead, you may want to consider switching to bottled water or purchasing a treatment device. Be sure to purchase a treatment device certified by an independent testing organization, such as NSF International. Neither EPA nor WASA certifies or endorses home drinking water treatment devices. You can search the NSF International website for certified drinking water treatment units by visiting:

www.nsf.org/Certified/DWTU

Choose a treatment device (i.e. filtration pitchers or tap filters) that will be used after potentially lead-leaching plumbing components. These **devices must be installed, operated and maintained according to manufacturer instructions.**

DC WASA is responsible for supplying drinking water to the residents of the District of Columbia. There is not a problem with lead in drinking water as it leaves the treatment plant; the problem arises when the water causes corrosion inside the lead service lines and in homes with lead in their plumbing.

Please visit our Web site at www.dcwasa.com or call our lead hot line at (202) 787-2732 to find out if you have a lead service line and the options for having it replaced.

We appreciate your participation in the Lead and Copper Tap Water Monitoring Program. WASA is committed to making continuous improvements in our service to District residents and businesses. We look forward to your continued support of our monitoring and testing programs.

If you have additional questions or concerns, please call **202 612-3440** DCWASA, Water Quality Division or write to DCWASA, Water Quality Division, 3900 Donaldson Pl. NW, Washington, D.C. 20016.

Sincerely,



Richard Giani
Manager, Water Quality Division

LETTER #4

Resident
Washington, DC, NE 20002

Dear Resident,

Thank you for participating in the Lead and Copper Tap Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DCWASA). The analysis of the samples collected during the monitoring period of July 2004 through December 2004, are now complete.

Participant selection was made according to Environmental Protection Agency guidelines. Each participant selected was required to collect and provide two samples of water to DCWASA, within the sampling period. These samples were collected to determine how faucet fixtures, household pipes, service lines and solder contribute to the lead and copper levels in tap water. First draw samples are required by EPA and are designed to determine lead levels originating from your fixtures and in-house plumbing, while second draw samples indicate concentrations coming from your service line (the line from the main to the house).

The monitoring tests reveal that the lead concentration of the tap water in your home is above the EPA action level. The EPA action level (AL) for lead in the drinking water is 15 parts per billion (ppb). However, test results of the copper samples collected from your home are below the EPA action level for copper of 1300 ppb. The test results for the samples collected from your home are as follows:

| Sample Site | QUADRANT | Concentration Of Lead in ppb | Concentration Of Copper in ppb |
|------------------|----------|------------------------------|--------------------------------|
| 909 HAMLIN ST | NE | 63ppb (1 st draw) | 107ppb (1 st draw) |
| | | 17ppb (2 nd draw) | 1ppb (2 nd draw) |
| EPA Action Level | | 15 ppb | 1300 ppb |

According to our records, your home has a lead service line. If this is not correct, please contact DCWASA at the telephone number listed below. DCWASA is currently working with EPA and the Washington Aqueduct to determine the cause of the elevated lead levels and to find a solution. Until a treatment can be found, DCWASA is recommending that you:

- **Use cold water for drinking or cooking, as hot water could contain higher levels of lead. Cold water should be heated on the stove for hot beverages or cooking.**
- **Draw water for drinking or cooking purposes immediately after another high water use activity, such as bathing or washing your clothes, so that a total of at least 10 minutes of flushing has occurred. (The large amount of water used will flush significant amounts of water, which might contain dissolved lead, from your home’s pipes.)**
- **Once flushing is complete, run the tap that you intend to use for drinking and cooking for another 60 seconds before use. It is highly recommended at this time to collect water in several clean containers and place them in your refrigerator for daily drinking and cooking purposes.**
- **Periodically, remove and clean the strainer/aerator device on your faucet to remove debris.**

Note: Boiling water does not reduce lead levels.

The DC Department of Health (DOH) has issued very specific advice to residents of the District that have been identified in WASA records as having a lead water service pipe or for which WASA records do not identify the material of the water service pipe. According to DOH, in homes which may have a lead service pipe, children under

six years and women who are pregnant or breast feeding should not drink unfiltered water or use it to prepare infant formula or concentrated juices until concerns regarding the lead levels in the water have been resolved.

The District of Columbia Department of Health (DC DOH) provides information on how to have children and pregnant women screened for blood lead levels. The DC DOH can be reached by calling (202) 535-2626 or by visiting its Web site www.dchealth.dc.gov If you have additional concerns about a child's health, please contact his or her pediatrician.

If you are flushing your water lines but still have concerns about lead, you may want to consider switching to bottled water or purchasing a treatment device. Be sure to purchase a treatment device certified by an independent testing organization, such as NSF International. Neither EPA nor WASA certifies or endorses home drinking water treatment devices. You can search the NSF International website for certified drinking water treatment units by visiting:

www.nsf.org/Certified/DWTU

Choose a treatment device (i.e. filtration pitchers or tap filters) that will be used after potentially lead-leaching plumbing components. These **devices must be installed, operated and maintained according to manufacturer instructions.**

DC WASA is responsible for supplying drinking water to the residents of the District of Columbia. There is not a problem with lead in drinking water as it leaves the treatment plant; the problem arises when the water causes corrosion inside the lead service lines and in homes with lead in their plumbing.

Please visit our Web site at www.dcwasa.com or call our lead hot line at (202) 787-2732 to find out if you have a lead service line and the options for having it replaced.

We appreciate your participation in the Lead and Copper Tap Water Monitoring Program. WASA is committed to making continuous improvements in our service to District residents and businesses. We look forward to your continued support of our monitoring and testing programs.

If you have additional questions or concerns, please call **202 612-3440** DCWASA, Water Quality Division or write to DCWASA, Water Quality Division, 3900 Donaldson Pl. NW, Washington, D.C. 20016.

Sincerely,



Richard Gian
Manager, Water Quality Division

Appendix C
Lead and Copper Monitoring Lists

Appendix C – Table 1
Lead and Copper
Routine Monitoring List for Jan – Jun 2005

| | First name | Last Name | Address | Quadrant | Pipe Material |
|----|----------------|------------|-------------------------|----------|---------------|
| 1 | CLARA | PARKS | 1008 MARYLAND AVE | NE | Lead |
| 2 | ROBERT | FAULKER | 1104 TRINIDAD AVE | NE | Lead |
| 3 | JENNIFER | POPOVIC | 1115 PARK ST | NE | Lead |
| 4 | BOZENA | CROUCH | 112 4TH ST. | SE | Lead |
| 5 | ERNEST | AGNEW | 1133 TRINIDAD AVE | NE | Lead |
| 6 | ROCHELLE | DORNATT | 119 16TH ST | NE | Lead |
| 7 | LESLIE | GRIFFIN | 1214 SHEPHERD ST. | NW | Lead |
| 8 | GENEVA | JONES | 1222 HAMILTON ST | NW | Lead |
| 9 | MIKE | KLUH | 1239 K ST. | SE | Lead |
| 10 | ED | REISKEN | 1240 D ST | SE | Lead |
| 11 | MS. | JOHNSON | 1262 COL RD | NW | Lead |
| 12 | EGLANTINA | LUCIO | 1319 POTOMAC AVE | SE | Unknown |
| 13 | TOM | HARDY | 1324 N. CAROLINA AVE | NE | Lead |
| 14 | WILBERT | FERGUSON | 1326 A ST | SE | Lead |
| 15 | DANIEL | MULLINS | 1326 NORTH CAROLINA AVE | NE | Lead |
| 16 | JACK | PIORKO | 1334 HEMLOCK ST. | NW | Lead |
| 17 | CAROL | GRISSON | 1338 A ST | SE | Lead |
| 18 | | | 1340 V ST. | SE | Unknown |
| 19 | RUTH | JOHNSON | 1400 FLORAL ST. | NW | Lead |
| 20 | NATALIE | HOPKINS | 1405 21ST. | NW | Lead |
| 21 | HENRY | WILLIAMS | 1419 SPRING RD | NW | Copper |
| 22 | IDA | JACKSON | 143 UHLAND TERRACE | NE | Unknown |
| 23 | MICHAEL | O'SULLIVAN | 1502 COLUMBIA RD | NW | Lead |
| 24 | ROBERT & STACY | KREGER | 1612 V ST | NW | Copper |
| 25 | VIETTA | DOWD | 1624C BEEKMAN PL | NW | Unknown |
| 26 | GREGORY | MOUNTS | 1626 19TH ST. | NW | Unknown |
| 27 | CASANDRA | SMTH | 1626 E ST. SE | SE | Lead |
| 28 | CARL | MODIG | 1635 WEBSTER ST. | NW | Lead |
| 29 | WILLIAM | GORDON | 1649 HARVARD ST | NW | Lead |
| 30 | B | DYE | 1701 INDEPENDENCE AVE | SE | Copper |
| 31 | MATTIE | McCOY | 1706 22ND ST. SE | SE | Lead |
| 32 | MARTIN | MOE | 1802 35TH ST | NW | Lead |
| 33 | GLEN | PARKER | 1803 MONROE ST | NW | Copper |
| 34 | DISTRICT | BAEHRENS | 1814 MONROE ST | NW | Copper |
| 35 | ROBERT | POHLMAN | 1815 MONROE ST | NW | Copper |
| 36 | F | HAGGARD | 1839 MONROE ST | NW | Copper |
| 37 | INORID | EVERS | 1843 MONROE ST | NW | Copper |
| 38 | LILIAN | BURGESS | 1850 2ND ST. | NW | Lead |
| 39 | ALBERTA | EDWARDS | 1863 MONROE ST | NW | Copper |
| 40 | RHONDA | HUDSON | 1929 SUMMIT PL. | NE | Lead |
| 41 | MICHAEL | GOULD | 1965 BILTMORE ST | NW | Lead |

| | First name | Last Name | Address | Quadrant | Pipe Material |
|----|------------|--------------|-----------------------|----------|---------------|
| 42 | STEVEN | CONWAY | 2002 37TH ST | NW | Lead |
| 43 | PETER | KLAPPERT | 2003 KLINGLE RD. | NW | Unknown |
| 44 | MEG | BUSSE | 2007 KLINGLE ST | NW | Unknown |
| 45 | WARREN | THOMAS | 2016 4TH ST | NE | Lead |
| 46 | BOSE | MONICA | 2017 BELMONT RD | NW | Lead |
| 47 | MONK | TOPPING | 202 11th St | SE | Lead |
| 48 | CRAIG | BENSON | 208 5TH ST | SE | Copper |
| 49 | | SIEGENTHALER | 2111 S ST. | NW | Lead |
| 50 | ROB | WARREN | 2208 12TH ST | NW | Unknown |
| 51 | LEAH | TAYLOR | 2237 CHESTER ST | SE | Unknown |
| 52 | ELIZABETH | EGGLESTON | 2238 HALL PL | NW | Lead |
| 53 | CHRIS | DIETRICH | 2702 P ST. | NW | Lead |
| 54 | OLIVIA | MORGAN | 2823 28TH ST | NW | Lead |
| 55 | LYNN | NYCE | 2858 28TH ST | NW | Lead |
| 56 | SEAN | KELLEY | 3 BROOKLEY AVE (BAFB) | SW | Unknown |
| 57 | ELYSA | GRAMAGLIA | 3030 44TH ST. | NW | Unknown |
| 58 | ALICE | PRATT | 311 ELM ST | NW | Lead |
| 59 | GEORGE | SCHWARLE | 3202 38TH ST | NW | Lead |
| 60 | JOHN | BUNTIN | 3218 MACOMB ST | NW | Unknown |
| 61 | DISTRICT | RESIDENT | 322 TENNESSEE AVE | NE | Lead |
| 62 | ROBERT | MATHIAS | 3250 HIGHLAND PL. | NW | Lead |
| 63 | CHARLES | REAMER | 3330 DENT PL | NW | Lead |
| 64 | STEPHANIE | DEMOSS | 3342 18TH ST | NW | Copper |
| 65 | ROSA | DAVENPORT | 3360 CLAY ST | NE | Lead |
| 66 | ALBERT | STURTEVANT | 3408 LOWELL ST | NW | Lead |
| 67 | FRANCIS | TOLAND | 3412 GARRISON ST | NW | Lead |
| 68 | ANTHONY | QUANTON | 3424 PORTER ST | NW | Lead |
| 69 | DOROTHY | LEVY | 3550 ALBEMARLE ST. | NW | Lead |
| 70 | JANICE | RAHIMI | 3601 WARREN ST. | NW | Lead |
| 71 | MARIE | ZUCKERMAN | 3628 S ST | NW | Lead |
| 72 | JANE | BERNOT | 3720 NORTHAMPTON ST | NW | Unknown |
| 73 | THOMAS | CROWDER | 3809 ALTON PL. | NW | Lead |
| 74 | LETITIA | GARDNER | 3815 JOCELYN ST. | NW | Unknown |
| 75 | GERALD | SMEENK | 3827 VEAZEY ST | NW | Lead |
| 76 | PHILIP | GIORDANO | 3835 BEECHER ST | NW | Lead |
| 77 | MARY | TUCKER | 3913 8TH ST | NW | Lead |
| 78 | MARY | WHITMAN | 3973 HARRISON ST | NW | Lead |
| 79 | MARY | FANT | 4011 13TH ST. | NW | Lead |
| 80 | ELIZABETH | WHITNEY | 406 9TH ST. | NE | Lead |
| 81 | JONATHON | MOORE | 4111 INGOMAR ST | NW | Unknown |
| 82 | XAVIER | LEGRAIN | 4131 YUMA ST | NW | Lead |
| 83 | ANTONIO | ESTEVEZ | 4230 FESSENDEN ST. | NW | Brass |
| 84 | RICHARD | ABBOTT | 4305 38TH ST | NW | Unknown |
| 85 | RICHARD | RIZIO | 4306 CHESAPEAKE ST | NW | Lead |

| | First name | Last Name | Address | Quadrant | Pipe Material |
|-----|----------------|--------------|---------------------|----------|---------------|
| 86 | | HEGY | 4307 CHESAPEAKE ST | NW | Lead |
| 87 | WILLIAM | DIAL | 4325 IOWA AVE | NW | Unknown |
| 88 | MARY | BUCKMAN | 4327 IOWA AVE | NW | Unknown |
| 89 | EMILY | ATTWELL | 4331 BRANDYWINE ST | NW | Lead |
| 90 | GEORGE | SELIM | 4332 BRANDYWINE ST | NW | Lead |
| 91 | ANNIE | GOMILLION | 440 3RD ST | NE | Unknown |
| 92 | KENNETH | EYE | 4401 5TH ST | NW | Lead |
| 93 | DEBORAH | BUTTERWORTH | 4413 GREENWICH PKWY | NW | Lead |
| 94 | RICHARDS | JEWETT | 4450 VOLTA PL. | NW | Lead |
| 95 | ROSA | DOUGLAS | 4507 13TH ST | NW | Copper |
| 96 | JACK | BOBO | 4622 15TH ST. | NW | Lead |
| 97 | ELLSTON | HOLMAN | 4818 8TH ST. | NW | Unknown |
| 98 | E. | JENKINS | 4818 ILLINOIS AVE | NW | Lead |
| 99 | JENIFER | POWELL | 4828 7TH ST | NW | Brass |
| 100 | MATTHEW | TUCHBAND | 4912 44TH ST | NW | Lead |
| 101 | ANGELA | CHRISTOPHER | 501 UPSHUR ST | NW | Lead |
| 102 | | KOSKELO | 5134 NEBRASKA AVE | NW | Lead |
| 103 | MARIA | NELSON | 5229 7TH ST | NW | Lead |
| 104 | JEAN | THOMAS | 5301 RENO RD. | NW | Lead |
| 105 | ANNIE | WILLIAMS | 5318 9TH ST | NW | Unknown |
| 106 | MAYA | PAABO | 5324 COLORADO AVE | NW | Lead |
| 107 | ALYSE | GRAHAM | 5404 39TH ST. | NW | Lead |
| 108 | DENIS | ANDRZEJEWSKI | 5405 39TH ST | NW | Lead |
| 109 | MR./MRS. | MINTZ | 5407 41ST ST | NW | Lead |
| 110 | DEBRA | KNAPP | 5717 SHERIER PL | NW | Lead |
| 111 | SMITH | PHYLLIS | 618 OTIS PL | NW | Lead |
| 112 | TANNA | MCDOWELL | 6213 7TH ST | NW | Lead |
| 113 | ANTONICE | WASHINGTON | 6413 KANSAS AVE. | NE | Brass |
| 114 | MURIEL | RAINES | 661 MARYLAND AVE | NE | Lead |
| 115 | DELORES | WASHINGTON | 712 JEFFERSON ST | NW | Unknown |
| 116 | JONATHAN | CARVER | 726 11TH ST | NW | Unknown |
| 117 | THERESA | JAYLER | 765 GIRARD ST | NW | Lead |
| 118 | AGNES | COLEMAN | 805 LONGFELLOW ST. | NW | Lead |
| 119 | MARY | WATTS | 817 DECATUR ST. | NW | Lead |
| 120 | VINCENT | CERRO | 833 DECATUR ST. | NW | Lead |
| 121 | LEROY | GIBSON | 909 HAMLIN ST | NE | Lead |
| 122 | PEGGY | HACKETT | 1016 DOUGLAS ST | NE | Lead |
| 123 | JOSH & HEATHER | EDELMAN | 349 TENNESSEE AVE | NE | Lead |
| 124 | MICHEAL | THOMAS | 3519 PORTER ST | NW | Lead |
| 125 | MICHAEL | SULLIVAN | 1812 14TH ST | SE | Lead |
| 126 | MATT | RIERZO | 2305 38TH ST | NW | Lead |
| 127 | TUNA | MECIT | 211 RANDOLPH PL | NE | Lead |
| 128 | MORVECKCA | MYRICK | 3009 7TH ST | SE | Lead |
| 129 | LILLIAN | JOWERS | 434 15TH ST | SE | Lead |

| | First name | Last Name | Address | Quadrant | Pipe Material |
|-----|--------------------------------|-----------|------------------------|----------|---------------|
| 130 | PAUL | BAKER | 2830 BRENTWOOD RD | NE | Lead |
| 131 | D | ISRAEL | 729 11ST | NE | Lead |
| 132 | ALAN | WEINTRAUT | 335 17TH PL | NE | Lead |
| 133 | SHARON | BROWN | 545 PARK RD | NW | Lead |
| 134 | KEVIN | BURNS | 2211 39TH ST | NW | Lead |
| 135 | R C & PHILIP F | CRONIN JR | 3618 PORTER ST | NW | Lead |
| 136 | SEYED N TESHANI ET AL | | 720 RHODE ISLAND AVE | NE | Lead |
| 137 | KIMBERLY | MOORE | 4616 HUNT PL | NE | Lead |
| 138 | DEBORAH | JOHNSON | 1145 OATES ST | NE | Lead |
| 139 | LATIN AMERICAN YOUTH CENTER | | 3035 15TH ST | NW | Lead |
| 140 | MEGAN | MADDEN | 312 14TH ST | NE | Lead |
| 141 | DAVID | KLAVITTER | 714 8TH ST | NE | Lead |
| 142 | JENNIFER | ANDBERG | 3908 13TH ST | NW | Lead |
| 143 | FORREST | MILLER | 331 RALEIGH ST | SE | Lead |
| 144 | MYRTLE | DANEWALIA | 1808 KEARNEY ST | NE | Lead |
| 145 | PETER | WILSON | 3301 BROWN St. | NW | Lead |
| 146 | TIMOTHY | FERRALL | 1420 S ST | SE | Lead |
| 147 | ROSE | COBBLER | 1424 S ST | SE | Lead |
| 148 | CARMEN | COMIN | 1341 Massachusetts Ave | SE | Lead |
| 149 | SHIRLEY | ROSEBORO | 3439 24ST | SE | Lead |
| 150 | JOSEPH | GRIFFITH | 2435 33RD ST | SE | Lead |
| 151 | KELLIE | CARROLL | 720 ALABAMA AVE | SE | Lead |
| 152 | DEWANA | HORTON | 2846 VISTA ST | NE | Lead |
| 153 | JAMES | YEAGER | 1746 KENYON ST | NW | Lead |
| 154 | MICHELLE | GREANIAS | 532 13TH ST | SE | Lead |
| 155 | DOROTHY | BALDWIN | 704 ALABAMA AVE | SE | Lead |
| 156 | TIA | BUTLER | 228 V ST | NE | Lead |
| 157 | DIANA | BERMUDEZ | 1226 D ST | NE | Lead |
| 158 | STACY | MILLER | 1250 FLORIDA AVE | NE | Lead |
| 159 | STEVE | POLITYKA | 2007 37TH ST | NW | Lead |
| 160 | | HALL | 608 Gallatin St | NW | Lead |
| 161 | GLYNN | LEWIS | 302 RITTENHOUSE ST | NW | Lead |
| 162 | MELODIE | KATE | 1241 JACKSON ST | NE | Lead |
| 163 | TODD | HAKEN | 835 3RD ST | NE | Lead |

All locations listed with a “Lead” service line are residential homes with full lead service lines according to DCWASA’s database.

Locations listed as “Unknown” or “brass” pipe material are homes that have previously exceeded second draw lead action levels in the past.

Homes listed with “Copper” pipe material are homes that have had partial lead service line replacement.

Appendix C - Table 2
Revised Lead and Copper Monitoring List for July – December 2005

| | Address | Quadrant | Pipe Material |
|----|-----------------------------|-----------|----------------|
| 1 | 1008 MARYLAND AVE | NE | Partial Copper |
| 2 | 1016 DOUGLAS ST | NE | Lead |
| 3 | 1104 TRINIDAD AVE | NE | Lead |
| 4 | 1110 45TH PL. | SE | Copper |
| 5 | 1115 PARK ST | NE | Partial Copper |
| 6 | 112 4TH ST. | SE | Lead |
| 7 | 1145 OATES ST | NE | Lead |
| 8 | 119 16TH ST | NE | Lead |
| 9 | 1214 SHEPHERD ST. | NW | Lead |
| 10 | 1222 HAMILTON ST | NW | Lead |
| 11 | 1226 D ST | NE | Lead |
| 12 | 1228 CARROLLSBURG PL | SW | Lead |
| 13 | 1240 D ST | SE | Lead |
| 14 | 1241 JACKSON ST | NE | Partial Copper |
| 15 | 1250 FLORIDA AVE | NE | Lead |
| 16 | 1262 COL RD | NW | Lead |
| 17 | 1319 21ST ST | NW | Lead |
| 18 | 1319 POTOMAC AVE | SE | Unknown |
| 19 | 1324 N. CAROLINA AVE | NE | Lead |
| 20 | 1326 A ST | SE | Partial Copper |
| 21 | 1326 NORTH CAROLINA AVE | NE | Full Copper |
| 22 | 1332 VERMONT AVE | NW | Lead |
| 23 | 1334 HEMLOCK ST. | NW | Lead |
| 24 | 1338 A ST | SE | Partial Copper |
| 25 | 1340 V ST. | SE | Unknown |
| 26 | 1341 Massachusetts Ave | SE | Partial Copper |
| 27 | 1353 JEFFERSON ST | NW | Lead |
| 28 | 1400 FLORAL ST. | NW | Lead |
| 29 | 1405 21ST. | NW | Lead |
| 30 | 1407 MONTAGUE ST | NW | Lead |
| 31 | 1419 SPRING RD | NW | Copper |
| 32 | 1420 S ST | SE | Lead |
| 33 | 1424 S ST | SE | Lead |
| 34 | 143 UHLAND TERRACE | NE | Unknown |
| 35 | 1451 S ST | NW | Lead |
| 36 | 1502 Columbia Rd | NW | Full Copper |

| | Address | Quadrant | Pipe Material |
|----|-------------------------|-----------|----------------|
| 37 | 1527 33RD ST | NW | Lead |
| 38 | 1612 V ST | NW | Copper |
| 39 | 1626 19TH ST. | NW | Unknown |
| 40 | 1626 E ST. SE | SE | Lead |
| 41 | 1635 WEBSTER ST. | NW | Lead |
| 42 | 1649 HARVARD ST | NW | Lead |
| 43 | 1701 INDEPENDENCE AVE | SE | Copper |
| 44 | 1746 KENYON ST | NW | Lead |
| 45 | 1802 35TH ST | NW | Lead |
| 46 | 1803 MONROE ST | NW | Full Copper |
| 47 | 1808 KEARNEY ST | NE | Lead |
| 48 | 1812 14TH ST | SE | Lead |
| 49 | 1814 MONROE ST | NW | Partial Copper |
| 50 | 1815 MONROE ST | NW | Partial Copper |
| 51 | 1825 L ST | NE | Lead |
| 52 | 1839 MONROE ST | NW | Partial Copper |
| 53 | 1843 MONROE ST | NW | Partial Copper |
| 54 | 1850 2ND ST. | NW | Lead |
| 55 | 1863 MONROE ST | NW | Partial Copper |
| 56 | 1929 SUMMIT PL | NE | Lead |
| 57 | 1931 SUMMIT PL. | NE | Lead |
| 58 | 1937 BILTMORE ST | NW | Lead |
| 59 | 1956 BILTMORE ST | NW | Lead |
| 60 | 1971 BILTMORE ST | NW | Lead |
| 61 | 2003 KLINGLE RD. | NW | Unknown |
| 62 | 2007 37TH ST | NW | Lead |
| 63 | 2007 KLINGLE ST | NW | Unknown |
| 64 | 2016 4TH ST | NE | Lead |
| 65 | 2017 BELMONT RD | NW | Lead |
| 66 | 202 11th St | SE | Lead |
| 67 | 205 TAYLOR ST. | NW | Partial Copper |
| 68 | 208 5TH ST | SE | Copper |
| 69 | 211 RANDOLPH PL | NE | Lead |
| 70 | 2111 S ST. | NW | Lead |
| 71 | 2134 NEWPORT PL | NW | Lead |
| 72 | 2136 NEWPORT PL | NW | Lead |
| 73 | 220 8TH ST | SE | Lead |

| | Address | Quadrant | Pipe Material |
|-----|----------------------------|-----------|----------------|
| 74 | 2208 12TH ST | NW | Unknown |
| 75 | 2211 39TH ST | NW | Lead |
| 76 | 2237 CHESTER ST | SE | Unknown |
| 77 | 2238 HALL PL | NW | Lead |
| 78 | 225 MISSISSIPPI AVE | SE | Lead |
| 79 | 228 V ST | NE | Lead |
| 80 | 2305 38TH ST | NW | Lead |
| 81 | 2418 3RD ST | NE | Lead |
| 82 | 2435 33RD ST | SE | Lead |
| 83 | 2448 HUIDEKOPER PL | NW | Lead |
| 84 | 2634 GEORGIA AVE | NW | Lead |
| 85 | 2702 P ST. | NW | Lead |
| 86 | 2823 28TH ST | NW | Lead |
| 87 | 2823 5TH ST | NE | Lead |
| 88 | 2830 BRENTWOOD RD | NE | Lead |
| 89 | 2846 VISTA ST | NE | Lead |
| 90 | 2858 28TH ST | NW | Lead |
| 91 | 3009 7TH ST | SE | Lead |
| 92 | 302 RITTENHOUSE ST | NW | Lead |
| 93 | 3030 44TH ST. | NW | Unknown |
| 94 | 3035 15TH ST | NW | Lead |
| 95 | 311 ELM ST | NW | Lead |
| 96 | 312 14TH ST | NE | Lead |
| 97 | 3202 38TH ST | NW | Lead |
| 98 | 3218 MACOMB ST | NW | Unknown |
| 99 | 3218 MORRISON ST | NW | Lead |
| 100 | 322 TENNESSEE AVE | NE | Lead |
| 101 | 3250 HIGHLAND PL. | NW | Partial Copper |
| 102 | 3301 BROWN St. | NW | Partial Copper |
| 103 | 331 RALEIGH ST | SE | Lead |
| 104 | 3342 18TH ST | NW | Full Copper |
| 105 | 335 17TH PL | NE | Lead |
| 106 | 3408 LOWELL ST | NW | Lead |
| 107 | 3412 GARRISON ST | NW | Lead |
| 108 | 3424 PORTER ST | NW | Lead |
| 109 | 3439 24ST | SE | Lead |
| 110 | 349 TENNESSEE AVE | NE | Lead |

| | Address | Quadrant | Pipe Material |
|-----|-----------------------|-----------|----------------|
| 111 | 3519 PORTER ST | NW | Lead |
| 112 | 3550 ALBEMARLE ST. | NW | Lead |
| 113 | 3601 WARREN ST. | NW | Lead |
| 114 | 3618 PORTER ST | NW | Lead |
| 115 | 3634 WARDER ST | NW | Lead |
| 116 | 3720 NORTHAMPTON ST | NW | Unknown |
| 117 | 3809 ALTON PL. | NW | Lead |
| 118 | 3815 JOCELYN ST. | NW | Unknown |
| 119 | 3827 VEAZEY ST | NW | Lead |
| 120 | 3835 BEECHER ST | NW | Lead |
| 121 | 3908 13TH ST | NW | Lead |
| 122 | 3913 8TH ST | NW | Partial Copper |
| 123 | 3973 HARRISON ST | NW | Lead |
| 124 | 406 9TH ST. | NE | Lead |
| 125 | 4111 INGOMAR ST | NW | Unknown |
| 126 | 4131 YUMA ST | NW | Lead |
| 127 | 4230 FESSENDEN ST. | NW | Brass |
| 128 | 4305 38TH ST | NW | Unknown |
| 129 | 4306 CHESAPEAKE ST | NW | Lead |
| 130 | 4307 CHESAPEAKE ST | NW | Lead |
| 131 | 4325 IOWA AVE | NW | Unknown |
| 132 | 4326 FOREST LN | NW | Lead |
| 133 | 4327 IOWA AVE | NW | Unknown |
| 134 | 4331 BRANDYWINE ST | NW | Lead |
| 135 | 4332 BRANDYWINE ST | NW | Lead |
| 136 | 434 15TH ST | SE | Lead |
| 137 | 440 3RD ST | NE | Unknown |
| 138 | 4401 5TH ST | NW | Lead |
| 139 | 4413 GREENWICH PKWY | NW | Lead |
| 140 | 4450 VOLTA PL. | NW | Lead |
| 141 | 4507 13TH ST | NW | Copper |
| 142 | 4518 14TH ST | NW | Lead |
| 143 | 4609 30TH ST | NW | Lead |
| 144 | 4616 HUNT PL | NE | Lead |
| 145 | 4622 15TH ST. | NW | Lead |
| 146 | 4818 8TH ST | NW | Lead |
| 147 | 4818 ILLINOIS AVE | NW | Lead |

| | Address | Quadrant | Pipe Material |
|-----|--------------------------|-----------|----------------|
| 148 | 4828 7TH ST | NW | Brass |
| 149 | 4912 44TH ST | NW | Lead |
| 150 | 501 UPSHUR ST | NW | Lead |
| 151 | 5121 ILLINOIS AVE | NW | Lead |
| 152 | 5134 NEBRASKA AVE | NW | Lead |
| 153 | 514 13th St | SE | Lead |
| 154 | 5229 7TH ST | NW | Lead |
| 155 | 5301 RENO RD. | NW | Lead |
| 156 | 5318 9TH ST | NW | Unknown |
| 157 | 532 13TH ST | SE | Lead |
| 158 | 5324 COLORADO AVE | NW | Lead |
| 159 | 5404 39TH ST. | NW | Lead |
| 160 | 5405 39TH ST | NW | Lead |
| 161 | 5407 41ST ST | NW | Full Copper |
| 162 | 545 PARK RD | NW | Lead |
| 163 | 5717 SHERIER PL | NW | Lead |
| 164 | 607 ATLANTIC ST | SE | Lead |
| 165 | 608 Gallatin St | NW | Lead |
| 166 | 618 OTIS PL | NW | Lead |
| 167 | 6213 7TH ST | NW | Partial Copper |
| 168 | 6413 KANSAS AVE. | NE | Brass |
| 169 | 661 MARYLAND AVE | NE | Partial Copper |
| 170 | 704 ALABAMA AVE | SE | Lead |
| 171 | 712 JEFFERSON ST | NW | Unknown |
| 172 | 714 8TH ST | NE | Lead |
| 173 | 720 ALABAMA AVE | SE | Lead |
| 174 | 720 PARK RD | NW | Lead |
| 175 | 720 RHODE ISLAND AVE | NE | Lead |
| 176 | 729 11TH ST | NE | Lead |
| 177 | 747 GIRARD ST | NW | Lead |
| 178 | 765 GIRARD ST | NW | Lead |
| 179 | 805 LONGFELLOW ST. | NW | Lead |
| 180 | 811 BUTTERNUT ST | NW | Lead |
| 181 | 817 DECATUR ST. | NW | Lead |
| 182 | 821 BUCHANAN ST | NW | Lead |
| 183 | 833 DECATUR ST. | NW | Lead |
| 184 | 835 3RD ST | NE | Lead |

| | Address | Quadrant | Pipe Material |
|-----|--------------------|-----------|---------------|
| 185 | 909 HAMLIN ST | NE | Lead |
| 186 | 926 14TH ST | SE | Lead |

The additional locations (bolded) were from the random computer generated list. Bottles were dropped off at these locations during the Jan – Jun 2005 monitoring period although approximately half of these residents did not participate during this semester.

Appendix C - Table 3.
Residents removed from the list due to owner request, or was recently determined by EPA as part of a consecutive system.

| | Address | Quadrant | Pipe Material | Notes |
|----|-----------------------|----------|---------------|----------------------|
| 1 | 1133 TRINIDAD AVE | NE | Lead | Stopped volunteering |
| 2 | 1239 K ST. | SE | Lead | Stopped volunteering |
| 3 | 1305 E CAPITOL ST | SE | Lead | Stopped volunteering |
| 4 | 1334 A ST | SE | Full Copper | Stopped volunteering |
| 5 | 1624 C BEEKMAN PL | NW | Unknown | Stopped volunteering |
| 6 | 1706 22ND ST. | SE | Lead | Stopped volunteering |
| 7 | 1826 VARNUM ST | NW | Lead | Stopped volunteering |
| 8 | 2002 37TH ST | NW | Lead | Stopped volunteering |
| 9 | 317 A ST. | SE | Lead | Stopped volunteering |
| 10 | 3330 DENT PL | NW | Lead | Stopped volunteering |
| 11 | 3360 CLAY ST | NE | Lead | Stopped volunteering |
| 12 | 3628 S ST | NW | Lead | Stopped volunteering |
| 13 | 4011 13TH ST. | NW | Lead | Stopped volunteering |
| 14 | 726 11TH ST | NW | Unknown | Stopped volunteering |
| 15 | 751 NEWTON PL | NW | Lead | Stopped volunteering |
| 16 | 3 BROOKLEY AVE (BAFB) | SW | Unknown | Consecutive System |

Section 7
Chain of Custody for the 3 samples invalidated
by EPA letter dated, January 5, 2006



NO GOOD

| CUSTOMER INFORMATION | LABORATORY USE ONLY |
|--------------------------------------|---|
| Name: <u>MICHAEL O'SULLIVAN</u> | Sample ID# _____ |
| Address: <u>1502 COLUMBIA RD. NW</u> | Flush Sample ID# _____ |
| City: <u>WASHINGTON DC 20009</u> | Sample Type: <u>D</u> System: <u>WASA FC AC</u> |
| Telephone #: <u>202-667-5443</u> | Date/Time/Received By: <u>11/1/05 bmr</u> |

- PLEASE VERIFY THE FOLLOWING AND MARK THE APPROPRIATE BOX:
- Was your home built before 1986? YES NO
 - Have there been any major plumbing changes within the premises after 1986? YES NO
 - ARE THERE ANY LEAKING PLUMBING, FAUCETS OR TOILETS? YES NO OTHER _____
 - IS YOUR ICE MAKER OFF? YES NO
 - IS YOUR HUMIDIFIER OFF? YES NO
 - ARE YOUR BASEBOARD/RADIATOR HEATING SYSTEMS OFF? YES NO
 - WAS THERE ANY OTHER HOUSEHOLD USAGE DURING 6-8 HR. PERIOD? YES NO
 - SPRINKLER SYSTEM OFF? YES NO
 - DO YOU HAVE A WATER TREATMENT UNIT OR FILTER ATTACHED TO YOUR PLUMBING SYSTEM OR FAUCET? YES NO
 - IF YES, WHAT TYPE OF TREATMENT _____
 - IF YES, WAS IT BYPASSED BEFORE SAMPLING? YES NO

Full copper - a 1/2 pipe replaced
 LS Replaced by WASA
 -also did a lead profile

PLEASE COMPLETE:

Water last used: Date: 10/25/2005 Time: 10 PM

1st Draw Sample collection: Date: 10/26/2005 Time: 7:50 AM

2nd Draw Sample collection: Date: 10/26/2005 Time: 7:50 AM

I have read the above directions and taken both tap samples in accordance with these directions.

Signature: Michael O'Sullivan Date: 10/26/2005

SAMPLE PICK-UP DATE October 26, 2005

IF YOU HAVE ANY QUESTIONS REGARDING THESE INSTRUCTIONS CALL (202) 612-3440 OR Email us at WQP2003@DCWASA.COM OR WRITE TO D.C. WATER AND SEWER AUTHORITY - DEPARTMENT OF WATER SERVICES, WATER QUALITY DIVISION, 3900 DONALDSON PLACE, NW, WASHINGTON, D.C. 20016.



| CUSTOMER INFORMATION | LABORATORY USE ONLY |
|--------------------------------------|--|
| Name: <u>MICHAEL O'SULLIVAN</u> | Sample ID# <u>0507268 025026</u> |
| Address: <u>1502 COLUMBIA RD. NW</u> | Flush Sample ID# _____ |
| City: <u>WASHINGTON DC 20009</u> | Sample Type: <u>D</u> System <u>WASA</u> FC AC |
| Telephone # <u>202-667-5443</u> | Date/Time/Received By: <u>7-29-05/1405/MS</u> |

PLEASE VERIFY THE FOLLOWING AND MARK THE APPROPRIATE BOX:

- ARE THERE ANY LEAKING FAUCETS OR TOILETS? YES NO OTHER _____
- IS YOUR ICE MAKER OFF? YES NO
- IS YOUR HUMIDIFIER OFF? YES NO
- ARE YOUR BASEBOARD/RADIATOR HEATING SYSTEMS OFF? YES NO
- WAS THERE ANY OTHER HOUSEHOLD USAGE DURING 6-8 HR. PERIOD? YES NO
- SPRINKLER SYSTEM OFF? YES NO
- DO YOU HAVE A WATER TREATMENT UNIT OR FILTER ATTACHED TO YOUR PLUMBING SYSTEM OR FAUCET? YES NO
 - o IF YES, WHAT TYPE OF TREATMENT _____
 - o IF YES, WAS IT BYPASSED BEFORE SAMPLING? YES NO

PLEASE COMPLETE:

Water last used: Date: 7/26/05 Time: 11:30 PM
 1st Draw Sample collection: Date: 7/27/05 Time: 8:25 AM
 2nd Draw Sample collection: Date: 7/27/05 Time: 8:27 PM

I have read the above directions and taken both tap samples in accordance with these directions.

Signature: Michael O'Sullivan Date: 7/27/05

SAMPLE PICK-UP DATE: WEDNESDAY JULY 27, 2005 _____

IF YOU HAVE ANY QUESTIONS REGARDING THESE INSTRUCTIONS CALL (202) 612-3440 OR Email us at WQP2003@DCWASA.COM OR WRITE TO D.C. WATER AND SEWER AUTHORITY - DEPARTMENT OF WATER SERVICES, WATER QUALITY DIVISION, 3900 DONALDSON PLACE, NW, WASHINGTON, D.C. 20016.

✓ No-boil - Resampling



| CUSTOMER INFORMATION | LABORATORY USE ONLY |
|-----------------------------------|---|
| Name <u>YEAGER James</u> | Sample ID# _____ |
| Address <u>1746 Kenyon St. NW</u> | Flush Sample ID# _____ |
| City <u>Washington, DC 20010</u> | Sample Type: <u>D</u> System: <u>WASA FC AC</u> |
| Telephone # <u>202-387-0230</u> | Date/Time/Received By: <u>hmm u/llos</u> |

PLEASE VERIFY THE FOLLOWING AND MARK THE APPROPRIATE BOX:

- Was your home built before 1986? YES NO
- Have there been any major plumbing changes within the premises after 1986? YES NO
- ARE THERE ANY LEAKING PLUMBING, FAUCETS OR TOILETS? YES NO OTHER _____
- IS YOUR ICE MAKER OFF? YES NO
- IS YOUR HUMIDIFIER OFF? YES NO
- ARE YOUR BASEBOARD/RADIATOR HEATING SYSTEMS OFF? YES NO
- WAS THERE ANY OTHER HOUSEHOLD USAGE DURING 8-8 HR. PERIOD? YES NO
- SPRINKLER SYSTEM OFF? YES NO
- DO YOU HAVE A WATER TREATMENT UNIT OR FILTER ATTACHED TO YOUR PLUMBING SYSTEM OR FAUCET? YES NO
 - IF YES, WHAT TYPE OF TREATMENT Genesis Water Filter System
 - IF YES, WAS IT BYPASSED BEFORE SAMPLING? YES NO

PLEASE COMPLETE:

Water last used: Date: 26 Oct 05 Time: 8:15pm
 1st Draw Sample collection: Date: 27 Oct 05 Time: 5:15am
 2nd Draw Sample collection: Date: 27 Oct 05 Time: 5:18am

I have read the above directions and taken both tap samples in accordance with these directions.

Signature: [Signature] (James Yeager) Date: Oct. 27, 05

SAMPLE PICK-UP DATE October 26, 2005

IF YOU HAVE ANY QUESTIONS REGARDING THESE INSTRUCTIONS CALL (202) 612-3440 OR Email us at WQP2003@DCWASA.COM OR WRITE TO D.C. WATER AND SEWER AUTHORITY - DEPARTMENT OF WATER SERVICES, WATER QUALITY DIVISION, 3900 DONALDSON PLACE, NW, WASHINGTON, D.C. 20016.



| CUSTOMER INFORMATION | LABORATORY USE ONLY |
|----------------------------------|---|
| Name <u>JAMES YEAGER</u> | Sample ID# _____ |
| Address <u>1746 KENYON ST NW</u> | Flush Sample ID# _____ |
| City <u>WASHINGTON DC 20010</u> | Sample Type: <u>D</u> System: <u>WASA FC AC</u> |
| Telephone # <u>202-787-1986</u> | Date/Time/Received By: <u>Sukam</u> <u>12/02/05</u> <u>11:45</u> |

PLEASE VERIFY THE FOLLOWING AND MARK THE APPROPRIATE BOX:

- Was your home built before 1986? YES NO
- Have there been any major plumbing changes within the premises after 1986? YES NO
- ARE THERE ANY LEAKING PLUMBING, FAUCETS OR TOILETS? YES NO OTHER _____
- IS YOUR ICE MAKER OFF? YES NO
- IS YOUR HUMIDIFIER OFF? YES NO
- ARE YOUR BASEBOARD/RADIATOR HEATING SYSTEMS OFF? YES NO
- WAS THERE ANY OTHER HOUSEHOLD USAGE DURING 6-8 HR. PERIOD? YES NO
- SPRINKLER SYSTEM OFF? YES NO
- DO YOU HAVE A WATER TREATMENT UNIT OR FILTER ATTACHED TO YOUR PLUMBING SYSTEM OR FAUCET? YES NO
 - IF YES, WHAT TYPE OF TREATMENT GENESIS WATER FILTER
 - IF YES, WAS IT BYPASSED BEFORE SAMPLING? YES NO

PLEASE COMPLETE:

Water last used: Date: 1 DEC Time: 10 pm
 1st Draw Sample collection: Date: 02 DEC Time: 6 am
 2nd Draw Sample collection: Date: 02 DEC Time: 6 am

I have read the above directions and taken both tap samples in accordance with these directions.

Signature: [Signature] Date: 02 DEC 2005

SAMPLE PICK-UP DATE: December 1, 2005

IF YOU HAVE ANY QUESTIONS REGARDING THESE INSTRUCTIONS CALL (202) 812-3440 OR Email us at WQP2003@DCWASA.COM OR WRITE TO D.C. WATER AND SEWER AUTHORITY - DEPARTMENT OF WATER SERVICES, WATER QUALITY DIVISION, 3900 DONALDSON PLACE, NW, WASHINGTON, D.C. 20018.