



## FOR RESIDENTIAL WALK-THROUGH SUBMISSIONS

Effective February 1, 2017, DC Water is reducing the effort and review time needed to review and approve a residential alteration/repair, DC Water will evaluate the impact of the proposed water fixtures on the existing service and if minor the complete meter sizing form will not be required.

Follow the instructions below:

- 1) Submit just the WSFU worksheet showing just the additional and deleted fixtures, and the service size.
- 2) If the proposed additional WSFU value is within the ranges indicated below the existing meter and service may be reused at your discretion.

Existing service line size	Additional WSFU that may be installed w/o needing a meter sizing form
5/8 inch	Up to 3.6
3/4 inch	Up to 5.5
1 inch	Up to 11
1 1/2 inch	Up to 25
2 inch	Up to 35

- 3) If the sum of the new WSFU is greater than the ranges above a complete meter sizing form will be required.
- 4) The designer of record (person signing the plan or a registered plumber) must sign any submitted forms. The homeowner or expediter may execute this form if a sealed plan sheet showing existing and proposed fittings (i.e. a riser diagram or other) accompanies it.

### Notes:

- 1) Approval of this form by DC Water for reuse is not a validation that the existing service will be adequate. It is only concurrence that the proposed fixtures should not greatly diminish the current level of service and therefore may not warrant upgrading the service.