



Lead and Copper Compliance Report January through June 2013

Table 1 summarizes the District of Columbia Water and Sewer Authority’s (DC Water) Lead and Copper compliance results for the monitoring period January through June 2013.

Table 1. Lead and Copper Summary Data

Number of Samples	
Lead and Copper	110
90th Percentile First Draw Concentrations	
Lead mg/L	0.004
Copper mg/L	0.094
Service Line Materials	
Full Lead	70%
Partial Lead	30%

The appendices and attachments contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
 - Table A.1 First Draw Lead Results
 - Table A.2 First Draw Copper Results

- Appendix B: Additional Monitoring Data
 - Table B.1 Second Draw Lead Results
 - Table B.2 Second Draw Copper Results

- Appendix C: Additional Sampling Information
 - Table C.1 Sample Kit Distribution
 - Table C.2 Sample Kits Not Returned
 - Table C.3 Samples Returned and Rejected for Compliance Analysis
 - Table C.4 Deviations from Sample Order
 - Table C.5 Sites with Compliance Results from January 2012 – December 2012 and No Results in January - June 2013

- Appendix D: Revisions to Sample Pool
 - Table D.1 Sample Pool for July to December 2013 Monitoring Period
 - Table D.2 Site Changes - Sites Removed, Added, or Priority Status Changed
- Attachment 1: Washington Aqueduct Test Results for LCR Compliance
- Attachment 2: Other Additional Monitoring Data:
 - Customer requested tests
 - Post-LSR
 - Lead profiles
 - Other Research
- Attachment 3: Certification of Consumer Tap Results for January – June 2013

Appendix A: Lead and Copper Compliance Data

Table A.1 First Draw Lead Results

No.	Address	Pipe Material	Collection Date	Lead 1st Draw (mg/L)
1	1203 Quincy St NW	Partial Lead	3/27/2013	0.0000
2	1318 Wallach Pl NW	Lead	1/30/2013	0.0000
3	1319 POTOMAC AVE SE	Partial Lead	3/26/2013	0.0000
4	1357 C St NE	Lead	1/30/2013	0.0000
5	1453 S St NW	Lead	6/13/2013	0.0000
6	15 Milmarson Pl NW	Lead	1/30/2013	0.0000
7	1603 Massachusetts Ave SE	Partial Lead	3/26/2013	0.0000
8	1635 WEBSTER ST NW	Lead	1/31/2013	0.0000
9	1706 NEW JERSEY AVE NW	Lead	1/29/2013	0.0000
10	1736 Bay St SE	Partial Lead	3/27/2013	0.0000
11	2007 37TH ST NW	Lead	1/30/2013	0.0000
12	213 49th St NE	Lead	1/30/2013	0.0000
13	24 Evarts St NE	Lead	4/25/2013	0.0000
14	2923 Cathedral AVE NW	Lead	6/13/2013	0.0000
15	3036 P St NW	Partial Lead	3/27/2013	0.0000
16	307 7th St NE	Lead	1/30/2013	0.0000
17	317 9th St SE	Lead	1/29/2013	0.0000
18	3215 Mckinley St NW	Partial Lead	4/24/2013	0.0000
19	3361 Stuyvesant Pl NW	Lead	4/23/2013	0.0000
20	3416 9th St NE	Partial Lead	4/24/2013	0.0000
21	3533 W Pl NW	Lead	2/28/2013	0.0000
22	36 Florida Ave NW	Lead	3/28/2013	0.0000
23	3809 ALTON Pl NW	Partial Lead	4/25/2013	0.0000
24	4120 Grant St NE	Lead	2/27/2013	0.0000
25	413 4th St SE	Partial Lead	4/24/2013	0.0000
26	4332 BRANDYWINE ST NW	Partial Lead	4/24/2013	0.0000
27	449 S St NW	Lead	6/13/2013	0.0000
28	4926 Glenbrook Rd NW	Lead	2/27/2013	0.0000
29	53 P St NW	Partial Lead	5/21/2013	0.0000
30	580 49th Pl NE	Lead	2/27/2013	0.0000
31	6105 Dix St NE	Lead	3/28/2013	0.0000
32	617 6th St NE	Lead	3/27/2013	0.0000
33	619 12th St NE	Lead	3/26/2013	0.0000
34	75 Bates St NW	Lead	3/26/2013	0.0000
35	834 Delafield Pl NW	Lead	3/27/2013	0.0000
36	905 Kent Pl NE	Lead	3/27/2013	0.0000
37	1353 JEFFERSON ST NW	Partial Lead	3/26/2013	0.0005

No.	Address	Pipe Material	Collection Date	Lead 1st Draw (mg/L)
38	5517 7th St NW	Lead	2/27/2013	0.0005
39	1620 Webster St NW	Lead	1/29/2013	0.0006
40	1826 Jackson St NE	Lead	1/29/2013	0.0006
41	308 9th St SE	Partial Lead	5/20/2013	0.0006
42	333 34th St NE	Partial Lead	4/24/2013	0.0006
43	1424 S ST NW	Lead	2/9/2013	0.0007
44	1613 Webster St NW	Lead	2/27/2013	0.0007
45	3206 38th St NW	Lead	1/30/2013	0.0007
46	3908 13TH ST NW	Lead	6/11/2013	0.0007
47	605 Columbia Rd NW	Partial Lead	4/22/2013	0.0007
48	6210 8th St NW	Lead	3/27/2013	0.0007
49	804 Delafield PI NW	Lead	4/24/2013	0.0007
50	331 RALEIGH ST SE	Lead	2/26/2013	0.0008
51	3601 WARREN ST NW	Lead	2/26/2013	0.0008
52	3625 Albermarle St NW	Lead	6/6/2013	0.0008
53	3917 8th St NW	Partial Lead	4/24/2013	0.0008
54	4627 49th St NW	Lead	2/27/2013	0.0008
55	5301 RENO RD NW	Partial Lead	6/12/2013	0.0008
56	1003 Quebec PI NW	Lead	4/23/2013	0.0009
57	3710 Huntington St NW	Lead	2/27/2013	0.0009
58	424 Luray PI NW	Lead	6/13/2013	0.0009
59	4310 37th St NW	Lead	2/26/2013	0.0009
60	4818 8th ST NW	Partial Lead	4/23/2013	0.0009
61	2408 2nd St NE	Partial Lead	5/21/2013	0.0010
62	2913 Brandywine St NW	Lead	1/30/2013	0.0010
63	336 Quackenbos St NE	Lead	2/28/2013	0.0010
64	5226 7th St NW	Lead	2/27/2013	0.0010
65	5404 39TH ST NW	Partial Lead	4/22/2013	0.0010
66	6001 33rd St NW	Lead	2/27/2013	0.0010
67	1222 HAMILTON ST NW	Partial Lead	6/11/2013	0.0011
68	2212 38th St NW	Lead	1/31/2013	0.0011
69	228 V ST NE	Lead	1/29/2013	0.0011
70	302 RITTENHOUSE ST NW	Partial Lead	3/28/2013	0.0011
71	5923 33rd St NW	Lead	2/28/2013	0.0011
72	780 Fairmont St NW	Partial Lead	4/22/2013	0.0011
73	10 S St NW	Lead	1/31/2013	0.0012
74	4131 YUMA ST NW	Lead	6/12/2013	0.0012
75	531 Tennessee Ave NE	Lead	2/25/2013	0.0012
76	605 ROCK CRK CHURCH RD NW	Partial Lead	6/18/2013	0.0012
77	3211 Central Ave NE	Lead	1/29/2013	0.0013
78	1519 Olive St NE	Lead	1/31/2013	0.0014

No.	Address	Pipe Material	Collection Date	Lead 1st Draw (mg/L)
79	617 M St NE	Partial Lead	4/24/2013	0.0014
80	807 Buchanan St NW	Lead	3/27/2013	0.0014
81	3218 MACOMB ST NW	Lead	1/31/2013	0.0015
82	2830 BRENTWOOD RD NE	Lead	1/29/2013	0.0016
83	4307 CHESAPEAKE ST NW	Lead	2/28/2013	0.0016
84	4418 14th St NE	Lead	2/27/2013	0.0016
85	1808 KEARNEY ST NE	Partial Lead	3/27/2013	0.0017
86	1703 D St NE	Lead	1/28/2013	0.0018
87	3907 13th St NW	Partial Lead	4/29/2013	0.0019
88	4215 39th St NW	Partial Lead	6/4/2013	0.0019
89	8 N St SW	Lead	6/11/2013	0.0019
90	87 S St NW	Lead	6/14/2013	0.0020
91	641 Gallatin St NW	Lead	3/28/2013	0.0021
92	702 9th St SE	Lead	6/12/2013	0.0022
93	1211 Carrollsburg Pl SW	Partial Lead	3/27/2013	0.0023
94	4401 5TH ST NW	Lead	2/26/2013	0.0024
95	912 Emerson St NW	Lead	6/12/2013	0.0024
96	1412 Shepherd St NW	Partial Lead	5/22/2013	0.0030
97	1378 Taylor St NW	Lead	1/30/2013	0.0031
98	3727 T St NW	Lead	2/27/2013	0.0032
99	4703 Macarthur Blvd NW	Lead	2/27/2013	0.0038
100	5234 Illinois Ave NW	Lead	2/26/2013	0.0038
101	4550 30TH ST NW	Lead	2/27/2013	0.0039
102	230 G St NE	Partial Lead	3/28/2013	0.0044
103	125 Madison St NW	Lead	6/11/2013	0.0050
104	2107 2nd St NE	Lead	6/10/2013	0.0052
105	1649 HARVARD ST NW	Lead	6/12/2013	0.0061
106	53 V St NW	Partial Lead	6/13/2013	0.0078
107	223 14th Pl NE	Partial Lead	3/25/2013	0.0105
108	109 19th St SE	Lead	6/9/2013	0.0111
109	4824 46th St NW	Lead	2/27/2013	0.0228
110	1505 Buchanan St NW	Lead	1/30/2013	0.0370

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.0000" may have been reported by the laboratory as non-detect or < 0.0005 mg/L.

Table A.2 First Draw Copper Results

No.	Address	Pipe Material	Collection Date	Copper 1st Draw (mg/L)
1	1357 C St NE	Lead	1/30/2013	0.000
2	3416 9th St NE	Partial Lead	4/24/2013	0.002
3	213 49th St NE	Lead	1/30/2013	0.003
4	807 Buchanan St NW	Lead	3/27/2013	0.003
5	1826 Jackson St NE	Lead	1/29/2013	0.004
6	5226 7th St NW	Lead	2/27/2013	0.004
7	580 49th PI NE	Lead	2/27/2013	0.004
8	6210 8th St NW	Lead	3/27/2013	0.004
9	912 Emerson St NW	Lead	6/12/2013	0.004
10	10 S St NW	Lead	1/31/2013	0.006
11	308 9th St SE	Partial Lead	5/20/2013	0.006
12	3533 W PI NW	Lead	2/28/2013	0.006
13	53 P St NW	Partial Lead	5/21/2013	0.006
14	1519 Olive St NE	Lead	1/31/2013	0.007
15	1603 Massachusetts Ave SE	Partial Lead	3/26/2013	0.007
16	4120 Grant St NE	Lead	2/27/2013	0.009
17	2107 2nd St NE	Lead	6/10/2013	0.010
18	4824 46th St NW	Lead	2/27/2013	0.010
19	702 9th St SE	Lead	6/12/2013	0.010
20	1412 Shepherd St NW	Partial Lead	5/22/2013	0.012
21	617 6th St NE	Lead	3/27/2013	0.012
22	619 12th St NE	Lead	3/26/2013	0.012
23	905 Kent PI NE	Lead	3/27/2013	0.012
24	1635 WEBSTER ST NW	Lead	1/31/2013	0.014
25	1222 HAMILTON ST NW	Partial Lead	6/11/2013	0.016
26	2830 BRENTWOOD RD NE	Lead	1/29/2013	0.016
27	302 RITTENHOUSE ST NW	Partial Lead	3/28/2013	0.016
28	531 Tennessee Ave NE	Lead	2/25/2013	0.016
29	804 Delafield PI NW	Lead	4/24/2013	0.016
30	1203 Quincy St NW	Partial Lead	3/27/2013	0.017
31	5517 7th St NW	Lead	2/27/2013	0.017
32	3908 13TH ST NW	Lead	6/11/2013	0.018
33	641 Gallatin St NW	Lead	3/28/2013	0.018
34	1378 Taylor St NW	Lead	1/30/2013	0.019
35	331 RALEIGH ST SE	Lead	2/26/2013	0.019
36	3710 Huntington St NW	Lead	2/27/2013	0.019
37	5234 Illinois Ave NW	Lead	2/26/2013	0.019
38	6001 33rd St NW	Lead	2/27/2013	0.019
39	75 Bates St NW	Lead	3/26/2013	0.019

No.	Address	Pipe Material	Collection Date	Copper 1st Draw (mg/L)
40	125 Madison St NW	Lead	6/11/2013	0.020
41	1706 NEW JERSEY AVE NW	Lead	1/29/2013	0.021
42	424 Luray Pl NW	Lead	6/13/2013	0.021
43	780 Fairmont St NW	Partial Lead	4/22/2013	0.021
44	2923 Cathedral AVE NW	Lead	6/13/2013	0.022
45	336 Quackenbos St NE	Lead	2/28/2013	0.023
46	4131 YUMA ST NW	Lead	6/12/2013	0.023
47	6105 Dix St NE	Lead	3/28/2013	0.024
48	3809 ALTON PL NW	Partial Lead	4/25/2013	0.025
49	1703 D St NE	Lead	1/28/2013	0.026
50	228 V ST NE	Lead	1/29/2013	0.026
51	3206 38th St NW	Lead	1/30/2013	0.026
52	4926 Glenbrook Rd NW	Lead	2/27/2013	0.027
53	1319 POTOMAC AVE SE	Partial Lead	3/26/2013	0.028
54	4310 37th St NW	Lead	2/26/2013	0.028
55	5404 39TH ST NW	Partial Lead	4/22/2013	0.028
56	307 7th St NE	Lead	1/30/2013	0.029
57	333 34th St NE	Partial Lead	4/24/2013	0.029
58	4550 30TH ST NW	Lead	2/27/2013	0.030
59	2913 Brandywine St NW	Lead	1/30/2013	0.031
60	1649 HARVARD ST NW	Lead	6/12/2013	0.032
61	2408 2nd St NE	Partial Lead	5/21/2013	0.032
62	4818 8th ST NW	Partial Lead	4/23/2013	0.033
63	2212 38th St NW	Lead	1/31/2013	0.036
64	1318 Wallach Pl NW	Lead	1/30/2013	0.037
65	3601 WARREN ST NW	Lead	2/26/2013	0.037
66	5301 RENO RD NW	Partial Lead	6/12/2013	0.038
67	230 G St NE	Partial Lead	3/28/2013	0.040
68	617 M St NE	Partial Lead	4/24/2013	0.040
69	53 V St NW	Partial Lead	6/13/2013	0.041
70	413 4th St SE	Partial Lead	4/24/2013	0.042
71	87 S St NW	Lead	6/14/2013	0.047
72	1424 S ST NW	Lead	2/9/2013	0.048
73	3625 Albermarle St NW	Lead	6/6/2013	0.048
74	4627 49th St NW	Lead	2/27/2013	0.049
75	834 Delafield Pl NW	Lead	3/27/2013	0.049
76	1620 Webster St NW	Lead	1/29/2013	0.050
77	4307 CHESAPEAKE ST NW	Lead	2/28/2013	0.050
78	449 S St NW	Lead	6/13/2013	0.050
79	4215 39th St NW	Partial Lead	6/4/2013	0.051
80	605 ROCK CRK CHURCH RD NW	Partial Lead	6/18/2013	0.051

No.	Address	Pipe Material	Collection Date	Copper 1st Draw (mg/L)
81	24 Evarts St NE	Lead	4/25/2013	0.052
82	4418 14th St NE	Lead	2/27/2013	0.060
83	109 19th St SE	Lead	6/9/2013	0.061
84	1453 S St NW	Lead	6/13/2013	0.061
85	317 9th St SE	Lead	1/29/2013	0.062
86	3218 MACOMB ST NW	Lead	1/31/2013	0.063
87	4332 BRANDYWINE ST NW	Partial Lead	4/24/2013	0.064
88	3036 P St NW	Partial Lead	3/27/2013	0.066
89	1353 JEFFERSON ST NW	Partial Lead	3/26/2013	0.070
90	1613 Webster St NW	Lead	2/27/2013	0.076
91	3211 Central Ave NE	Lead	1/29/2013	0.077
92	3727 T St NW	Lead	2/27/2013	0.078
93	4401 5TH ST NW	Lead	2/26/2013	0.080
94	8 N St SW	Lead	6/11/2013	0.080
95	2007 37TH ST NW	Lead	1/30/2013	0.081
96	1003 Quebec Pl NW	Lead	4/23/2013	0.086
97	15 Milmarson Pl NW	Lead	1/30/2013	0.086
98	1808 KEARNEY ST NE	Partial Lead	3/27/2013	0.089
99	3917 8th St NW	Partial Lead	4/24/2013	0.094
100	36 Florida Ave NW	Lead	3/28/2013	0.095
101	3361 Stuyvesant Pl NW	Lead	4/23/2013	0.098
102	1505 Buchanan St NW	Lead	1/30/2013	0.104
103	1211 Carrollsburg Pl SW	Partial Lead	3/27/2013	0.111
104	3215 Mckinley St NW	Partial Lead	4/24/2013	0.116
105	605 Columbia Rd NW	Partial Lead	4/22/2013	0.122
106	4703 Macarthur Blvd NW	Lead	2/27/2013	0.129
107	223 14th Pl NE	Partial Lead	3/25/2013	0.140
108	5923 33rd St NW	Lead	2/28/2013	0.140
109	1736 Bay St SE	Partial Lead	3/27/2013	0.141
110	3907 13th St NW	Partial Lead	4/29/2013	0.146

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.000" may have been reported by the laboratory as non-detect or < 0.001 mg/L.

Appendix B: Additional Monitoring Data

Tables B.1 and B.2 present results from the second draw samples collected at the time of the Lead and Copper Rule compliance sampling. Additional monitoring data presented in Attachment 2 to this report contains sample data collected from other DC Water programs that focused on lead, copper, or other metals that included lead sample results. A description of the program followed by the data set is included in Attachment 2.

Table B.1 Second Draw Lead Results

No.	Address	Pipe Material	Collection Date	Lead 2nd Draw (mg/L)
1	1203 Quincy St NW	Partial Lead	3/27/2013	0.0000
2	1318 Wallach Pl NW	Lead	1/30/2013	0.0000
3	1319 POTOMAC AVE SE	Partial Lead	3/26/2013	0.0000
4	1357 C St NE	Lead	1/30/2013	0.0000
5	1453 S St NW	Lead	6/13/2013	0.0000
6	15 Milmarson Pl NW	Lead	1/30/2013	0.0000
7	1603 Massachusetts Ave SE	Partial Lead	3/26/2013	0.0000
8	1613 Webster St NW	Lead	2/27/2013	0.0000
9	1620 Webster St NW	Lead	1/29/2013	0.0000
10	1706 NEW JERSEY AVE NW	Lead	1/29/2013	0.0000
11	1736 Bay St SE	Partial Lead	3/27/2013	0.0000
12	2007 37TH ST NW	Lead	1/30/2013	0.0000
13	213 49th St NE	Lead	1/30/2013	0.0000
14	228 V ST NE	Lead	1/29/2013	0.0000
15	24 Evarts St NE	Lead	4/25/2013	0.0000
16	2923 Cathedral AVE NW	Lead	6/13/2013	0.0000
17	3036 P St NW	Partial Lead	3/27/2013	0.0000
18	307 7th St NE	Lead	1/30/2013	0.0000
19	308 9th St SE	Partial Lead	5/20/2013	0.0000
20	317 9th St SE	Lead	1/29/2013	0.0000
21	331 RALEIGH ST SE	Lead	2/26/2013	0.0000
22	333 34th St NE	Partial Lead	4/24/2013	0.0000
23	336 Quackenbos St NE	Lead	2/28/2013	0.0000
24	3361 Stuyvesant Pl NW	Lead	4/23/2013	0.0000
25	3416 9th St NE	Partial Lead	4/24/2013	0.0000

No.	Address	Pipe Material	Collection Date	Lead 2nd Draw (mg/L)
26	3533 W PI NW	Lead	2/28/2013	0.0000
27	36 Florida Ave NW	Lead	3/28/2013	0.0000
28	3601 WARREN ST NW	Lead	2/26/2013	0.0000
29	3809 ALTON PL NW	Partial Lead	4/25/2013	0.0000
30	413 4th St SE	Partial Lead	4/24/2013	0.0000
31	4332 BRANDYWINE ST NW	Partial Lead	4/24/2013	0.0000
32	449 S St NW	Lead	6/13/2013	0.0000
33	4926 Glenbrook Rd NW	Lead	2/27/2013	0.0000
34	53 P St NW	Partial Lead	5/21/2013	0.0000
35	5517 7th St NW	Lead	2/27/2013	0.0000
36	580 49th PI NE	Lead	2/27/2013	0.0000
37	6105 Dix St NE	Lead	3/28/2013	0.0000
38	617 6th St NE	Lead	3/27/2013	0.0000
39	619 12th St NE	Lead	3/26/2013	0.0000
40	75 Bates St NW	Lead	3/26/2013	0.0000
41	780 Fairmont St NW	Partial Lead	4/22/2013	0.0000
42	834 Delafield PI NW	Lead	3/27/2013	0.0000
43	905 Kent PI NE	Lead	3/27/2013	0.0000
44	1635 WEBSTER ST NW	Lead	1/31/2013	0.0005
45	4307 CHESAPEAKE ST NW	Lead	2/28/2013	0.0005
46	1222 HAMILTON ST NW	Partial Lead	6/11/2013	0.0006
47	1826 Jackson St NE	Lead	1/29/2013	0.0006
48	4627 49th St NW	Lead	2/27/2013	0.0006
49	605 Columbia Rd NW	Partial Lead	4/22/2013	0.0006
50	804 Delafield PI NW	Lead	4/24/2013	0.0006
51	10 S St NW	Lead	1/31/2013	0.0007
52	1808 KEARNEY ST NE	Partial Lead	3/27/2013	0.0007
53	3215 Mckinley St NW	Partial Lead	4/24/2013	0.0007
54	3917 8th St NW	Partial Lead	4/24/2013	0.0007
55	1003 Quebec PI NW	Lead	4/23/2013	0.0008
56	1519 Olive St NE	Lead	1/31/2013	0.0008
57	3211 Central Ave NE	Lead	1/29/2013	0.0008
58	3907 13th St NW	Partial Lead	4/29/2013	0.0008
59	424 Luray PI NW	Lead	6/13/2013	0.0008
60	4818 8th ST NW	Partial Lead	4/23/2013	0.0008
61	3625 Albermarle St NW	Lead	6/6/2013	0.0009
62	6210 8th St NW	Lead	3/27/2013	0.0009
63	5301 RENO RD NW	Partial Lead	6/12/2013	0.0010
64	5404 39TH ST NW	Partial Lead	4/22/2013	0.0010
65	617 M St NE	Partial Lead	4/24/2013	0.0010
66	1424 S ST NW	Lead	2/9/2013	0.0012

No.	Address	Pipe Material	Collection Date	Lead 2nd Draw (mg/L)
67	641 Gallatin St NW	Lead	3/28/2013	0.0012
68	4310 37th St NW	Lead	2/26/2013	0.0013
69	531 Tennessee Ave NE	Lead	2/25/2013	0.0013
70	2830 BRENTWOOD RD NE	Lead	1/29/2013	0.0014
71	6001 33rd St NW	Lead	2/27/2013	0.0014
72	912 Emerson St NW	Lead	6/12/2013	0.0014
73	2913 Brandywine St NW	Lead	1/30/2013	0.0015
74	1703 D St NE	Lead	1/28/2013	0.0016
75	2107 2nd St NE	Lead	6/10/2013	0.0016
76	5923 33rd St NW	Lead	2/28/2013	0.0016
77	4215 39th St NW	Partial Lead	6/4/2013	0.0017
78	4418 14th St NE	Lead	2/27/2013	0.0017
79	1353 JEFFERSON ST NW	Partial Lead	3/26/2013	0.0019
80	3908 13TH ST NW	Lead	6/11/2013	0.0019
81	4703 Macarthur Blvd NW	Lead	2/27/2013	0.0019
82	302 RITTENHOUSE ST NW	Partial Lead	3/28/2013	0.0020
83	8 N St SW	Lead	6/11/2013	0.0022
84	1412 Shepherd St NW	Partial Lead	5/22/2013	0.0024
85	1378 Taylor St NW	Lead	1/30/2013	0.0026
86	4401 5TH ST NW	Lead	2/26/2013	0.0026
87	2408 2nd St NE	Partial Lead	5/21/2013	0.0028
88	5234 Illinois Ave NW	Lead	2/26/2013	0.0029
89	2212 38th St NW	Lead	1/31/2013	0.0030
90	1649 HARVARD ST NW	Lead	6/12/2013	0.0034
91	4550 30TH ST NW	Lead	2/27/2013	0.0034
92	5226 7th St NW	Lead	2/27/2013	0.0034
93	4131 YUMA ST NW	Lead	6/12/2013	0.0035
94	3218 MACOMB ST NW	Lead	1/31/2013	0.0036
95	702 9th St SE	Lead	6/12/2013	0.0036
96	3710 Huntington St NW	Lead	2/27/2013	0.0039
97	4824 46th St NW	Lead	2/27/2013	0.0043
98	53 V St NW	Partial Lead	6/13/2013	0.0045
99	605 ROCK CRK CHURCH RD NW	Partial Lead	6/18/2013	0.0045
100	1211 Carrollsburg Pl SW	Partial Lead	3/27/2013	0.0047
101	3727 T St NW	Lead	2/27/2013	0.0053
102	1505 Buchanan St NW	Lead	1/30/2013	0.0055
103	3206 38th St NW	Lead	1/30/2013	0.0055
104	87 S St NW	Lead	6/14/2013	0.0078
105	230 G St NE	Partial Lead	3/28/2013	0.0088
106	807 Buchanan St NW	Lead	3/27/2013	0.0098
107	109 19th St SE	Lead	6/9/2013	0.0108

No.	Address	Pipe Material	Collection Date	Lead 2nd Draw (mg/L)
108	125 Madison St NW	Lead	6/11/2013	0.0138

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) Results expressed as “0.0000” may have been reported by the laboratory as non-detect or < 0.0005 mg/L.
- 3) The second draw samples were rejected from 223 14th Pl NE and 4120 Grant St NE because they did not follow the sampling criteria for collecting the second draw sample as described in the instructions.

Table B.2 Second Draw Copper Results

No.	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
1	1357 C St NE	Lead	1/30/2013	0.000
2	3416 9th St NE	Partial Lead	4/24/2013	0.002
3	807 Buchanan St NW	Lead	3/27/2013	0.002
4	213 49th St NE	Lead	1/30/2013	0.003
5	5226 7th St NW	Lead	2/27/2013	0.003
6	10 S St NW	Lead	1/31/2013	0.004
7	2107 2nd St NE	Lead	6/10/2013	0.004
8	3601 WARREN ST NW	Lead	2/26/2013	0.004
9	6001 33rd St NW	Lead	2/27/2013	0.004
10	6210 8th St NW	Lead	3/27/2013	0.004
11	702 9th St SE	Lead	6/12/2013	0.004
12	75 Bates St NW	Lead	3/26/2013	0.004
13	1318 Wallach Pl NW	Lead	1/30/2013	0.005
14	1519 Olive St NE	Lead	1/31/2013	0.005
15	1620 Webster St NW	Lead	1/29/2013	0.005
16	1826 Jackson St NE	Lead	1/29/2013	0.005
17	228 V ST NE	Lead	1/29/2013	0.005
18	3625 Albermarle St NW	Lead	6/6/2013	0.005
19	4131 YUMA ST NW	Lead	6/12/2013	0.005
20	4550 30TH ST NW	Lead	2/27/2013	0.005
21	605 ROCK CRK CHURCH RD NW	Partial Lead	6/18/2013	0.005
22	2913 Brandywine St NW	Lead	1/30/2013	0.006
23	317 9th St SE	Lead	1/29/2013	0.006
24	4824 46th St NW	Lead	2/27/2013	0.006
25	580 49th Pl NE	Lead	2/27/2013	0.006
26	1378 Taylor St NW	Lead	1/30/2013	0.007
27	1706 NEW JERSEY AVE NW	Lead	1/29/2013	0.007
28	3211 Central Ave NE	Lead	1/29/2013	0.007
29	3218 MACOMB ST NW	Lead	1/31/2013	0.007
30	4418 14th St NE	Lead	2/27/2013	0.007
31	6105 Dix St NE	Lead	3/28/2013	0.007
32	641 Gallatin St NW	Lead	3/28/2013	0.007
33	912 Emerson St NW	Lead	6/12/2013	0.007
34	1603 Massachusetts Ave SE	Partial Lead	3/26/2013	0.008
35	331 RALEIGH ST SE	Lead	2/26/2013	0.008
36	3533 W Pl NW	Lead	2/28/2013	0.008
37	3710 Huntington St NW	Lead	2/27/2013	0.008
38	424 Luray Pl NW	Lead	6/13/2013	0.008
39	53 P St NW	Partial Lead	5/21/2013	0.008

No.	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
40	5517 7th St NW	Lead	2/27/2013	0.008
41	125 Madison St NW	Lead	6/11/2013	0.009
42	2212 38th St NW	Lead	1/31/2013	0.009
43	531 Tennessee Ave NE	Lead	2/25/2013	0.009
44	804 Delafield Pl NW	Lead	4/24/2013	0.009
45	834 Delafield Pl NW	Lead	3/27/2013	0.009
46	905 Kent Pl NE	Lead	3/27/2013	0.009
47	230 G St NE	Partial Lead	3/28/2013	0.010
48	2830 BRENTWOOD RD NE	Lead	1/29/2013	0.010
49	3036 P St NW	Partial Lead	3/27/2013	0.010
50	3206 38th St NW	Lead	1/30/2013	0.010
51	336 Quackenbos St NE	Lead	2/28/2013	0.010
52	780 Fairmont St NW	Partial Lead	4/22/2013	0.010
53	1635 WEBSTER ST NW	Lead	1/31/2013	0.011
54	36 Florida Ave NW	Lead	3/28/2013	0.011
55	617 6th St NE	Lead	3/27/2013	0.011
56	1203 Quincy St NW	Partial Lead	3/27/2013	0.012
57	1412 Shepherd St NW	Partial Lead	5/22/2013	0.012
58	2923 Cathedral AVE NW	Lead	6/13/2013	0.012
59	4215 39th St NW	Partial Lead	6/4/2013	0.012
60	4307 CHESAPEAKE ST NW	Lead	2/28/2013	0.012
61	4703 Macarthur Blvd NW	Lead	2/27/2013	0.012
62	109 19th St SE	Lead	6/9/2013	0.013
63	1505 Buchanan St NW	Lead	1/30/2013	0.013
64	307 7th St NE	Lead	1/30/2013	0.013
65	3727 T St NW	Lead	2/27/2013	0.013
66	2007 37TH ST NW	Lead	1/30/2013	0.014
67	302 RITTENHOUSE ST NW	Partial Lead	3/28/2013	0.014
68	5234 Illinois Ave NW	Lead	2/26/2013	0.014
69	1424 S ST NW	Lead	2/9/2013	0.015
70	333 34th St NE	Partial Lead	4/24/2013	0.015
71	1319 POTOMAC AVE SE	Partial Lead	3/26/2013	0.016
72	53 V St NW	Partial Lead	6/13/2013	0.017
73	3809 ALTON PL NW	Partial Lead	4/25/2013	0.018
74	413 4th St SE	Partial Lead	4/24/2013	0.019
75	1649 HARVARD ST NW	Lead	6/12/2013	0.020
76	1222 HAMILTON ST NW	Partial Lead	6/11/2013	0.021
77	5301 RENO RD NW	Partial Lead	6/12/2013	0.021
78	308 9th St SE	Partial Lead	5/20/2013	0.023
79	4818 8th ST NW	Partial Lead	4/23/2013	0.023
80	1703 D St NE	Lead	1/28/2013	0.024

No.	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
81	619 12th St NE	Lead	3/26/2013	0.024
82	3361 Stuyvesant Pl NW	Lead	4/23/2013	0.025
83	5404 39TH ST NW	Partial Lead	4/22/2013	0.026
84	3917 8th St NW	Partial Lead	4/24/2013	0.028
85	4310 37th St NW	Lead	2/26/2013	0.028
86	449 S St NW	Lead	6/13/2013	0.028
87	24 Evarts St NE	Lead	4/25/2013	0.030
88	3215 McKinley St NW	Partial Lead	4/24/2013	0.034
89	1353 JEFFERSON ST NW	Partial Lead	3/26/2013	0.035
90	1808 KEARNEY ST NE	Partial Lead	3/27/2013	0.036
91	87 S St NW	Lead	6/14/2013	0.039
92	1453 S St NW	Lead	6/13/2013	0.043
93	3908 13TH ST NW	Lead	6/11/2013	0.046
94	4401 5TH ST NW	Lead	2/26/2013	0.046
95	15 Milmarson Pl NW	Lead	1/30/2013	0.047
96	4926 Glenbrook Rd NW	Lead	2/27/2013	0.051
97	1211 Carrollsburg Pl SW	Partial Lead	3/27/2013	0.052
98	4627 49th St NW	Lead	2/27/2013	0.052
99	1003 Quebec Pl NW	Lead	4/23/2013	0.054
100	4332 BRANDYWINE ST NW	Partial Lead	4/24/2013	0.056
101	2408 2nd St NE	Partial Lead	5/21/2013	0.058
102	605 Columbia Rd NW	Partial Lead	4/22/2013	0.069
103	1613 Webster St NW	Lead	2/27/2013	0.071
104	617 M St NE	Partial Lead	4/24/2013	0.075
105	5923 33rd St NW	Lead	2/28/2013	0.077
106	3907 13th St NW	Partial Lead	4/29/2013	0.082
107	8 N St SW	Lead	6/11/2013	0.088
108	1736 Bay St SE	Partial Lead	3/27/2013	0.124

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) The second draw samples were rejected from 223 14th Pl NE and 4120 Grant St NE because they did not follow the sampling criteria for collecting the second draw sample as described in the instructions.
- 3) Results expressed as “0.000” may have been reported by the laboratory as non-detect or < 0.001 mg/L.

Appendix C – Additional Sampling Information

Table C.1 Sample Kit Distribution

No	Address	Bottle Drop Date
1	10 S St NW	1/28/2013
2	1003 Otis St NE	1/28/2013
3	1010 10th St NE	1/28/2013
4	1011 Taylor St NE	1/28/2013
5	1014 Douglas St NE	1/28/2013
6	1025 44th St NE	1/28/2013
7	1106 Allison St NW	1/28/2013
8	119 16TH ST NE	1/28/2013
9	1212 E Capitol St NE	1/28/2013
10	125 Madison St NW	1/28/2013
11	1262 COLUMBIA RD NW	1/28/2013
12	1315 FRANKLIN ST NE	1/28/2013
13	1318 Wallach Pl NW	1/28/2013
14	1346 F St NE	1/28/2013
15	1346 Madison St NW	1/28/2013
16	1357 C St NE	1/28/2013
17	1378 Taylor St NW	1/28/2013
18	1424 S ST NW	1/28/2013
19	1429 Ives Pl SE	1/28/2013
20	143 UHLAND TER NE	1/28/2013
21	1434 Taylor St NW	1/28/2013
22	15 Milmarson Pl NW	1/28/2013
23	1505 Buchanan St NW	1/28/2013
24	1519 Olive St NE	1/28/2013
25	1520 Locust Rd NW	1/28/2013
26	1620 Hamlin St NE	1/28/2013
27	1620 Webster St NW	1/28/2013
28	1623 U St SE	1/28/2013
29	1635 WEBSTER ST NW	1/28/2013
30	1649 HARVARD ST NW	1/28/2013
31	1703 D St NE	1/28/2013
32	1705 2nd St NE	1/28/2013
33	1706 NEW JERSEY AVE NW	1/28/2013
34	1826 Jackson St NE	1/28/2013
35	2007 37TH ST NW	1/28/2013
36	213 49th St NE	1/28/2013
37	2212 38th St NW	1/28/2013
38	228 V ST NE	1/28/2013

No	Address	Bottle Drop Date
39	2435 33RD ST SE	1/28/2013
40	2830 BRENTWOOD RD NE	1/28/2013
41	2913 Brandywine St NW	1/28/2013
42	2923 Cathedral AVE NW	1/28/2013
43	307 7th St NE	1/28/2013
44	317 9th St SE	1/28/2013
45	3206 38th St NW	1/28/2013
46	3211 Central Ave NE	1/28/2013
47	3216 Klinge Rd NW	1/28/2013
48	3218 MACOMB ST NW	1/28/2013
49	3218 MORRISON ST NW	1/28/2013
50	1613 Webster St NW	2/25/2013
51	322 TENNESSEE AVE NE	2/25/2013
52	3232 Klinge Rd NW	2/25/2013
53	331 RALEIGH ST SE	2/25/2013
54	331 Upshur St NW	2/25/2013
55	336 Quackenbos St NE	2/25/2013
56	3400 Holmead PI NW	2/25/2013
57	3533 W PI NW	2/25/2013
58	36 Florida Ave NW	2/25/2013
59	3601 WARREN ST NW	2/25/2013
60	3706 35th St NW	2/25/2013
61	3710 Huntington St NW	2/25/2013
62	3727 T St NW	2/25/2013
63	3908 13TH ST NW	2/25/2013
64	3973 HARRISON ST NW	2/25/2013
65	4111 INGOMAR ST NW	2/25/2013
66	4118 13TH ST NW	2/25/2013
67	4120 Grant St NE	2/25/2013
68	4131 YUMA ST NW	2/25/2013
69	4214 8th St NW	2/25/2013
70	424 Luray PI NW	2/25/2013
71	4307 CHESAPEAKE ST NW	2/25/2013
72	4310 37th St NW	2/25/2013
73	4401 5TH ST NW	2/25/2013
74	4411 15th St NW	2/25/2013
75	4418 14th St NE	2/25/2013
76	4550 30TH ST NW	2/25/2013
77	4613 9th St NW	2/25/2013
78	4627 49th St NW	2/25/2013
79	4703 Macarthur Blvd NW	2/25/2013
80	4818 ILLINOIS AVE NW	2/25/2013

No	Address	Bottle Drop Date
81	4824 46th St NW	2/25/2013
82	4926 Glenbrook Rd NW	2/25/2013
83	501 Webster St NW	2/25/2013
84	5024 7th St NW	2/25/2013
85	5226 7th St NW	2/25/2013
86	5234 Illinois Ave NW	2/25/2013
87	524 10th St SE	2/25/2013
88	531 Tennessee Ave NE	2/25/2013
89	5318 9TH ST NW	2/25/2013
90	5517 7th St NW	2/25/2013
91	5613 30th St NW	2/25/2013
92	580 49th Pl NE	2/25/2013
93	5817 7th St NW	2/25/2013
94	5923 33rd St NW	2/25/2013
95	6001 33rd St NW	2/25/2013
96	608 Gallatin St NW	2/25/2013
97	6105 Dix St NE	2/25/2013
98	1203 Quincy St NW	3/25/2013
99	1211 Carrollsburg Pl SW	3/25/2013
100	1222 HAMILTON ST NW	3/25/2013
101	1319 POTOMAC AVE SE	3/25/2013
102	1353 JEFFERSON ST NW	3/25/2013
103	1387 N Carolina Ave NE	3/25/2013
104	1420 Hamlin St NE	3/25/2013
105	1603 Massachusetts Ave SE	3/25/2013
106	1614 V St SE	3/25/2013
107	1619 G St SE	3/25/2013
108	1671 Rosedale St NE	3/25/2013
109	1731 L St NE	3/25/2013
110	1736 Bay St SE	3/25/2013
111	1808 KEARNEY ST NE	3/25/2013
112	1836 L St NE	3/25/2013
113	1931 SUMMIT PL NE	3/25/2013
114	201 13th St NE	3/25/2013
115	223 14th Pl NE	3/25/2013
116	230 G St NE	3/25/2013
117	231 K St NE	3/25/2013
118	234 Longfellow St NW	3/25/2013
119	302 RITTENHOUSE ST NW	3/25/2013
120	3036 P St NW	3/25/2013
121	3202 38TH ST NW	3/25/2013
122	36 Florida Ave NW	3/25/2013

No	Address	Bottle Drop Date
123	3612 34th St NW	3/25/2013
124	611 Roxboro Pl NW	3/25/2013
125	617 6th St NE	3/25/2013
126	619 12th St NE	3/25/2013
127	619 Girard St NE	3/25/2013
128	621 Upshur St NW	3/25/2013
129	6210 8th St NW	3/25/2013
130	6308 8th St NW	3/25/2013
131	636 ROCK CRK CHURCH RD NW	3/25/2013
132	641 Gallatin St NW	3/25/2013
133	644 Lamont St NW	3/25/2013
134	702 9th St SE	3/25/2013
135	720 ALABAMA AVE SE	3/25/2013
136	743 Gresham Pl NW	3/25/2013
137	75 Bates St NW	3/25/2013
138	753 Gresham Pl NW	3/25/2013
139	8 N St SW	3/25/2013
140	807 Buchanan St NW	3/25/2013
141	834 Delafield Pl NW	3/25/2013
142	87 S St NW	3/25/2013
143	905 Kent Pl NE	3/25/2013
144	912 Emerson St NW	3/25/2013
145	913 Hamlin St NE	3/25/2013
146	926 Hamilton St NW	3/25/2013
147	1003 Quebec Pl NW	4/22/2013
148	108 Varnum St NW	4/22/2013
149	1331 Irving St NE	4/22/2013
150	1339 U St SE	4/22/2013
151	1409 22nd St SE	4/22/2013
152	1436 S St NW	4/22/2013
153	1453 S St NW	4/22/2013
154	1525 D St NE	4/22/2013
155	1533 Upshur St NW	4/22/2013
156	2107 2nd St NE	4/22/2013
157	2300 Woodridge St NE	4/22/2013
158	24 Evarts St NE	4/22/2013
159	258 15th St SE	4/22/2013
160	2649 Bowen Rd SE	4/22/2013
161	3033 Bladensburg Rd NE	4/22/2013
162	3215 McKinley St NW	4/22/2013
163	333 34th St NE	4/22/2013
164	335 17TH PL NE	4/22/2013

No	Address	Bottle Drop Date
165	3361 Stuyvesant Pl NW	4/22/2013
166	3416 9th St NE	4/22/2013
167	3427 Oliver St NW	4/22/2013
168	3511 Woodley Rd NW	4/22/2013
169	3531 16TH ST NW	4/22/2013
170	3809 ALTON PL NW	4/22/2013
171	3907 13th St NW	4/22/2013
172	3913 8TH ST NW	4/22/2013
173	3917 8th St NW	4/22/2013
174	410 Farragut St NW	4/22/2013
175	413 4th St SE	4/22/2013
176	416 7th St NE	4/22/2013
177	420 Kenyon St NW	4/22/2013
178	4210 Clay St NE	4/22/2013
179	432 15th St SE	4/22/2013
180	4327 IOWA AVE NW	4/22/2013
181	4332 BRANDYWINE ST NW	4/22/2013
182	4419 14th St NE	4/22/2013
183	4423 Kane Pl NE	4/22/2013
184	449 S St NW	4/22/2013
185	452 Newton Pl NW	4/22/2013
186	4606 Sheriff Rd NE	4/22/2013
187	4609 5th St NW	4/22/2013
188	4818 8th ST NW	4/22/2013
189	507 Alabama Ave SE	4/22/2013
190	5316 28th St NW	4/22/2013
191	5404 39TH ST NW	4/22/2013
192	605 Columbia Rd NW	4/22/2013
193	617 M St NE	4/22/2013
194	6213 7TH ST NW	4/22/2013
195	780 Fairmont St NW	4/22/2013
196	804 Delafield Pl NW	4/22/2013
197	1207 Trinidad Ave NE	5/20/2013
198	1214 Evarts St NE	5/20/2013
199	1238 HALF ST SW	5/20/2013
200	1353 Iris St NW	5/20/2013
201	1412 N Carolina Ave NE	5/20/2013
202	1412 S St NW	5/20/2013
203	1412 Shepherd St NW	5/20/2013
204	1424 Perry Pl NW	5/20/2013
205	1424 S ST SE	5/20/2013
206	1451 S ST NW	5/20/2013

No	Address	Bottle Drop Date
207	1505 Lawrence St NE	5/20/2013
208	1523 D St SE	5/20/2013
209	1533 Constitution Ave NE	5/20/2013
210	1755 Lanier Pl NW	5/20/2013
211	1802 35TH ST NW	5/20/2013
212	1802 Kilbourne Pl NW	5/20/2013
213	1825 L ST NE	5/20/2013
214	1839 MONROE ST NW	5/20/2013
215	1843 MONROE ST NW	5/20/2013
216	1850 2ND ST NW	5/20/2013
217	1863 MONROE ST NW	5/20/2013
218	1908 Biltmore St NW	5/20/2013
219	202 11th St SE	5/20/2013
220	205 TAYLOR ST NW	5/20/2013
221	2118 14th St SE	5/20/2013
222	2220 13th St SE	5/20/2013
223	228 Randolph Pl NE	5/20/2013
224	2305 Minnesota Ave SE	5/20/2013
225	2408 2nd St NE	5/20/2013
226	2823 28TH ST NW	5/20/2013
227	2928 33rd Pl NW	5/20/2013
228	3030 44TH ST NW	5/20/2013
229	308 9th St SE	5/20/2013
230	3105 34th St NW	5/20/2013
231	312 14TH ST NE	5/20/2013
232	313 16th St SE	5/20/2013
233	3531 16TH ST NW	5/20/2013
234	4327 IOWA AVE NW	5/20/2013
235	53 P St NW	5/20/2013
236	536 Newton Pl NW	5/20/2013
237	5516 Kansas Ave NW	5/20/2013
238	5907 4th St NW	5/20/2013
239	5909 16th St NW	5/20/2013
240	632 Webster St NW	5/20/2013
241	760 Gresham Pl NW	5/20/2013
242	81 O St NW	5/20/2013
243	810 Savannah St SE	5/20/2013
244	811 E St SE	5/20/2013
245	822 K St NE	5/20/2013
246	88 R St NW	5/20/2013
247	910 Farragut St NW	5/20/2013
248	915 Farragut St NW	5/20/2013

No	Address	Bottle Drop Date
249	915 Shepherd St NW	5/20/2013
250	109 19th St SE	6/3/2013
251	42 Q St NE	6/3/2013
252	4215 39th St NW	6/3/2013
253	522 Park Rd NW	6/3/2013
254	817 DECATUR ST NW	6/3/2013
255	3625 Albermarle St NW	6/5/2013
256	1003 Otis St NE	6/10/2013
257	1010 10th St NE	6/10/2013
258	1014 Douglas St NE	6/10/2013
259	1212 E Capitol St NE	6/10/2013
260	1222 HAMILTON ST NW	6/10/2013
261	125 Madison St NW	6/10/2013
262	1339 U St SE	6/10/2013
263	1346 Madison St NW	6/10/2013
264	1387 N Carolina Ave NE	6/10/2013
265	1409 22nd St SE	6/10/2013
266	1420 Hamlin St NE	6/10/2013
267	143 UHLAND TER NE	6/10/2013
268	1434 Taylor St NW	6/10/2013
269	1453 S St NW	6/10/2013
270	1525 D St NE	6/10/2013
271	1533 Upshur St NW	6/10/2013
272	1614 V St SE	6/10/2013
273	1619 G St SE	6/10/2013
274	1620 Hamlin St NE	6/10/2013
275	1649 HARVARD ST NW	6/10/2013
276	1671 Rosedale St NE	6/10/2013
277	1705 2nd St NE	6/10/2013
278	1931 SUMMIT PL NE	6/10/2013
279	201 13th St NE	6/10/2013
280	2107 2nd St NE	6/10/2013
281	2300 Woodridge St NE	6/10/2013
282	231 K St NE	6/10/2013
283	258 15th St SE	6/10/2013
284	2923 Cathedral AVE NW	6/10/2013
285	3033 Bladensburg Rd NE	6/10/2013
286	319 Ingraham St NW	6/10/2013
287	32 Todd Pl NE	6/10/2013
288	3202 38TH ST NW	6/10/2013
289	3216 Klinge Rd NW	6/10/2013
290	3218 MORRISON ST NW	6/10/2013

No	Address	Bottle Drop Date
291	322 TENNESSEE AVE NE	6/10/2013
292	3232 Klinge Rd NW	6/10/2013
293	3301 BROWN St NW	6/10/2013
294	335 17TH PL NE	6/10/2013
295	3427 Oliver St NW	6/10/2013
296	3428 Brown St NW	6/10/2013
297	3612 34th St NW	6/10/2013
298	3721 Windom Pl NW	6/10/2013
299	3908 13TH ST NW	6/10/2013
300	3913 8TH ST NW	6/10/2013
301	3973 HARRISON ST NW	6/10/2013
302	410 Farragut St NW	6/10/2013
303	4111 INGOMAR ST NW	6/10/2013
304	4118 13TH ST NW	6/10/2013
305	4131 YUMA ST NW	6/10/2013
306	420 Kenyon St NW	6/10/2013
307	4210 Clay St NE	6/10/2013
308	424 Luray Pl NW	6/10/2013
309	441 Quincy St NW	6/10/2013
310	4419 14th St NE	6/10/2013
311	4423 Kane Pl NE	6/10/2013
312	449 S St NW	6/10/2013
313	452 Newton Pl NW	6/10/2013
314	4606 Sheriff Rd NE	6/10/2013
315	4609 5th St NW	6/10/2013
316	4616 HUNT PL NE	6/10/2013
317	4818 ILLINOIS AVE NW	6/10/2013
318	506 Irving St NW	6/10/2013
319	507 Alabama Ave SE	6/10/2013
320	513 Florida Ave NE	6/10/2013
321	514 13th St SE	6/10/2013
322	518 Varnum St NW	6/10/2013
323	524 10th St SE	6/10/2013
324	53 V St NW	6/10/2013
325	5301 RENO RD NW	6/10/2013
326	5304 Reno Rd NW	6/10/2013
327	5316 28th St NW	6/10/2013
328	5817 7th St NW	6/10/2013
329	605 ROCK CRK CHURCH RD NW	6/10/2013
330	611 Roxboro Pl NW	6/10/2013
331	617 Kenyon St NW	6/10/2013
332	619 Girard St NE	6/10/2013

No	Address	Bottle Drop Date
333	621 Upshur St NW	6/10/2013
334	644 Lamont St NW	6/10/2013
335	661 MARYLAND AVE NE	6/10/2013
336	702 9th St SE	6/10/2013
337	720 ALABAMA AVE SE	6/10/2013
338	736 Fairmont St NW	6/10/2013
339	743 Gresham Pl NW	6/10/2013
340	75 P St NW	6/10/2013
341	753 Gresham Pl NW	6/10/2013
342	765 GIRARD ST NW	6/10/2013
343	7721 14th St NW	6/10/2013
344	8 N St SW	6/10/2013
345	833 DECATUR ST NW	6/10/2013
346	87 S St NW	6/10/2013
347	912 Emerson St NW	6/10/2013
348	913 Hamlin St NE	6/10/2013
349	924 Hamilton St NW	6/10/2013
350	926 Hamilton St NW	6/10/2013

Table C.2 Sample Kits Not Returned

No	Address	Bottle Drop Date
1	1003 Otis St NE	1/28/2013
2	1010 10th St NE	1/28/2013
3	1014 Douglas St NE	1/28/2013
4	1212 E Capitol St NE	1/28/2013
5	125 Madison St NW	1/28/2013
6	1346 Madison St NW	1/28/2013
7	143 UHLAND TER NE	1/28/2013
8	1434 Taylor St NW	1/28/2013
9	1620 Hamlin St NE	1/28/2013
10	1649 HARVARD ST NW	1/28/2013
11	1705 2nd St NE	1/28/2013
12	2923 Cathedral AVE NW	1/28/2013
13	3216 Klinge Rd NW	1/28/2013
14	3218 MORRISON ST NW	1/28/2013
15	322 TENNESSEE AVE NE	2/25/2013
16	3232 Klinge Rd NW	2/25/2013
17	3908 13TH ST NW	2/25/2013
18	3973 HARRISON ST NW	2/25/2013
19	4111 INGOMAR ST NW	2/25/2013
20	4118 13TH ST NW	2/25/2013
21	4131 YUMA ST NW	2/25/2013
22	424 Luray Pl NW	2/25/2013
23	4818 ILLINOIS AVE NW	2/25/2013
24	524 10th St SE	2/25/2013
25	5817 7th St NW	2/25/2013
26	1387 N Carolina Ave NE	3/25/2013
27	1420 Hamlin St NE	3/25/2013
28	1614 V St SE	3/25/2013
29	1619 G St SE	3/25/2013
30	1671 Rosedale St NE	3/25/2013
31	1931 SUMMIT PL NE	3/25/2013
32	201 13th St NE	3/25/2013
33	231 K St NE	3/25/2013
34	3202 38TH ST NW	3/25/2013
35	3612 34th St NW	3/25/2013
36	611 Roxboro Pl NW	3/25/2013
37	619 Girard St NE	3/25/2013
38	621 Upshur St NW	3/25/2013
39	644 Lamont St NW	3/25/2013

No	Address	Bottle Drop Date
40	702 9th St SE	3/25/2013
41	720 ALABAMA AVE SE	3/25/2013
42	743 Gresham Pl NW	3/25/2013
43	753 Gresham Pl NW	3/25/2013
44	8 N St SW	3/25/2013
45	87 S St NW	3/25/2013
46	912 Emerson St NW	3/25/2013
47	913 Hamlin St NE	3/25/2013
48	926 Hamilton St NW	3/25/2013
49	1339 U St SE	4/22/2013
50	1409 22nd St SE	4/22/2013
51	1453 S St NW	4/22/2013
52	1525 D St NE	4/22/2013
53	1533 Upshur St NW	4/22/2013
54	2107 2nd St NE	4/22/2013
55	2300 Woodridge St NE	4/22/2013
56	258 15th St SE	4/22/2013
57	3033 Bladensburg Rd NE	4/22/2013
58	335 17TH PL NE	4/22/2013
59	3427 Oliver St NW	4/22/2013
60	3913 8TH ST NW	4/22/2013
61	410 Farragut St NW	4/22/2013
62	416 7th St NE	4/22/2013
63	420 Kenyon St NW	4/22/2013
64	4210 Clay St NE	4/22/2013
65	432 15th St SE	4/22/2013
66	4419 14th St NE	4/22/2013
67	4423 Kane Pl NE	4/22/2013
68	449 S St NW	4/22/2013
69	452 Newton Pl NW	4/22/2013
70	4606 Sheriff Rd NE	4/22/2013
71	4609 5th St NW	4/22/2013
72	507 Alabama Ave SE	4/22/2013
73	5316 28th St NW	4/22/2013
74	1207 Trinidad Ave NE	5/20/2013
75	1214 Evarts St NE	5/20/2013
76	1238 HALF ST SW	5/20/2013
77	1353 Iris St NW	5/20/2013
78	1412 N Carolina Ave NE	5/20/2013
79	1424 Perry Pl NW	5/20/2013
80	1424 S ST SE	5/20/2013
81	1451 S ST NW	5/20/2013

No	Address	Bottle Drop Date
82	1523 D St SE	5/20/2013
83	1533 Constitution Ave NE	5/20/2013
84	1755 Lanier Pl NW	5/20/2013
85	1802 35TH ST NW	5/20/2013
86	1802 Kilbourne Pl NW	5/20/2013
87	1825 L ST NE	5/20/2013
88	1850 2ND ST NW	5/20/2013
89	202 11th St SE	5/20/2013
90	205 TAYLOR ST NW	5/20/2013
91	2220 13th St SE	5/20/2013
92	228 Randolph Pl NE	5/20/2013
93	2305 Minnesota Ave SE	5/20/2013
94	2823 28TH ST NW	5/20/2013
95	2928 33rd Pl NW	5/20/2013
96	3030 44TH ST NW	5/20/2013
97	3105 34th St NW	5/20/2013
98	312 14TH ST NE	5/20/2013
99	313 16th St SE	5/20/2013
100	3531 16TH ST NW	5/20/2013
101	536 Newton Pl NW	5/20/2013
102	5516 Kansas Ave NW	5/20/2013
103	5907 4th St NW	5/20/2013
104	5909 16th St NW	5/20/2013
105	632 Webster St NW	5/20/2013
106	760 Gresham Pl NW	5/20/2013
107	81 O St NW	5/20/2013
108	810 Savannah St SE	5/20/2013
109	822 K St NE	5/20/2013
110	88 R St NW	5/20/2013
111	910 Farragut St NW	5/20/2013
112	915 Farragut St NW	5/20/2013
113	915 Shepherd St NW	5/20/2013
114	42 Q St NE	6/3/2013
115	522 Park Rd NW	6/3/2013
116	817 DECATUR ST NW	6/3/2013
117	1010 10th St NE	6/10/2013
118	1014 Douglas St NE	6/10/2013
119	1212 E Capitol St NE	6/10/2013
120	1346 Madison St NW	6/10/2013
121	1409 22nd St SE	6/10/2013
122	1420 Hamlin St NE	6/10/2013
123	143 UHLAND TER NE	6/10/2013

No	Address	Bottle Drop Date
124	1525 D St NE	6/10/2013
125	1533 Upshur St NW	6/10/2013
126	1614 V St SE	6/10/2013
127	1619 G St SE	6/10/2013
128	1671 Rosedale St NE	6/10/2013
129	1705 2nd St NE	6/10/2013
130	1931 SUMMIT PL NE	6/10/2013
131	201 13th St NE	6/10/2013
132	2300 Woodridge St NE	6/10/2013
133	231 K St NE	6/10/2013
134	258 15th St SE	6/10/2013
135	3033 Bladensburg Rd NE	6/10/2013
136	3202 38TH ST NW	6/10/2013
137	3216 Klinge Rd NW	6/10/2013
138	3218 MORRISON ST NW	6/10/2013
139	322 TENNESSEE AVE NE	6/10/2013
140	3232 Klinge Rd NW	6/10/2013
141	335 17TH PL NE	6/10/2013
142	3427 Oliver St NW	6/10/2013
143	3428 Brown St NW	6/10/2013
144	3612 34th St NW	6/10/2013
145	3721 Windom Pl NW	6/10/2013
146	3913 8TH ST NW	6/10/2013
147	3973 HARRISON ST NW	6/10/2013
148	410 Farragut St NW	6/10/2013
149	4111 INGOMAR ST NW	6/10/2013
150	420 Kenyon St NW	6/10/2013
151	4210 Clay St NE	6/10/2013
152	441 Quincy St NW	6/10/2013
153	4419 14th St NE	6/10/2013
154	4423 Kane Pl NE	6/10/2013
155	452 Newton Pl NW	6/10/2013
156	4606 Sheriff Rd NE	6/10/2013
157	4609 5th St NW	6/10/2013
158	4818 ILLINOIS AVE NW	6/10/2013
159	506 Irving St NW	6/10/2013
160	507 Alabama Ave SE	6/10/2013
161	513 Florida Ave NE	6/10/2013
162	514 13th St SE	6/10/2013
163	518 Varnum St NW	6/10/2013
164	524 10th St SE	6/10/2013
165	5304 Reno Rd NW	6/10/2013

No	Address	Bottle Drop Date
166	5316 28th St NW	6/10/2013
167	5817 7th St NW	6/10/2013
168	611 Roxboro Pl NW	6/10/2013
169	617 Kenyon St NW	6/10/2013
170	619 Girard St NE	6/10/2013
171	621 Upshur St NW	6/10/2013
172	644 Lamont St NW	6/10/2013
173	661 MARYLAND AVE NE	6/10/2013
174	720 ALABAMA AVE SE	6/10/2013
175	736 Fairmont St NW	6/10/2013
176	743 Gresham Pl NW	6/10/2013
177	75 P St NW	6/10/2013
178	753 Gresham Pl NW	6/10/2013
179	765 GIRARD ST NW	6/10/2013
180	833 DECATUR ST NW	6/10/2013
181	913 Hamlin St NE	6/10/2013
182	924 Hamilton St NW	6/10/2013

Table C.3 Samples Returned and Rejected for Compliance Analysis

No	Address	Bottle Drop Date	Reject Reason
1	1011 Taylor St NE	1/28/2013	No stagnation
2	1025 44th St NE	1/28/2013	No Chain of Custody provided
3	1106 Allison St NW	1/28/2013	Incomplete Chain of Custody
4	119 16TH ST NE	1/28/2013	Ice maker on
5	1262 COLUMBIA RD NW	1/28/2013	No Chain of Custody provided
6	1315 FRANKLIN ST NE	1/28/2013	No Chain of Custody provided
7	1346 F St NE	1/28/2013	Leak in plumbing
8	1429 Ives Pl SE	1/28/2013	No Chain of Custody provided
9	1520 Locust Rd NW	1/28/2013	Water used during stagnation period
10	1623 U St SE	1/28/2013	Bottles not identified with Draw 1 or 2
11	2435 33RD ST SE	1/28/2013	Incomplete Chain of Custody
12	331 Upshur St NW	2/25/2013	Incomplete Chain of Custody
13	3400 Holmead Pl NW	2/25/2013	No Chain of Custody provided
14	36 Florida Ave NW	2/25/2013	Stagnation unknown
15	3706 35th St NW	2/25/2013	Bottles not identified with Draw 1 or 2
16	4214 8th St NW	2/25/2013	Incomplete Chain of Custody
17	4411 15th St NW	2/25/2013	Ice maker on
18	4613 9th St NW	2/25/2013	Bottles not identified with Draw 1 or 2
19	501 Webster St NW	2/25/2013	Incomplete Chain of Custody
20	5024 7th St NW	2/25/2013	Incomplete Chain of Custody
21	5318 9TH ST NW	2/25/2013	Incomplete Chain of Custody
22	5613 30th St NW	2/25/2013	No stagnation
23	608 Gallatin St NW	2/25/2013	Leak in plumbing
24	1222 HAMILTON ST NW	3/25/2013	Samples provided over 14 days after sample collection
25	1731 L St NE	3/25/2013	Leak in plumbing
26	1836 L St NE	3/25/2013	No stagnation
27	234 Longfellow St NW	3/25/2013	Less than 6 hours stagnation
28	6308 8th St NW	3/25/2013	Incomplete Chain of Custody
29	636 ROCK CRK CHURCH RD NW	3/25/2013	Ice maker on
30	108 Varnum St NW	4/22/2013	No Chain of Custody provided
31	1331 Irving St NE	4/22/2013	Bottles not identified with Draw 1 or 2
32	1436 S St NW	4/22/2013	Water used during stagnation period
33	2649 Bowen Rd SE	4/22/2013	Bottles not identified with Draw 1 or 2
34	3511 Woodley Rd NW	4/22/2013	No stagnation
35	3531 16TH ST NW	4/22/2013	Ice maker on
36	4327 IOWA AVE NW	4/22/2013	Water used during stagnation period
37	6213 7TH ST NW	4/22/2013	Leak in plumbing
38	1412 S St NW	5/20/2013	Samples provided over 14 days after sample collection
39	1505 Lawrence St NE	5/20/2013	Ice maker on

No	Address	Bottle Drop Date	Reject Reason
40	1839 MONROE ST NW	5/20/2013	Multi-family residence
41	1843 MONROE ST NW	5/20/2013	Ice maker on
42	1863 MONROE ST NW	5/20/2013	Multi-family residence
43	1908 Biltmore St NW	5/20/2013	Water used during stagnation period
44	2118 14th St SE	5/20/2013	Leak in plumbing
45	4327 IOWA AVE NW	5/20/2013	Ice maker on
46	811 E St SE	5/20/2013	Multi-family residence
47	1003 Otis St NE	6/10/2013	No Chain of Custody provided
48	1339 U St SE	6/10/2013	No Chain of Custody provided
49	1387 N Carolina Ave NE	6/10/2013	No Chain of Custody provided
50	1434 Taylor St NW	6/10/2013	No Chain of Custody provided
51	1620 Hamlin St NE	6/10/2013	Bottles not full; no stagnation
52	319 Ingraham St NW	6/10/2013	No lead; private side replacement reported on Chain of Custody
53	32 Todd Pl NE	6/10/2013	No Chain of Custody provided
54	3301 BROWN St NW	6/10/2013	Less than 6 hours stagnation
55	4118 13TH ST NW	6/10/2013	Leak in plumbing
56	4616 HUNT PL NE	6/10/2013	Ice maker on
57	7721 14th St NW	6/10/2013	Ice maker on
58	926 Hamilton St NW	6/10/2013	Ice maker on

Table C.4 Deviations from Sample Order

No	Address	Priority	Sched Month	Deviation Reason
1	1003 Otis St NE	Primary	Jan	No samples first time; dropped again ^[1]
2	1010 10th St NE	Primary	Jan	No samples first time; dropped again ^[1]
3	1014 Douglas St NE	Primary	Jan	No samples first time; dropped again ^[1]
4	109 19th St SE	New	June	Added site this semester ^[2]
5	1212 E Capitol St NE	Primary	Jan	No samples first time; dropped again ^[1]
6	1222 HAMILTON ST NW	Primary	Mar	No samples first time; dropped again ^[1]
7	125 Madison St NW	Primary	Jan	No samples first time; dropped again ^[1]
8	1339 U St SE	Secondary	Apr	No samples first time; dropped again ^[1]
9	1346 Madison St NW	Primary	Jan	No samples first time; dropped again ^[1]
10	1387 N Carolina Ave NE	Primary	Mar	No samples first time; dropped again ^[1]
11	1409 22nd St SE	Secondary	Apr	No samples first time; dropped again ^[1]
12	1420 Hamlin St NE	Primary	Mar	No samples first time; dropped again ^[1]
13	143 UHLAND TER NE	Primary	Jan	No samples first time; dropped again ^[1]
14	1434 Taylor St NW	Primary	Jan	No samples first time; dropped again ^[1]
15	1453 S St NW	Secondary	Apr	No samples first time; dropped again ^[1]
16	1525 D St NE	Secondary	Apr	No samples first time; dropped again ^[1]
17	1533 Upshur St NW	Secondary	Apr	No samples first time; dropped again ^[1]
18	1613 Webster St NW	New	Feb	Added site this semester ^[2]
19	1614 V St SE	Primary	Mar	No samples first time; dropped again ^[1]
20	1619 G St SE	Primary	Mar	No samples first time; dropped again ^[1]
21	1620 Hamlin St NE	Primary	Jan	No samples first time; dropped again ^[1]
22	1649 HARVARD ST NW	Primary	Jan	No samples first time; dropped again ^[1]
23	1671 Rosedale St NE	Primary	Mar	No samples first time; dropped again ^[1]
24	1705 2nd St NE	Primary	Jan	No samples first time; dropped again ^[1]
25	1931 SUMMIT PL NE	Primary	Mar	No samples first time; dropped again ^[1]
26	201 13th St NE	Primary	Mar	No samples first time; dropped again ^[1]
27	2107 2nd St NE	Secondary	Apr	No samples first time; dropped again ^[1]
28	2128 O ST NW	Primary	Jan	2 mailboxes at home; removed from LCR sampling
29	2300 Woodridge St NE	Secondary	Apr	No samples first time; dropped again ^[1]
30	231 K St NE	Primary	Mar	No samples first time; dropped again ^[1]
31	258 15th St SE	Secondary	Apr	No samples first time; dropped again ^[1]
32	2923 Cathedral AVE NW	Primary	Jan	No samples first time; dropped again ^[1]
33	3033 Bladensburg Rd NE	Secondary	Apr	No samples first time; dropped again ^[1]
34	3202 38TH ST NW	Primary	Mar	No samples first time; dropped again ^[1]
35	3216 Klinge Rd NW	Primary	Jan	No samples first time; dropped again ^[1]
36	3218 MORRISON ST NW	Primary	Jan	No samples first time; dropped again ^[1]
37	322 TENNESSEE AVE NE	Primary	Feb	No samples first time; dropped again ^[1]
38	3232 Klinge Rd NW	Primary	Feb	No samples first time; dropped again ^[1]
39	335 17TH PL NE	Primary	Apr	No samples first time; dropped again ^[1]

No	Address	Priority	Sched Month	Deviation Reason
40	3427 Oliver St NW	Secondary	Apr	No samples first time; dropped again ^[1]
41	3531 16TH ST NW	Primary	May	Apr samples rejected; dropped again in May
42	3612 34th St NW	Primary	Mar	No samples first time; dropped again ^[1]
43	3612 34th St NW	Primary	Mar	Missed drop in Feb, dropped in March
44	3625 Albermarle St NW	New	June	Added site this semester ^[2]
45	3908 13TH ST NW	Primary	Feb	No samples first time; dropped again ^[1]
46	3913 8TH ST NW	Primary	Apr	No samples first time; dropped again ^[1]
47	3973 HARRISON ST NW	Primary	Feb	No samples first time; dropped again ^[1]
48	410 Farragut St NW	Secondary	Apr	No samples first time; dropped again ^[1]
49	4111 INGOMAR ST NW	Primary	Feb	No samples first time; dropped again ^[1]
50	4118 13TH ST NW	Primary	Feb	No samples first time; dropped again ^[1]
51	4131 YUMA ST NW	Primary	Feb	No samples first time; dropped again ^[1]
52	42 Q St NE	Secondary	June	Called customer; they agreed to provide samples ^[1]
53	420 Kenyon St NW	Primary	Apr	No samples first time; dropped again ^[1]
54	4210 Clay St NE	Secondary	Apr	No samples first time; dropped again ^[1]
55	4215 39th St NW	Secondary	June	Called customer; they agreed to provide samples ^[1]
56	424 Luray Pl NW	Primary	Feb	No samples first time; dropped again ^[1]
57	4327 IOWA AVE NW	Primary	May	Apr samples rejected; dropped again in May
58	4409 Lowell St NW	Primary	Feb	Vacation; sample next semester
59	4419 14th St NE	Secondary	Apr	No samples first time; dropped again ^[1]
60	4423 Kane Pl NE	Secondary	Apr	No samples first time; dropped again ^[1]
61	449 S St NW	Secondary	Apr	No samples first time; dropped again ^[1]
62	452 Newton Pl NW	Secondary	Apr	No samples first time; dropped again ^[1]
63	4606 Sheriff Rd NE	Secondary	Apr	No samples first time; dropped again ^[1]
64	4609 5th St NW	Secondary	Apr	No samples first time; dropped again ^[1]
65	4818 ILLINOIS AVE NW	Primary	Feb	No samples first time; dropped again ^[1]
66	507 Alabama Ave SE	Secondary	Apr	No samples first time; dropped again ^[1]
67	522 Park Rd NW	Secondary	June	Called customer; they agreed to provide samples ^[1]
68	524 10th St SE	Primary	Feb	No samples first time; dropped again ^[1]
69	524 Shepherd St NW	Primary	Feb	Requested to not participate in LCR program
70	5316 28th St NW	Primary	Apr	No samples first time; dropped again ^[1]
71	5731 3rd Pl NW	Primary	Feb	Vacation; sample next semester
72	5817 7th St NW	Primary	Feb	No samples first time; dropped again ^[1]
73	611 Roxboro Pl NW	Primary	Mar	No samples first time; dropped again ^[1]
74	619 Girard St NE	Primary	Mar	No samples first time; dropped again ^[1]
75	621 Upshur St NW	Primary	Mar	No samples first time; dropped again ^[1]
76	644 Lamont St NW	Primary	Mar	No samples first time; dropped again ^[1]
77	702 9th St SE	Primary	Mar	No samples first time; dropped again ^[1]
78	720 ALABAMA AVE SE	Primary	Mar	No samples first time; dropped again ^[1]
79	743 Gresham Pl NW	Primary	Mar	No samples first time; dropped again ^[1]

No	Address	Priority	Sched Month	Deviation Reason
80	753 Gresham Pl NW	Primary	Mar	No samples first time; dropped again ^[1]
81	8 N St SW	Primary	Mar	No samples first time; dropped again ^[1]
82	817 DECATUR ST NW	Secondary	June	Called customer; they agreed to provide samples ^[1]
83	87 S St NW	Primary	Mar	No samples first time; dropped again ^[1]
84	912 Emerson St NW	Primary	Mar	No samples first time; dropped again ^[1]
85	913 Hamlin St NE	Primary	Mar	No samples first time; dropped again ^[1]
86	926 Hamilton St NW	Primary	Mar	No samples first time; dropped again ^[1]

Notes:

- 1) DC Water did not have samples from 100 homes after the May sample distribution and collection. We called the remainder of the sites on the list to identify those that could provide samples in the next week. Customers from six homes agreed to provide samples the first week of June. DC Water distributed samples to the remainder of the pool and all the eligible homes that did not provide samples in January, February, March, and April sample distributions.
- 2) New participants are customers who contacted DC Water, requested a lead test, and agreed to participate in the Lead and Copper Monitoring Program. All new participants are single family homes and a full lead service line according to DC Water records.

Table C.5 Sites with Compliance Results from January 2012 – December 2012 and No Results in January - June 2013

No.	Address	Reason
1	1010 10th St NE	Did not return bottles; See Table C.2
2	1011 Taylor St NE	Samples rejected; See Table C.3
3	1014 Douglas St NE	Did not return bottles; See Table C.2
4	1025 44th St NE	Samples rejected; See Table C.3
5	1106 Allison St NW	Samples rejected; See Table C.3
6	118 Kentucky Ave SE	Removed from Sample Pool prior to 2013
7	119 16TH ST NE	Samples rejected; See Table C.3
8	1212 E Capitol St NE	Did not return bottles; See Table C.2
9	1315 FRANKLIN ST NE	Samples rejected; See Table C.3
10	1346 F St NE	Samples rejected; See Table C.3
11	1346 Madison St NW	Did not return bottles; See Table C.2
12	1420 Hamlin St NE	Did not return bottles; See Table C.2
13	1434 Taylor St NW	Samples rejected; See Table C.3
14	144 Tennessee Ave NE	Removed from Sample Pool prior to 2013
15	1520 Locust Rd NW	Samples rejected; See Table C.3
16	1614 V St SE	Did not return bottles; See Table C.2
17	1705 2nd St NE	Did not return bottles; See Table C.2
18	1836 L St NE	Samples rejected; See Table C.3
19	201 13th St NE	Did not return bottles; See Table C.2
20	2128 O ST NW	Removed from Sample Pool this semester: See Table C.4
21	231 K St NE	Did not return bottles; See Table C.2
22	234 Longfellow St NW	Samples rejected; See Table C.3
23	2435 33RD ST SE	Samples rejected; See Table C.3
24	3202 38TH ST NW	Did not return bottles; See Table C.2
25	3216 Klinge Rd NW	Did not return bottles; See Table C.2
26	3218 MORRISON ST NW	Did not return bottles; See Table C.2
27	322 TENNESSEE AVE NE	Did not return bottles; See Table C.2
28	3232 Klinge Rd NW	Did not return bottles; See Table C.2
29	335 17TH PL NE	Did not return bottles; See Table C.2
30	349 TENNESSEE AVE NE	Removed from Sample Pool prior to 2013
31	3531 16TH ST NW	Samples rejected; See Table C.3
32	3612 34th St NW	Did not return bottles; See Table C.2
33	3706 35th St NW	Samples rejected; See Table C.3
34	3913 8TH ST NW	Did not return bottles; See Table C.2
35	3973 HARRISON ST NW	Did not return bottles; See Table C.2
36	4111 INGOMAR ST NW	Did not return bottles; See Table C.2
37	420 Kenyon St NW	Did not return bottles; See Table C.2
38	4214 8th St NW	Samples rejected; See Table C.3
39	4409 Lowell St NW	No bottles dropped this semester; See Table C.4

No.	Address	Reason
40	4613 9th St NW	Samples rejected; See Table C.3
41	4818 ILLINOIS AVE NW	Did not return bottles; See Table C.2
42	501 Webster St NW	Samples rejected; See Table C.3
43	502 Oglethorpe St NW	Removed from Sample Pool prior to 2013
44	5024 7th St NW	Samples rejected; See Table C.3
45	524 10th St SE	Did not return bottles; See Table C.2
46	5316 28th St NW	Did not return bottles; See Table C.2
47	5613 30th St NW	Samples rejected; See Table C.3
48	611 Roxboro Pl NW	Did not return bottles; See Table C.2
49	619 Girard St NE	Did not return bottles; See Table C.2
50	6213 7TH ST NW	Samples rejected; See Table C.3
51	636 ROCK CRK CHURCH RD NW	Samples rejected; See Table C.3
52	7129 Georgia Ave NW	Removed from Sample Pool prior to 2013
53	720 ALABAMA AVE SE	Did not return bottles; See Table C.2
54	753 Gresham Pl NW	Did not return bottles; See Table C.2
55	913 Hamlin St NE	Did not return bottles; See Table C.2
56	926 Hamilton St NW	Samples rejected; See Table C.3

Appendix D: Revisions to Sample Pool

Table D.1 Sample Pool for July to December 2013 Monitoring Period

No.	Address	Pipe Material	Priority
1	10 S St NW	Lead	Primary
2	1003 Otis St NE	Lead	Primary
3	1003 Quebec Pl NW	Lead	Primary
4	1010 10th St NE	Lead	Primary
5	1011 Taylor St NE	Lead	Primary
6	1025 44th St NE	Lead	Primary
7	108 Varnum St NW	Lead	Primary
8	109 19th St SE	Lead	Primary
9	1106 Allison St NW	Lead	Primary
10	119 16TH ST NE	Lead	Primary
11	125 Madison St NW	Lead	Primary
12	1262 COLUMBIA RD NW	Lead	Primary
13	1315 FRANKLIN ST NE	Lead	Primary
14	1318 Wallach Pl NW	Lead	Primary
15	1331 Irving St NE	Lead	Primary
16	1339 U St SE	Lead	Primary
17	1346 F St NE	Lead	Primary
18	1357 C St NE	Lead	Primary
19	1378 Taylor St NW	Lead	Primary
20	1424 S ST NW	Lead	Primary
21	1429 Ives Pl SE	Lead	Primary
22	1434 Taylor St NW	Lead	Primary
23	1436 S St NW	Lead	Primary
24	1453 S St NW	Lead	Primary
25	15 Milmarson Pl NW	Lead	Primary
26	1505 Buchanan St NW	Lead	Primary
27	1519 Olive St NE	Lead	Primary
28	1520 Locust Rd NW	Lead	Primary
29	1613 Webster St NW	Lead	Primary
30	1620 Hamlin St NE	Lead	Primary
31	1620 Webster St NW	Lead	Primary
32	1623 U St SE	Lead	Primary
33	1635 WEBSTER ST NW	Lead	Primary
34	1649 HARVARD ST NW	Lead	Primary
35	1703 D St NE	Lead	Primary
36	1706 NEW JERSEY AVE NW	Lead	Primary
37	1826 Jackson St NE	Lead	Primary
38	2007 37TH ST NW	Lead	Primary
39	2107 2nd St NE	Lead	Primary
40	213 49th St NE	Lead	Primary

No.	Address	Pipe Material	Priority
41	2212 38th St NW	Lead	Primary
42	228 V ST NE	Lead	Primary
43	24 Evarts St NE	Lead	Primary
44	2435 33RD ST SE	Lead	Primary
45	2649 Bowen Rd SE	Lead	Primary
46	2830 BRENTWOOD RD NE	Lead	Primary
47	2913 Brandywine St NW	Lead	Primary
48	2923 Cathedral AVE NW	Lead	Primary
49	307 7th St NE	Lead	Primary
50	317 9th St SE	Lead	Primary
51	3206 38th St NW	Lead	Primary
52	3211 Central Ave NE	Lead	Primary
53	3216 Klinge Rd NW	Lead	Primary
54	3218 MACOMB ST NW	Lead	Primary
55	3218 MORRISON ST NW	Lead	Primary
56	322 TENNESSEE AVE NE	Lead	Primary
57	331 RALEIGH ST SE	Lead	Primary
58	331 Upshur St NW	Lead	Primary
59	336 Quackenbos St NE	Lead	Primary
60	3361 Stuyvesant PI NW	Lead	Primary
61	3400 Holmead PI NW	Lead	Primary
62	3511 Woodley Rd NW	Lead	Primary
63	3533 W PI NW	Lead	Primary
64	36 Florida Ave NW	Lead	Primary
65	3601 WARREN ST NW	Lead	Primary
66	3625 Albermarle St NW	Lead	Primary
67	3706 35th St NW	Lead	Primary
68	3710 Huntington St NW	Lead	Primary
69	3727 T St NW	Lead	Primary
70	3908 13TH ST NW	Lead	Primary
71	4111 INGOMAR ST NW	Lead	Primary
72	4118 13TH ST NW	Lead	Primary
73	4120 Grant St NE	Lead	Primary
74	4131 YUMA ST NW	Lead	Primary
75	4214 8th St NW	Lead	Primary
76	424 Luray PI NW	Lead	Primary
77	4307 CHESAPEAKE ST NW	Lead	Primary
78	4310 37th St NW	Lead	Primary
79	4401 5TH ST NW	Lead	Primary
80	4409 Lowell St NW	Lead	primary
81	4411 15th St NW	Lead	Primary
82	4418 14th St NE	Lead	Primary

No.	Address	Pipe Material	Priority
83	449 S St NW	Lead	Primary
84	4550 30TH ST NW	Lead	Primary
85	4613 9th St NW	Lead	Primary
86	4627 49th St NW	Lead	Primary
87	4703 Macarthur Blvd NW	Lead	Primary
88	4818 ILLINOIS AVE NW	Lead	Primary
89	4824 46th St NW	Lead	Primary
90	4926 Glenbrook Rd NW	Lead	Primary
91	501 Webster St NW	Lead	Primary
92	5024 7th St NW	Lead	Primary
93	5226 7th St NW	Lead	Primary
94	5234 Illinois Ave NW	Lead	Primary
95	524 10th St SE	Lead	Primary
96	531 Tennessee Ave NE	Lead	Primary
97	5318 9TH ST NW	Lead	Primary
98	5517 7th St NW	Lead	Primary
99	5613 30th St NW	Lead	Primary
100	5731 3rd PI NW	Lead	primary
101	580 49th PI NE	Lead	Primary
102	5817 7th St NW	Lead	Primary
103	5923 33rd St NW	Lead	Primary
104	6001 33rd St NW	Lead	Primary
105	608 Gallatin St NW	Lead	Primary
106	6105 Dix St NE	Lead	Primary
107	611 Roxboro PI NW	Lead	Primary
108	617 6th St NE	Lead	Primary
109	619 12th St NE	Lead	Primary
110	619 Girard St NE	Lead	Primary
111	6210 8th St NW	Lead	Primary
112	6308 8th St NW	Lead	Primary
113	636 ROCK CRK CHURCH RD NW	Lead	Primary
114	641 Gallatin St NW	Lead	Primary
115	644 Lamont St NW	Lead	Primary
116	702 9th St SE	Lead	Primary
117	743 Gresham PI NW	Lead	Primary
118	75 Bates St NW	Lead	Primary
119	753 Gresham PI NW	Lead	Primary
120	8 N St SW	Lead	Primary
121	804 Delafield PI NW	Lead	Primary
122	807 Buchanan St NW	Lead	Primary
123	834 Delafield PI NW	Lead	Primary
124	87 S St NW	Lead	Primary

No.	Address	Pipe Material	Priority
125	905 Kent PI NE	Lead	Primary
126	912 Emerson St NW	Lead	Primary
127	913 Hamlin St NE	Lead	Primary
128	926 Hamilton St NW	Lead	Primary
129	1203 Quincy St NW	Partial Lead	Primary
130	1211 Carrollsburg PI SW	Partial Lead	Primary
131	1222 HAMILTON ST NW	Partial Lead	Primary
132	1319 POTOMAC AVE SE	Partial Lead	Primary
133	1353 JEFFERSON ST NW	Partial Lead	Primary
134	1387 N Carolina Ave NE	Partial Lead	Primary
135	1412 S St NW	Partial Lead	Primary
136	1412 Shepherd St NW	Partial Lead	Primary
137	1420 Hamlin St NE	Partial Lead	Primary
138	1603 Massachusetts Ave SE	Partial Lead	Primary
139	1731 L St NE	Partial Lead	Primary
140	1736 Bay St SE	Partial Lead	Primary
141	1808 KEARNEY ST NE	Partial Lead	Primary
142	1836 L St NE	Partial Lead	Primary
143	1843 MONROE ST NW	Partial Lead	Primary
144	1908 Biltmore St NW	Partial Lead	Primary
145	2118 14th St SE	Partial Lead	Primary
146	223 14th PI NE	Partial Lead	Primary
147	230 G St NE	Partial Lead	Primary
148	231 K St NE	Partial Lead	Primary
149	234 Longfellow St NW	Partial Lead	Primary
150	2408 2nd St NE	Partial Lead	Primary
151	302 RITTENHOUSE ST NW	Partial Lead	Primary
152	3036 P St NW	Partial Lead	Primary
153	308 9th St SE	Partial Lead	Primary
154	32 Todd PI NE	Partial Lead	Primary
155	3202 38TH ST NW	Partial Lead	Primary
156	3215 Mckinley St NW	Partial Lead	Primary
157	3301 BROWN St NW	Partial Lead	Primary
158	333 34th St NE	Partial Lead	Primary
159	335 17TH PL NE	Partial Lead	Primary
160	3416 9th St NE	Partial Lead	Primary
161	3531 16TH ST NW	Partial Lead	Primary
162	3809 ALTON PL NW	Partial Lead	Primary
163	3907 13th St NW	Partial Lead	Primary
164	3913 8TH ST NW	Partial Lead	Primary
165	3917 8th St NW	Partial Lead	Primary
166	413 4th St SE	Partial Lead	Primary

No.	Address	Pipe Material	Priority
167	4215 39th St NW	Partial Lead	Primary
168	4327 IOWA AVE NW	Partial Lead	Primary
169	4332 BRANDYWINE ST NW	Partial Lead	Primary
170	4616 HUNT PL NE	Partial Lead	Primary
171	4818 8th ST NW	Partial Lead	Primary
172	53 P St NW	Partial Lead	Primary
173	53 V St NW	Partial Lead	Primary
174	5301 RENO RD NW	Partial Lead	Primary
175	5316 28th St NW	Partial Lead	Primary
176	5404 39TH ST NW	Partial Lead	Primary
177	605 Columbia Rd NW	Partial Lead	Primary
178	605 ROCK CRK CHURCH RD NW	Partial Lead	Primary
179	617 M St NE	Partial Lead	Primary
180	6213 7TH ST NW	Partial Lead	Primary
181	7721 14th St NW	Partial Lead	Primary
182	780 Fairmont St NW	Partial Lead	Primary
183	1014 Douglas St NE	Lead	Secondary
184	1212 E Capitol St NE	Lead	Secondary
185	1346 Madison St NW	Lead	Secondary
186	143 UHLAND TER NE	Lead	Secondary
187	1705 2nd St NE	Lead	Secondary
188	3232 Klinge Rd NW	Lead	Secondary
189	3612 34th St NW	Lead	Secondary
190	416 7th St NE	Lead	Secondary
191	5907 4th St NW	Lead	Secondary
192	621 Upshur St NW	Lead	Secondary
193	720 ALABAMA AVE SE	Lead	Secondary
194	822 K St NE	Lead	Secondary
195	910 Farragut St NW	Lead	Secondary
196	915 Farragut St NW	Lead	Secondary
197	915 Shepherd St NW	Lead	Secondary
198	1207 Trinidad Ave NE	Partial Lead	Secondary
199	1214 Evarts St NE	Partial Lead	Secondary
200	1238 HALF ST SW	Partial Lead	Secondary
201	1353 Iris St NW	Partial Lead	Secondary
202	1424 S ST SE	Partial Lead	Secondary
203	1614 V St SE	Partial Lead	Secondary
204	1619 G St SE	Partial Lead	Secondary
205	1671 Rosedale St NE	Partial Lead	Secondary
206	1802 35TH ST NW	Partial Lead	Secondary
207	1802 Kilbourne PI NW	Partial Lead	Secondary
208	1850 2ND ST NW	Partial Lead	Secondary

No.	Address	Pipe Material	Priority
209	1931 SUMMIT PL NE	Partial Lead	Secondary
210	201 13th St NE	Partial Lead	Secondary
211	205 TAYLOR ST NW	Partial Lead	Secondary
212	2220 13th St SE	Partial Lead	Secondary
213	228 Randolph Pl NE	Partial Lead	Secondary
214	2305 Minnesota Ave SE	Partial Lead	Secondary
215	2823 28TH ST NW	Partial Lead	Secondary
216	2928 33rd Pl NW	Partial Lead	Secondary
217	3030 44TH ST NW	Partial Lead	Secondary
218	3105 34th St NW	Partial Lead	Secondary
219	312 14TH ST NE	Partial Lead	Secondary
220	313 16th St SE	Partial Lead	Secondary
221	3428 Brown St NW	Partial Lead	Secondary
222	3721 Windom Pl NW	Partial Lead	Secondary
223	42 Q St NE	Partial Lead	Secondary
224	420 Kenyon St NW	Partial Lead	Secondary
225	441 Quincy St NW	Partial Lead	Secondary
226	506 Irving St NW	Partial Lead	Secondary
227	513 Florida Ave NE	Partial Lead	Secondary
228	514 13th St SE	Partial Lead	Secondary
229	522 Park Rd NW	Partial Lead	Secondary
230	5304 Reno Rd NW	Partial Lead	Secondary
231	617 Kenyon St NW	Partial Lead	Secondary
232	661 MARYLAND AVE NE	Partial Lead	Secondary
233	736 Fairmont St NW	Partial Lead	Secondary
234	75 P St NW	Partial Lead	Secondary
235	765 GIRARD ST NW	Partial Lead	Secondary
236	817 DECATUR ST NW	Partial Lead	Secondary
237	833 DECATUR ST NW	Partial Lead	Secondary
238	924 Hamilton St NW	Partial Lead	Secondary

Table D.2 Site Changes - Sites Removed, Added, or Priority Status Changed

No	Address	Pipe Material	Previous Priority	New Priority	Reason
1	1003 Quebec Pl NW	Lead	Secondary	Primary	Returned bottles this semester
2	1014 Douglas St NE	Lead	Primary	Secondary	Did not return bottles in last two sampling events
3	108 Varnum St NW	Lead	Secondary	Primary	Returned bottles this semester
4	109 19th St SE	Lead	New Site	Primary	New site added this semester
5	1212 E Capitol St NE	Lead	Primary	Secondary	Did not return bottles in last two sampling events
6	1331 Irving St NE	Lead	Secondary	Primary	Returned bottles this semester
7	1339 U St SE	Lead	Secondary	Primary	Returned bottles this semester
8	1346 Madison St NW	Lead	Primary	Secondary	Did not return bottles in last two sampling events
9	1409 22nd St SE	Lead	Secondary	Removed	Did not return bottles in last four sampling events
10	1412 N Carolina Ave NE	Partial Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
11	1412 S St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
12	1412 Shepherd St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
13	1424 Perry Pl NW	Partial Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
14	143 UHLAND TER NE	Lead	Primary	Secondary	Did not return bottles in last two sampling events
15	1436 S St NW	Lead	Secondary	Primary	Returned bottles this semester
16	1451 S ST NW	Partial Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
17	1453 S St NW	Lead	Secondary	Primary	Returned bottles this semester
18	1505 Lawrence St NE	Partial Lead	Secondary	Removed	Ice maker cannot be turned off
19	1523 D St SE	Partial Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
20	1525 D St NE	Lead	Secondary	Removed	Did not return bottles in last four sampling events
21	1533 Constitution Ave NE	Partial Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
22	1533 Upshur St NW	Lead	Secondary	Removed	Did not return bottles in last four sampling events
23	1613 Webster St NW	Lead	New Site	Primary	New site added this semester
24	1614 V St SE	Partial Lead	Primary	Secondary	Did not return bottles in last two sampling events
25	1619 G St SE	Partial Lead	Primary	Secondary	Did not return bottles in last two sampling events

No	Address	Pipe Material	Previous Priority	New Priority	Reason
26	1671 Rosedale St NE	Partial Lead	Primary	Secondary	Did not return bottles in last two sampling events
27	1705 2nd St NE	Lead	Primary	Secondary	Did not return bottles in last two sampling events
28	1755 Lanier Pl NW	Partial Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
29	1825 L St NE	Partial Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
30	1839 MONROE ST NW	Partial Lead	Secondary	Removed	Multi-family residence
31	1843 MONROE ST NW	Partial Lead	Secondary	Primary	Returned bottles this semester
32	1863 MONROE ST NW	Partial Lead	Secondary	Removed	Multi-family residence
33	1908 Biltmore St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
34	1931 SUMMIT PL NE	Partial Lead	Primary	Secondary	Did not return bottles in last two sampling events
35	201 13th St NE	Partial Lead	Primary	Secondary	Did not return bottles in last two sampling events
36	202 11th St SE	Partial Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
37	2107 2nd St NE	Lead	Secondary	Primary	Returned bottles this semester
38	2118 14th St SE	Partial Lead	Secondary	Primary	Returned bottles this semester
39	2128 O St NW	Lead	Primary	Removed	Multi-family residence
40	2300 Woodridge St NE	Lead	Secondary	Removed	Did not return bottles in last four sampling events
41	24 Everts St NE	Lead	Secondary	Primary	Returned bottles this semester
42	2408 2nd St NE	Partial Lead	Secondary	Primary	Returned bottles this semester
43	258 15th St SE	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
44	2649 Bowen Rd SE	Lead	Secondary	Primary	Returned bottles this semester
45	3033 Bladensburg Rd NE	Lead	Secondary	Removed	Did not return bottles in last four sampling events
46	308 9th St SE	Partial Lead	Secondary	Primary	Returned bottles this semester
47	319 Ingraham St NW	Partial Lead	Secondary	Removed	No lead; public portion replaced in 2007; customer reported private side replacement conducted in 2010 (reported on 6/2013 Chain of Custody)
48	32 Todd Pl NE	Partial Lead	Secondary	Primary	Returned bottles this semester
49	3232 Klinge Rd NW	Lead	Primary	Secondary	Did not return bottles in last two sampling events
50	3301 BROWN St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
51	3361 Stuyvesant Pl NW	Lead	Secondary	Primary	Returned bottles this semester

No	Address	Pipe Material	Previous Priority	New Priority	Reason
52	3427 Oliver St NW	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
53	3511 Woodley Rd NW	Lead	Secondary	Primary	Returned bottles this semester
54	3612 34th St NW	Lead	Primary	Secondary	Did not return bottles in last two sampling events
55	3625 Albermarle St NW	Lead	New Site	Primary	New site added this semester
56	3973 HARRISON ST NW	Lead	Primary	Removed	Request no participation
57	410 Farragut St NW	Lead	Secondary	Removed	Did not return bottles in last four sampling events
58	420 Kenyon St NW	Partial Lead	Primary	Secondary	Did not return bottles in last two sampling events
59	4210 Clay St NE	Lead	Secondary	Removed	Did not return bottles in last four sampling events
60	4215 39th St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
61	432 15th St SE	Lead	Secondary	Removed	Request no participation
62	4419 14th St NE	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
63	4423 Kane Pl NE	Lead	Secondary	Removed	Did not return bottles in last four sampling events
64	449 S St NW	Lead	Secondary	Primary	Returned bottles this semester
65	452 Newton Pl NW	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
66	4606 Sheriff Rd NE	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
67	4609 5th St NW	Lead	Secondary	Removed	Did not return bottles in last four sampling events
68	4616 HUNT PL NE	Partial Lead	Secondary	Primary	Returned bottles this semester
69	507 Alabama Ave SE	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
70	518 Varnum St NW	Partial Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
71	524 Shepherd St NW	Lead	Primary	Removed	Request no participation
72	53 P St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
73	53 P St NW	Partial Lead	Primary	Primary	Customer reported private side replacement conducted in October 2012; reported on May 2013 Chain of Custody
74	53 V St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
75	5301 RENO RD NW	Partial Lead	Secondary	Primary	Returned bottles this semester
76	536 Newton Pl NW	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events

No	Address	Pipe Material	Previous Priority	New Priority	Reason
77	5516 Kansas Ave NW	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
78	5909 16th St NW	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
79	605 ROCK CRK CHURCH RD NW	Partial Lead	Secondary	Primary	Returned bottles this semester
80	621 Upshur St NW	Lead	Primary	Secondary	Did not return bottles in last two sampling events
81	632 Webster St NW	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
82	720 ALABAMA AVE SE	Lead	Primary	Secondary	Did not return bottles in last two sampling events
83	760 Gresham Pl NW	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
84	7721 14th St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
85	81 O St NW	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
86	810 Savannah St SE	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events
87	811 E St SE	Lead	Secondary	Removed	Multi-family residence
88	88 R St NW	Lead	Secondary	Removed	Removed; not returned bottles in last four sampling events

Notes:

- 1) New participants are customers who contacted DC Water, requested a lead test, and agreed to participate in the Lead and Copper Monitoring Program. All new participants are single family homes and a full lead service line according to DC Water records.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-001

SAMPLE INFORMATION

Sample Number: 1302023-001 Customer Sample Number: 3100985 Project: LCR
Location: 1st draw 1703 D ST NE Type: Dist.

Collection Date: 1/28/2013 Collection Time: 17:26 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.085 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	2/15/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/11/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-002

SAMPLE INFORMATION

Sample Number: 1302023-002 Customer Sample Number: 3100985 Project: LCR
Location: 2nd draw 1703 D ST NE Type: Dist.

Collection Date: 1/28/2013 Collection Time: 17:28 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.098 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-003

SAMPLE INFORMATION

Sample Number: 1302023-003 Customer Sample Number: 3107442 Project: LCR
Location: 1st draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 6:01 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.077 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-004

SAMPLE INFORMATION

Sample Number: 1302023-004 Customer Sample Number: 3107442 Project: LCR
Location: 2nd draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.066 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-005

SAMPLE INFORMATION

Sample Number: 1302023-005 Customer Sample Number: 3124875 Project: LCR
Location: 1st draw 228 V ST NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 19:45 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.029 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-006

SAMPLE INFORMATION

Sample Number: 1302023-006 Customer Sample Number: 3124875 Project: LCR
Location: 2nd draw 228 V ST NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 19:48 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.101 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-007

SAMPLE INFORMATION

Sample Number: 1302023-007 Customer Sample Number: 3006211 Project: LCR
Location: 1st draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 1/29/2013 Collection Time: 18:40 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-008

SAMPLE INFORMATION

Sample Number: 1302023-008 Customer Sample Number: 3006211 Project: LCR
Location: 2nd draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 1/29/2013 Collection Time: 18:43 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-009

SAMPLE INFORMATION

Sample Number: 1302023-009 Customer Sample Number: 3107490 Project: LCR
Location: 1st draw 2830 BRENTWOOD RD NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 21:20 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.028 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-010

SAMPLE INFORMATION

Sample Number: 1302023-010 Customer Sample Number: 3107490 Project: LCR
Location: 2nd draw 2830 BRENTWOOD RD NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 21:22 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.025 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-011

SAMPLE INFORMATION

Sample Number: 1302023-011 Customer Sample Number: 3029191 Project: LCR
Location: 1st draw 1620 WEBSTER ST NW Type: Dist.

Collection Date: 1/29/2013 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.050 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-012

SAMPLE INFORMATION

Sample Number: 1302023-012 Customer Sample Number: 3029191 Project: LCR
Location: 2nd draw 1620 WEBSTER ST NW Type: Dist.

Collection Date: 1/29/2013 Collection Time: 5:53 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-013

SAMPLE INFORMATION

Sample Number: 1302023-013 Customer Sample Number: 3073087 Project: LCR
Location: 1st draw 317 9TH ST SE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.040 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.062 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/11/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-014

SAMPLE INFORMATION

Sample Number: 1302023-014 Customer Sample Number: 3073087 Project: LCR
Location: 2nd draw 317 9TH ST SE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 18:33 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.040 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-015

SAMPLE INFORMATION

Sample Number: 1302023-015 Customer Sample Number: 3058228 Project: LCR
Location: 1st draw 2913 BRANDYWINE ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 9:05 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.110 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.031 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-016

SAMPLE INFORMATION

Sample Number: 1302023-016 Customer Sample Number: 3058228 Project: LCR
Location: 2nd draw 2913 BRANDYWINE ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 9:07 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.041 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-017

SAMPLE INFORMATION

Sample Number: 1302023-017 Customer Sample Number: 3109545 Project: LCR
Location: 1st draw 213 49TH ST NE Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.025 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-018

SAMPLE INFORMATION

Sample Number: 1302023-018 Customer Sample Number: 3109545 Project: LCR
Location: 2nd draw 213 49TH ST NE Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:34 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-019

SAMPLE INFORMATION

Sample Number: 1302023-019 Customer Sample Number: 3111675 Project: LCR
Location: 1st draw 307 7TH ST NE Type: Dist.

Collection Date: 1/30/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-020

SAMPLE INFORMATION

Sample Number: 1302023-020 Customer Sample Number: 3111675 Project: LCR
Location: 2nd draw 307 7TH ST NE Type: Dist.

Collection Date: 1/30/2013 Collection Time: 6:52 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/11/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-021

SAMPLE INFORMATION

Sample Number: 1302023-021 Customer Sample Number: 3028665 Project: LCR
Location: 1st draw 1378 TAYLOR ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0031 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-022

SAMPLE INFORMATION

Sample Number: 1302023-022 Customer Sample Number: 3028665 Project: LCR
Location: 2nd draw 1378 TAYLOR ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-023

SAMPLE INFORMATION

Sample Number: 1302023-023 Customer Sample Number: 3002817 Project: LCR
Location: 1st draw 1318 WALLACH PL NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.037 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-024

SAMPLE INFORMATION

Sample Number: 1302023-024 Customer Sample Number: 3002817 Project: LCR
Location: 2nd draw 1318 WALLACH PL NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:28 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-025

SAMPLE INFORMATION

Sample Number: 1302023-025 Customer Sample Number: 3009912 Project: LCR
Location: 1st draw 2007 37TH ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.081 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-026

SAMPLE INFORMATION

Sample Number: 1302023-026 Customer Sample Number: 3009912 Project: LCR
Location: 2nd draw 2007 37TH ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-027

SAMPLE INFORMATION

Sample Number: 1302023-027 Customer Sample Number: 3035196 Project: LCR
Location: 1st draw 3206 38TH ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.150 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-028

SAMPLE INFORMATION

Sample Number: 1302023-028 Customer Sample Number: 3035196 Project: LCR
Location: 2nd draw 3206 38TH ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 8:02 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0055 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-029

SAMPLE INFORMATION

Sample Number: 1302023-029 Customer Sample Number: 3026174 Project: LCR
Location: 1st draw 15 MILMARSON PL NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 5:38 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.086 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-030

SAMPLE INFORMATION

Sample Number: 1302023-030 Customer Sample Number: 3026714 Project: LCR
Location: 2nd draw 15 MILMARSON PL NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.047 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-031

SAMPLE INFORMATION

Sample Number: 1302023-031 Customer Sample Number: 3100201 Project: LCR
Location: 1st draw 1357 C ST NE Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	< 0.001 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-032

SAMPLE INFORMATION

Sample Number: 1302023-032 Customer Sample Number: 3100201 Project: LCR
Location: 2nd draw 1357 C ST NE Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	ND mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/11/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-033

SAMPLE INFORMATION

Sample Number: 1302023-033 Customer Sample Number: 3111360 Project: LCR
Location: 1st draw 1519 OLIVE ST, NE Type: Dist.

Collection Date: 1/31/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.097 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-034

SAMPLE INFORMATION

Sample Number: 1302023-034 Customer Sample Number: 3111360 Project: LCR
Location: 2nd draw 1519 OLIVE ST, NE Type: Dist.

Collection Date: 1/31/2013 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.086 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	2/15/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/11/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-035

SAMPLE INFORMATION

Sample Number: 1302023-035 Customer Sample Number: 3029182 Project: LCR
Location: 1st draw 1635 WEBSTER ST, NW Type: Dist.

Collection Date: 1/31/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.029 mg/L	2/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	2/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-036

SAMPLE INFORMATION

Sample Number: 1302023-036 Customer Sample Number: 3029182 Project: LCR
Location: 2nd draw 1635 WEBSTER ST, NW Type: Dist.

Collection Date: 1/31/2013 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-037

SAMPLE INFORMATION

Sample Number: 1302023-037 Customer Sample Number: 3017940 Project: LCR
Location: 1st draw 10 S ST NW Type: Dist.

Collection Date: 1/31/2013 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.026 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-038

SAMPLE INFORMATION

Sample Number: 1302023-038 Customer Sample Number: 3017940 Project: LCR
Location: 2nd draw 10 S ST NW Type: Dist.

Collection Date: 1/31/2013 Collection Time: 6:47 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-039

SAMPLE INFORMATION

Sample Number: 1302023-039 Customer Sample Number: 3035973 Project: LCR
Location: 1st draw 3218 MACOMB ST NW Type: Dist.

Collection Date: 1/31/2013 Collection Time: 6:22 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.063 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-040

SAMPLE INFORMATION

Sample Number: 1302023-040 Customer Sample Number: 3035973 Project: LCR
Location: 2nd draw 3218 MACOMB ST NW Type: Dist.

Collection Date: 1/31/2013 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0036 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-041

SAMPLE INFORMATION

Sample Number: 1302023-041 Customer Sample Number: 3010160 Project: LCR
Location: 1st draw 2212 38TH ST NW Type: Dist.

Collection Date: 1/31/2013 Collection Time: 17:57 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.036 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302023-042

SAMPLE INFORMATION

Sample Number: 1302023-042 Customer Sample Number: 3010160 Project: LCR
Location: 2nd draw 2212 38TH ST NW Type: Dist.

Collection Date: 1/31/2013 Collection Time: 17:57 Sampler: HOME OWNER Received Date and Time: 2/5/2013 10:39:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/11/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302048-001

SAMPLE INFORMATION

Sample Number: 1302048-001 Customer Sample Number: 3106027 Project: LCR
Location: 1st draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 2/7/2013 10:24:13 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.026 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302048-002

SAMPLE INFORMATION

Sample Number: 1302048-002 Customer Sample Number: 3106027 Project: LCR
Location: 2nd draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 2/7/2013 10:24:13 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.026 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302096-001

SAMPLE INFORMATION

Sample Number: 1302096-001 Customer Sample Number: 3027905 Project: LCR
Location: 1st draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 2/12/2013 4:20:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.104 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0370 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302096-002

SAMPLE INFORMATION

Sample Number: 1302096-002 Customer Sample Number: 3027905 Project: LCR
Location: 2nd draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:52 Sampler: HOME OWNER Received Date and Time: 2/12/2013 4:20:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	3/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0055 mg/L	3/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302154-001

SAMPLE INFORMATION

Sample Number: 1302154-001 Customer Sample Number: 3002488 Project: LCR
Location: 1st draw 1424 S ST NW Type: Dist.

Collection Date: 2/9/2013 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:05:09 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.048 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302154-002

SAMPLE INFORMATION

Sample Number: 1302154-002 Customer Sample Number: 3002488 Project: LCR
Location: 2nd draw 1424 S ST NW Type: Dist.

Collection Date: 2/9/2013 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:05:09 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-001

SAMPLE INFORMATION

Sample Number: 1303012-001 Customer Sample Number: 3122289 Project: LCR
Location: 1st Draw 531 TENNESSEE AVE NE Type: Dist.

Collection Date: 2/25/2013 Collection Time: 18:14 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-002

SAMPLE INFORMATION

Sample Number: 1303012-002 Customer Sample Number: 3122289 Project: LCR
Location: 2nd Draw 531 TENNESSEE AVE NE Type: Dist.

Collection Date: 2/25/2013 Collection Time: 18:15 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-003

SAMPLE INFORMATION

Sample Number: 1303012-003 Customer Sample Number: 3041389 Project: LCR
Location: 1st Draw 3601 WARREN ST. NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.041 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.037 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-004

SAMPLE INFORMATION

Sample Number: 1303012-004 Customer Sample Number: 3041389 Project: LCR
Location: 2nd Draw 3601 WARREN ST. NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 6:28 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.086 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-005

SAMPLE INFORMATION

Sample Number: 1303012-005 Customer Sample Number: 3041310 Project: LCR
Location: 1st Draw 4310 37TH ST NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-006

SAMPLE INFORMATION

Sample Number: 1303012-006 Customer Sample Number: 3041310 Project: LCR
Location: 2nd Draw 4310 37TH ST NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-007

SAMPLE INFORMATION

Sample Number: 1303012-007 Customer Sample Number: 3021575 Project: LCR
Location: 1st Draw 4401 5TH ST. NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 7:49 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.080 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-008

SAMPLE INFORMATION

Sample Number: 1303012-008 Customer Sample Number: 3021575 Project: LCR
Location: 2nd Draw 4401 5TH ST. NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.046 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-009

SAMPLE INFORMATION

Sample Number: 1303012-009 Customer Sample Number: 3070403 Project: LCR
Location: 1st Draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 2/26/2013 Collection Time: 15:08 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.032 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-010

SAMPLE INFORMATION

Sample Number: 1303012-010 Customer Sample Number: 3070403 Project: LCR
Location: 2nd Draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 2/26/2013 Collection Time: 15:12 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-011

SAMPLE INFORMATION

Sample Number: 1303012-011 Customer Sample Number: 3051579 Project: LCR
Location: 1st Draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 21:30 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0038 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-012

SAMPLE INFORMATION

Sample Number: 1303012-012 Customer Sample Number: 3051579 Project: LCR
Location: 2nd Draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 21:32 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0029 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-013

SAMPLE INFORMATION

Sample Number: 1303012-013 Customer Sample Number: 3108722 Project: LCR
Location: 1st Draw 4120 GRANT ST NE Type: Dist.

Collection Date: 2/27/2013 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-014

SAMPLE INFORMATION

Sample Number: 1303012-014 Customer Sample Number: 3058406 Project: LCR
Location: 1st Draw 4550 30TH ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.030 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0039 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-015

SAMPLE INFORMATION

Sample Number: 1303012-015 Customer Sample Number: 3058406 Project: LCR
Location: 2nd Draw 4550 30TH ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:09 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0034 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-016

SAMPLE INFORMATION

Sample Number: 1303012-016 Customer Sample Number: 3024112 Project: LCR
Location: 1st Draw 5517 7TH ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.044 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-017

SAMPLE INFORMATION

Sample Number: 1303012-017 Customer Sample Number: 3024112 Project: LCR
Location: 2nd Draw 5517 7TH ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.038 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-018

SAMPLE INFORMATION

Sample Number: 1303012-018 Customer Sample Number: 3038949 Project: LCR
Location: 1st Draw 6001 33RD ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:18 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.023 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-019

SAMPLE INFORMATION

Sample Number: 1303012-019 Customer Sample Number: 3038949 Project: LCR
Location: 2nd Draw 6001 33RD ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:19 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-020

SAMPLE INFORMATION

Sample Number: 1303012-020 Customer Sample Number: 3043615 Project: LCR
Location: 1st Draw 4824 46TH ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.048 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0228 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-021

SAMPLE INFORMATION

Sample Number: 1303012-021 Customer Sample Number: 3043615 Project: LCR
Location: 2nd Draw 4824 46TH ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.096 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0043 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-022

SAMPLE INFORMATION

Sample Number: 1303012-022 Customer Sample Number: 3043835 Project: LCR
Location: 1st Draw 4627 49TH ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.049 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-023

SAMPLE INFORMATION

Sample Number: 1303012-023 Customer Sample Number: 3043835 Project: LCR
Location: 2nd Draw 4627 49TH ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.032 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.052 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-024

SAMPLE INFORMATION

Sample Number: 1303012-024 Customer Sample Number: 3055284 Project: LCR
Location: 1st Draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:41 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.129 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0038 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-025

SAMPLE INFORMATION

Sample Number: 1303012-025 Customer Sample Number: 3055284 Project: LCR
Location: 2nd Draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:43 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-026

SAMPLE INFORMATION

Sample Number: 1303012-026 Customer Sample Number: 3040552 Project: LCR
Location: 1st Draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:44 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-027

SAMPLE INFORMATION

Sample Number: 1303012-027 Customer Sample Number: 3040552 Project: LCR
Location: 2nd Draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:47 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0039 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-028

SAMPLE INFORMATION

Sample Number: 1303012-028 Customer Sample Number: 3023204 Project: LCR
Location: 1st Draw 5226 7TH ST. NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.323 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-029

SAMPLE INFORMATION

Sample Number: 1303012-029 Customer Sample Number: 3023204 Project: LCR
Location: 2nd Draw 5226 7TH ST. NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.038 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0034 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-030

SAMPLE INFORMATION

Sample Number: 1303012-030 Customer Sample Number: 3010741 Project: LCR
Location: 1st Draw 3727 T ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.050 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.078 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0032 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-031

SAMPLE INFORMATION

Sample Number: 1303012-031 Customer Sample Number: 3010741 Project: LCR
Location: 2nd Draw 3727 T ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.066 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0053 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-032

SAMPLE INFORMATION

Sample Number: 1303012-032 Customer Sample Number: 3029171 Project: LCR
Location: 1st Draw 1613 WEBSTER ST. NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.076 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-033

SAMPLE INFORMATION

Sample Number: 1303012-033 Customer Sample Number: 3029171 Project: LCR
Location: 2nd Draw 1613 WEBSTER ST. NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.019 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.071 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-034

SAMPLE INFORMATION

Sample Number: 1303012-034 Customer Sample Number: 3109413 Project: LCR
Location: 1st Draw 580 49TH PL NE Type: Dist.

Collection Date: 2/27/2013 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-035

SAMPLE INFORMATION

Sample Number: 1303012-035 Customer Sample Number: 3109413 Project: LCR
Location: 2nd Draw 580 49TH PL NE Type: Dist.

Collection Date: 2/27/2013 Collection Time: 8:20 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-036

SAMPLE INFORMATION

Sample Number: 1303012-036 Customer Sample Number: 3104746 Project: LCR
Location: 1st Draw 4418 14TH ST NE Type: Dist.

Collection Date: 2/27/2013 Collection Time: 18:05 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.060 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-037

SAMPLE INFORMATION

Sample Number: 1303012-037 Customer Sample Number: 3104746 Project: LCR
Location: 2nd Draw 4418 14TH ST NE Type: Dist.

Collection Date: 2/27/2013 Collection Time: 18:15 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-038

SAMPLE INFORMATION

Sample Number: 1303012-038 Customer Sample Number: 3042083 Project: LCR
Location: 1st Draw 4307 CHESAPEAKE ST. NW Type: Dist.

Collection Date: 2/28/2013 Collection Time: 5:49 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.050 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-039

SAMPLE INFORMATION

Sample Number: 1303012-039 Customer Sample Number: 3042083 Project: LCR
Location: 2nd Draw 4307 CHESAPEAKE ST. NW Type: Dist.

Collection Date: 2/28/2013 Collection Time: 17:51 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-040

SAMPLE INFORMATION

Sample Number: 1303012-040 Customer Sample Number: 3038936 Project: LCR
Location: 1st Draw 5923 33RD ST NW Type: Dist.

Collection Date: 2/28/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.040 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.140 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-041

SAMPLE INFORMATION

Sample Number: 1303012-041 Customer Sample Number: 3038936 Project: LCR
Location: 2nd Draw 5923 33RD ST NW Type: Dist.

Collection Date: 2/28/2013 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.077 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-042

SAMPLE INFORMATION

Sample Number: 1303012-042 Customer Sample Number: 3009852 Project: LCR
Location: 1st Draw 3533 W PL NW Type: Dist.

Collection Date: 2/28/2013 Collection Time: 8:06 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303012-043

SAMPLE INFORMATION

Sample Number: 1303012-043 Customer Sample Number: 3009852 Project: LCR
Location: 2nd Draw 3533 W PL NW Type: Dist.

Collection Date: 2/28/2013 Collection Time: 8:07 Sampler: HOME OWNER Received Date and Time: 3/4/2013 9:14:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303038-001

SAMPLE INFORMATION

Sample Number: 1303038-001 Customer Sample Number: 3117544 Project: LCR
Location: 1st draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 2/28/2013 Collection Time: 6:11 Sampler: HOME OWNER Received Date and Time: 3/5/2013 4:06:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.101 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303038-002

SAMPLE INFORMATION

Sample Number: 1303038-002 Customer Sample Number: 3117544 Project: LCR
Location: 2nd draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 2/28/2013 Collection Time: 6:13 Sampler: HOME OWNER Received Date and Time: 3/5/2013 4:06:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.086 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303057-001

SAMPLE INFORMATION

Sample Number: 1303057-001 Customer Sample Number: 3045865 Project: LCR
Location: 1st draw 4926 GLENBROOK RD., NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:06 Sampler: HOME OWNER Received Date and Time: 3/8/2013 9:15:48 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.027 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/5/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303057-002

SAMPLE INFORMATION

Sample Number: 1303057-002 Customer Sample Number: 3045865 Project: LCR
Location: 2nd draw 4926 GLENBROOK RD., NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 6:08 Sampler: HOME OWNER Received Date and Time: 3/8/2013 9:15:48 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.051 mg/L	3/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-001

SAMPLE INFORMATION

Sample Number: 1304007-001 Customer Sample Number: 3022262 Project: LCR
Location: 1st Draw 834 DELAFIELD PL NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.049 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-002

SAMPLE INFORMATION

Sample Number: 1304007-002 Customer Sample Number: 3022262 Project: LCR
Location: 2nd Draw 834 DELAFIELD PL NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-003

SAMPLE INFORMATION

Sample Number: 1304007-003 Customer Sample Number: 3097707 Project: LCR
Location: 1st Draw 230 G ST NE Type: Dist.

Collection Date: 3/28/2013 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.030 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0044 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-004

SAMPLE INFORMATION

Sample Number: 1304007-004 Customer Sample Number: 3097707 Project: LCR
Location: 2nd Draw 230 G ST NE Type: Dist.

Collection Date: 3/28/2013 Collection Time: 6:39 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0088 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-005

SAMPLE INFORMATION

Sample Number: 1304007-005 Customer Sample Number: 3076112 Project: LCR
Location: 1st draw 1736 BAY ST SE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 16:17 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.141 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-006

SAMPLE INFORMATION

Sample Number: 1304007-006 Customer Sample Number: 3076112 Project: LCR
Location: 2nd Draw 1736 BAY ST SE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 16:18 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.124 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-007

SAMPLE INFORMATION

Sample Number: 1304007-007 Customer Sample Number: 3008069 Project: LCR
Location: 1st Draw 3036 P ST NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 7:53 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.066 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-008

SAMPLE INFORMATION

Sample Number: 1304007-008 Customer Sample Number: 3008069 Project: LCR
Location: 2nd draw 3036 P ST NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-009

SAMPLE INFORMATION

Sample Number: 1304007-009 Customer Sample Number: 3023157 Project: LCR
Location: 1st Draw 641 GALLATIN ST NW Type: Dist.

Collection Date: 3/28/2013 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0021 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-010

SAMPLE INFORMATION

Sample Number: 1304007-010 Customer Sample Number: 3023157 Project: LCR
Location: 2nd Draw 641 GALLATIN ST NW Type: Dist.

Collection Date: 3/28/2013 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.019 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-011

SAMPLE INFORMATION

Sample Number: 1304007-011 Customer Sample Number: 3130077 Project: LCR
Location: 1st Draw 223 14TH PL NE Type: Dist.

Collection Date: 3/25/2013 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.059 mg/L	4/12/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.140 mg/L	4/12/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0105 mg/L	4/12/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-012

SAMPLE INFORMATION

Sample Number: 1304007-012 Customer Sample Number: 3087203 Project: LCR
Location: 1st Draw 1319 POTOMAC AV SE Type: Dist.

Collection Date: 3/26/2013 Collection Time: 6:27 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-013

SAMPLE INFORMATION

Sample Number: 1304007-013 Customer Sample Number: 3087203 Project: LCR
Location: 2nd Draw 1319 POTOMAC AV SE Type: Dist.

Collection Date: 3/26/2013 Collection Time: 6:28 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-014

SAMPLE INFORMATION

Sample Number: 1304007-014 Customer Sample Number: 3092716 Project: LCR
Location: 1st Draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 8:38 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.056 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.111 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0023 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-015

SAMPLE INFORMATION

Sample Number: 1304007-015 Customer Sample Number: 3092716 Project: LCR
Location: 2nd Draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 8:38 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.039 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.052 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0047 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-016

SAMPLE INFORMATION

Sample Number: 1304007-016 Customer Sample Number: 3099778 Project: LCR
Location: 1st Draw 619 12TH ST NE Type: Dist.

Collection Date: 3/26/2013 Collection Time: 23:00 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.031 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-017

SAMPLE INFORMATION

Sample Number: 1304007-017 Customer Sample Number: 3099778 Project: LCR
Location: 2nd Draw 619 12TH ST NE Type: Dist.

Collection Date: 3/26/2013 Collection Time: 23:00 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.038 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-018

SAMPLE INFORMATION

Sample Number: 1304007-018 Customer Sample Number: 3106057 Project: LCR
Location: 1st Draw 1808 KEARNEY ST NE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.039 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.089 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-019

SAMPLE INFORMATION

Sample Number: 1304007-019 Customer Sample Number: 3106057 Project: LCR
Location: 2nd Draw 1808 KEARNEY ST NE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:19 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.036 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-020

SAMPLE INFORMATION

Sample Number: 1304007-020 Customer Sample Number: 3049333 Project: LCR
Location: 1st Draw 1353 JEFFERSON ST NW Type: Dist.

Collection Date: 3/26/2013 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.070 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-021

SAMPLE INFORMATION

Sample Number: 1304007-021 Customer Sample Number: 3049333 Project: LCR
Location: 2nd Draw 1353 JEFFERSON ST NW Type: Dist.

Collection Date: 3/26/2013 Collection Time: 18:32 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.035 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-022

SAMPLE INFORMATION

Sample Number: 1304007-022 Customer Sample Number: 3122831 Project: LCR
Location: 1st Draw 905 KENT PL NE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 4:35 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.059 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-023

SAMPLE INFORMATION

Sample Number: 1304007-023 Customer Sample Number: 3122831 Project: LCR
Location: 2nd Draw 905 KENT PL NE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 4:37 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.057 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-024

SAMPLE INFORMATION

Sample Number: 1304007-024 Customer Sample Number: 3087431 Project: LCR
Location: 1st Draw 1603 MASSACHUSETTS AVE SE Type: Dist.

Collection Date: 3/26/2013 Collection Time: 22:00 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-025

SAMPLE INFORMATION

Sample Number: 1304007-025 Customer Sample Number: 3087431 Project: LCR
Location: 2nd Draw 1603 MASSACHUSETTS AVE SE Type: Dist.

Collection Date: 3/26/2013 Collection Time: 22:05 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-026

SAMPLE INFORMATION

Sample Number: 1304007-026 Customer Sample Number: 3006813 Project: LCR
Location: 1st Draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 3/28/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.095 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-027

SAMPLE INFORMATION

Sample Number: 1304007-027 Customer Sample Number: 3006813 Project: LCR
Location: 2nd Draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 3/28/2013 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-028

SAMPLE INFORMATION

Sample Number: 1304007-028 Customer Sample Number: 3011592 Project: LCR
Location: 1st Draw 75 BATES ST NW Type: Dist.

Collection Date: 3/26/2013 Collection Time: 17:49 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-029

SAMPLE INFORMATION

Sample Number: 1304007-029 Customer Sample Number: 3011592 Project: LCR
Location: 2nd Draw 75 BATES ST NW Type: Dist.

Collection Date: 3/26/2013 Collection Time: 17:51 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-030

SAMPLE INFORMATION

Sample Number: 1304007-030 Customer Sample Number: 3022011 Project: LCR
Location: 1st Draw 807 BUCHANAN ST NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-031

SAMPLE INFORMATION

Sample Number: 1304007-031 Customer Sample Number: 3022011 Project: LCR
Location: 2nd Draw 807 BUCHANAN ST NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.002 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0098 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-032

SAMPLE INFORMATION

Sample Number: 1304007-032 Customer Sample Number: 3029443 Project: LCR
Location: 1st Draw 1203 QUINCY ST NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.297 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-033

SAMPLE INFORMATION

Sample Number: 1304007-033 Customer Sample Number: 3029443 Project: LCR
Location: 2nd Draw 1203 QUINCY ST NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.019 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-034

SAMPLE INFORMATION

Sample Number: 1304007-034 Customer Sample Number: 3127230 Project: LCR
Location: 1st Draw 617 6TH ST NE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304007-035

SAMPLE INFORMATION

Sample Number: 1304007-035 Customer Sample Number: 3127230 Project: LCR
Location: 2nd Draw 617 6TH ST NE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 4/1/2013 10:50:57 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304047-001

SAMPLE INFORMATION

Sample Number: 1304047-001 Customer Sample Number: 3026837 Project: LCR
Location: 1st draw 6210 8TH ST NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 4/3/2013 3:46:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304047-002

SAMPLE INFORMATION

Sample Number: 1304047-002 Customer Sample Number: 3026837 Project: LCR
Location: 2nd draw 6210 8TH ST NW Type: Dist.

Collection Date: 3/27/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 4/3/2013 3:46:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304053-001

SAMPLE INFORMATION

Sample Number: 1304053-001 Customer Sample Number: 3026604 Project: LCR
Location: 1st draw 302 RITTENHOUSE ST NW Type: Dist.

Collection Date: 3/28/2013 Collection Time: 3:20 Sampler: HOME OWNER Received Date and Time: 4/4/2013 12:45:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.040 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	4/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304053-002

SAMPLE INFORMATION

Sample Number: 1304053-002 Customer Sample Number: 3026604 Project: LCR
Location: 2nd draw 302 RITTENHOUSE ST NW Type: Dist.

Collection Date: 3/28/2013 Collection Time: 3:45 Sampler: HOME OWNER Received Date and Time: 4/4/2013 12:45:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	4/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	4/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304072-001

SAMPLE INFORMATION

Sample Number: 1304072-001 Customer Sample Number: 3092217 Project: LCR
Location: 1st draw 6105 DIX ST NE Type: Dist.

Collection Date: 3/28/2013 Collection Time: 6:27 Sampler: HOME OWNER Received Date and Time: 4/8/2013 9:27:31 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/10/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	4/10/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/10/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/1/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: LC-W1304072-002

SAMPLE INFORMATION

Sample Number: 1304072-002 Customer Sample Number: 3092217 Project: LCR
Location: 2nd draw 6105 DIX ST NE Type: Dist.

Collection Date: 3/28/2013 Collection Time: 6:29 Sampler: HOME OWNER Received Date and Time: 4/8/2013 9:27:31 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	4/10/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	4/10/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/10/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-001

SAMPLE INFORMATION

Sample Number: 1304253-001 Customer Sample Number: 3032623 Project: LCR
Location: 1st draw 780 FAIRMONT ST NW Type: Dist.

Collection Date: 4/22/2013 Collection Time: 21:07 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.127 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-002

SAMPLE INFORMATION

Sample Number: 1304253-002 Customer Sample Number: 3032623 Project: LCR
Location: 2nd draw 780 FAIRMONT ST NW Type: Dist.

Collection Date: 4/22/2013 Collection Time: 21:08 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.096 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-003

SAMPLE INFORMATION

Sample Number: 1304253-003 Customer Sample Number: 3019336 Project: LCR
Location: 1st draw 605 COLUMBIA RD NW Type: Dist.

Collection Date: 4/22/2013 Collection Time: 17:53 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.122 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-004

SAMPLE INFORMATION

Sample Number: 1304253-004 Customer Sample Number: 3019336 Project: LCR
Location: 2nd draw 605 COLUMBIA RD NW Type: Dist.

Collection Date: 4/22/2013 Collection Time: 17:54 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.069 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-005

SAMPLE INFORMATION

Sample Number: 1304253-005 Customer Sample Number: 3039963 Project: LCR
Location: 1st draw 5404 39TH ST NW Type: Dist.

Collection Date: 4/22/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.048 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-006

SAMPLE INFORMATION

Sample Number: 1304253-006 Customer Sample Number: 3039963 Project: LCR
Location: 2nd draw 5404 39TH ST NW Type: Dist.

Collection Date: 4/22/2013 Collection Time: 7:01 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.039 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-007

SAMPLE INFORMATION

Sample Number: 1304253-007 Customer Sample Number: 3029396 Project: LCR
Location: 1st draw 1003 QUEBEC PL NW Type: Dist.

Collection Date: 4/23/2013 Collection Time: 20:53 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.086 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-008

SAMPLE INFORMATION

Sample Number: 1304253-008 Customer Sample Number: 3029396 Project: LCR
Location: 2nd draw 1003 QUEBEC PL NW Type: Dist.

Collection Date: 4/23/2013 Collection Time: 20:53 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.084 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.054 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-009

SAMPLE INFORMATION

Sample Number: 1304253-009 Customer Sample Number: 3038165 Project: LCR
Location: 1st draw 3361 STUYVESANT PL NW Type: Dist.

Collection Date: 4/23/2013 Collection Time: 5:15 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.032 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.098 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-010

SAMPLE INFORMATION

Sample Number: 1304253-010 Customer Sample Number: 3038165 Project: LCR
Location: 2nd draw 3361 STUYVESANT PL NW Type: Dist.

Collection Date: 4/23/2013 Collection Time: 5:15 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.045 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-011

SAMPLE INFORMATION

Sample Number: 1304253-011 Customer Sample Number: 3022580 Project: LCR
Location: 1st draw 4818 8TH ST NW Type: Dist.

Collection Date: 4/23/2013 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.033 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-012

SAMPLE INFORMATION

Sample Number: 1304253-012 Customer Sample Number: 3022580 Project: LCR
Location: 2nd draw 4818 8TH ST NW Type: Dist.

Collection Date: 4/23/2013 Collection Time: 18:05 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-013

SAMPLE INFORMATION

Sample Number: 1304253-013 Customer Sample Number: 3038872 Project: LCR
Location: 1st draw 3215 MCKINLEY ST NW Type: Dist.

Collection Date: 4/24/2013 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.267 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.116 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-014

SAMPLE INFORMATION

Sample Number: 1304253-014 Customer Sample Number: 3038872 Project: LCR
Location: 2nd draw 3215 MCKINLEY ST NW Type: Dist.

Collection Date: 4/24/2013 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.088 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.034 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-015

SAMPLE INFORMATION

Sample Number: 1304253-015 Customer Sample Number: 3020687 Project: LCR
Location: 1st draw 3917 8TH ST NW Type: Dist.

Collection Date: 4/24/2013 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.094 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-016

SAMPLE INFORMATION

Sample Number: 1304253-016 Customer Sample Number: 3020687 Project: LCR
Location: 2nd draw 3917 8TH ST NW Type: Dist.

Collection Date: 4/24/2013 Collection Time: 6:39 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-017

SAMPLE INFORMATION

Sample Number: 1304253-017 Customer Sample Number: 3108541 Project: LCR
Location: 1st draw 333 34TH ST NE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-018

SAMPLE INFORMATION

Sample Number: 1304253-018 Customer Sample Number: 3108541 Project: LCR
Location: 2nd draw 333 34TH ST NE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.031 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-019

SAMPLE INFORMATION

Sample Number: 1304253-019 Customer Sample Number: 3127313 Project: LCR
Location: 1st draw 617 M ST NE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 18:15 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.058 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-020

SAMPLE INFORMATION

Sample Number: 1304253-020 Customer Sample Number: 3127313 Project: LCR
Location: 2nd draw 617 M ST NE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 18:17 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.045 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.075 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-021

SAMPLE INFORMATION

Sample Number: 1304253-021 Customer Sample Number: 3072261 Project: LCR
Location: 1st draw 413 4TH ST SE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 5:58 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.042 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-022

SAMPLE INFORMATION

Sample Number: 1304253-022 Customer Sample Number: 3072261 Project: LCR
Location: 2nd draw 413 4TH ST SE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-023

SAMPLE INFORMATION

Sample Number: 1304253-023 Customer Sample Number: 3103403 Project: LCR
Location: 1st draw 3416 9TH ST NE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.002 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-024

SAMPLE INFORMATION

Sample Number: 1304253-024 Customer Sample Number: 3103403 Project: LCR
Location: 2nd draw 3416 9TH ST NE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.019 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.002 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-025

SAMPLE INFORMATION

Sample Number: 1304253-025 Customer Sample Number: 3042773 Project: LCR
Location: 1st draw 4332 BRANDYWINE ST NW Type: Dist.

Collection Date: 4/24/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.064 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-026

SAMPLE INFORMATION

Sample Number: 1304253-026 Customer Sample Number: 3042773 Project: LCR
Location: 2nd draw 4332 BRANDYWINE ST NW Type: Dist.

Collection Date: 4/24/2013 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.056 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-027

SAMPLE INFORMATION

Sample Number: 1304253-027 Customer Sample Number: 3125513 Project: LCR
Location: 1st draw 24 EVARTS ST NE Type: Dist.

Collection Date: 4/25/2013 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.444 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.052 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-028

SAMPLE INFORMATION

Sample Number: 1304253-028 Customer Sample Number: 3125513 Project: LCR
Location: 2nd draw 24 EVARTS ST NE Type: Dist.

Collection Date: 4/25/2013 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.429 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.030 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-029

SAMPLE INFORMATION

Sample Number: 1304253-029 Customer Sample Number: 3041213 Project: LCR
Location: 1st draw 3809 ALTON PL NW Type: Dist.

Collection Date: 4/25/2013 Collection Time: 6:17 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1304253-030

SAMPLE INFORMATION

Sample Number: 1304253-030 Customer Sample Number: 3041213 Project: LCR
Location: 2nd draw 3809 ALTON PL NW Type: Dist.

Collection Date: 4/25/2013 Collection Time: 6:19 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:24:08 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1305002-001

SAMPLE INFORMATION

Sample Number: 1305002-001 Customer Sample Number: 3029267 Project: LCR
Location: 1st draw 3907 13TH ST NW Type: Dist.

Collection Date: 4/29/2013 Collection Time: 21:30 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:47:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.146 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1305002-002

SAMPLE INFORMATION

Sample Number: 1305002-002 Customer Sample Number: 3029267 Project: LCR
Location: 2nd draw 3907 13TH ST NW Type: Dist.

Collection Date: 4/29/2013 Collection Time: 21:34 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:47:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.082 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1305002-003

SAMPLE INFORMATION

Sample Number: 1305002-003 Customer Sample Number: 3022277 Project: LCR
Location: 1st draw 804 DELAFIELD PL. NW Type: Dist.

Collection Date: 4/24/2013 Collection Time: 5:27 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:47:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	5/15/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/21/2013
Report Number: LC-W1305002-004

SAMPLE INFORMATION

Sample Number: 1305002-004 Customer Sample Number: 3022277 Project: LCR
Location: 2nd draw 804 DELAFIELD PL. NW Type: Dist.

Collection Date: 4/24/2013 Collection Time: 5:29 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:47:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	5/15/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	5/15/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1305264-001

SAMPLE INFORMATION

Sample Number: 1305264-001 Customer Sample Number: 3073211 Project: LCR
Location: 1st draw 308 9TH ST SE Type: Dist.

Collection Date: 5/20/2013 Collection Time: 16:05 Sampler: HOME OWNER Received Date and Time: 5/31/2013 11:41:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.028 mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	6/13/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1305264-002

SAMPLE INFORMATION

Sample Number: 1305264-002 Customer Sample Number: 3073211 Project: LCR
Location: 2nd draw 308 9TH ST SE Type: Dist.

Collection Date: 5/20/2013 Collection Time: 16:06 Sampler: HOME OWNER Received Date and Time: 5/31/2013 11:41:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	6/13/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1305264-003

SAMPLE INFORMATION

Sample Number: 1305264-003 Customer Sample Number: 3006873 Project: LCR
Location: 1st draw 53 P ST NW Type: Dist.

Collection Date: 5/21/2013 Collection Time: 19:30 Sampler: HOME OWNER Received Date and Time: 5/31/2013 11:41:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	6/13/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1305264-004

SAMPLE INFORMATION

Sample Number: 1305264-004 Customer Sample Number: 3006873 Project: LCR
Location: 2nd draw 53 P ST NW Type: Dist.

Collection Date: 5/21/2013 Collection Time: 19:35 Sampler: HOME OWNER Received Date and Time: 5/31/2013 11:41:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	6/13/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1305264-005

SAMPLE INFORMATION

Sample Number: 1305264-005 Customer Sample Number: 3103161 Project: LCR
Location: 1st draw 2408 2ND ST NE Type: Dist.

Collection Date: 5/21/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 5/31/2013 11:41:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	6/13/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1305264-006

SAMPLE INFORMATION

Sample Number: 1305264-006 Customer Sample Number: 3103161 Project: LCR
Location: 2nd draw 2408 2ND ST NE Type: Dist.

Collection Date: 5/21/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 5/31/2013 11:41:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.058 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0028 mg/L	6/13/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1305264-007

SAMPLE INFORMATION

Sample Number: 1305264-007 Customer Sample Number: 3030408 Project: LCR
Location: 1st draw 1412 SHEPHERD ST.,NW Type: Dist.

Collection Date: 5/22/2013 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 5/31/2013 11:41:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.161 mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	6/13/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1305264-008

SAMPLE INFORMATION

Sample Number: 1305264-008 Customer Sample Number: 3030408 Project: LCR
Location: 2nd draw 1412 SHEPHERD ST.,NW Type: Dist.

Collection Date: 5/22/2013 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 5/31/2013 11:41:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.173 mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	6/13/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306052-001

SAMPLE INFORMATION

Sample Number: 1306052-001 Customer Sample Number: 3041124 Project: LCR
Location: 1st draw 4215 39TH ST NW Type: Dist.

Collection Date: 6/4/2013 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 6/7/2013 8:35:51 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.095 mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.051 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	6/13/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306052-002

SAMPLE INFORMATION

Sample Number: 1306052-002 Customer Sample Number: 3041124 Project: LCR
Location: 2nd draw 4215 39TH ST NW Type: Dist.

Collection Date: 6/4/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 6/7/2013 8:35:51 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.139 mg/L	6/13/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	6/13/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	6/13/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306090-001

SAMPLE INFORMATION

Sample Number: 1306090-001 Customer Sample Number: 3036642 Project: LCR
Location: 1st draw 3625 ALBEMARLE ST NW Type: Dist.

Collection Date: 6/6/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 6/12/2013 1:32:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.048 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306090-002

SAMPLE INFORMATION

Sample Number: 1306090-002 Customer Sample Number: 3036642 Project: LCR
Location: 2nd draw 3625 ALBEMARLE ST NW Type: Dist.

Collection Date: 6/6/2013 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 6/12/2013 1:32:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306090-003

SAMPLE INFORMATION

Sample Number: 1306090-003 Customer Sample Number: 3075926 Project: LCR
Location: 1st draw 109 19TH ST SE Type: Dist.

Collection Date: 6/9/2013 Collection Time: 10:25 Sampler: HOME OWNER Received Date and Time: 6/12/2013 1:32:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.050 mg/L	6/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.061 mg/L	6/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0111 mg/L	6/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306090-004

SAMPLE INFORMATION

Sample Number: 1306090-004 Customer Sample Number: 3075926 Project: LCR
Location: 2nd draw 109 19TH ST SE Type: Dist.

Collection Date: 6/9/2013 Collection Time: 10:26 Sampler: HOME OWNER Received Date and Time: 6/12/2013 1:32:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0108 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-001

SAMPLE INFORMATION

Sample Number: 1306115-001 Customer Sample Number: 3103119 Project: LCR
Location: 1st draw 2107 2ND ST NE Type: Dist.

Collection Date: 6/10/2013 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0052 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-002

SAMPLE INFORMATION

Sample Number: 1306115-002 Customer Sample Number: 3103119 Project: LCR
Location: 2nd draw 2107 2ND ST NE Type: Dist.

Collection Date: 6/10/2013 Collection Time: 6:47 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-003

SAMPLE INFORMATION

Sample Number: 1306115-003 Customer Sample Number: 3025494 Project: LCR
Location: 1st draw 125 MADISON ST NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.141 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0050 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-004

SAMPLE INFORMATION

Sample Number: 1306115-004 Customer Sample Number: 3025494 Project: LCR
Location: 2nd draw 125 MADISON ST NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 5:42 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.164 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0138 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-005

SAMPLE INFORMATION

Sample Number: 1306115-005 Customer Sample Number: 3092217 Project: LCR
Location: 1st draw 8 N ST SW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 20:10 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.080 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-006

SAMPLE INFORMATION

Sample Number: 1306115-006 Customer Sample Number: 3092217 Project: LCR
Location: 2nd draw 8 N ST SW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 20:11 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.088 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-007

SAMPLE INFORMATION

Sample Number: 1306115-007 Customer Sample Number: 3028753 Project: LCR
Location: 1st draw 3908 13TH ST NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 8:11 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.040 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-008

SAMPLE INFORMATION

Sample Number: 1306115-008 Customer Sample Number: 3028753 Project: LCR
Location: 2nd draw 3908 13TH ST NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 8:11 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.030 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.046 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-009

SAMPLE INFORMATION

Sample Number: 1306115-009 Customer Sample Number: 3034000 Project: LCR
Location: 1st draw 1649 HARVARD ST NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 5:50 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.139 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0061 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-010

SAMPLE INFORMATION

Sample Number: 1306115-010 Customer Sample Number: 3034000 Project: LCR
Location: 2nd draw 1649 HARVARD ST NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 5:52 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.079 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0034 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-011

SAMPLE INFORMATION

Sample Number: 1306115-011 Customer Sample Number: 3022524 Project: LCR
Location: 1st draw 912 EMERSON ST NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 5:51 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-012

SAMPLE INFORMATION

Sample Number: 1306115-012 Customer Sample Number: 3022524 Project: LCR
Location: 2nd draw 912 EMERSON ST NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 5:54 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-013

SAMPLE INFORMATION

Sample Number: 1306115-013 Customer Sample Number: 3039888 Project: LCR
Location: 1st draw 5301 RENO RD NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 7:53 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.038 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-014

SAMPLE INFORMATION

Sample Number: 1306115-014 Customer Sample Number: 3039888 Project: LCR
Location: 2nd draw 5301 RENO RD NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 7:57 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-015

SAMPLE INFORMATION

Sample Number: 1306115-015 Customer Sample Number: 3073488 Project: LCR
Location: 1st draw 702 9TH ST., SE Type: Dist.

Collection Date: 6/12/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-016

SAMPLE INFORMATION

Sample Number: 1306115-016 Customer Sample Number: 3073488 Project: LCR
Location: 2nd draw 702 9TH ST., SE Type: Dist.

Collection Date: 6/12/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0036 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-017

SAMPLE INFORMATION

Sample Number: 1306115-017 Customer Sample Number: Project: LCR
Location: 1st draw 1453 S ST NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.061 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-018

SAMPLE INFORMATION

Sample Number: 1306115-018 Customer Sample Number: Project: LCR
Location: 2nd draw 1453 S ST NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.043 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-019

SAMPLE INFORMATION

Sample Number: 1306115-019 Customer Sample Number: Project: LCR
Location: 1st draw 53 V ST NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.376 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0078 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-020

SAMPLE INFORMATION

Sample Number: 1306115-020 Customer Sample Number: Project: LCR
Location: 2nd draw 53 V ST NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.162 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0045 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-021

SAMPLE INFORMATION

Sample Number: 1306115-021 Customer Sample Number: Project: LCR
Location: 1st draw 449 S ST NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.050 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-022

SAMPLE INFORMATION

Sample Number: 1306115-022 Customer Sample Number: Project: LCR
Location: 2nd draw 449 S ST NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-023

SAMPLE INFORMATION

Sample Number: 1306115-023 Customer Sample Number: Project: LCR
Location: 1st draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 7:48 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.112 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306115-024

SAMPLE INFORMATION

Sample Number: 1306115-024 Customer Sample Number: Project: LCR
Location: 2nd draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 7:52 Sampler: HOME OWNER Received Date and Time: 6/14/2013 8:49:29 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306119-001

SAMPLE INFORMATION

Sample Number: 1306119-001 Customer Sample Number: Project: LCR
Location: 1st draw 1222 HAMILTON ST NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/14/2013 2:23:57 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.046 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306119-002

SAMPLE INFORMATION

Sample Number: 1306119-002 Customer Sample Number: Project: LCR
Location: 2nd draw 1222 HAMILTON ST NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 6/14/2013 2:23:57 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.038 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306129-001

SAMPLE INFORMATION

Sample Number: 1306129-001 Customer Sample Number: 3019855 Project: LCR
Location: 1st draw 424 LURAY PL NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 6/17/2013 11:05:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306129-002

SAMPLE INFORMATION

Sample Number: 1306129-002 Customer Sample Number: 3019855 Project: LCR
Location: 2nd draw 424 LURAY PL NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 6/17/2013 11:05:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306129-003

SAMPLE INFORMATION

Sample Number: 1306129-003 Customer Sample Number: 3017981 Project: LCR
Location: 1st draw 87 S ST. NW Type: Dist.

Collection Date: 6/14/2013 Collection Time: 5:04 Sampler: HOME OWNER Received Date and Time: 6/17/2013 11:05:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.047 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306129-004

SAMPLE INFORMATION

Sample Number: 1306129-004 Customer Sample Number: 3017981 Project: LCR
Location: 2nd draw 87 S ST. NW Type: Dist.

Collection Date: 6/14/2013 Collection Time: 5:10 Sampler: HOME OWNER Received Date and Time: 6/17/2013 11:05:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.065 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.039 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0078 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306130-001

SAMPLE INFORMATION

Sample Number: 1306130-001 Customer Sample Number: Project: LCR
Location: 1st draw 4131 YUMA ST NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 6/17/2013 12:00:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/21/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306130-002

SAMPLE INFORMATION

Sample Number: 1306130-002 Customer Sample Number: Project: LCR
Location: 2nd draw 4131 YUMA ST NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 6/17/2013 12:00:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	6/18/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	6/18/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0035 mg/L	6/18/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306173-001

SAMPLE INFORMATION

Sample Number: 1306173-001 Customer Sample Number: Project: LCR
Location: 1st draw 605 ROCK CRK CHURCH RD NW Type: Dist.

Collection Date: 6/18/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 6/19/2013 3:17:19 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.051 mg/L	6/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	6/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/21/2013
Report Number: LC-W1306173-002

SAMPLE INFORMATION

Sample Number: 1306173-002 Customer Sample Number: Project: LCR
Location: 2nd draw 605 ROCK CRK CHURCH RD NW Type: Dist.

Collection Date: 6/18/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 6/19/2013 3:17:19 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	6/20/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	6/20/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0045 mg/L	6/20/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/21/2013

Date

Attachment 2

Non-Regulated Lead Samples

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212128-001

SAMPLE INFORMATION

Sample Number: 1212128-001 Customer Sample Number: 3046408 Program: DS
Location: 1st draw 6914 6TH ST NW Type: Dist.

Collection Date: 12/11/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 12/14/2012 9:40:33 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212128-002

SAMPLE INFORMATION

Sample Number: 1212128-002 Customer Sample Number: 3046408 Program: DS
Location: 2nd draw 6914 6TH ST NW Type: Dist.

Collection Date: 12/11/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 12/14/2012 9:40:33 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212173-003

SAMPLE INFORMATION

Sample Number: 1212173-003 Customer Sample Number: 3029403 Program: DS
Location: 1st draw 1017 QUEBEC PL NW Type: Dist.

Collection Date: 12/16/2012 Collection Time: 10:24 Sampler: HOME OWNER Received Date and Time: 12/19/2012 4:22:09 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212173-004

SAMPLE INFORMATION

Sample Number: 1212173-004 Customer Sample Number: 3029403 Program: DS
Location: 2nd draw 1017 QUEBEC PL NW Type: Dist.

Collection Date: 12/16/2012 Collection Time: 10:25 Sampler: HOME OWNER Received Date and Time: 12/19/2012 4:22:09 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212173-005

SAMPLE INFORMATION

Sample Number: 1212173-005 Customer Sample Number: 3098234 Program: DS
Location: 1st draw 1107 50TH ST NE Type: Dist.

Collection Date: 12/17/2012 Collection Time: 5:29 Sampler: HOME OWNER Received Date and Time: 12/19/2012 4:22:09 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	107 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212173-006

SAMPLE INFORMATION

Sample Number: 1212173-006 Customer Sample Number: 3098234 Program: DS
Location: 2nd draw 1107 50TH ST NE Type: Dist.

Collection Date: 12/17/2012 Collection Time: 5:36 Sampler: HOME OWNER Received Date and Time: 12/19/2012 4:22:09 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	19.6 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212188-001

SAMPLE INFORMATION

Sample Number: 1212188-001 Customer Sample Number: 3098435 Program: DS
Location: 1st Draw 1112 4TH ST NE Type: Dist.

Collection Date: 12/19/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 12/21/2012 9:23:04 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212188-002

SAMPLE INFORMATION

Sample Number: 1212188-002 Customer Sample Number: 3098435 Program: DS
Location: 2nd Draw 1112 4TH ST NE Type: Dist.

Collection Date: 12/19/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 12/21/2012 9:23:04 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212188-003

SAMPLE INFORMATION

Sample Number: 1212188-003 Customer Sample Number: 3101075 Program: DS
Location: 1st Draw 1605 D ST. NE Type: Dist.

Collection Date: 12/19/2012 Collection Time: 19:40 Sampler: HOME OWNER Received Date and Time: 12/21/2012 9:23:04 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.3 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212188-004

SAMPLE INFORMATION

Sample Number: 1212188-004 Customer Sample Number: 3101075 Program: DS
Location: 2nd Draw 1605 D ST. NE Type: Dist.

Collection Date: 12/19/2012 Collection Time: 19:44 Sampler: HOME OWNER Received Date and Time: 12/21/2012 9:23:04 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.8 ug/L	1/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212223-001

SAMPLE INFORMATION

Sample Number: 1212223-001 Customer Sample Number: 3125757 Program: DS
Location: 1st draw 1514 KEARNY ST NE Type: Dist.

Collection Date: 12/22/2012 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 12/28/2012 3:29:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.5 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212223-002

SAMPLE INFORMATION

Sample Number: 1212223-002 Customer Sample Number: 3125757 Program: DS
Location: 2nd draw 1514 KEARNY ST NE Type: Dist.

Collection Date: 12/22/2012 Collection Time: 9:04 Sampler: HOME OWNER Received Date and Time: 12/28/2012 3:29:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1301025-003

SAMPLE INFORMATION

Sample Number: 1301025-003 Customer Sample Number: 3124411 Program: DS
Location: 1st Draw 2022 C ST. NE Type: Dist.

Collection Date: 12/27/2012 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 1/3/2013 3:32:33 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1301025-004

SAMPLE INFORMATION

Sample Number: 1301025-004 Customer Sample Number: 3124411 Program: DS
Location: 2nd Draw 2022 C ST. NE Type: Dist.

Collection Date: 12/27/2012 Collection Time: 8:32 Sampler: HOME OWNER Received Date and Time: 1/3/2013 3:32:33 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1301025-005

SAMPLE INFORMATION

Sample Number: 1301025-005 Customer Sample Number: 3121070 Program: DS
Location: 1st Draw 516 CONSTITUTION AVE NE Type: Dist.

Collection Date: 12/30/2012 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 1/3/2013 3:32:33 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1301025-006

SAMPLE INFORMATION

Sample Number: 1301025-006 Customer Sample Number: 3121070 Program: DS
Location: 2nd Draw 516 CONSTITUTION AVE NE Type: Dist.

Collection Date: 12/30/2012 Collection Time: 7:48 Sampler: HOME OWNER Received Date and Time: 1/3/2013 3:32:33 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	1/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1301025-007

SAMPLE INFORMATION

Sample Number: 1301025-007 Customer Sample Number: 20002 Program: DS
Location: 1st Draw 1430 F STREET NE Type: Dist.

Collection Date: 1/2/2013 Collection Time: 8:07 Sampler: HOME OWNER Received Date and Time: 1/3/2013 3:32:33 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1301025-008

SAMPLE INFORMATION

Sample Number: 1301025-008 Customer Sample Number: 20002 Program: DS
Location: 2nd Draw 1430 F STREET NE Type: Dist.

Collection Date: 1/2/2013 Collection Time: 8:09 Sampler: HOME OWNER Received Date and Time: 1/3/2013 3:32:33 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301122-003

SAMPLE INFORMATION

Sample Number: 1301122-003 Customer Sample Number: 3099470 Program: DS
Location: 1st draw 104 13TH ST NE Type: Dist.

Collection Date: 1/11/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 1/15/2013 1:00:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301122-004

SAMPLE INFORMATION

Sample Number: 1301122-004 Customer Sample Number: 3099470 Program: DS
Location: 2nd draw 104 13TH ST NE Type: Dist.

Collection Date: 1/11/2013 Collection Time: 7:22 Sampler: HOME OWNER Received Date and Time: 1/15/2013 1:00:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301122-005

SAMPLE INFORMATION

Sample Number: 1301122-005 Customer Sample Number: 3009275 Program: DS
Location: 1st draw 3421 DENT PLACE NW Type: Dist.

Collection Date: 1/13/2013 Collection Time: 7:54 Sampler: HOME OWNER Received Date and Time: 1/15/2013 1:00:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301122-006

SAMPLE INFORMATION

Sample Number: 1301122-006 Customer Sample Number: 3009275 Program: DS
Location: 2nd draw 3421 DENT PLACE NW Type: Dist.

Collection Date: 1/13/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 1/15/2013 1:00:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301151-001

SAMPLE INFORMATION

Sample Number: 1301151-001 Customer Sample Number: 3108037 Program: DS
Location: 1st Draw 3117 CHANNING ST., NE Type: Dist.

Collection Date: 1/14/2013 Collection Time: 4:47 Sampler: HOME OWNER Received Date and Time: 1/18/2013 11:28:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301151-002

SAMPLE INFORMATION

Sample Number: 1301151-002 Customer Sample Number: 3108037 Program: DS
Location: 2nd Draw 3117 CHANNING ST., NE Type: Dist.

Collection Date: 1/14/2013 Collection Time: 4:53 Sampler: HOME OWNER Received Date and Time: 1/18/2013 11:28:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301154-001

SAMPLE INFORMATION

Sample Number: 1301154-001 Customer Sample Number: 3043229 Program: DS
Location: 1st draw 4630 FESSENDEN ST NW Type: Dist.

Collection Date: 1/14/2013 Collection Time: 18:18 Sampler: HOME OWNER Received Date and Time: 1/22/2013 9:02:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	17.3 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301154-002

SAMPLE INFORMATION

Sample Number: 1301154-002 Customer Sample Number: 3043229 Program: DS
Location: 2nd draw 4630 FESSENDEN ST NW Type: Dist.

Collection Date: 1/14/2013 Collection Time: 18:20 Sampler: HOME OWNER Received Date and Time: 1/22/2013 9:02:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	19.1 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301188-001

SAMPLE INFORMATION

Sample Number: 1301188-001 Customer Sample Number: 3021191 Program: DS
Location: 1st draw 4228 4TH ST NW Type: Dist.

Collection Date: 1/20/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 1/24/2013 10:17:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.3 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301188-002

SAMPLE INFORMATION

Sample Number: 1301188-002 Customer Sample Number: 3021191 Program: DS
Location: 2nd draw 4228 4TH ST NW Type: Dist.

Collection Date: 1/20/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 1/24/2013 10:17:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301230-001

SAMPLE INFORMATION

Sample Number: 1301230-001 Customer Sample Number: 3008610 Program: DS
Location: 1st draw 3315 P ST NW Type: Dist.

Collection Date: 1/25/2013 Collection Time: 5:02 Sampler: HOME OWNER Received Date and Time: 1/30/2013 8:59:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.9 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301230-002

SAMPLE INFORMATION

Sample Number: 1301230-002 Customer Sample Number: 3008610 Program: DS
Location: 2nd draw 3315 P ST NW Type: Dist.

Collection Date: 1/25/2013 Collection Time: 5:02 Sampler: HOME OWNER Received Date and Time: 1/30/2013 8:59:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.2 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301230-003

SAMPLE INFORMATION

Sample Number: 1301230-003 Customer Sample Number: 3128037 Program: DS
Location: 1st draw 337 K ST NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 1/30/2013 8:59:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301230-004

SAMPLE INFORMATION

Sample Number: 1301230-004 Customer Sample Number: 3128037 Program: DS
Location: 2nd draw 337 K ST NE Type: Dist.

Collection Date: 1/29/2013 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 1/30/2013 8:59:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302049-001

SAMPLE INFORMATION

Sample Number: 1302049-001 Customer Sample Number: 3098149 Program: DS
Location: 1st draw 523 M ST NE Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 2/7/2013 10:26:41 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302049-002

SAMPLE INFORMATION

Sample Number: 1302049-002 Customer Sample Number: 3098149 Program: DS
Location: 2nd draw 523 M ST NE Type: Dist.

Collection Date: 1/30/2013 Collection Time: 7:32 Sampler: HOME OWNER Received Date and Time: 2/7/2013 10:26:41 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302049-003

SAMPLE INFORMATION

Sample Number: 1302049-003 Customer Sample Number: 3036615 Program: DS
Location: 1st draw 3546 ALBEMARLE ST NW Type: Dist.

Collection Date: 2/2/2013 Collection Time: 7:54 Sampler: HOME OWNER Received Date and Time: 2/7/2013 10:26:41 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302049-004

SAMPLE INFORMATION

Sample Number: 1302049-004 Customer Sample Number: 3036615 Program: DS
Location: 2nd draw 3546 ALBEMARLE ST NW Type: Dist.

Collection Date: 2/2/2013 Collection Time: 7:54 Sampler: HOME OWNER Received Date and Time: 2/7/2013 10:26:41 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302049-005

SAMPLE INFORMATION

Sample Number: 1302049-005 Customer Sample Number: 3009188 Program: DS
Location: 1st draw 1629 33RD ST NW Type: Dist.

Collection Date: 2/2/2013 Collection Time: 11:30 Sampler: HOME OWNER Received Date and Time: 2/7/2013 10:26:41 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.2 ug/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302049-006

SAMPLE INFORMATION

Sample Number: 1302049-006 Customer Sample Number: 3009188 Program: DS
Location: 2nd draw 1629 33RD ST NW Type: Dist.

Collection Date: 2/2/2013 Collection Time: 11:33 Sampler: HOME OWNER Received Date and Time: 2/7/2013 10:26:41 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302095-005

SAMPLE INFORMATION

Sample Number: 1302095-005 Customer Sample Number: 3042859 Program: DS
Location: 1st draw 4310 BRANDYWINE ST NW Type: Dist.

Collection Date: 2/3/2013 Collection Time: 16:20 Sampler: HOME OWNER Received Date and Time: 2/12/2013 4:13:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302095-006

SAMPLE INFORMATION

Sample Number: 1302095-006 Customer Sample Number: 3042859 Program: DS
Location: 2nd draw 4310 BRANDYWINE ST NW Type: Dist.

Collection Date: 2/3/2013 Collection Time: 16:22 Sampler: HOME OWNER Received Date and Time: 2/12/2013 4:13:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.9 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302115-001

SAMPLE INFORMATION

Sample Number: 1302115-001 Customer Sample Number: 3104484 Program: DS
Location: 1st draw 4021 13TH ST NE Type: Dist.

Collection Date: 2/11/2013 Collection Time: 19:42 Sampler: HOME OWNER Received Date and Time: 2/13/2013 3:54:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302115-002

SAMPLE INFORMATION

Sample Number: 1302115-002 Customer Sample Number: 3104484 Program: DS
Location: 2nd draw 4021 13TH ST NE Type: Dist.

Collection Date: 2/11/2013 Collection Time: 19:45 Sampler: HOME OWNER Received Date and Time: 2/13/2013 3:54:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.9 ug/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302155-003

SAMPLE INFORMATION

Sample Number: 1302155-003 Customer Sample Number: 3009887 Program: DS
Location: 1st draw 2113 37TH ST NW Type: Dist.

Collection Date: 2/11/2013 Collection Time: 18:11 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:09:11 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.9 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302155-004

SAMPLE INFORMATION

Sample Number: 1302155-004 Customer Sample Number: 3009887 Program: DS
Location: 2nd draw 2113 37TH ST NW Type: Dist.

Collection Date: 2/11/2013 Collection Time: 18:13 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:09:11 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	8.3 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302155-005

SAMPLE INFORMATION

Sample Number: 1302155-005 Customer Sample Number: 3030920 Program: DS
Location: 1st draw 1751 PARK RD NW Type: Dist.

Collection Date: 2/12/2013 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:09:11 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302155-006

SAMPLE INFORMATION

Sample Number: 1302155-006 Customer Sample Number: 3030920 Program: DS
Location: 2nd draw 1751 PARK RD NW Type: Dist.

Collection Date: 2/12/2013 Collection Time: 8:17 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:09:11 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302192-001

SAMPLE INFORMATION

Sample Number: 1302192-001 Customer Sample Number: 3000731 Program: DS
Location: 1st draw 1416 HOPKINS ST. NW Type: Dist.

Collection Date: 2/13/2013 Collection Time: 16:50 Sampler: HOME OWNER Received Date and Time: 2/22/2013 1:17:34 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302192-002

SAMPLE INFORMATION

Sample Number: 1302192-002 Customer Sample Number: 3000731 Program: DS
Location: 2nd draw 1416 HOPKINS ST. NW Type: Dist.

Collection Date: 2/13/2013 Collection Time: 16:52 Sampler: HOME OWNER Received Date and Time: 2/22/2013 1:17:34 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302216-001

SAMPLE INFORMATION

Sample Number: 1302216-001 Customer Sample Number: 3072561 Program: DS
Location: 1st Draw 660 INDEPENDENCE AVE. SE Type: Dist.

Collection Date: 2/21/2013 Collection Time: 18:26 Sampler: HOME OWNER Received Date and Time: 2/26/2013 2:54:12 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302216-002

SAMPLE INFORMATION

Sample Number: 1302216-002 Customer Sample Number: 3072561 Program: DS
Location: 2nd Draw 660 INDEPENDENCE AVE. SE Type: Dist.

Collection Date: 2/21/2013 Collection Time: 18:28 Sampler: HOME OWNER Received Date and Time: 2/26/2013 2:54:12 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302237-001

SAMPLE INFORMATION

Sample Number: 1302237-001 Customer Sample Number: 3105984 Program: DS
Location: 1st draw 1817 HAMLIN ST NE Type: Dist.

Collection Date: 2/23/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 2/28/2013 10:31:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302237-002

SAMPLE INFORMATION

Sample Number: 1302237-002 Customer Sample Number: 3105984 Program: DS
Location: 2nd draw 1817 HAMLIN ST NE Type: Dist.

Collection Date: 2/23/2013 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 2/28/2013 10:31:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302237-003

SAMPLE INFORMATION

Sample Number: 1302237-003 Customer Sample Number: 3102405 Program: DS
Location: 1st draw 1280 NEAL ST NE Type: Dist.

Collection Date: 2/24/2013 Collection Time: 8:20 Sampler: HOME OWNER Received Date and Time: 2/28/2013 10:31:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.6 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302237-004

SAMPLE INFORMATION

Sample Number: 1302237-004 Customer Sample Number: 3102405 Program: DS
Location: 2nd draw 1280 NEAL ST NE Type: Dist.

Collection Date: 2/24/2013 Collection Time: 8:22 Sampler: HOME OWNER Received Date and Time: 2/28/2013 10:31:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302237-005

SAMPLE INFORMATION

Sample Number: 1302237-005 Customer Sample Number: 3059452 Program: DS
Location: 1st draw 2944 BRANDYWINE ST NW Type: Dist.
Collection Date: 2/27/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 2/28/2013 10:31:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.1 ug/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302237-006

SAMPLE INFORMATION

Sample Number: 1302237-006 Customer Sample Number: 3059452 Program: DS
Location: 2nd draw 2944 BRANDYWINE ST NW Type: Dist.

Collection Date: 2/27/2013 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 2/28/2013 10:31:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303037-001

SAMPLE INFORMATION

Sample Number: 1303037-001 Customer Sample Number: 3041821 Program: DS
Location: 1st draw 3614 34TH ST NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/5/2013 4:03:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303037-002

SAMPLE INFORMATION

Sample Number: 1303037-002 Customer Sample Number: 3041821 Program: DS
Location: 2nd draw 3614 34TH ST NW Type: Dist.

Collection Date: 2/26/2013 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 3/5/2013 4:03:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.8 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303056-001

SAMPLE INFORMATION

Sample Number: 1303056-001 Customer Sample Number: 3075191 Program: DS
Location: 1st draw 1433 A ST SE Type: Dist.

Collection Date: 2/26/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/8/2013 9:10:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303056-002

SAMPLE INFORMATION

Sample Number: 1303056-002 Customer Sample Number: 3075191 Program: DS
Location: 2nd draw 1433 A ST SE Type: Dist.

Collection Date: 2/26/2013 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 3/8/2013 9:10:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303056-003

SAMPLE INFORMATION

Sample Number: 1303056-003 Customer Sample Number: 3103786 Program: DS
Location: 1st draw 1221 MICHIGAN AVE NE Type: Dist.

Collection Date: 2/28/2013 Collection Time: 14:06 Sampler: HOME OWNER Received Date and Time: 3/8/2013 9:10:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303056-004

SAMPLE INFORMATION

Sample Number: 1303056-004 Customer Sample Number: 3103786 Program: DS
Location: 2nd draw 1221 MICHIGAN AVE NE Type: Dist.

Collection Date: 2/28/2013 Collection Time: 14:08 Sampler: HOME OWNER Received Date and Time: 3/8/2013 9:10:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.1 ug/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303074-003

SAMPLE INFORMATION

Sample Number: 1303074-003 Customer Sample Number: 3025724 Program: DS
Location: 1st Draw 211 INGRAHAM ST NW Type: Dist.

Collection Date: 3/7/2013 Collection Time: 8:49 Sampler: HOME OWNER Received Date and Time: 3/11/2013 1:41:37 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303074-004

SAMPLE INFORMATION

Sample Number: 1303074-004 Customer Sample Number: 3025724 Program: DS
Location: 2nd Draw 211 INGRAHAM ST NW Type: Dist.

Collection Date: 3/7/2013 Collection Time: 8:50 Sampler: HOME OWNER Received Date and Time: 3/11/2013 1:41:37 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-001

SAMPLE INFORMATION

Sample Number: 1303114-001 Customer Sample Number: 3032026 Program: DS
Location: 1st draw 745 NEWTON PL NW Type: Dist.

Collection Date: 3/7/2013 Collection Time: 15:10 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-002

SAMPLE INFORMATION

Sample Number: 1303114-002 Customer Sample Number: 3032026 Program: DS
Location: 2nd draw 745 NEWTON PL NW Type: Dist.

Collection Date: 3/7/2013 Collection Time: 15:12 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-003

SAMPLE INFORMATION

Sample Number: 1303114-003 Customer Sample Number: 3046406 Program: DS
Location: 1st draw 6918 6TH ST NW Type: Dist.

Collection Date: 3/8/2013 Collection Time: 8:50 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-004

SAMPLE INFORMATION

Sample Number: 1303114-004 Customer Sample Number: 3046406 Program: DS
Location: 2nd draw 6918 6TH ST NW Type: Dist.

Collection Date: 3/8/2013 Collection Time: 8:53 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	10.7 ug/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-005

SAMPLE INFORMATION

Sample Number: 1303114-005 Customer Sample Number: 3040287 Program: DS
Location: 1st draw 5015 41ST ST NW Type: Dist.

Collection Date: 3/10/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-006

SAMPLE INFORMATION

Sample Number: 1303114-006 Customer Sample Number: 3040287 Program: DS
Location: 2nd draw 5015 41ST ST NW Type: Dist.

Collection Date: 3/10/2013 Collection Time: 6:01 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	8.8 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-007

SAMPLE INFORMATION

Sample Number: 1303114-007 Customer Sample Number: 3055592 Program: DS
Location: 1st draw 4817 BENDING LN NW Type: Dist.

Collection Date: 3/10/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-008

SAMPLE INFORMATION

Sample Number: 1303114-008 Customer Sample Number: 3055592 Program: DS
Location: 2nd draw 4817 BENDING LN NW Type: Dist.

Collection Date: 3/10/2013 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-009

SAMPLE INFORMATION

Sample Number: 1303114-009 Customer Sample Number: 3143565 Program: DS
Location: 1st draw 1037 5TH ST SE Type: Dist.

Collection Date: 3/12/2013 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303114-010

SAMPLE INFORMATION

Sample Number: 1303114-010 Customer Sample Number: 3143565 Program: DS
Location: 2nd draw 1037 5TH ST SE Type: Dist.

Collection Date: 3/12/2013 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 3/14/2013 11:30:14 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/8/2013
Report Number: LC-W1301032-001

SAMPLE INFORMATION

Sample Number: 1301032-001 Customer Sample Number: 3098471 Program: DS
Location: 1st Draw 1028 5TH ST. NE Type: Dist.

Collection Date: 12/30/2013 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 1/4/2013 2:04:37 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/8/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/8/2013
Report Number: LC-W1301032-002

SAMPLE INFORMATION

Sample Number: 1301032-002 Customer Sample Number: 3098471 Program: DS
Location: 2nd Draw 1028 5TH ST. NE Type: Dist.

Collection Date: 12/30/2013 Collection Time: 7:53 Sampler: HOME OWNER Received Date and Time: 1/4/2013 2:04:37 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/8/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303155-001

SAMPLE INFORMATION

Sample Number: 1303155-001 Customer Sample Number: 3047675 Program: DS
Location: 1st draw 1413 KALMIA RD NW Type: Dist.

Collection Date: 3/11/2013 Collection Time: 16:00 Sampler: HOME OWNER Received Date and Time: 3/19/2013 4:12:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303155-002

SAMPLE INFORMATION

Sample Number: 1303155-002 Customer Sample Number: 3047675 Program: DS
Location: 2nd draw 1413 KALMIA RD NW Type: Dist.

Collection Date: 3/11/2013 Collection Time: 16:05 Sampler: HOME OWNER Received Date and Time: 3/19/2013 4:12:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303155-003

SAMPLE INFORMATION

Sample Number: 1303155-003 Customer Sample Number: 3106528 Program: DS
Location: 1st draw 2232 TAYLOR ST NE Type: Dist.

Collection Date: 3/11/2013 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 3/19/2013 4:12:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303155-004

SAMPLE INFORMATION

Sample Number: 1303155-004 Customer Sample Number: 3106528 Program: DS
Location: 2nd draw 2232 TAYLOR ST NE Type: Dist.

Collection Date: 3/11/2013 Collection Time: 18:32 Sampler: HOME OWNER Received Date and Time: 3/19/2013 4:12:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303170-001

SAMPLE INFORMATION

Sample Number: 1303170-001 Customer Sample Number: 3102374 Program: DS
Location: 1st draw 1234 TRINIDAD AVE NE Type: Dist.

Collection Date: 3/12/2013 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 3/20/2013 4:27:34 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303170-002

SAMPLE INFORMATION

Sample Number: 1303170-002 Customer Sample Number: 3102374 Program: DS
Location: 2nd draw 1234 TRINIDAD AVE NE Type: Dist.

Collection Date: 3/12/2013 Collection Time: 6:41 Sampler: HOME OWNER Received Date and Time: 3/20/2013 4:27:34 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303202-003

SAMPLE INFORMATION

Sample Number: 1303202-003 Customer Sample Number: 3147530 Program: DS
Location: 1st draw 4650 BROAD BRANCH RD. Type: Dist.

Collection Date: 3/15/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 3/25/2013 3:09:35 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303202-004

SAMPLE INFORMATION

Sample Number: 1303202-004 Customer Sample Number: 3147530 Program: DS
Location: 2nd draw 4650 BROAD BRANCH RD. Type: Dist.

Collection Date: 3/15/2013 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 3/25/2013 3:09:35 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303202-005

SAMPLE INFORMATION

Sample Number: 1303202-005 Customer Sample Number: 3029391 Program: DS
Location: 1st draw 1006 QUEBEC PL NW Type: Dist.

Collection Date: 3/16/2013 Collection Time: 7:37 Sampler: HOME OWNER Received Date and Time: 3/25/2013 3:09:35 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.7 ug/L	4/4/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303202-006

SAMPLE INFORMATION

Sample Number: 1303202-006 Customer Sample Number: 3029391 Program: DS
Location: 2nd draw 1006 QUEBEC PL NW Type: Dist.

Collection Date: 3/16/2013 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 3/25/2013 3:09:35 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.6 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303202-007

SAMPLE INFORMATION

Sample Number: 1303202-007 Customer Sample Number: 3007494 Program: DS
Location: 1st draw 2809 O ST. NW Type: Dist.

Collection Date: 3/20/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 3/25/2013 3:09:35 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.5 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303202-008

SAMPLE INFORMATION

Sample Number: 1303202-008 Customer Sample Number: 3007494 Program: DS
Location: 2nd draw 2809 O ST. NW Type: Dist.

Collection Date: 3/20/2013 Collection Time: 9:05 Sampler: HOME OWNER Received Date and Time: 3/25/2013 3:09:35 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303238-001

SAMPLE INFORMATION

Sample Number: 1303238-001 Customer Sample Number: 3021531 Program: DS
Location: 1st Draw 405 WEBSTER ST NW Type: Dist.

Collection Date: 3/21/2013 Collection Time: 5:04 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:39:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303238-002

SAMPLE INFORMATION

Sample Number: 1303238-002 Customer Sample Number: 3021531 Program: DS
Location: 2nd Draw 405 WEBSTER ST NW Type: Dist.

Collection Date: 3/21/2013 Collection Time: 5:07 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:39:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303238-005

SAMPLE INFORMATION

Sample Number: 1303238-005 Customer Sample Number: 3143565 Program: DS
Location: 1st Draw 321 L ST SE Type: Dist.

Collection Date: 3/25/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:39:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303238-006

SAMPLE INFORMATION

Sample Number: 1303238-006 Customer Sample Number: 3143565 Program: DS
Location: 2nd Draw 321 L ST SE Type: Dist.

Collection Date: 3/25/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:39:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303238-007

SAMPLE INFORMATION

Sample Number: 1303238-007 Customer Sample Number: 3057147 Program: DS
Location: 1st Draw 5337 28TH ST NW Type: Dist.

Collection Date: 3/26/2013 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:39:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.1 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303238-008

SAMPLE INFORMATION

Sample Number: 1303238-008 Customer Sample Number: 3057147 Program: DS
Location: 2nd Draw 5337 28TH ST NW Type: Dist.

Collection Date: 3/26/2013 Collection Time: 6:46 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:39:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1304054-001

SAMPLE INFORMATION

Sample Number: 1304054-001 Customer Sample Number: 3027500 Program: DS
Location: 1st draw 6629 PINEY BRANCH RD NW Type: Dist.

Collection Date: 4/2/2013 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 4/4/2013 12:48:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	18.5 ug/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1304054-002

SAMPLE INFORMATION

Sample Number: 1304054-002 Customer Sample Number: 3027500 Program: DS
Location: 2nd draw 6629 PINEY BRANCH RD NW Type: Dist.

Collection Date: 4/2/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 4/4/2013 12:48:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	8.7 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/2/2013
Report Number: LC-W1304071-001

SAMPLE INFORMATION

Sample Number: 1304071-001 Customer Sample Number: 3018740 Program: DS
Location: 1st draw 134 SEATON PL NW Type: Dist.

Collection Date: 4/2/2013 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 4/8/2013 9:22:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	4/10/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/2/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/2/2013
Report Number: LC-W1304071-002

SAMPLE INFORMATION

Sample Number: 1304071-002 Customer Sample Number: 3018740 Program: DS
Location: 2nd draw 134 SEATON PL NW Type: Dist.

Collection Date: 4/2/2013 Collection Time: 20:02 Sampler: HOME OWNER Received Date and Time: 4/8/2013 9:22:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	4/10/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/2/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/2/2013
Report Number: LC-W1304071-003

SAMPLE INFORMATION

Sample Number: 1304071-003 Customer Sample Number: 3041416 Program: DS
Location: 1st draw 4010 RENO RD NW Type: Dist.

Collection Date: 4/4/2013 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 4/8/2013 9:22:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/2/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/2/2013
Report Number: LC-W1304071-004

SAMPLE INFORMATION

Sample Number: 1304071-004 Customer Sample Number: 3041416 Program: DS
Location: 2nd draw 4010 RENO RD NW Type: Dist.

Collection Date: 4/4/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 4/8/2013 9:22:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/2/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304137-003

SAMPLE INFORMATION

Sample Number: 1304137-003 Customer Sample Number: 3121129 Program: DS
Location: 1st draw 629 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 4/9/2013 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 4/15/2013 1:24:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304137-004

SAMPLE INFORMATION

Sample Number: 1304137-004 Customer Sample Number: 3121129 Program: DS
Location: 2nd draw 629 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 4/9/2013 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 4/15/2013 1:24:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304189-001

SAMPLE INFORMATION

Sample Number: 1304189-001 Customer Sample Number: 3045907 Program: DS
Location: 1st draw 5024 KLINGLE ST NW Type: Dist.

Collection Date: 4/13/2013 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 4/19/2013 11:05:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304189-002

SAMPLE INFORMATION

Sample Number: 1304189-002 Customer Sample Number: 3045907 Program: DS
Location: 2nd draw 5024 KLINGLE ST NW Type: Dist.

Collection Date: 4/13/2013 Collection Time: 8:32 Sampler: HOME OWNER Received Date and Time: 4/19/2013 11:05:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304189-003

SAMPLE INFORMATION

Sample Number: 1304189-003 Customer Sample Number: 3034717 Program: DS
Location: 1st draw 2206 WYOMING AVE NW Type: Dist.

Collection Date: 4/15/2013 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 4/19/2013 11:05:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304189-004

SAMPLE INFORMATION

Sample Number: 1304189-004 Customer Sample Number: 3034717 Program: DS
Location: 2nd draw 2206 WYOMING AVE NW Type: Dist.

Collection Date: 4/15/2013 Collection Time: 6:46 Sampler: HOME OWNER Received Date and Time: 4/19/2013 11:05:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.8 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304240-003

SAMPLE INFORMATION

Sample Number: 1304240-003 Customer Sample Number: 3018137 Program: DS
Location: 1st draw 56 V ST NW Type: Dist.

Collection Date: 4/20/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 4/25/2013 3:55:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304240-004

SAMPLE INFORMATION

Sample Number: 1304240-004 Customer Sample Number: 3018137 Program: DS
Location: 2nd draw 56 V ST NW Type: Dist.

Collection Date: 4/20/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 4/25/2013 3:55:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-005

SAMPLE INFORMATION

Sample Number: 1304252-005 Customer Sample Number: 3009441 Program: DS
Location: 1st draw 1720 35TH ST NW Type: Dist.

Collection Date: 4/22/2013 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-006

SAMPLE INFORMATION

Sample Number: 1304252-006 Customer Sample Number: 3009441 Program: DS
Location: 2nd draw 1720 35TH ST NW Type: Dist.

Collection Date: 4/22/2013 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-007

SAMPLE INFORMATION

Sample Number: 1304252-007 Customer Sample Number: 3122845 Program: DS
Location: 1st draw 925 K ST. NE Type: Dist.

Collection Date: 4/18/2013 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-008

SAMPLE INFORMATION

Sample Number: 1304252-008 Customer Sample Number: 3122845 Program: DS
Location: 2nd draw 925 K ST. NE Type: Dist.

Collection Date: 4/18/2013 Collection Time: 18:32 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.4 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-011

SAMPLE INFORMATION

Sample Number: 1304252-011 Customer Sample Number: 3120860 Program: DS
Location: 1st draw 426 11TH ST NE Type: Dist.

Collection Date: 4/25/2013 Collection Time: 6:13 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-012

SAMPLE INFORMATION

Sample Number: 1304252-012 Customer Sample Number: 3120860 Program: DS
Location: 2nd draw 426 11TH ST NE Type: Dist.

Collection Date: 4/25/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305003-001

SAMPLE INFORMATION

Sample Number: 1305003-001 Customer Sample Number: 3017957 Program: DS
Location: 1st draw 35 S ST NW Type: Dist.

Collection Date: 4/29/2013 Collection Time: 11:11 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:50:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.6 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305003-002

SAMPLE INFORMATION

Sample Number: 1305003-002 Customer Sample Number: 3017957 Program: DS
Location: 2nd draw 35 S ST NW Type: Dist.

Collection Date: 4/29/2013 Collection Time: 11:15 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:50:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	12.3 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305036-001

SAMPLE INFORMATION

Sample Number: 1305036-001 Customer Sample Number: 3049699 Program: DS
Location: 1st draw 1333 HAMILTON ST NW Type: Dist.

Collection Date: 4/25/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/3/2013 12:34:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305036-002

SAMPLE INFORMATION

Sample Number: 1305036-002 Customer Sample Number: 3049699 Program: DS
Location: 2nd draw 1333 HAMILTON ST NW Type: Dist.

Collection Date: 4/25/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/3/2013 12:34:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305036-003

SAMPLE INFORMATION

Sample Number: 1305036-003 Customer Sample Number: 3032076 Program: DS
Location: 1st draw 739 MORTON ST NW Type: Dist.

Collection Date: 4/29/2013 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 5/3/2013 12:34:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305036-004

SAMPLE INFORMATION

Sample Number: 1305036-004 Customer Sample Number: 3032076 Program: DS
Location: 2nd draw 739 MORTON ST NW Type: Dist.

Collection Date: 4/29/2013 Collection Time: 6:57 Sampler: HOME OWNER Received Date and Time: 5/3/2013 12:34:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305036-005

SAMPLE INFORMATION

Sample Number: 1305036-005 Customer Sample Number: 3127115 Program: DS
Location: 1st draw 609 ORLEANS PLACE NE Type: Dist.

Collection Date: 4/29/2013 Collection Time: 17:57 Sampler: HOME OWNER Received Date and Time: 5/3/2013 12:34:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305036-006

SAMPLE INFORMATION

Sample Number: 1305036-006 Customer Sample Number: 3127115 Program: DS
Location: 2nd draw 609 ORLEANS PLACE NE Type: Dist.

Collection Date: 4/29/2013 Collection Time: 17:58 Sampler: HOME OWNER Received Date and Time: 5/3/2013 12:34:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305036-007

SAMPLE INFORMATION

Sample Number: 1305036-007 Customer Sample Number: 3048211 Program: DS
Location: 1st draw 1885 PLYMOUTH ST NW Type: Dist.

Collection Date: 5/1/2013 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 5/3/2013 12:34:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	13.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305036-008

SAMPLE INFORMATION

Sample Number: 1305036-008 Customer Sample Number: 3048211 Program: DS
Location: 2nd draw 1885 PLYMOUTH ST NW Type: Dist.

Collection Date: 5/1/2013 Collection Time: 7:07 Sampler: HOME OWNER Received Date and Time: 5/3/2013 12:34:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	8.3 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-001

SAMPLE INFORMATION

Sample Number: 1305068-001 Customer Sample Number: 3057318 Program: DS
Location: 1st Draw 514 T ST NW Type: Dist.

Collection Date: 4/25/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-002

SAMPLE INFORMATION

Sample Number: 1305068-002 Customer Sample Number: 3057318 Program: DS
Location: 2nd Draw 514 T ST NW Type: Dist.

Collection Date: 4/25/2013 Collection Time: 9:02 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-003

SAMPLE INFORMATION

Sample Number: 1305068-003 Customer Sample Number: 3124287 Program: DS
Location: 1st Draw 513 NICHOLSON ST NE Type: Dist.

Collection Date: 4/29/2013 Collection Time: 12:15 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	5/15/2016	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-004

SAMPLE INFORMATION

Sample Number: 1305068-004 Customer Sample Number: 3124287 Program: DS
Location: 2nd Draw 513 NICHOLSON ST NE Type: Dist.

Collection Date: 4/29/2013 Collection Time: 12:17 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-007

SAMPLE INFORMATION

Sample Number: 1305068-007 Customer Sample Number: 3097515 Program: DS
Location: 1st Draw 611 M ST. NE #3 Type: Dist.

Collection Date: 5/2/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-008

SAMPLE INFORMATION

Sample Number: 1305068-008 Customer Sample Number: 3097515 Program: DS
Location: 2nd Draw 611 M ST. NE #3 Type: Dist.

Collection Date: 5/2/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-009

SAMPLE INFORMATION

Sample Number: 1305068-009 Customer Sample Number: 3009074 Program: DS
Location: 1st Draw 1601 CATON PL NW Type: Dist.

Collection Date: 5/2/2013 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-010

SAMPLE INFORMATION

Sample Number: 1305068-010 Customer Sample Number: 3009074 Program: DS
Location: 2nd Draw 1601 CATON PL NW Type: Dist.

Collection Date: 5/2/2013 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305101-005

SAMPLE INFORMATION

Sample Number: 1305101-005 Customer Sample Number: 3009624 Program: DS
Location: 1st Draw 1920 35TH PL NW Type: Dist.

Collection Date: 5/6/2013 Collection Time: 21:03 Sampler: HOME OWNER Received Date and Time: 5/13/2013 8:34:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.7 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305101-006

SAMPLE INFORMATION

Sample Number: 1305101-006 Customer Sample Number: 3009624 Program: DS
Location: 2nd Draw 1920 35TH PL NW Type: Dist.

Collection Date: 5/6/2013 Collection Time: 21:07 Sampler: HOME OWNER Received Date and Time: 5/13/2013 8:34:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	9.8 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/30/2013
Report Number: LC-W1304189-005

SAMPLE INFORMATION

Sample Number: 1304189-005 Customer Sample Number: 3126239 Program: DS
Location: 1st draw 815 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 4/18/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/19/2013 11:05:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.0 ug/L	5/23/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/30/2013
Report Number: LC-W1304189-006

SAMPLE INFORMATION

Sample Number: 1304189-006 Customer Sample Number: 3126239 Program: DS
Location: 2nd draw 815 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 4/18/2013 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 4/19/2013 11:05:00 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-005

SAMPLE INFORMATION

Sample Number: 1305145-005 Customer Sample Number: 3008313 Program: DS
Location: 1st draw 3228 O ST NW Type: Dist.

Collection Date: 5/10/2013 Collection Time: 6:07 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-006

SAMPLE INFORMATION

Sample Number: 1305145-006 Customer Sample Number: 3008313 Program: DS
Location: 2nd draw 3228 O ST NW Type: Dist.

Collection Date: 5/10/2013 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-007

SAMPLE INFORMATION

Sample Number: 1305145-007 Customer Sample Number: 3035674 Program: DS
Location: 1st draw 2618 GARFIELD ST NW Type: Dist.

Collection Date: 5/13/2013 Collection Time: 6:46 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	6/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-008

SAMPLE INFORMATION

Sample Number: 1305145-008 Customer Sample Number: 3035674 Program: DS
Location: 2nd draw 2618 GARFIELD ST NW Type: Dist.

Collection Date: 5/13/2013 Collection Time: 6:48 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	6/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-009

SAMPLE INFORMATION

Sample Number: 1305145-009 Customer Sample Number: 3058508 Program: DS
Location: 1st draw 4845 ILLINOIS AVE NW Type: Dist.

Collection Date: 5/14/2013 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	6/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-010

SAMPLE INFORMATION

Sample Number: 1305145-010 Customer Sample Number: 3058508 Program: DS
Location: 2nd draw 4845 ILLINOIS AVE NW Type: Dist.

Collection Date: 5/14/2013 Collection Time: 5:44 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	6/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-011

SAMPLE INFORMATION

Sample Number: 1305145-011 Customer Sample Number: 3047752 Program: DS
Location: 1st draw 1209 FERN ST NW Type: Dist.

Collection Date: 5/14/2013 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	6/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-012

SAMPLE INFORMATION

Sample Number: 1305145-012 Customer Sample Number: 3047752 Program: DS
Location: 2nd draw 1209 FERN ST NW Type: Dist.

Collection Date: 5/14/2013 Collection Time: 6:29 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.9 ug/L	6/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-003

SAMPLE INFORMATION

Sample Number: 1305180-003 Customer Sample Number: 3009613 Program: DS
Location: 1st draw 1911 35TH PLACE NW Type: Dist.

Collection Date: 5/13/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	6/6/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-004

SAMPLE INFORMATION

Sample Number: 1305180-004 Customer Sample Number: 3009613 Program: DS
Location: 2nd draw 1911 35TH PLACE NW Type: Dist.

Collection Date: 5/13/2013 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	6/6/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-007

SAMPLE INFORMATION

Sample Number: 1305180-007 Customer Sample Number: 3018319 Program: DS
Location: 1st draw 64 CHANNING ST NW Type: Dist.

Collection Date: 5/15/2013 Collection Time: 16:16 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	6/6/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-008

SAMPLE INFORMATION

Sample Number: 1305180-008 Customer Sample Number: 3018319 Program: DS
Location: 2nd draw 64 CHANNING ST NW Type: Dist.

Collection Date: 5/15/2013 Collection Time: 16:18 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	6/6/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-009

SAMPLE INFORMATION

Sample Number: 1305180-009 Customer Sample Number: 3006084 Program: DS
Location: 1st draw 1633 NEW JERSEY AVE NW Type: Dist.

Collection Date: 5/16/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	6/6/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-010

SAMPLE INFORMATION

Sample Number: 1305180-010 Customer Sample Number: 3006084 Program: DS
Location: 2nd draw 1633 NEW JERSEY AVE NW Type: Dist.

Collection Date: 5/16/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/6/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305161-004

SAMPLE INFORMATION

Sample Number: 1305161-004 Customer Sample Number: 3098819 Program: DS
Location: 1st draw 1136 7TH ST NE Type: Dist.

Collection Date: 5/15/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/17/2013 2:37:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305161-005

SAMPLE INFORMATION

Sample Number: 1305161-005 Customer Sample Number: 3098819 Program: DS
Location: 2nd draw 1136 7TH ST NE Type: Dist.

Collection Date: 5/15/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/17/2013 2:37:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305161-006

SAMPLE INFORMATION

Sample Number: 1305161-006 Customer Sample Number: 3020972 Program: DS
Location: 1st draw 512 TAYLOR ST NW Type: Dist.

Collection Date: 5/16/2013 Collection Time: 16:48 Sampler: HOME OWNER Received Date and Time: 5/17/2013 2:37:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305161-007

SAMPLE INFORMATION

Sample Number: 1305161-007 Customer Sample Number: 3020972 Program: DS
Location: 2nd draw 512 TAYLOR ST NW Type: Dist.

Collection Date: 5/16/2013 Collection Time: 16:50 Sampler: HOME OWNER Received Date and Time: 5/17/2013 2:37:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305218-001

SAMPLE INFORMATION

Sample Number: 1305218-001 Customer Sample Number: 3034246 Program: DS
Location: 1st Draw 1921 CALVERT ST., NW Type: Dist.

Collection Date: 5/20/2013 Collection Time: 6:06 Sampler: HOME OWNER Received Date and Time: 5/24/2013 9:25:41 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	6/13/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305218-002

SAMPLE INFORMATION

Sample Number: 1305218-002 Customer Sample Number: 3034246 Program: DS
Location: 2nd Draw 1921 CALVERT ST., NW Type: Dist.

Collection Date: 5/20/2013 Collection Time: 6:08 Sampler: HOME OWNER Received Date and Time: 5/24/2013 9:25:41 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.2 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305218-003

SAMPLE INFORMATION

Sample Number: 1305218-003 Customer Sample Number: 3065791 Program: DS
Location: 1st Draw 3824 LIVINGSTON ST NW Type: Dist.

Collection Date: 5/20/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 5/24/2013 9:25:41 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305218-004

SAMPLE INFORMATION

Sample Number: 1305218-004 Customer Sample Number: 3065791 Program: DS
Location: 2nd Draw 3824 LIVINGSTON ST NW Type: Dist.

Collection Date: 5/20/2013 Collection Time: 6:17 Sampler: HOME OWNER Received Date and Time: 5/24/2013 9:25:41 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	6/13/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-001

SAMPLE INFORMATION

Sample Number: 1305251-001 Customer Sample Number: 3070942 Program: DS
Location: 1st draw 4018 PENNSYLVANIA AVE SE Type: Dist.

Collection Date: 5/28/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-002

SAMPLE INFORMATION

Sample Number: 1305251-002 Customer Sample Number: 3070942 Program: DS
Location: 2nd draw 4018 PENNSYLVANIA AVE SE Type: Dist.

Collection Date: 5/28/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-007

SAMPLE INFORMATION

Sample Number: 1305251-007 Customer Sample Number: Program: DS
Location: 1st draw 3600 F ST SE (KITCHEN) Type: Dist.

Collection Date: 5/17/2013 Collection Time: 5:05 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	14.0 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-008

SAMPLE INFORMATION

Sample Number: 1305251-008 Customer Sample Number: Program: DS
Location: 2nd draw 3600 F ST SE (KITCHEN) Type: Dist.

Collection Date: 5/17/2013 Collection Time: 5:15 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-010

SAMPLE INFORMATION

Sample Number: 1305251-010 Customer Sample Number: Program: DS
Location: 2nd draw 3600 F ST SE (FORT DUPONT Type: Dist.
ACTIVITY CENTER)
Collection Date: 5/22/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/26/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-012

SAMPLE INFORMATION

Sample Number: 1305251-012 Customer Sample Number: Program: DS
Location: 2nd draw 1900 ANACOSTIA DR SE (ANACOSTIA Type: Dist.
PARK PAVILION)

Collection Date: 5/22/2013 Collection Time: 10:20 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-013

SAMPLE INFORMATION

Sample Number: 1305251-013 Customer Sample Number: Program: DS
Location: 1st draw 1900 ANACOSTIA DR SE (BATHROOM - Type: Dist.
MEN)
Collection Date: 5/20/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	12.8 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-014

SAMPLE INFORMATION

Sample Number: 1305251-014 Customer Sample Number: Program: DS
Location: 2nd draw 1900 ANACOSTIA DR SE (BATHROOM - Type: Dist.
MEN)

Collection Date: 5/20/2013 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306053-001

SAMPLE INFORMATION

Sample Number: 1306053-001 Customer Sample Number: 3131219 Program: DS
Location: 1st draw 1046 42 ST NE Type: Dist.

Collection Date: 5/29/2013 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 6/7/2013 8:40:30 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.2 ug/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306053-002

SAMPLE INFORMATION

Sample Number: 1306053-002 Customer Sample Number: 3131219 Program: DS
Location: 2nd draw 1046 42 ST NE Type: Dist.

Collection Date: 5/29/2013 Collection Time: 5:24 Sampler: HOME OWNER Received Date and Time: 6/7/2013 8:40:30 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.3 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306053-003

SAMPLE INFORMATION

Sample Number: 1306053-003 Customer Sample Number: 3120141 Program: DS
Location: 1st draw 25 15TH ST NE Type: Dist.

Collection Date: 6/3/2013 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 6/7/2013 8:40:30 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306053-004

SAMPLE INFORMATION

Sample Number: 1306053-004 Customer Sample Number: 3120141 Program: DS
Location: 2nd draw 25 15TH ST NE Type: Dist.

Collection Date: 6/3/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 6/7/2013 8:40:30 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-001

SAMPLE INFORMATION

Sample Number: 1306106-001 Customer Sample Number: 3009344 Program: DS
Location: 1st draw 3323 RESERVOIR RD NW Type: Dist.

Collection Date: 6/9/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-002

SAMPLE INFORMATION

Sample Number: 1306106-002 Customer Sample Number: 3009344 Program: DS
Location: 2nd draw 3323 RESERVOIR RD NW Type: Dist.

Collection Date: 6/9/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-003

SAMPLE INFORMATION

Sample Number: 1306106-003 Customer Sample Number: 3019253 Program: DS
Location: 1st draw 515 HARVARD ST NW Type: Dist.

Collection Date: 6/9/2013 Collection Time: 8:20 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-004

SAMPLE INFORMATION

Sample Number: 1306106-004 Customer Sample Number: 3019253 Program: DS
Location: 2nd draw 515 HARVARD ST NW Type: Dist.

Collection Date: 6/9/2013 Collection Time: 8:25 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-005

SAMPLE INFORMATION

Sample Number: 1306106-005 Customer Sample Number: 3041231 Program: DS
Location: 1st draw 4221 39TH ST NW Type: Dist.

Collection Date: 6/10/2013 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-006

SAMPLE INFORMATION

Sample Number: 1306106-006 Customer Sample Number: 3041231 Program: DS
Location: 2nd draw 4221 39TH ST NW Type: Dist.

Collection Date: 6/10/2013 Collection Time: 7:44 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-007

SAMPLE INFORMATION

Sample Number: 1306106-007 Customer Sample Number: 3125598 Program: DS
Location: 1st draw 2711 NORTH CAPITOL ST NE Type: Dist.

Collection Date: 6/10/2013 Collection Time: 19:32 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-008

SAMPLE INFORMATION

Sample Number: 1306106-008 Customer Sample Number: 3125598 Program: DS
Location: 2nd draw 2711 NORTH CAPITOL ST NE Type: Dist.

Collection Date: 6/10/2013 Collection Time: 19:33 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-009

SAMPLE INFORMATION

Sample Number: 1306106-009 Customer Sample Number: 3006149 Program: DS
Location: 1st draw 427 Q ST NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306106-010

SAMPLE INFORMATION

Sample Number: 1306106-010 Customer Sample Number: 3006149 Program: DS
Location: 2nd draw 427 Q ST NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 6/13/2013 9:48:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306128-003

SAMPLE INFORMATION

Sample Number: 1306128-003 Customer Sample Number: 3019727 Program: DS
Location: 1st draw 647 KEEFER PL NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 14:30 Sampler: HOME OWNER Received Date and Time: 6/17/2013 10:58:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.1 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306128-004

SAMPLE INFORMATION

Sample Number: 1306128-004 Customer Sample Number: 3019727 Program: DS
Location: 2nd draw 647 KEEFER PL NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 14:30 Sampler: HOME OWNER Received Date and Time: 6/17/2013 10:58:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.7 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306128-005

SAMPLE INFORMATION

Sample Number: 1306128-005 Customer Sample Number: 3029236 Program: DS
Location: 1st draw 921 QUINCY ST NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 6/17/2013 10:58:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306128-006

SAMPLE INFORMATION

Sample Number: 1306128-006 Customer Sample Number: 3029236 Program: DS
Location: 2nd draw 921 QUINCY ST NW Type: Dist.

Collection Date: 6/13/2013 Collection Time: 18:03 Sampler: HOME OWNER Received Date and Time: 6/17/2013 10:58:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306174-001

SAMPLE INFORMATION

Sample Number: 1306174-001 Customer Sample Number: 3031518 Program: DS
Location: 1st draw 1828 PARK RD NW Type: Dist.

Collection Date: 6/16/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/19/2013 3:17:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	6/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306174-002

SAMPLE INFORMATION

Sample Number: 1306174-002 Customer Sample Number: 3031518 Program: DS
Location: 2nd draw 1828 PARK RD NW Type: Dist.

Collection Date: 6/16/2013 Collection Time: 8:02 Sampler: HOME OWNER Received Date and Time: 6/19/2013 3:17:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	6/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off 4.5 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212173-001

SAMPLE INFORMATION

Sample Number: 1212173-001 Customer Sample Number: 3054011 Program: Post-LSR
Location: 1st draw 3116 SHERMAN AVE NW Type: Dist.

Collection Date: 12/16/2012 Collection Time: 5:48 Sampler: HOME OWNER Received Date and Time: 12/19/2012 4:22:09 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1212173-002

SAMPLE INFORMATION

Sample Number: 1212173-002 Customer Sample Number: 3054011 Program: Post-LSR
Location: 2nd draw 3116 SHERMAN AVE NW Type: Dist.

Collection Date: 12/16/2012 Collection Time: 5:52 Sampler: HOME OWNER Received Date and Time: 12/19/2012 4:22:09 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1301025-001

SAMPLE INFORMATION

Sample Number: 1301025-001 Customer Sample Number: 3062019 Program: Post-LSR
Location: 1st Draw 1922 3RD ST NW Type: Dist.

Collection Date: 12/24/2012 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 1/3/2013 3:32:33 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2013
Report Number: LC-W1301025-002

SAMPLE INFORMATION

Sample Number: 1301025-002 Customer Sample Number: 3062019 Program: Post-LSR
Location: 2nd Draw 1922 3RD ST NW Type: Dist.

Collection Date: 12/24/2012 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 1/3/2013 3:32:33 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	1/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301122-001

SAMPLE INFORMATION

Sample Number: 1301122-001 Customer Sample Number: 3054158 Program: Post-LSR
Location: 1st draw 3115 SHERMAN AVE NW Type: Dist.

Collection Date: 1/9/2013 Collection Time: 5:51 Sampler: HOME OWNER Received Date and Time: 1/15/2013 1:00:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301122-002

SAMPLE INFORMATION

Sample Number: 1301122-002 Customer Sample Number: 3054158 Program: Post-LSR
Location: 2nd draw 3115 SHERMAN AVE NW Type: Dist.

Collection Date: 1/9/2013 Collection Time: 5:54 Sampler: HOME OWNER Received Date and Time: 1/15/2013 1:00:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301154-003

SAMPLE INFORMATION

Sample Number: 1301154-003 Customer Sample Number: 3031891 Program: Post-LSR
Location: 1st draw 3220 13TH ST NW Type: Dist.

Collection Date: 1/15/2013 Collection Time: 16:30 Sampler: HOME OWNER Received Date and Time: 1/22/2013 9:02:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301154-004

SAMPLE INFORMATION

Sample Number: 1301154-004 Customer Sample Number: 3031891 Program: Post-LSR
Location: 2nd draw 3220 13TH ST NW Type: Dist.

Collection Date: 1/15/2013 Collection Time: 16:30 Sampler: HOME OWNER Received Date and Time: 1/22/2013 9:02:55 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301174-001

SAMPLE INFORMATION

Sample Number: 1301174-001 Customer Sample Number: 3044486 Program: Post-LSR
Location: 1st draw 1709 HOBAN RD NW Type: Dist.

Collection Date: 1/13/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 1/23/2013 11:35:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301174-002

SAMPLE INFORMATION

Sample Number: 1301174-002 Customer Sample Number: 3044486 Program: Post-LSR
Location: 2nd draw 1709 HOBAN RD NW Type: Dist.

Collection Date: 1/13/2013 Collection Time: 7:21 Sampler: HOME OWNER Received Date and Time: 1/23/2013 11:35:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301174-003

SAMPLE INFORMATION

Sample Number: 1301174-003 Customer Sample Number: 3054010 Program: Post-LSR
Location: 1st draw 3118 SHERMAN AVE NW Type: Dist.

Collection Date: 1/17/2013 Collection Time: 17:56 Sampler: HOME OWNER Received Date and Time: 1/23/2013 11:35:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301174-004

SAMPLE INFORMATION

Sample Number: 1301174-004 Customer Sample Number: 3054010 Program: Post-LSR
Location: 2nd draw 3118 SHERMAN AVE NW Type: Dist.

Collection Date: 1/17/2013 Collection Time: 17:58 Sampler: HOME OWNER Received Date and Time: 1/23/2013 11:35:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.2 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301188-003

SAMPLE INFORMATION

Sample Number: 1301188-003 Customer Sample Number: 3044491 Program: Post-LSR
Location: 1st draw 1801 HOBAN RD NW Type: Dist.

Collection Date: 1/22/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 1/24/2013 10:17:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1301188-004

SAMPLE INFORMATION

Sample Number: 1301188-004 Customer Sample Number: 3044491 Program: Post-LSR
Location: 2nd draw 1801 HOBAN RD NW Type: Dist.

Collection Date: 1/22/2013 Collection Time: 8:04 Sampler: HOME OWNER Received Date and Time: 1/24/2013 10:17:19 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/11/2013
Report Number: LC-W1302002-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302002-001 Customer Sample Number: 3007732 Program: Post-LSR
Location: 1st draw 3005 CAMBRIDGE PL NW Type: Dist.
Collection Date: 1/27/2013 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 2/1/2013 9:07:23 AM Received By: MChicoine

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.2 ug/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/11/2013
Report Number: LC-W1302002-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302002-002 Customer Sample Number: 3007732 Program: Post-LSR
Location: 2nd draw 3005 CAMBRIDGE PL NW Type: Dist.
Collection Date: 1/27/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 2/1/2013 9:07:23 AM Received By: MChicoine

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/11/2013
Report Number: LC-W1302002-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302002-003 Customer Sample Number: 3121925 Program: Post-LSR
Location: 1st draw 144 TENNESSEE AVE NE Type: Dist.
Collection Date: 1/29/2013 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 2/1/2013 9:07:23 AM Received By: MChicoine

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/11/2013
Report Number: LC-W1302002-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302002-004 Customer Sample Number: 3121925 Program: Post-LSR
Location: 2nd draw 144 TENNESSEE AVE NE Type: Dist.
Collection Date: 1/29/2013 Collection Time: 6:14 Sampler: HOME OWNER Received Date and Time: 2/1/2013 9:07:23 AM Received By: MChicoine

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302095-001

SAMPLE INFORMATION

Sample Number: 1302095-001 Customer Sample Number: 3059248 Program: Post-LSR
Location: 1st draw 3217 SHERMAN AVE NW Type: Dist.

Collection Date: 2/7/2013 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 2/12/2013 4:13:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302095-002

SAMPLE INFORMATION

Sample Number: 1302095-002 Customer Sample Number: 3059248 Program: Post-LSR
Location: 2nd draw 3217 SHERMAN AVE NW Type: Dist.

Collection Date: 2/7/2013 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 2/12/2013 4:13:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	3/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302095-003

SAMPLE INFORMATION

Sample Number: 1302095-003 Customer Sample Number: 3054023 Program: Post-LSR
Location: 1st draw 3301 SHERMAN AVE NW Type: Dist.

Collection Date: 2/5/2013 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 2/12/2013 4:13:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.3 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302095-004

SAMPLE INFORMATION

Sample Number: 1302095-004 Customer Sample Number: 3054023 Program: Post-LSR
Location: 2nd draw 3301 SHERMAN AVE NW Type: Dist.

Collection Date: 2/5/2013 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 2/12/2013 4:13:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.8 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302115-003

SAMPLE INFORMATION

Sample Number: 1302115-003 Customer Sample Number: 3049932 Program: Post-LSR
Location: 1st draw 1322 EMERSON ST NW Type: Dist.

Collection Date: 2/7/2013 Collection Time: 22:00 Sampler: HOME OWNER Received Date and Time: 2/13/2013 3:54:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	9.8 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/11/2013
Report Number: LC-W1302115-004

SAMPLE INFORMATION

Sample Number: 1302115-004 Customer Sample Number: 3049932 Program: Post-LSR
Location: 2nd draw 1322 EMERSON ST NW Type: Dist.

Collection Date: 2/7/2013 Collection Time: 22:00 Sampler: HOME OWNER Received Date and Time: 2/13/2013 3:54:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	3/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/11/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302155-001

SAMPLE INFORMATION

Sample Number: 1302155-001 Customer Sample Number: 3098803 Program: Post-LSR
Location: 1st draw 1106 7TH ST APT B NE Type: Dist.

Collection Date: 2/10/2013 Collection Time: 10:00 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:09:11 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302155-002

SAMPLE INFORMATION

Sample Number: 1302155-002 Customer Sample Number: 3098803 Program: Post-LSR
Location: 2nd draw 1106 7TH ST APT B NE Type: Dist.

Collection Date: 2/10/2013 Collection Time: 10:02 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:09:11 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302155-007

SAMPLE INFORMATION

Sample Number: 1302155-007 Customer Sample Number: 3098803 Program: Post-LSR
Location: 1st draw 1106 7TH ST NE Type: Dist.

Collection Date: 2/13/2013 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:09:11 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302155-008

SAMPLE INFORMATION

Sample Number: 1302155-008 Customer Sample Number: 3098803 Program: Post-LSR
Location: 2nd draw 1106 7TH ST NE Type: Dist.

Collection Date: 2/13/2013 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 2/19/2013 4:09:11 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302173-001

SAMPLE INFORMATION

Sample Number: 1302173-001 Customer Sample Number: 3127367 Program: Post-LSR
Location: 1st draw 1405 WEST VIRGINIA AVE NE Type: Dist.
Collection Date: 2/6/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/20/2013 4:15:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302173-002

SAMPLE INFORMATION

Sample Number: 1302173-002 Customer Sample Number: 3127367 Program: Post-LSR
Location: 2nd draw 1405 WEST VIRGINIA AVE NE Type: Dist.

Collection Date: 2/6/2013 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 2/20/2013 4:15:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302192-003

SAMPLE INFORMATION

Sample Number: 1302192-003 Customer Sample Number: 3098782 Program: Post-LSR
Location: 1st draw 1113 7TH ST NE Type: Dist.

Collection Date: 2/19/2013 Collection Time: 18:25 Sampler: HOME OWNER Received Date and Time: 2/22/2013 1:17:34 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1302192-004

SAMPLE INFORMATION

Sample Number: 1302192-004 Customer Sample Number: 3098782 Program: Post-LSR
Location: 2nd draw 1113 7TH ST NE Type: Dist.

Collection Date: 2/19/2013 Collection Time: 18:25 Sampler: HOME OWNER Received Date and Time: 2/22/2013 1:17:34 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303056-005

SAMPLE INFORMATION

Sample Number: 1303056-005 Customer Sample Number: 3056814 Program: Post-LSR
Location: 1st draw 4234 8TH ST NW Type: Dist.

Collection Date: 3/3/2013 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 3/8/2013 9:10:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303056-006

SAMPLE INFORMATION

Sample Number: 1303056-006 Customer Sample Number: 3056814 Program: Post-LSR
Location: 2nd draw 4234 8TH ST NW Type: Dist.

Collection Date: 3/3/2013 Collection Time: 8:35 Sampler: HOME OWNER Received Date and Time: 3/8/2013 9:10:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303074-001

SAMPLE INFORMATION

Sample Number: 1303074-001 Customer Sample Number: 3008657 Program: Post-LSR
Location: 1st Draw 3249 O ST. NW Type: Dist.

Collection Date: 3/4/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 3/11/2013 1:41:37 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	3/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/5/2013
Report Number: LC-W1303074-002

SAMPLE INFORMATION

Sample Number: 1303074-002 Customer Sample Number: 3008657 Program: Post-LSR
Location: 2nd Draw 3249 O ST. NW Type: Dist.

Collection Date: 3/4/2013 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 3/11/2013 1:41:37 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/20/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303155-005

SAMPLE INFORMATION

Sample Number: 1303155-005 Customer Sample Number: 3054912 Program: Post-LSR
Location: 1st draw 2507 MASSACHUSETTS AVE NW Type: Dist.

Collection Date: 3/13/2013 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 3/19/2013 4:12:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303155-006

SAMPLE INFORMATION

Sample Number: 1303155-006 Customer Sample Number: 3054912 Program: Post-LSR
Location: 2nd draw 2507 MASSACHUSETTS AVE NW Type: Dist.

Collection Date: 3/13/2013 Collection Time: 8:13 Sampler: HOME OWNER Received Date and Time: 3/19/2013 4:12:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	4/4/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303202-001

SAMPLE INFORMATION

Sample Number: 1303202-001 Customer Sample Number: 3127167 Program: Post-LSR
Location: 1st draw 635 MORTON PL. NE Type: Dist.

Collection Date: 3/13/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/25/2013 3:09:35 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/18/2013
Report Number: LC-W1303202-002

SAMPLE INFORMATION

Sample Number: 1303202-002 Customer Sample Number: 3127167 Program: Post-LSR
Location: 2nd draw 635 MORTON PL. NE Type: Dist.

Collection Date: 3/13/2013 Collection Time: 7:01 Sampler: HOME OWNER Received Date and Time: 3/25/2013 3:09:35 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303207-001

SAMPLE INFORMATION

Sample Number: 1303207-001 Customer Sample Number: 3127169 Program: Post-LSR
Location: 1st draw 639 MORTON PL NE Type: Dist.

Collection Date: 3/21/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/26/2013 10:23:24 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303207-002

SAMPLE INFORMATION

Sample Number: 1303207-002 Customer Sample Number: 3127169 Program: Post-LSR
Location: 2nd draw 639 MORTON PL NE Type: Dist.

Collection Date: 3/21/2013 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 3/26/2013 10:23:24 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303207-003

SAMPLE INFORMATION

Sample Number: 1303207-003 Customer Sample Number: 3127149 Program: Post-LSR
Location: 1st draw 628 MORTON PL NE Type: Dist.
Collection Date: 3/22/2013 Collection Time: 9:05 Sampler: HOME OWNER Received Date and Time: 3/26/2013 10:23:24 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.2 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303207-004

SAMPLE INFORMATION

Sample Number: 1303207-004 Customer Sample Number: 3127149 Program: Post-LSR
Location: 2nd draw 628 MORTON PL NE Type: Dist.

Collection Date: 3/22/2013 Collection Time: 9:10 Sampler: HOME OWNER Received Date and Time: 3/26/2013 10:23:24 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.9 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303237-001

SAMPLE INFORMATION

Sample Number: 1303237-001 Customer Sample Number: 3127091 Program: Post-LSR
Location: 1st draw 650 ORLEANS PL, NE Type: Dist.

Collection Date: 3/28/2013 Collection Time: 8:05 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:27:55 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303237-002

SAMPLE INFORMATION

Sample Number: 1303237-002 Customer Sample Number: 3127091 Program: Post-LSR
Location: 2nd draw 650 ORLEANS PL, NE Type: Dist.

Collection Date: 3/28/2013 Collection Time: 8:06 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:27:55 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303237-003

SAMPLE INFORMATION

Sample Number: 1303237-003 Customer Sample Number: 3127120 Program: Post-LSR
Location: 1st draw 623 ORLEANS PL, NE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 19:40 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:27:55 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/9/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303237-004

SAMPLE INFORMATION

Sample Number: 1303237-004 Customer Sample Number: 3127120 Program: Post-LSR
Location: 2nd draw 623 ORLEANS PL, NE Type: Dist.

Collection Date: 3/27/2013 Collection Time: 19:41 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:27:55 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303238-003

SAMPLE INFORMATION

Sample Number: 1303238-003 Customer Sample Number: 3127154 Program: Post-LSR
Location: 1st Draw 612 MORTON PL NE Type: Dist.

Collection Date: 3/24/2013 Collection Time: 6:28 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:39:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.8 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2013
Report Number: LC-W1303238-004

SAMPLE INFORMATION

Sample Number: 1303238-004 Customer Sample Number: 3127154 Program: Post-LSR
Location: 2nd Draw 612 MORTON PL NE Type: Dist.

Collection Date: 3/24/2013 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 3/29/2013 2:39:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.7 ug/L	4/9/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/2/2013
Report Number: LC-W1304071-005

SAMPLE INFORMATION

Sample Number: 1304071-005 Customer Sample Number: 3127158 Program: Post-LSR
Location: 1st draw 615 MORTON PL NE Type: Dist.
Collection Date: 4/4/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 4/8/2013 9:22:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	27.4 ug/L	4/10/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/2/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/2/2013
Report Number: LC-W1304071-006

SAMPLE INFORMATION

Sample Number: 1304071-006 Customer Sample Number: 3127158 Program: Post-LSR
Location: 2nd draw 615 MORTON PL NE Type: Dist.

Collection Date: 4/4/2013 Collection Time: 9:10 Sampler: HOME OWNER Received Date and Time: 4/8/2013 9:22:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	4/10/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/2/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304137-001

SAMPLE INFORMATION

Sample Number: 1304137-001 Customer Sample Number: 3032020 Program: Post-LSR
Location: 1st draw 715 NEWTON PL NW Type: Dist.

Collection Date: 4/8/2013 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 4/15/2013 1:24:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304137-002

SAMPLE INFORMATION

Sample Number: 1304137-002 Customer Sample Number: 3032020 Program: Post-LSR
Location: 2nd draw 715 NEWTON PL NW Type: Dist.

Collection Date: 4/8/2013 Collection Time: 17:51 Sampler: HOME OWNER Received Date and Time: 4/15/2013 1:24:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304161-001

SAMPLE INFORMATION

Sample Number: 1304161-001 Customer Sample Number: 3121971 Program: Post-LSR
Location: 1st draw 443 12TH ST NE Type: Dist.

Collection Date: 4/13/2013 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 4/17/2013 8:23:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304161-002

SAMPLE INFORMATION

Sample Number: 1304161-002 Customer Sample Number: 3121971 Program: Post-LSR
Location: 2nd draw 443 12TH ST NE Type: Dist.

Collection Date: 4/13/2013 Collection Time: 7:52 Sampler: HOME OWNER Received Date and Time: 4/17/2013 8:23:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304161-003

SAMPLE INFORMATION

Sample Number: 1304161-003 Customer Sample Number: 3032022 Program: Post-LSR
Location: 1st draw 719 NEWTON PL NW Type: Dist.

Collection Date: 4/15/2013 Collection Time: 5:13 Sampler: HOME OWNER Received Date and Time: 4/17/2013 8:23:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.4 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304161-004

SAMPLE INFORMATION

Sample Number: 1304161-004 Customer Sample Number: 3032022 Program: Post-LSR
Location: 2nd draw 719 NEWTON PL NW Type: Dist.

Collection Date: 4/15/2013 Collection Time: 5:16 Sampler: HOME OWNER Received Date and Time: 4/17/2013 8:23:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304240-001

SAMPLE INFORMATION

Sample Number: 1304240-001 Customer Sample Number: 3032018 Program: Post-LSR
Location: 1st draw 709 NEWTON PL NW Type: Dist.
Collection Date: 4/17/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/25/2013 3:55:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304240-002

SAMPLE INFORMATION

Sample Number: 1304240-002 Customer Sample Number: 3032018 Program: Post-LSR
Location: 2nd draw 709 NEWTON PL NW Type: Dist.

Collection Date: 4/17/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/25/2013 3:55:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-001

SAMPLE INFORMATION

Sample Number: 1304252-001 Customer Sample Number: 3126994 Program: Post-LSR
Location: 1st draw 617 L ST NE Type: Dist.

Collection Date: 4/23/2013 Collection Time: 18:15 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.7 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-002

SAMPLE INFORMATION

Sample Number: 1304252-002 Customer Sample Number: 3126994 Program: Post-LSR
Location: 2nd draw 617 L ST NE Type: Dist.

Collection Date: 4/23/2013 Collection Time: 18:17 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.4 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-003

SAMPLE INFORMATION

Sample Number: 1304252-003 Customer Sample Number: 3071527 Program: Post-LSR
Location: 1st draw 152 N. CAROLINA AVE SE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 5:46 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1304252-004

SAMPLE INFORMATION

Sample Number: 1304252-004 Customer Sample Number: 3071527 Program: Post-LSR
Location: 2nd draw 152 N. CAROLINA AVE SE Type: Dist.

Collection Date: 4/24/2013 Collection Time: 5:49 Sampler: HOME OWNER Received Date and Time: 4/29/2013 11:12:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305003-003

SAMPLE INFORMATION

Sample Number: 1305003-003 Customer Sample Number: 3127176 Program: Post-LSR
Location: 1st draw 653 MORTON PL NE Type: Dist.

Collection Date: 4/27/2013 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:50:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305003-004

SAMPLE INFORMATION

Sample Number: 1305003-004 Customer Sample Number: 3127176 Program: Post-LSR
Location: 2nd draw 653 MORTON PL NE Type: Dist.

Collection Date: 4/27/2013 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:50:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305003-005

SAMPLE INFORMATION

Sample Number: 1305003-005 Customer Sample Number: 3127183 Program: Post-LSR
Location: 1st draw 646 L ST NE Type: Dist.

Collection Date: 4/21/2013 Collection Time: 10:00 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:50:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305003-006

SAMPLE INFORMATION

Sample Number: 1305003-006 Customer Sample Number: 3127183 Program: Post-LSR
Location: 2nd draw 646 L ST NE Type: Dist.

Collection Date: 4/21/2013 Collection Time: 10:00 Sampler: HOME OWNER Received Date and Time: 5/1/2013 9:50:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-005

SAMPLE INFORMATION

Sample Number: 1305068-005 Customer Sample Number: 3127307 Program: Post-LSR
Location: 1st Draw 614 M ST. NE Type: Dist.

Collection Date: 4/30/2013 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-006

SAMPLE INFORMATION

Sample Number: 1305068-006 Customer Sample Number: 3127307 Program: Post-LSR
Location: 2nd Draw 614 M ST. NE Type: Dist.

Collection Date: 4/30/2013 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-011

SAMPLE INFORMATION

Sample Number: 1305068-011 Customer Sample Number: 3127312 Program: Post-LSR
Location: 1st Draw 615 M ST. NE Type: Dist.

Collection Date: 5/2/2013 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-012

SAMPLE INFORMATION

Sample Number: 1305068-012 Customer Sample Number: 3127312 Program: Post-LSR
Location: 2nd Draw 615 M ST. NE Type: Dist.

Collection Date: 5/2/2013 Collection Time: 17:05 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.6 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-013

SAMPLE INFORMATION

Sample Number: 1305068-013 Customer Sample Number: 3053222 Program: Post-LSR
Location: 1st Draw 5506 NEBRASKA Type: Dist.

Collection Date: 5/4/2013 Collection Time: 7:41 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-014

SAMPLE INFORMATION

Sample Number: 1305068-014 Customer Sample Number: 3053222 Program: Post-LSR
Location: 2nd Draw 5506 NEBRASKA Type: Dist.

Collection Date: 5/4/2013 Collection Time: 7:43 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-015

SAMPLE INFORMATION

Sample Number: 1305068-015 Customer Sample Number: 3127313 Program: Post-LSR
Location: 1st Draw 617 M ST NE Type: Dist.

Collection Date: 5/7/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	5/15/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305068-016

SAMPLE INFORMATION

Sample Number: 1305068-016 Customer Sample Number: 3127313 Program: Post-LSR
Location: 2nd Draw 617 M ST NE Type: Dist.

Collection Date: 5/7/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/8/2013 10:18:46 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305101-001

SAMPLE INFORMATION

Sample Number: 1305101-001 Customer Sample Number: 3099350 Program: Post-LSR
Location: 1st Draw 1229 F ST NE Type: Dist.
Collection Date: 5/4/2013 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 5/13/2013 8:34:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305101-002

SAMPLE INFORMATION

Sample Number: 1305101-002 Customer Sample Number: 3099350 Program: Post-LSR
Location: 2nd Draw 1229 F ST NE Type: Dist.
Collection Date: 5/4/2013 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 5/13/2013 8:34:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305101-003

SAMPLE INFORMATION

Sample Number: 1305101-003 Customer Sample Number: 3100111 Program: Post-LSR
Location: 1st Draw 1358 C ST NE Type: Dist.

Collection Date: 5/6/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/13/2013 8:34:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.6 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305101-004

SAMPLE INFORMATION

Sample Number: 1305101-004 Customer Sample Number: 3100111 Program: Post-LSR
Location: 2nd Draw 1358 C ST NE Type: Dist.

Collection Date: 5/6/2013 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 5/13/2013 8:34:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.4 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305101-007

SAMPLE INFORMATION

Sample Number: 1305101-007 Customer Sample Number: 3127375 Program: Post-LSR
Location: 1st Draw 631 M ST NE Type: Dist.

Collection Date: 5/8/2013 Collection Time: 3:59 Sampler: HOME OWNER Received Date and Time: 5/13/2013 8:34:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2013
Report Number: LC-W1305101-008

SAMPLE INFORMATION

Sample Number: 1305101-008 Customer Sample Number: 3127375 Program: Post-LSR
Location: 2nd Draw 631 M ST NE Type: Dist.

Collection Date: 5/8/2013 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 5/13/2013 8:34:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/15/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-001

SAMPLE INFORMATION

Sample Number: 1305145-001 Customer Sample Number: 3121922 Program: Post-LSR
Location: 1st draw 138 TENNESSEE AVE NE Type: Dist.

Collection Date: 5/7/2013 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	6/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-002

SAMPLE INFORMATION

Sample Number: 1305145-002 Customer Sample Number: 3121922 Program: Post-LSR
Location: 2nd draw 138 TENNESSEE AVE NE Type: Dist.

Collection Date: 5/7/2013 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-003

SAMPLE INFORMATION

Sample Number: 1305145-003 Customer Sample Number: 3127372 Program: Post-LSR
Location: 1st draw 625 M ST NE Type: Dist.

Collection Date: 5/8/2013 Collection Time: 18:20 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.2 ug/L	6/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305145-004

SAMPLE INFORMATION

Sample Number: 1305145-004 Customer Sample Number: 3127372 Program: Post-LSR
Location: 2nd draw 625 M ST NE Type: Dist.

Collection Date: 5/8/2013 Collection Time: 18:23 Sampler: HOME OWNER Received Date and Time: 5/16/2013 11:19:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.8 ug/L	6/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-001

SAMPLE INFORMATION

Sample Number: 1305180-001 Customer Sample Number: 3007705 Program: Post-LSR
Location: 1st draw 3022 CAMBRIDGE PL NW Type: Dist.

Collection Date: 5/11/2013 Collection Time: 4:45 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/6/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-002

SAMPLE INFORMATION

Sample Number: 1305180-002 Customer Sample Number: 3007705 Program: Post-LSR
Location: 2nd draw 3022 CAMBRIDGE PL NW Type: Dist.

Collection Date: 5/11/2013 Collection Time: 4:50 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/6/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-005

SAMPLE INFORMATION

Sample Number: 1305180-005 Customer Sample Number: 3127190 Program: Post-LSR
Location: 1st draw 632 L ST NE Type: Dist.

Collection Date: 5/15/2013 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/6/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: LC-W1305180-006

SAMPLE INFORMATION

Sample Number: 1305180-006 Customer Sample Number: 3127190 Program: Post-LSR
Location: 2nd draw 632 L ST NE Type: Dist.

Collection Date: 5/15/2013 Collection Time: 4:35 Sampler: HOME OWNER Received Date and Time: 5/21/2013 9:55:06 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/6/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305161-001

SAMPLE INFORMATION

Sample Number: 1305161-001 Customer Sample Number: 3127170 Program: Post-LSR
Location: 1st draw 641 MORTON PLACE NE Type: Dist.

Collection Date: 5/6/2013 Collection Time: 17:15 Sampler: HOME OWNER Received Date and Time: 5/17/2013 2:37:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305161-002

SAMPLE INFORMATION

Sample Number: 1305161-002 Customer Sample Number: 3127170 Program: Post-LSR
Location: 2nd draw 641 MORTON PLACE NE Type: Dist.

Collection Date: 5/6/2013 Collection Time: 17:19 Sampler: HOME OWNER Received Date and Time: 5/17/2013 2:37:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305161-003

SAMPLE INFORMATION

Sample Number: 1305161-003 Customer Sample Number: 3127315 Program: Post-LSR
Location: 1st draw 621 M STREET NE Type: Dist.

Collection Date: 5/8/2013 Collection Time: 5:53 Sampler: HOME OWNER Received Date and Time: 5/17/2013 2:37:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305218-005

SAMPLE INFORMATION

Sample Number: 1305218-005 Customer Sample Number: 3129287 Program: Post-LSR
Location: 1st Draw 512 1/2 M ST NE Type: Dist.

Collection Date: 5/21/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 5/24/2013 9:25:41 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	8.4 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305218-006

SAMPLE INFORMATION

Sample Number: 1305218-006 Customer Sample Number: 3129287 Program: Post-LSR
Location: 2nd Draw 512 1/2 M ST NE Type: Dist.

Collection Date: 5/21/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 5/24/2013 9:25:41 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-003

SAMPLE INFORMATION

Sample Number: 1305251-003 Customer Sample Number: 3127286 Program: Post-LSR
Location: 1st draw 514 M ST NE Type: Dist.

Collection Date: 5/29/2013 Collection Time: 8:26 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-004

SAMPLE INFORMATION

Sample Number: 1305251-004 Customer Sample Number: 3127286 Program: Post-LSR
Location: 2nd draw 514 M ST NE Type: Dist.

Collection Date: 5/29/2013 Collection Time: 8:27 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-005

SAMPLE INFORMATION

Sample Number: 1305251-005 Customer Sample Number: 3127298 Program: Post-LSR
Location: 1st draw 519 M ST NE Type: Dist.

Collection Date: 5/29/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	6/13/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1305251-006

SAMPLE INFORMATION

Sample Number: 1305251-006 Customer Sample Number: 3127298 Program: Post-LSR
Location: 2nd draw 519 M ST NE Type: Dist.

Collection Date: 5/29/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 5/30/2013 9:46:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306128-001

SAMPLE INFORMATION

Sample Number: 1306128-001 Customer Sample Number: 3127174 Program: Post-LSR
Location: 1st draw 649 MORTON PL NE Type: Dist.
Collection Date: 6/9/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/17/2013 10:58:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306128-002

SAMPLE INFORMATION

Sample Number: 1306128-002 Customer Sample Number: 3127174 Program: Post-LSR
Location: 2nd draw 649 MORTON PL NE Type: Dist.

Collection Date: 6/9/2013 Collection Time: 8:02 Sampler: HOME OWNER Received Date and Time: 6/17/2013 10:58:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306128-007

Report revised on 7/8/13 by MC.
For Lab Sample Number: 1306128-007, the Program code was changed from
DS to POST-LSR as requested by Jessica Edwards-Brandt (DCWATER) on
7/8/13.

SAMPLE INFORMATION

Sample Number: 1306128-007
Location: 1st draw 412 M ST NE

Customer Sample Number: 3120949
Type: Dist.
Program: Post-LSR

Collection Date: 6/14/2013
Collection Time: 9:00
Sampler: HOME OWNER
Received Date and Time: 6/17/2013 10:58:58 AM
Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.4 ug/L	6/18/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306128-008

Report revised on 7/8/13 by MC.
For Lab Sample Number: 1306128-008, the Program code was changed from
DS to POST-LSR as requested by Jessica Edwards-Brandt (DCWATER) on
7/8/13.

SAMPLE INFORMATION

Sample Number: 1306128-008 Customer Sample Number: 3120949 Program: Post-LSR
Location: 2nd draw 412 M ST NE Type: Dist.

Collection Date: 6/14/2013 Collection Time: 9:05 Sampler: HOME OWNER Received Date and Time: 6/17/2013 10:58:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	6/18/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306174-003

Report revised on 7/8/13 by MC.
For Lab Sample Number: 1306174-003, the Program code was changed from
DS to POST-LSR as requested by Jessica Edwards-Brandt (DCWATER) on
7/8/13.

SAMPLE INFORMATION

Sample Number: 1306174-003 Customer Sample Number: 3050162 Program: Post-LSR
Location: 1st draw 127 FLORIDA AVE NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 6/19/2013 3:17:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	6/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: LC-W1306174-004

Report revised on 7/8/13 by MC.
For Lab Sample Number: 1306174-004, the Program code was changed from
DS to POST-LSR as requested by Jessica Edwards-Brandt (DCWATER) on
7/8/13.

SAMPLE INFORMATION

Sample Number: 1306174-004 Customer Sample Number: 3050162 Program: Post-LSR
Location: 2nd draw 127 FLORIDA AVE NW Type: Dist.

Collection Date: 6/11/2013 Collection Time: 6:39 Sampler: HOME OWNER Received Date and Time: 6/19/2013 3:17:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	6/20/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:

Michael Chicoine, Laboratory Manager

6/26/2013

Date

Lead Profile Information

DC Water surveys the plumbing of customers' homes and collects consecutive samples to identify the sources of lead. The homes are those that had elevated lead from previous samples collected for compliance monitoring or from other programs.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-001
Location: 01a
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	234 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	131 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	157 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.34 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-002
Location: 01aF
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	65.3 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	72.3 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-003
Location: 01b
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	254 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	83.2 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	15.6 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-004
Location: 01bF
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	47.3 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.7 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-005
Location: 01c
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	251 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	76.6 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-006
Location: 01cF
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	43.9 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-007
Location: 01d
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	262 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	81.7 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-008
Location: 01dF
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.9 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.3 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-009
Location: 02
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	248 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	82.1 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-010
Location: 02F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	48.3 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-011
Location: 03
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	254 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	81.6 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2013
Report Number: M- W1302009-012

SAMPLE INFORMATION

Sample Number: 1302009-012
Location: 03F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.5 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-013
Location: 04
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	229 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	74.1 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-014
Location: 04F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	45.8 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-015

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-015
Location: 05
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	260 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	76.1 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-016
Location: 05F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 9:00 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	43.2 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-017

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-017
Location: 06
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	248 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	66.7 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-018

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-018
Location: 06F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	41.1 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-019

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-019
Location: 10
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	251 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	64.8 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-020

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-020
Location: 10F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	37.8 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-021

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-021
Location: 20
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	262 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	65.7 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-022

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-022
Location: 20F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	37.1 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-023

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-023
Location: 30
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	253 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	60.2 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-024

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-024
Location: 30F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	35.8 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-025

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-025
Location: 40
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	250 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	55.7 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-026

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-026
Location: 40F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	33.7 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-027

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-027
Location: 45
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	267 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	50.8 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-028

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-028
Location: 45F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.4 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-029

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-029
Location: 50
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	256 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	45.2 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-030

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-030
Location: 50F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.7 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-031

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-031
Location: 55
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	290 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.4 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-032

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-032
Location: 55F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	25.7 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-033

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-033
Location: 60
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	292 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	41.9 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-034

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-034
Location: 60F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	24.6 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2013
Report Number: M- W1302009-035

SAMPLE INFORMATION

Sample Number: 1302009-035
Location: 70
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	299 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	35.1 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-036

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-036
Location: 70F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	17.8 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-037

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-037
Location: 80
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	324 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	31.3 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-038

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-038
Location: 80F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.1 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-039

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-039
Location: 90
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	344 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	27.9 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-040

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-040
Location: 90F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.9 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-041

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-041
Location: 100
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	352 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	24.4 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-042

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-042
Location: 100F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.3 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-043

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-043
Location: 110
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	379 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.0 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-044

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-044
Location: 110F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	10.1 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-045

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-045
Location: 120
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	430 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.0 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-046

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-046
Location: 120F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.53 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-047

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-047
Location: 130
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	446 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	18.5 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-048

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-048
Location: 130F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.59 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-049

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-049
Location: H1
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	557 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.2 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-050

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-050
Location: H2
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	568 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.6 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-051

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-051
Location: X
LPR 1107 50TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	495 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	23.8 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-052

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-052 Customer Sample Number:
Location: 00 Type: Dist.
LPR 1107 50TH ST NE (INITIAL CUSTOMER COLLECTED)

Collection Date: 2/1/2013 Collection Time: 20:15 Sampler: CUSTOMER Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	294 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	45.1 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-053

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-053
Location: 00F
LPR 1107 50TH ST NE (INITIAL CUSTOMER COLLECTED)
Customer Sample Number:
Type: Dist.

Collection Date: 2/1/2013
Collection Time: 20:15
Sampler: CUSTOMER
Received Date and Time: 2/4/2013 11:02:34 AM
Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	23.5 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-054

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-054
Location: S2
LPR 1107 50TH ST NE (SINK#2, UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	162 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	248 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	298 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.09 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-055

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-055
Location: H1F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.71 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.42 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-056

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-056
Location: H2F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.28 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/11/2013
Report Number: M- W1302009-057

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-057
Location: XF
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.54 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/11/2013
Report Number: M- W1302009-058

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1302009-058
Location: 110F
LPR 1107 50TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/2/2013 Collection Time: 8:30 Sampler: AB/CW Received Date and Time: 2/4/2013 11:02:34 AM Received By: DGambrah

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	10.3 ug/L	2/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

2/11/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-001

SAMPLE INFORMATION

Sample Number: 1303185-001
Location: 01a
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	21.8 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	41.3 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	212 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.55 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-002

SAMPLE INFORMATION

Sample Number: 1303185-002
Location: 01aF
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	12.1 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	31.8 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	184 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-003

SAMPLE INFORMATION

Sample Number: 1303185-003
Location: 01b
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	70.0 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	53.5 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	23.0 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.31 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-004

SAMPLE INFORMATION

Sample Number: 1303185-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 4630 FESSENDEN ST NW
Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	44.2 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	24.2 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-005

SAMPLE INFORMATION

Sample Number: 1303185-005
Location: 01c
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	23.6 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	51.2 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	26.9 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.28 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-006

SAMPLE INFORMATION

Sample Number: 1303185-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 4630 FESSENDEN ST NW
Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	40.7 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	24.1 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-007

SAMPLE INFORMATION

Sample Number: 1303185-007
Location: 01d
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	128 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	60.6 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	25.7 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.57 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-008

SAMPLE INFORMATION

Sample Number: 1303185-008
Location: 01dF
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	42.7 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	22.7 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-009

SAMPLE INFORMATION

Sample Number: 1303185-009
Location: 02
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	162 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.0 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	28.2 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.60 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-010

SAMPLE INFORMATION

Sample Number: 1303185-010
Location: 02F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	25.2 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	24.9 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-011

SAMPLE INFORMATION

Sample Number: 1303185-011
Location: 03
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	126 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.94 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.6 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.75 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-012

SAMPLE INFORMATION

Sample Number: 1303185-012
Location: 03F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.55 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.6 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-013

SAMPLE INFORMATION

Sample Number: 1303185-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 4630 FESSENDEN ST NW
Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	24.4 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.78 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.04 ug/L	4/10/2013	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-014

SAMPLE INFORMATION

Sample Number: 1303185-014
Location: 04F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.59 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.2 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-015

SAMPLE INFORMATION

Sample Number: 1303185-015
Location: 05
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.50 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.16 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-016

SAMPLE INFORMATION

Sample Number: 1303185-016
Location: 05F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.99 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-017

SAMPLE INFORMATION

Sample Number: 1303185-017
Location: 06
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.66 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.34 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-018

SAMPLE INFORMATION

Sample Number: 1303185-018
Location: 06F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.97 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-019

SAMPLE INFORMATION

Sample Number: 1303185-019
Location: 07
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.72 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.06 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-020

SAMPLE INFORMATION

Sample Number: 1303185-020
Location: 07F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.33 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-021

SAMPLE INFORMATION

Sample Number: 1303185-021
Location: 08
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.78 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-022

SAMPLE INFORMATION

Sample Number: 1303185-022
Location: 08F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.10 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-023

SAMPLE INFORMATION

Sample Number: 1303185-023
Location: 09
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.94 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-024

SAMPLE INFORMATION

Sample Number: 1303185-024
Location: 09F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.36 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-025

SAMPLE INFORMATION

Sample Number: 1303185-025
Location: 10
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.79 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-026

SAMPLE INFORMATION

Sample Number: 1303185-026
Location: 10F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.99 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-027

SAMPLE INFORMATION

Sample Number: 1303185-027
Location: 11
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.24 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-028

SAMPLE INFORMATION

Sample Number: 1303185-028
Location: 11F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.80 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-029

SAMPLE INFORMATION

Sample Number: 1303185-029
Location: 12
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.08 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-030

SAMPLE INFORMATION

Sample Number: 1303185-030
Location: 12F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.73 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-031

SAMPLE INFORMATION

Sample Number: 1303185-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 4630 FESSENDEN ST NW
Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	32.9 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.05 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	18.0 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.72 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-032

SAMPLE INFORMATION

Sample Number: 1303185-032
Location: H1F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.46 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-033

SAMPLE INFORMATION

Sample Number: 1303185-033
Location: H2
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	23.7 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.82 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.00 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-034

SAMPLE INFORMATION

Sample Number: 1303185-034
Location: H2F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.87 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-035

SAMPLE INFORMATION

Sample Number: 1303185-035
Location: H3
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	34.0 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.61 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	17.0 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.79 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-036

SAMPLE INFORMATION

Sample Number: 1303185-036
Location: H3F
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.46 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-037

SAMPLE INFORMATION

Sample Number: 1303185-037
Location: H4
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	33.3 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.63 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	45.3 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.63 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-038

SAMPLE INFORMATION

Sample Number: 1303185-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 4630 FESSENDEN ST NW
Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.34 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-039

SAMPLE INFORMATION

Sample Number: 1303185-039
Location: X
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	154 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	27.0 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	135 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	10.9 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-040

SAMPLE INFORMATION

Sample Number: 1303185-040
Location: XF
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/21/2013 Collection Time: 8:30 Sampler: IC/DM Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.29 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	26.0 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-041

SAMPLE INFORMATION

Sample Number: 1303185-041
Location: 00
LPR 4630 FESSENDEN ST NW

Customer Sample Number:
Type: Dist.

Collection Date: 3/20/2013 Collection Time: 21:40 Sampler: CUSTOMER Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.2 ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.86 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/1/2013
Report Number: M- W1303185-042

SAMPLE INFORMATION

Sample Number: 1303185-042 Customer Sample Number:
Location: 00F Type: Dist.
LPR 4630 FESSENDEN ST NW
Collection Date: 3/20/2013 Collection Time: 21:40 Sampler: CUSTOMER Received Date and Time: 3/22/2013 9:18:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.34 ug/L	4/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.9 ug/L	4/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/10/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/1/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-001

SAMPLE INFORMATION

Sample Number: 1304010-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-002

SAMPLE INFORMATION

Sample Number: 1304010-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/ CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-003

SAMPLE INFORMATION

Sample Number: 1304010-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-004

SAMPLE INFORMATION

Sample Number: 1304010-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-005

SAMPLE INFORMATION

Sample Number: 1304010-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-006

SAMPLE INFORMATION

Sample Number: 1304010-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-007

SAMPLE INFORMATION

Sample Number: 1304010-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-008

SAMPLE INFORMATION

Sample Number: 1304010-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-009

SAMPLE INFORMATION

Sample Number: 1304010-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-010

SAMPLE INFORMATION

Sample Number: 1304010-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 4918 FITCH PL NE FILTERED

Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	4/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.62 ug/L	4/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-010

SAMPLE INFORMATION

Sample Number: 1304010-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-011

SAMPLE INFORMATION

Sample Number: 1304010-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-012

SAMPLE INFORMATION

Sample Number: 1304010-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-013

SAMPLE INFORMATION

Sample Number: 1304010-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-014

SAMPLE INFORMATION

Sample Number: 1304010-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-015

SAMPLE INFORMATION

Sample Number: 1304010-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-016

SAMPLE INFORMATION

Sample Number: 1304010-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 4918 FITCH PL NE FILTERED

Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	4/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.36 ug/L	4/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-016

SAMPLE INFORMATION

Sample Number: 1304010-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-017

SAMPLE INFORMATION

Sample Number: 1304010-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED

Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	4/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	19.1 ug/L	4/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.60 ug/L	4/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-017

SAMPLE INFORMATION

Sample Number: 1304010-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-018

SAMPLE INFORMATION

Sample Number: 1304010-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-019

SAMPLE INFORMATION

Sample Number: 1304010-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-020

SAMPLE INFORMATION

Sample Number: 1304010-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-021

SAMPLE INFORMATION

Sample Number: 1304010-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-022

SAMPLE INFORMATION

Sample Number: 1304010-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-023

SAMPLE INFORMATION

Sample Number: 1304010-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-024

SAMPLE INFORMATION

Sample Number: 1304010-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-025

SAMPLE INFORMATION

Sample Number: 1304010-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-026

SAMPLE INFORMATION

Sample Number: 1304010-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-027

SAMPLE INFORMATION

Sample Number: 1304010-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-028

SAMPLE INFORMATION

Sample Number: 1304010-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-029

SAMPLE INFORMATION

Sample Number: 1304010-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-030

SAMPLE INFORMATION

Sample Number: 1304010-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-031

SAMPLE INFORMATION

Sample Number: 1304010-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-032

SAMPLE INFORMATION

Sample Number: 1304010-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-033

SAMPLE INFORMATION

Sample Number: 1304010-033 Customer Sample Number:
Location: H2 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-034

SAMPLE INFORMATION

Sample Number: 1304010-034 Customer Sample Number:
Location: H2F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-035

SAMPLE INFORMATION

Sample Number: 1304010-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-036

SAMPLE INFORMATION

Sample Number: 1304010-036 Customer Sample Number:
Location: H3F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-037

SAMPLE INFORMATION

Sample Number: 1304010-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-038

SAMPLE INFORMATION

Sample Number: 1304010-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-039

SAMPLE INFORMATION

Sample Number: 1304010-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-040

SAMPLE INFORMATION

Sample Number: 1304010-040 Customer Sample Number:
Location: H5F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-041

SAMPLE INFORMATION

Sample Number: 1304010-041 Customer Sample Number:
Location: X Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/29/2013 9:00 IC/CW 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-042

SAMPLE INFORMATION

Sample Number: 1304010-042 Customer Sample Number:
Location: XF Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/29/2013 Collection Time: 9:00 Sampler: IC/CW Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-043

SAMPLE INFORMATION

Sample Number: 1304010-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED

Collection Date: 3/28/2013 Collection Time: 10:00 Sampler: CUSTOMER Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	4/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	14.5 ug/L	4/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.68 ug/L	4/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	4/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-043

SAMPLE INFORMATION

Sample Number: 1304010-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/28/2013 10:00 CUSTOMER 4/1/2013 2:11:22 PM BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2013
Report Number: M- W1304010-044

SAMPLE INFORMATION

Sample Number: 1304010-044 Customer Sample Number:
Location: 00F Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 3/28/2013 Collection Time: 10:00 Sampler: CUSTOMER Received Date and Time: 4/1/2013 2:11:22 PM Received By: BSmith

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-001

SAMPLE INFORMATION

Sample Number: 1305069-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: 5/7/2013 Collection Time: 8:15 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-002

SAMPLE INFORMATION

Sample Number: 1305069-002 Customer Sample Number:
Location: 01af Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/7/2013 Collection Time: 8:15 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.68 ug/L	6/6/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/6/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	159 ug/L	6/6/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	87.8 ug/L	6/6/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/6/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-002

SAMPLE INFORMATION

Sample Number: 1305069-002 Customer Sample Number:
Location: 01af Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/7/2013 Collection Time: 8:15 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-003

SAMPLE INFORMATION

Sample Number: 1305069-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:15 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-004

SAMPLE INFORMATION

Sample Number: 1305069-004 Customer Sample Number:
Location: 01bf Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:15 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-005

SAMPLE INFORMATION

Sample Number: 1305069-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:15 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-006

SAMPLE INFORMATION

Sample Number: 1305069-006 Customer Sample Number:
Location: 01cf Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/7/2013 Collection Time: 8:15 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-007

SAMPLE INFORMATION

Sample Number: 1305069-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:15 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-008

SAMPLE INFORMATION

Sample Number: 1305069-008 Customer Sample Number:
Location: 01df Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:15 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-009

SAMPLE INFORMATION

Sample Number: 1305069-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: 5/7/2013 Collection Time: 8:15 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-010

SAMPLE INFORMATION

Sample Number: 1305069-010 Customer Sample Number:
Location: 02f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/7/2013 Collection Time: 8:15 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.0 ug/L	6/6/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/6/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	203 ug/L	6/6/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/6/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/6/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-010

SAMPLE INFORMATION

Sample Number: 1305069-010 Customer Sample Number:
Location: 02f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/7/2013 Collection Time: 8:15 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-011

SAMPLE INFORMATION

Sample Number: 1305069-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:15 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-012

SAMPLE INFORMATION

Sample Number: 1305069-012 Customer Sample Number:
Location: 03f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/7/2013 Collection Time: 8:15 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-013

SAMPLE INFORMATION

Sample Number: 1305069-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:15 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-014

SAMPLE INFORMATION

Sample Number: 1305069-014 Customer Sample Number:
Location: 04f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/7/2013 Collection Time: 8:15 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.0 ug/L	6/6/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/6/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	59.9 ug/L	6/6/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.6 ug/L	6/6/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	6/6/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-015

SAMPLE INFORMATION

Sample Number: 1305069-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:15 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-016

SAMPLE INFORMATION

Sample Number: 1305069-016 Customer Sample Number:
Location: 05f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:15 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-017

SAMPLE INFORMATION

Sample Number: 1305069-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: 5/7/2013 Collection Time: 8:30 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.24 ug/L	6/6/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	25.8 ug/L	6/6/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.4 ug/L	6/6/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/6/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.60 ug/L	6/6/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-017

SAMPLE INFORMATION

Sample Number: 1305069-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-018

SAMPLE INFORMATION

Sample Number: 1305069-018 Customer Sample Number:
Location: 06f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-019

SAMPLE INFORMATION

Sample Number: 1305069-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-020

SAMPLE INFORMATION

Sample Number: 1305069-020 Customer Sample Number:
Location: 07f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-021

SAMPLE INFORMATION

Sample Number: 1305069-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-022

SAMPLE INFORMATION

Sample Number: 1305069-022 Customer Sample Number:
Location: 08f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-023

SAMPLE INFORMATION

Sample Number: 1305069-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-024

SAMPLE INFORMATION

Sample Number: 1305069-024 Customer Sample Number:
Location: 09f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-025

SAMPLE INFORMATION

Sample Number: 1305069-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-026

SAMPLE INFORMATION

Sample Number: 1305069-026 Customer Sample Number:
Location: 10f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/7/2013 Collection Time: 8:30 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.9 ug/L	6/6/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/6/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.0 ug/L	6/6/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/6/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/6/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-026

SAMPLE INFORMATION

Sample Number: 1305069-026 Customer Sample Number:
Location: 10f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-027

SAMPLE INFORMATION

Sample Number: 1305069-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-028

SAMPLE INFORMATION

Sample Number: 1305069-028 Customer Sample Number:
Location: 11f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-029

SAMPLE INFORMATION

Sample Number: 1305069-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-030

SAMPLE INFORMATION

Sample Number: 1305069-030 Customer Sample Number:
Location: 12f Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-031

SAMPLE INFORMATION

Sample Number: 1305069-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-032

SAMPLE INFORMATION

Sample Number: 1305069-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-033

SAMPLE INFORMATION

Sample Number: 1305069-033 Customer Sample Number:
Location: H2 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: 5/7/2013 Collection Time: 8:30 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-034

SAMPLE INFORMATION

Sample Number: 1305069-034 Customer Sample Number:
Location: H2F Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-035

SAMPLE INFORMATION

Sample Number: 1305069-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-036

SAMPLE INFORMATION

Sample Number: 1305069-036 Customer Sample Number:
Location: H3F Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-037

SAMPLE INFORMATION

Sample Number: 1305069-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-038

SAMPLE INFORMATION

Sample Number: 1305069-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-039

SAMPLE INFORMATION

Sample Number: 1305069-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: 5/7/2013 Collection Time: 8:30 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.58 ug/L	6/6/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	30.9 ug/L	6/6/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	39.8 ug/L	6/6/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/6/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.65 ug/L	6/6/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-039

SAMPLE INFORMATION

Sample Number: 1305069-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-040

SAMPLE INFORMATION

Sample Number: 1305069-040 Customer Sample Number:
Location: H5F Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-041

SAMPLE INFORMATION

Sample Number: 1305069-041
Customer Sample Number:
Location: X Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: 5/7/2013 Collection Time: 8:30 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.87 ug/L	6/6/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	54.1 ug/L	6/6/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	81.5 ug/L	6/6/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	16.4 ug/L	6/6/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.31 ug/L	6/6/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-041

SAMPLE INFORMATION

Sample Number: 1305069-041 Customer Sample Number:
Location: X Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: 5/7/2013 Collection Time: 8:30 Sampler: DM/YT Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-042

SAMPLE INFORMATION

Sample Number: 1305069-042 Customer Sample Number:
Location: XF Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/7/2013 8:30 DM/YT 5/8/2013 10:37:08 AM HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-043

SAMPLE INFORMATION

Sample Number: 1305069-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: 5/6/2013 Collection Time: 21:55 Sampler: CUSTOMER Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.63 ug/L	6/6/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	44.4 ug/L	6/6/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	40.1 ug/L	6/6/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.5 ug/L	6/6/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.82 ug/L	6/6/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-043

SAMPLE INFORMATION

Sample Number: 1305069-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 6629 PINEY BRANCH RD NW - UNFILTERED
Collection Date: 5/6/2013 Collection Time: 21:55 Sampler: CUSTOMER Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-044

SAMPLE INFORMATION

Sample Number: 1305069-044 Customer Sample Number:
Location: 00F Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/6/2013 Collection Time: 21:55 Sampler: CUSTOMER Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.01 ug/L	6/6/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/6/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	23.0 ug/L	6/6/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/6/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/6/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305069-044

SAMPLE INFORMATION

Sample Number: 1305069-044 Customer Sample Number:
Location: 00F Type: Dist.
LPR 6629 PINEY BRANCH RD NW - FILTERED
Collection Date: 5/6/2013 Collection Time: 21:55 Sampler: CUSTOMER Received Date and Time: 5/8/2013 10:37:08 AM Received By: HBeiter

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-001

SAMPLE INFORMATION

Sample Number: 1305144-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-002

SAMPLE INFORMATION

Sample Number: 1305144-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-003

SAMPLE INFORMATION

Sample Number: 1305144-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-004

SAMPLE INFORMATION

Sample Number: 1305144-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-005

SAMPLE INFORMATION

Sample Number: 1305144-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-006

SAMPLE INFORMATION

Sample Number: 1305144-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-007

SAMPLE INFORMATION

Sample Number: 1305144-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-008

SAMPLE INFORMATION

Sample Number: 1305144-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-009

SAMPLE INFORMATION

Sample Number: 1305144-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-010

SAMPLE INFORMATION

Sample Number: 1305144-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-011

SAMPLE INFORMATION

Sample Number: 1305144-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-012

SAMPLE INFORMATION

Sample Number: 1305144-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-013

SAMPLE INFORMATION

Sample Number: 1305144-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-014

SAMPLE INFORMATION

Sample Number: 1305144-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-015

SAMPLE INFORMATION

Sample Number: 1305144-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-016

SAMPLE INFORMATION

Sample Number: 1305144-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-017

SAMPLE INFORMATION

Sample Number: 1305144-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-018

SAMPLE INFORMATION

Sample Number: 1305144-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-019

SAMPLE INFORMATION

Sample Number: 1305144-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED

Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	6/7/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	6/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	103 ug/L	6/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	8.52 ug/L	6/7/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-019

SAMPLE INFORMATION

Sample Number: 1305144-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-020

SAMPLE INFORMATION

Sample Number: 1305144-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-021

SAMPLE INFORMATION

Sample Number: 1305144-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-022

SAMPLE INFORMATION

Sample Number: 1305144-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-023

SAMPLE INFORMATION

Sample Number: 1305144-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-024

SAMPLE INFORMATION

Sample Number: 1305144-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-025

SAMPLE INFORMATION

Sample Number: 1305144-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-026

SAMPLE INFORMATION

Sample Number: 1305144-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-027

SAMPLE INFORMATION

Sample Number: 1305144-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-028

SAMPLE INFORMATION

Sample Number: 1305144-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-029

SAMPLE INFORMATION

Sample Number: 1305144-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-030

SAMPLE INFORMATION

Sample Number: 1305144-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-031

SAMPLE INFORMATION

Sample Number: 1305144-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-032

SAMPLE INFORMATION

Sample Number: 1305144-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-033

SAMPLE INFORMATION

Sample Number: 1305144-033 Customer Sample Number:
Location: H2 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-034

SAMPLE INFORMATION

Sample Number: 1305144-034 Customer Sample Number:
Location: H2F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-036

SAMPLE INFORMATION

Sample Number: 1305144-036 Customer Sample Number:
Location: H3F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-037

SAMPLE INFORMATION

Sample Number: 1305144-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-038

SAMPLE INFORMATION

Sample Number: 1305144-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-039

SAMPLE INFORMATION

Sample Number: 1305144-039 Customer Sample Number:
Location: X Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 10:00 IC/ CW 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-040

SAMPLE INFORMATION

Sample Number: 1305144-040 Customer Sample Number:
Location: XF Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 10:00 Sampler: IC/ CW Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-041

SAMPLE INFORMATION

Sample Number: 1305144-041 Customer Sample Number:
Location: 00 Type: Dist.
LPR 615 MORTON PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/15/2013 3:00 CUSTOMER 5/16/2013 11:07:53 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/12/2013
Report Number: M- W1305144-042

SAMPLE INFORMATION

Sample Number: 1305144-042 Customer Sample Number:
Location: 00F Type: Dist.
LPR 615 MORTON PL NE FILTERED
Collection Date: 5/15/2013 Collection Time: 3:00 Sampler: CUSTOMER Received Date and Time: 5/16/2013 11:07:53 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-001

SAMPLE INFORMATION

Sample Number: 1305179-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-002

SAMPLE INFORMATION

Sample Number: 1305179-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-003

SAMPLE INFORMATION

Sample Number: 1305179-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-004

SAMPLE INFORMATION

Sample Number: 1305179-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-005

SAMPLE INFORMATION

Sample Number: 1305179-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/26/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-006

SAMPLE INFORMATION

Sample Number: 1305179-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-007

SAMPLE INFORMATION

Sample Number: 1305179-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/26/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-009

SAMPLE INFORMATION

Sample Number: 1305179-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-010

SAMPLE INFORMATION

Sample Number: 1305179-010 Customer Sample Number:
Location: 03 Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-011

SAMPLE INFORMATION

Sample Number: 1305179-011 Customer Sample Number:
Location: 04 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-012

SAMPLE INFORMATION

Sample Number: 1305179-012
Location: 05
LPR 4918 FITCH PL NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	6/13/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	15.5 ug/L	6/13/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.15 ug/L	6/13/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/13/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/13/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-012

SAMPLE INFORMATION

Sample Number: 1305179-012 Customer Sample Number:
Location: 05 Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-013

SAMPLE INFORMATION

Sample Number: 1305179-013 Customer Sample Number:
Location: 06 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-014

SAMPLE INFORMATION

Sample Number: 1305179-014 Customer Sample Number:
Location: 07 Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-015

SAMPLE INFORMATION

Sample Number: 1305179-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-016

SAMPLE INFORMATION

Sample Number: 1305179-016 Customer Sample Number:
Location: 09 Type: Dist.
LPR 4918 FITCH PL NE FILTERED

Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-017

SAMPLE INFORMATION

Sample Number: 1305179-017 Customer Sample Number:
Location: H1 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-018

SAMPLE INFORMATION

Sample Number: 1305179-018 Customer Sample Number:
Location: H2 Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/26/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-019

SAMPLE INFORMATION

Sample Number: 1305179-019 Customer Sample Number:
Location: H3 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-020

SAMPLE INFORMATION

Sample Number: 1305179-020 Customer Sample Number:
Location: H4 Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-021

SAMPLE INFORMATION

Sample Number: 1305179-021 Customer Sample Number:
Location: H5 Type: Dist.
LPR 4918 FITCH PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2013 9:00 IC/YT 5/21/2013 9:45:41 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/26/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/26/2013
Report Number: M- W1305179-022

SAMPLE INFORMATION

Sample Number: 1305179-022 Customer Sample Number:
Location: X Type: Dist.
LPR 4918 FITCH PL NE FILTERED
Collection Date: 5/20/2013 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2013 9:45:41 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/26/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

DC Water - Other Research

DC Water collected samples from two hydrants during a research trial to clear the water main of biofilm on May 2, 2013. DC Water collected samples before and after the research trial.

All samples were analyzed by the Washington Aqueduct.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2013
Report Number: M- W1305015-009

SAMPLE INFORMATION

Sample Number: 1305015-009

Customer Sample Number:

Location: TAYLOR ST & DEAD END ST., NE HYDRANT

Type: SP Project: FLZ

H09085

Collection Date:
5/1/2013

Collection Time:
13:00

Sampler:
IC

Received Date and Time:
5/1/2013 3:18:53 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	10 ug/L	< 10 ug/L	5/7/2013	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	77.4 ug/L	5/7/2013	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	0.58 ug/L	5/7/2013	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	19.4 ug/L	5/7/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	5290 ug/L	5/7/2013	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	1.59 ug/L	5/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.9 ug/L	5/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	5/7/2013	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2013
Report Number: M- W1305015-009

SAMPLE INFORMATION

Sample Number: 1305015-009

Customer Sample Number:

Location: TAYLOR ST & DEAD END ST., NE HYDRANT

Type: SP Project: FLZ

H09085

Collection Date:
5/1/2013

Collection Time:
13:00

Sampler:
IC

Received Date and Time:
5/1/2013 3:18:53 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	0.88 ug/L	5/7/2013	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	152 ug/L	5/7/2013	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	5/7/2013	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	56.7 ug/L	5/7/2013	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2013
Report Number: M- W1305015-009

SAMPLE INFORMATION

Sample Number: 1305015-009

Customer Sample Number:

Location: TAYLOR ST & DEAD END ST., NE HYDRANT

Type: SP Project: FLZ

H09085

Collection Date:
5/1/2013

Collection Time:
13:00

Sampler:
IC

Received Date and Time:
5/1/2013 3:18:53 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/14/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2013
Report Number: M- W1305015-010

SAMPLE INFORMATION

Sample Number: 1305015-010

Customer Sample Number:

Location: TAYLOR ST BTW 20TH & 22ND STS NE HYDRANT

Type: SP Project: FLZ

H04507

Collection Date:
5/1/2013

Collection Time:
13:30

Sampler:
IC

Received Date and Time:
5/1/2013 3:18:53 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	10 ug/L	< 10 ug/L	5/7/2013	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	33.7 ug/L	5/7/2013	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	1.00 ug/L	5/7/2013	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	15.2 ug/L	5/7/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	1290 ug/L	5/7/2013	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	1.48 ug/L	5/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.99 ug/L	5/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	5/7/2013	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2013
Report Number: M- W1305015-010

SAMPLE INFORMATION

Sample Number: 1305015-010

Customer Sample Number:

Location: TAYLOR ST BTW 20TH & 22ND STS NE HYDRANT

Type: SP Project: FLZ

H04507

Collection Date:
5/1/2013

Collection Time:
13:30

Sampler:
IC

Received Date and Time:
5/1/2013 3:18:53 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	0.91 ug/L	5/7/2013	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	144 ug/L	5/7/2013	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	5/7/2013	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	36.7 ug/L	5/7/2013	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.63 ug/L	5/7/2013	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2013
Report Number: M- W1305015-010

SAMPLE INFORMATION

Sample Number: 1305015-010

Customer Sample Number:

Location: TAYLOR ST BTW 20TH & 22ND STS NE HYDRANT

Type: SP Project: FLZ

H04507

Collection Date:
5/1/2013

Collection Time:
13:30

Sampler:
IC

Received Date and Time:
5/1/2013 3:18:53 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/14/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2013
Report Number: M- W1305035-004

SAMPLE INFORMATION

Sample Number: 1305035-004

Customer Sample Number:

Location: TAYLOR ST BW 20TH & 22ND STS NE HYDRANT

Type: SP Project: FLZ

Collection Date:
5/2/2013

Collection Time:
14:30

Sampler:
IC

Received Date and Time:
5/3/2013 12:28:14 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	10 ug/L	< 10 ug/L	5/7/2013	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	44.9 ug/L	5/7/2013	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	0.91 ug/L	5/7/2013	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	15.4 ug/L	5/7/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	1830 ug/L	5/7/2013	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	1.52 ug/L	5/7/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.60 ug/L	5/7/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	5/7/2013	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 5/14/2013
 Report Number: M- W1305035-004

SAMPLE INFORMATION

Sample Number: 1305035-004

Customer Sample Number:

Location: TAYLOR ST BW 20TH & 22ND STS NE HYDRANT

Type: SP Project: FLZ

Collection Date:
5/2/2013

Collection Time:
14:30

Sampler:
IC

Received Date and Time:
5/3/2013 12:28:14 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	146 ug/L	5/7/2013	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	< 0.5 ug/L	5/7/2013	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	5/7/2013	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	40.8 ug/L	5/7/2013	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.16 ug/L	5/7/2013	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2013
Report Number: M- W1305035-004

SAMPLE INFORMATION

Sample Number: 1305035-004

Customer Sample Number:

Location: TAYLOR ST BW 20TH & 22ND STS NE HYDRANT

Type: SP Project: FLZ

Collection Date:
5/2/2013

Collection Time:
14:30

Sampler:
IC

Received Date and Time:
5/3/2013 12:28:14 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	5/7/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

5/14/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 6/3/2013
 Report Number: M- W1305035-002

SAMPLE INFORMATION

Sample Number: 1305035-002

Customer Sample Number:

Location: TAYLOR ST & DEAD END ST., NE HYDRANT

Type: SP Project: FLZ

Collection Date:
5/2/2013

Collection Time:
14:30

Sampler:
IC

Received Date and Time:
5/3/2013 12:28:14 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.84 ug/L	5/23/2013	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	5/23/2013	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	59.4 ug/L	5/23/2013	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	5/23/2013	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	< 0.5 ug/L	5/23/2013	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	18.4 ug/L	5/23/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	3000 ug/L	5/23/2013	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	5/23/2013	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	1.73 ug/L	5/23/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.38 ug/L	5/23/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	5/23/2013	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/3/2013
Report Number: M- W1305035-002

SAMPLE INFORMATION

Sample Number: 1305035-002

Customer Sample Number:

Location: TAYLOR ST & DEAD END ST., NE HYDRANT

Type: SP Project: FLZ

Collection Date:
5/2/2013

Collection Time:
14:30

Sampler:
IC

Received Date and Time:
5/3/2013 12:28:14 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	5/23/2013	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	ND ug/L	5/23/2013	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	150 ug/L	5/23/2013	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	< 0.5 ug/L	5/23/2013	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	5/23/2013	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	5/23/2013	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	< 0.5 ug/L	5/23/2013	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	39.3 ug/L	5/23/2013	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	5/23/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.64 ug/L	5/23/2013	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	5/23/2013	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/3/2013
Report Number: M- W1305035-002

SAMPLE INFORMATION

Sample Number: 1305035-002

Customer Sample Number:

Location: TAYLOR ST & DEAD END ST., NE HYDRANT

Type: SP Project: FLZ

Collection Date:
5/2/2013

Collection Time:
14:30

Sampler:
IC

Received Date and Time:
5/3/2013 12:28:14 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	5/23/2013	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

6/3/2013

Date


5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

Attachment 3

Customer Letter Distribution Certification



DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY | 3900 DONALDSON PLACE, NW | WASHINGTON, DC 20016

July 8, 2013

William Arguto
U.S. Environmental Protection Agency Region III
1650 Arch Street
Philadelphia, PA 19103-2029

Re: Certification of Distribution of Consumer Test Results

Dear Mr. Arguto:

The District of Columbia Water and Sewer Authority (PWSID: DC000002) hereby certifies that for the lead and copper compliance monitoring period ending June 30, 2013, the “consumer notification of test results” have been distributed to the participating Lead and Copper Compliance monitoring customers in a manner consistent with the requirements of 40 CFR § 141.85(d). Pursuant to 40 CFR § 141.90(f)(3), attached are copies of sample consumer notifications.

Sincerely,

A handwritten signature in black ink, appearing to read "Jessica Edwards-Brandt". The signature is stylized and includes a long horizontal line extending to the right.

Jessica Edwards-Brandt
Manager, Drinking Water Division

cc: Charles Kiely
Gregory Hope
Randy Hayman



January 9, 2013

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead and copper levels were below the Environmental Protection Agency (EPA) action levels.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

If you are pregnant or have children under age six, you should consider using cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Some people who drink water containing copper in excess of the action level may, with short term

exposure, experience gastrointestinal distress, and with long-term exposure may experience liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager



January 9, 2013

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead level was above the Environmental Protection Agency (EPA) action level. DC Water recommends that you take steps to minimize potential lead exposure. You should filter your water until lead levels decline in your drinking water. If you are pregnant or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The first draw water sample was above the lead action level. The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

Short-term exposure to copper levels above the action level may cause gastrointestinal distress, and long-term exposure may contribute to liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dwater.com/lead.

Sincerely,



George S. Hawkins, General Manager



January 9, 2013

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead level was above the Environmental Protection Agency (EPA) action level. DC Water recommends that you take steps to minimize potential lead exposure. You should filter your water until lead levels decline in your drinking water. If you are pregnant or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The second draw water sample was above the lead action level. The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

Short-term exposure to copper levels above the action level may cause gastrointestinal distress, and long-term exposure may contribute to liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager