



Lead and Copper Compliance Report January through June 2014

Table 1 summarizes the District of Columbia Water and Sewer Authority's (DC Water) Lead and Copper compliance results for the monitoring period January through June 2014.

Table 1. Lead and Copper Summary Data

Number of Samples	
Lead and Copper	111
90th Percentile First Draw Concentrations	
Lead mg/L	0.002
Copper mg/L	0.082
Service Line Materials	
Full Lead	78%
Partial Lead	22%

The appendices and attachments contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
 - Table A.1 First Draw Lead Results
 - Table A.2 First Draw Copper Results

- Appendix B: Additional Monitoring Data
 - Table B.1 Second Draw Lead Results
 - Table B.2 Second Draw Copper Results

- Appendix C: Additional Sampling Information
 - Table C.1 Sample Kit Distribution
 - Table C.2 Sample Kits Not Returned
 - Table C.3 Samples Returned but Rejected for Compliance Analysis
 - Table C.4 Deviations from Sample Kit Distribution Order
 - Table C.5 Sites with Compliance Results from January 2013 – December 2013 and No Results in January – June 2014
 - Table C.6 Customer Notification of Results

- Appendix D: Revisions to Sample Pool
 - Table D.1 Sample Pool for July – December 2014
 - Table D.2 Site Changes – Sites Removed, Added, or Priority Status Changed

- Appendix E: Revised Template Notices for Customer LCR Results
 - Service Line Lead Public and Non-lead Private
 - Service Line Lead Public and Private
 - Service Line Non-lead Public and Lead Private

- Attachment 1: Washington Aqueduct Test Results for LCR Compliance

- Attachment 2: Other Additional Monitoring Data:
 - Customer requested tests
 - Post-LSR
 - Lead profiles
 - Other Research

- Attachment 3: Certification of Consumer Tap Results for January through June 2014

Appendix A: Lead and Copper Compliance Data

Table A.1 First Draw Lead Results

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
1	1706 NEW JERSEY AVE NW	Lead	1/28/2014	0.0000
2	1318 Wallach Pl NW	Lead	1/29/2014	0.0000
3	1375 MONROE ST NW	Lead	1/27/2014	0.0000
4	331 RALEIGH ST SE	Lead	2/26/2014	0.0000
5	3206 38th St NW	Lead	2/26/2014	0.0000
6	4627 49th St NW	Lead	2/27/2014	0.0000
7	4926 Glenbrook Rd NW	Lead	2/27/2014	0.0000
8	4120 Grant St NE	Lead	3/5/2014	0.0000
9	307 7th St NE	Lead	2/26/2014	0.0000
10	5024 7th St NW	Lead	2/25/2014	0.0000
11	1613 Webster St NW	Lead	2/27/2014	0.0000
12	309 11TH ST SE	Lead	2/26/2014	0.0000
13	4806 Kansas Ave NW	Lead	2/25/2014	0.0000
14	5312 ILLINOIS AVE NW	Lead	2/25/2014	0.0000
15	3724 CHESAPEAKE ST NW	Lead	2/25/2014	0.0000
16	4719 9TH ST NW	Lead	2/25/2014	0.0000
17	2007 37TH ST NW	Lead	3/31/2014	0.0000
18	1436 S St NW	Partial Lead	3/26/2014	0.0000
19	619 12th St NE	Lead	3/26/2014	0.0000
20	2408 2nd St NE	Partial Lead	3/24/2014	0.0000
21	617 6th St NE	Lead	3/26/2014	0.0000
22	3036 P St NW	Partial Lead	3/26/2014	0.0000
23	6308 8th St NW	Lead	3/27/2014	0.0000
24	621 Upshur St NW	Lead	3/26/2014	0.0000
25	308 9th St SE	Partial Lead	3/24/2014	0.0000
26	2923 Cathedral AVE NW	Lead	3/28/2014	0.0000
27	3913 8TH ST NW	Partial Lead	4/29/2014	0.0000
28	231 K St NE	Partial Lead	4/29/2014	0.0000
29	3416 9th St NE	Partial Lead	4/29/2014	0.0000
30	413 4th St SE	Partial Lead	4/30/2014	0.0000
31	414 G ST NE	Lead	6/3/2014	0.0000
32	1010 10th St NE	Lead	4/30/2014	0.0000
33	313 10TH ST SE	Lead	5/23/2014	0.0000
34	522 4TH ST SE	Lead	6/3/2014	0.0000
35	744 9TH ST SE	Lead	6/4/2014	0.0000
36	3218 MORRISON ST NW	Lead	4/30/2014	0.0000
37	502 A ST SE	Lead	6/4/2014	0.0000
38	3510 QUESADA ST NW	Lead	6/4/2014	0.0000
39	4818 8th ST NW	Partial Lead	4/29/2014	0.0000
40	3809 ALTON PL NW	Partial Lead	4/30/2014	0.0000
41	3917 8th St NW	Partial Lead	5/1/2014	0.0000
42	3033 CAMBRIDGE PL NW	Lead	6/4/2014	0.0000

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
43	6210 8th St NW	Lead	3/26/2014	0.0000
44	322 TENNESSEE AVE NE	Lead	4/30/2014	0.0000
45	5301 RENO RD NW	Partial Lead	4/30/2014	0.0000
46	333 34th St NE	Partial Lead	4/30/2014	0.0000
47	5007 13TH ST NW	Lead	5/20/2014	0.0000
48	412 BRANDYWINE ST SE	Lead	5/21/2014	0.0000
49	1003 Otis St NE	Lead	1/27/2014	0.0000
50	2913 Brandywine St NW	Lead	2/26/2014	0.0000
51	2904 P ST SE	Lead	2/25/2014	0.0000
52	1319 POTOMAC AVE SE	Partial Lead	3/26/2014	0.0000
53	3309 35TH ST NW	Lead	6/5/2014	0.0000
54	1826 Jackson St NE	Lead	1/29/2014	0.0000
55	822 Allison St NW	Lead	2/26/2014	0.0000
56	3907 13th St NW	Partial Lead	5/6/2014	0.0000
57	1020 INDEPENDENCE AVE SE	Lead	6/2/2014	0.0000
58	2435 33RD ST SE	Lead	1/29/2014	0.0000
59	1738 ALLISON ST NW	Lead	1/30/2014	0.0000
60	3710 Huntington St NW	Lead	2/26/2014	0.0000
61	336 Quackenbos St NE	Lead	2/26/2014	0.0000
62	912 Emerson St NW	Lead	3/26/2014	0.0000
63	807 Buchanan St NW	Lead	3/26/2014	0.0000
64	4413 5th St NW	Lead	2/25/2014	0.0000
65	913 Hamlin St NE	Lead	3/25/2014	0.0000
66	3761 W ST NW	Lead	6/3/2014	0.0000
67	4418 14th St NE	Lead	2/26/2014	0.0010
68	3211 Central Ave NE	Lead	2/25/2014	0.0010
69	3625 Albermarle St NW	Lead	2/26/2014	0.0010
70	2832 BRENTWOOD RD NE	Lead	2/26/2014	0.0010
71	2121 3RD ST NE	Lead	5/21/2014	0.0010
72	1911 P ST SE	Lead	5/22/2014	0.0010
73	4401 5TH ST NW	Lead	2/25/2014	0.0011
74	1211 Carrollsburg Pl SW	Partial Lead	3/25/2014	0.0011
75	1715 IRVING ST NE	Lead	5/20/2014	0.0011
76	1703 D St NE	Lead	1/27/2014	0.0012
77	4131 YUMA ST NW	Lead	2/26/2014	0.0012
78	3030 44TH ST NW	Partial Lead	3/27/2014	0.0012
79	4215 39th St NW	Partial Lead	4/28/2014	0.0012
80	3636 13TH ST NW	Lead	2/25/2014	0.0013
81	1808 KEARNEY ST NE	Partial Lead	3/28/2014	0.0013
82	8 N St SW	Lead	3/25/2014	0.0013
83	421 Hamilton St NW	Lead	3/26/2014	0.0013
84	6209 30TH ST NW	Lead	3/29/2014	0.0014
85	4703 Macarthur Blvd NW	Lead	2/26/2014	0.0015
86	5223 KANSAS AVE NW	Lead	6/3/2014	0.0015
87	109 19th St SE	Lead	1/28/2014	0.0016
88	1305 TAYLOR ST NW	Lead	1/28/2014	0.0016

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
89	6205 14TH ST NW	Lead	6/3/2014	0.0016
90	120 VARNUM ST NW	Lead	6/3/2014	0.0017
91	12 14TH ST SE	Partial Lead	1/27/2014	0.0018
92	5923 33rd St NW	Lead	3/26/2014	0.0018
93	4811 Illinois Ave NW	Lead	2/11/2014	0.0018
94	1113 STAPLES ST NE	Lead	6/4/2014	0.0018
95	4525 15TH ST NW	Lead	6/11/2014	0.0019
96	4550 30TH ST NW	Lead	2/25/2014	0.0022
97	702 9th St SE	Lead	3/25/2014	0.0022
98	1508 GOOD HOPE RD SE	Lead	5/21/2014	0.0022
99	228 V ST NE	Lead	1/29/2014	0.0023
100	501 Webster St NW	Lead	2/24/2014	0.0024
101	5404 39TH ST NW	Partial Lead	4/29/2014	0.0024
102	119 16TH ST NE	Lead	1/29/2014	0.0026
103	1513 27TH ST NW	Lead	1/28/2014	0.0026
104	450 Newton Pl NW	Lead	3/2/2014	0.0026
105	1412 Shepherd St NW	Partial Lead	3/25/2014	0.0027
106	3727 T St NW	Lead	2/26/2014	0.0030
107	1222 HAMILTON ST NW	Partial Lead	3/25/2014	0.0031
108	125 Madison St NW	Lead	1/29/2014	0.0032
109	36 Florida Ave NW	Partial Lead	4/30/2014	0.0066
110	2830 BRENTWOOD RD NE	Lead	2/25/2014	0.0074
111	1505 Buchanan St NW	Lead	1/28/2014	0.0090

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory records.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.0000" may have been reported by the laboratory as less than 0.001 mg/L or non-detect.

Table A.2 First Draw Copper Results

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
1	4120 Grant St NE	Lead	3/5/2014	0.003
2	3416 9th St NE	Partial Lead	4/29/2014	0.003
3	4413 5th St NW	Lead	2/25/2014	0.004
4	6210 8th St NW	Lead	3/26/2014	0.004
5	3761 W ST NW	Lead	6/3/2014	0.004
6	912 Emerson St NW	Lead	3/26/2014	0.005
7	807 Buchanan St NW	Lead	3/26/2014	0.005
8	1113 STAPLES ST NE	Lead	6/4/2014	0.005
9	308 9th St SE	Partial Lead	3/24/2014	0.006
10	5312 ILLINOIS AVE NW	Lead	2/25/2014	0.007
11	322 TENNESSEE AVE NE	Lead	4/30/2014	0.008
12	412 BRANDYWINE ST SE	Lead	5/21/2014	0.008
13	617 6th St NE	Lead	3/26/2014	0.010
14	3206 38th St NW	Lead	2/26/2014	0.011
15	228 V ST NE	Lead	1/29/2014	0.012
16	1305 TAYLOR ST NW	Lead	1/28/2014	0.012
17	2913 Brandywine St NW	Lead	2/26/2014	0.012
18	309 11TH ST SE	Lead	2/26/2014	0.012
19	331 RALEIGH ST SE	Lead	2/26/2014	0.013
20	2923 Cathedral AVE NW	Lead	3/28/2014	0.013
21	1911 P ST SE	Lead	5/22/2014	0.013
22	414 G ST NE	Lead	6/3/2014	0.013
23	1706 NEW JERSEY AVE NW	Lead	1/28/2014	0.014
24	4719 9TH ST NW	Lead	2/25/2014	0.014
25	3913 8TH ST NW	Partial Lead	4/29/2014	0.014
26	522 4TH ST SE	Lead	6/3/2014	0.014
27	744 9TH ST SE	Lead	6/4/2014	0.014
28	3033 CAMBRIDGE PL NW	Lead	6/4/2014	0.015
29	3710 Huntington St NW	Lead	2/26/2014	0.016
30	125 Madison St NW	Lead	1/29/2014	0.017
31	1826 Jackson St NE	Lead	1/29/2014	0.017
32	1222 HAMILTON ST NW	Partial Lead	3/25/2014	0.017
33	619 12th St NE	Lead	3/26/2014	0.017
34	336 Quackenbos St NE	Lead	2/26/2014	0.018
35	450 Newton Pl NW	Lead	3/2/2014	0.018
36	1319 POTOMAC AVE SE	Partial Lead	3/26/2014	0.018
37	702 9th St SE	Lead	3/25/2014	0.018
38	2408 2nd St NE	Partial Lead	3/24/2014	0.018
39	2435 33RD ST SE	Lead	1/29/2014	0.019
40	1703 D St NE	Lead	1/27/2014	0.020
41	12 14TH ST SE	Partial Lead	1/27/2014	0.020
42	4550 30TH ST NW	Lead	2/25/2014	0.020
43	4525 15TH ST NW	Lead	6/11/2014	0.020
44	4131 YUMA ST NW	Lead	2/26/2014	0.021

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
45	307 7th St NE	Lead	2/26/2014	0.022
46	3636 13TH ST NW	Lead	2/25/2014	0.022
47	6205 14TH ST NW	Lead	6/3/2014	0.022
48	5024 7th St NW	Lead	2/25/2014	0.023
49	413 4th St SE	Partial Lead	4/30/2014	0.024
50	1412 Shepherd St NW	Partial Lead	3/25/2014	0.025
51	1020 INDEPENDENCE AVE SE	Lead	6/2/2014	0.025
52	109 19th St SE	Lead	1/28/2014	0.026
53	4926 Glenbrook Rd NW	Lead	2/27/2014	0.026
54	6209 30TH ST NW	Lead	3/29/2014	0.027
55	1010 10th St NE	Lead	4/30/2014	0.027
56	1715 IRVING ST NE	Lead	5/20/2014	0.027
57	822 Allison St NW	Lead	2/26/2014	0.028
58	3625 Albermarle St NW	Lead	2/26/2014	0.029
59	3809 ALTON PL NW	Partial Lead	4/30/2014	0.029
60	2121 3RD ST NE	Lead	5/21/2014	0.029
61	5007 13TH ST NW	Lead	5/20/2014	0.030
62	313 10TH ST SE	Lead	5/23/2014	0.030
63	1513 27TH ST NW	Lead	1/28/2014	0.031
64	5301 RENO RD NW	Partial Lead	4/30/2014	0.031
65	913 Hamlin St NE	Lead	3/25/2014	0.032
66	4627 49th St NW	Lead	2/27/2014	0.033
67	231 K St NE	Partial Lead	4/29/2014	0.033
68	333 34th St NE	Partial Lead	4/30/2014	0.033
69	1738 ALLISON ST NW	Lead	1/30/2014	0.036
70	1375 MONROE ST NW	Lead	1/27/2014	0.036
71	2904 P ST SE	Lead	2/25/2014	0.036
72	4418 14th St NE	Lead	2/26/2014	0.037
73	5404 39TH ST NW	Partial Lead	4/29/2014	0.037
74	3309 35TH ST NW	Lead	6/5/2014	0.037
75	1003 Otis St NE	Lead	1/27/2014	0.039
76	2832 BRENTWOOD RD NE	Lead	2/26/2014	0.039
77	1508 GOOD HOPE RD SE	Lead	5/21/2014	0.039
78	120 VARNUM ST NW	Lead	6/3/2014	0.039
79	3727 T St NW	Lead	2/26/2014	0.041
80	3218 MORRISON ST NW	Lead	4/30/2014	0.045
81	421 Hamilton St NW	Lead	3/26/2014	0.047
82	5223 KANSAS AVE NW	Lead	6/3/2014	0.048
83	1318 Wallach Pl NW	Lead	1/29/2014	0.049
84	6308 8th St NW	Lead	3/27/2014	0.049
85	3510 QUESADA ST NW	Lead	6/4/2014	0.050
86	119 16TH ST NE	Lead	1/29/2014	0.052
87	621 Upshur St NW	Lead	3/26/2014	0.055
88	4401 5TH ST NW	Lead	2/25/2014	0.056
89	4818 8th ST NW	Partial Lead	4/29/2014	0.056
90	3211 Central Ave NE	Lead	2/25/2014	0.058

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
91	1613 Webster St NW	Lead	2/27/2014	0.060
92	3036 P St NW	Partial Lead	3/26/2014	0.064
93	3030 44TH ST NW	Partial Lead	3/27/2014	0.065
94	3724 CHESAPEAKE ST NW	Lead	2/25/2014	0.067
95	1505 Buchanan St NW	Lead	1/28/2014	0.071
96	4703 Macarthur Blvd NW	Lead	2/26/2014	0.076
97	4215 39th St NW	Partial Lead	4/28/2014	0.076
98	3917 8th St NW	Partial Lead	5/1/2014	0.077
99	4806 Kansas Ave NW	Lead	2/25/2014	0.078
100	501 Webster St NW	Lead	2/24/2014	0.082
101	1808 KEARNEY ST NE	Partial Lead	3/28/2014	0.092
102	2007 37TH ST NW	Lead	3/31/2014	0.092
103	1211 Carrollsburg Pl SW	Partial Lead	3/25/2014	0.096
104	8 N St SW	Lead	3/25/2014	0.113
105	3907 13th St NW	Partial Lead	5/6/2014	0.117
106	502 A ST SE	Lead	6/4/2014	0.133
107	1436 S St NW	Partial Lead	3/26/2014	0.145
108	4811 Illinois Ave NW	Lead	2/11/2014	0.158
109	5923 33rd St NW	Lead	3/26/2014	0.175
110	36 Florida Ave NW	Partial Lead	4/30/2014	0.203
111	2830 BRENTWOOD RD NE	Lead	2/25/2014	0.459

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory records.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.000" may have been reported by the laboratory as less than 0.001 mg/L or non-detect.

Appendix B: Additional Monitoring Data

Tables B.1 and B.2 present results from the second draw samples collected at the time of the Lead and Copper Rule compliance sampling. Additional monitoring data presented in Attachment 2 to this report contains sample data collected from other DC Water programs that focused on lead, copper, or other metals that included lead sample results. A description of the program followed by the data set is included in Attachment 2.

Table B.1 Second Draw Lead Results

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
1	2435 33RD ST SE	Lead	1/29/2014	0.0000
2	1706 NEW JERSEY AVE NW	Lead	1/28/2014	0.0000
3	1318 Wallach Pl NW	Lead	1/29/2014	0.0000
4	12 14TH ST SE	Partial Lead	1/27/2014	0.0000
5	331 RALEIGH ST SE	Lead	2/26/2014	0.0000
6	4627 49th St NW	Lead	2/27/2014	0.0000
7	4926 Glenbrook Rd NW	Lead	2/27/2014	0.0000
8	4703 Macarthur Blvd NW	Lead	2/26/2014	0.0000
9	336 Quackenbos St NE	Lead	2/26/2014	0.0000
10	307 7th St NE	Lead	2/26/2014	0.0000
11	3625 Albermarle St NW	Lead	2/26/2014	0.0000
12	309 11TH ST SE	Lead	2/26/2014	0.0000
13	5312 ILLINOIS AVE NW	Lead	2/25/2014	0.0000
14	3724 CHESAPEAKE ST NW	Lead	2/25/2014	0.0000
15	4719 9TH ST NW	Lead	2/25/2014	0.0000
16	1319 POTOMAC AVE SE	Partial Lead	3/26/2014	0.0000
17	2007 37TH ST NW	Lead	3/31/2014	0.0000
18	1436 S St NW	Partial Lead	3/26/2014	0.0000
19	619 12th St NE	Lead	3/26/2014	0.0000
20	617 6th St NE	Lead	3/26/2014	0.0000
21	3036 P St NW	Partial Lead	3/26/2014	0.0000
22	6308 8th St NW	Lead	3/27/2014	0.0000
23	621 Upshur St NW	Lead	3/26/2014	0.0000
24	308 9th St SE	Partial Lead	3/24/2014	0.0000
25	2923 Cathedral AVE NW	Lead	3/28/2014	0.0000
26	231 K St NE	Partial Lead	4/29/2014	0.0000
27	3416 9th St NE	Partial Lead	4/29/2014	0.0000
28	413 4th St SE	Partial Lead	4/30/2014	0.0000
29	36 Florida Ave NW	Partial Lead	4/30/2014	0.0000
30	522 4TH ST SE	Lead	6/3/2014	0.0000
31	414 G ST NE	Lead	6/3/2014	0.0000
32	502 A ST SE	Lead	6/4/2014	0.0000
33	744 9TH ST SE	Lead	6/4/2014	0.0000
34	3510 QUESADA ST NW	Lead	6/4/2014	0.0000
35	3917 8th St NW	Partial Lead	5/1/2014	0.0000
36	333 34th St NE	Partial Lead	4/30/2014	0.0000

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
37	3907 13th St NW	Partial Lead	5/6/2014	0.0000
38	3033 CAMBRIDGE PL NW	Lead	6/4/2014	0.0000
39	3913 8TH ST NW	Partial Lead	4/29/2014	0.0000
40	3218 MORRISON ST NW	Lead	4/30/2014	0.0000
41	1010 10th St NE	Lead	4/30/2014	0.0000
42	412 BRANDYWINE ST SE	Lead	5/21/2014	0.0000
43	313 10TH ST SE	Lead	5/23/2014	0.0000
44	1738 ALLISON ST NW	Lead	1/30/2014	0.0000
45	3809 ALTON PL NW	Partial Lead	4/30/2014	0.0000
46	1613 Webster St NW	Lead	2/27/2014	0.0000
47	6210 8th St NW	Lead	3/26/2014	0.0000
48	4818 8th ST NW	Partial Lead	4/29/2014	0.0000
49	1826 Jackson St NE	Lead	1/29/2014	0.0000
50	4806 Kansas Ave NW	Lead	2/25/2014	0.0000
51	4413 5th St NW	Lead	2/25/2014	0.0000
52	1222 HAMILTON ST NW	Partial Lead	3/25/2014	0.0000
53	1808 KEARNEY ST NE	Partial Lead	3/28/2014	0.0000
54	5301 RENO RD NW	Partial Lead	4/30/2014	0.0000
55	119 16TH ST NE	Lead	1/29/2014	0.0000
56	1003 Otis St NE	Lead	1/27/2014	0.0000
57	1412 Shepherd St NW	Partial Lead	3/25/2014	0.0000
58	5923 33rd St NW	Lead	3/26/2014	0.0000
59	913 Hamlin St NE	Lead	3/25/2014	0.0000
60	6209 30TH ST NW	Lead	3/29/2014	0.0000
61	2121 3RD ST NE	Lead	5/21/2014	0.0000
62	3761 W ST NW	Lead	6/3/2014	0.0000
63	125 Madison St NW	Lead	1/29/2014	0.0010
64	822 Allison St NW	Lead	2/26/2014	0.0010
65	5404 39TH ST NW	Partial Lead	4/29/2014	0.0010
66	3309 35TH ST NW	Lead	6/5/2014	0.0010
67	4401 5TH ST NW	Lead	2/25/2014	0.0012
68	1305 TAYLOR ST NW	Lead	1/28/2014	0.0014
69	1715 IRVING ST NE	Lead	5/20/2014	0.0014
70	3211 Central Ave NE	Lead	2/25/2014	0.0015
71	5007 13TH ST NW	Lead	5/20/2014	0.0015
72	2832 BRENTWOOD RD NE	Lead	2/26/2014	0.0016
73	1911 P ST SE	Lead	5/22/2014	0.0016
74	2830 BRENTWOOD RD NE	Lead	2/25/2014	0.0017
75	4550 30TH ST NW	Lead	2/25/2014	0.0017
76	3206 38th St NW	Lead	2/26/2014	0.0018
77	6205 14TH ST NW	Lead	6/3/2014	0.0018
78	1703 D St NE	Lead	1/27/2014	0.0019
79	120 VARNUM ST NW	Lead	6/3/2014	0.0019
80	4418 14th St NE	Lead	2/26/2014	0.0020
81	2913 Brandywine St NW	Lead	2/26/2014	0.0020
82	4215 39th St NW	Partial Lead	4/28/2014	0.0020

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
83	228 V ST NE	Lead	1/29/2014	0.0022
84	2904 P ST SE	Lead	2/25/2014	0.0022
85	2408 2nd St NE	Partial Lead	3/24/2014	0.0022
86	1375 MONROE ST NW	Lead	1/27/2014	0.0023
87	421 Hamilton St NW	Lead	3/26/2014	0.0023
88	1508 GOOD HOPE RD SE	Lead	5/21/2014	0.0025
89	4525 15TH ST NW	Lead	6/11/2014	0.0026
90	3710 Huntington St NW	Lead	2/26/2014	0.0027
91	912 Emerson St NW	Lead	3/26/2014	0.0030
92	3636 13TH ST NW	Lead	2/25/2014	0.0031
93	1113 STAPLES ST NE	Lead	6/4/2014	0.0031
94	807 Buchanan St NW	Lead	3/26/2014	0.0035
95	450 Newton Pl NW	Lead	3/2/2014	0.0036
96	4131 YUMA ST NW	Lead	2/26/2014	0.0038
97	1505 Buchanan St NW	Lead	1/28/2014	0.0040
98	3727 T St NW	Lead	2/26/2014	0.0043
99	8 N St SW	Lead	3/25/2014	0.0044
100	4811 Illinois Ave NW	Lead	2/11/2014	0.0044
101	1211 Carrollsburg Pl SW	Partial Lead	3/25/2014	0.0047
102	1020 INDEPENDENCE AVE SE	Lead	6/2/2014	0.0048
103	702 9th St SE	Lead	3/25/2014	0.0056
104	1513 27TH ST NW	Lead	1/28/2014	0.0057
105	109 19th St SE	Lead	1/28/2014	0.0074
106	5223 KANSAS AVE NW	Lead	6/3/2014	0.0103
107	3030 44TH ST NW	Partial Lead	3/27/2014	0.0228

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) Results expressed as “0.0000” may have been reported by the laboratory as less than 0.001 mg/L or non-detect.
- 3) The second draw samples were rejected from 4120 Grant St NE, 5024 7th St NW, 501 Webster St NW, and 322 Tennessee Ave NE because they did not follow the sampling procedures for collecting the second draw sample as described in the instructions.

Table B.2 Second Draw Copper Results

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
1	1706 NEW JERSEY AVE NW	Lead	1/28/2014	0.002
2	2435 33RD ST SE	Lead	1/29/2014	0.003
3	4550 30TH ST NW	Lead	2/25/2014	0.003
4	3625 Albermarle St NW	Lead	2/26/2014	0.003
5	2923 Cathedral AVE NW	Lead	3/28/2014	0.003
6	807 Buchanan St NW	Lead	3/26/2014	0.003
7	3416 9th St NE	Partial Lead	4/29/2014	0.003
8	3761 W ST NW	Lead	6/3/2014	0.003
9	4131 YUMA ST NW	Lead	2/26/2014	0.004
10	331 RALEIGH ST SE	Lead	2/26/2014	0.004
11	2913 Brandywine St NW	Lead	2/26/2014	0.004
12	4413 5th St NW	Lead	2/25/2014	0.004
13	702 9th St SE	Lead	3/25/2014	0.004
14	6210 8th St NW	Lead	3/26/2014	0.004
15	125 Madison St NW	Lead	1/29/2014	0.005
16	1826 Jackson St NE	Lead	1/29/2014	0.005
17	1318 Wallach Pl NW	Lead	1/29/2014	0.005
18	4418 14th St NE	Lead	2/26/2014	0.005
19	5007 13TH ST NW	Lead	5/20/2014	0.005
20	412 BRANDYWINE ST SE	Lead	5/21/2014	0.005
21	1113 STAPLES ST NE	Lead	6/4/2014	0.005
22	119 16TH ST NE	Lead	1/29/2014	0.006
23	109 19th St SE	Lead	1/28/2014	0.006
24	1305 TAYLOR ST NW	Lead	1/28/2014	0.006
25	3211 Central Ave NE	Lead	2/25/2014	0.006
26	522 4TH ST SE	Lead	6/3/2014	0.006
27	1020 INDEPENDENCE AVE SE	Lead	6/2/2014	0.006
28	3710 Huntington St NW	Lead	2/26/2014	0.007
29	450 Newton Pl NW	Lead	3/2/2014	0.007
30	308 9th St SE	Partial Lead	3/24/2014	0.007
31	421 Hamilton St NW	Lead	3/26/2014	0.007
32	3218 MORRISON ST NW	Lead	4/30/2014	0.007
33	3510 QUESADA ST NW	Lead	6/4/2014	0.007
34	336 Quackenbos St NE	Lead	2/26/2014	0.008
35	3727 T St NW	Lead	2/26/2014	0.008
36	5312 ILLINOIS AVE NW	Lead	2/25/2014	0.008
37	3033 CAMBRIDGE PL NW	Lead	6/4/2014	0.008
38	414 G ST NE	Lead	6/3/2014	0.008
39	1375 MONROE ST NW	Lead	1/27/2014	0.009
40	4719 9TH ST NW	Lead	2/25/2014	0.009
41	3913 8TH ST NW	Partial Lead	4/29/2014	0.009
42	1911 P ST SE	Lead	5/22/2014	0.009
43	744 9TH ST SE	Lead	6/4/2014	0.009
44	3636 13TH ST NW	Lead	2/25/2014	0.010

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
45	1222 HAMILTON ST NW	Partial Lead	3/25/2014	0.010
46	2007 37TH ST NW	Lead	3/31/2014	0.010
47	1412 Shepherd St NW	Partial Lead	3/25/2014	0.010
48	912 Emerson St NW	Lead	3/26/2014	0.010
49	6205 14TH ST NW	Lead	6/3/2014	0.010
50	3309 35TH ST NW	Lead	6/5/2014	0.010
51	309 11TH ST SE	Lead	2/26/2014	0.011
52	2904 P ST SE	Lead	2/25/2014	0.011
53	2832 BRENTWOOD RD NE	Lead	2/26/2014	0.011
54	307 7th St NE	Lead	2/26/2014	0.012
55	617 6th St NE	Lead	3/26/2014	0.012
56	313 10TH ST SE	Lead	5/23/2014	0.012
57	1505 Buchanan St NW	Lead	1/28/2014	0.013
58	619 12th St NE	Lead	3/26/2014	0.013
59	5301 RENO RD NW	Partial Lead	4/30/2014	0.013
60	231 K St NE	Partial Lead	4/29/2014	0.013
61	1010 10th St NE	Lead	4/30/2014	0.013
62	4525 15TH ST NW	Lead	6/11/2014	0.013
63	228 V ST NE	Lead	1/29/2014	0.014
64	120 VARNUM ST NW	Lead	6/3/2014	0.014
65	1703 D St NE	Lead	1/27/2014	0.015
66	1513 27TH ST NW	Lead	1/28/2014	0.015
67	5223 KANSAS AVE NW	Lead	6/3/2014	0.015
68	1003 Otis St NE	Lead	1/27/2014	0.018
69	2830 BRENTWOOD RD NE	Lead	2/25/2014	0.018
70	822 Allison St NW	Lead	2/26/2014	0.018
71	3809 ALTON PL NW	Partial Lead	4/30/2014	0.018
72	413 4th St SE	Partial Lead	4/30/2014	0.018
73	6209 30TH ST NW	Lead	3/29/2014	0.019
74	6308 8th St NW	Lead	3/27/2014	0.020
75	913 Hamlin St NE	Lead	3/25/2014	0.020
76	1508 GOOD HOPE RD SE	Lead	5/21/2014	0.020
77	502 A ST SE	Lead	6/4/2014	0.020
78	1715 IRVING ST NE	Lead	5/20/2014	0.021
79	3030 44TH ST NW	Partial Lead	3/27/2014	0.022
80	3206 38th St NW	Lead	2/26/2014	0.023
81	5404 39TH ST NW	Partial Lead	4/29/2014	0.023
82	1319 POTOMAC AVE SE	Partial Lead	3/26/2014	0.025
83	621 Upshur St NW	Lead	3/26/2014	0.025
84	4215 39th St NW	Partial Lead	4/28/2014	0.025
85	333 34th St NE	Partial Lead	4/30/2014	0.025
86	1738 ALLISON ST NW	Lead	1/30/2014	0.028
87	3036 P St NW	Partial Lead	3/26/2014	0.032
88	8 N St SW	Lead	3/25/2014	0.032
89	4818 8th ST NW	Partial Lead	4/29/2014	0.033
90	2121 3RD ST NE	Lead	5/21/2014	0.034

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
91	4401 5TH ST NW	Lead	2/25/2014	0.035
92	4627 49th St NW	Lead	2/27/2014	0.037
93	3917 8th St NW	Partial Lead	5/1/2014	0.038
94	12 14TH ST SE	Partial Lead	1/27/2014	0.039
95	4926 Glenbrook Rd NW	Lead	2/27/2014	0.040
96	36 Florida Ave NW	Partial Lead	4/30/2014	0.047
97	2408 2nd St NE	Partial Lead	3/24/2014	0.051
98	1613 Webster St NW	Lead	2/27/2014	0.053
99	3724 CHESAPEAKE ST NW	Lead	2/25/2014	0.055
100	4703 Macarthur Blvd NW	Lead	2/26/2014	0.059
101	1211 Carrollsburg Pl SW	Partial Lead	3/25/2014	0.059
102	4806 Kansas Ave NW	Lead	2/25/2014	0.061
103	1808 KEARNEY ST NE	Partial Lead	3/28/2014	0.066
104	3907 13th St NW	Partial Lead	5/6/2014	0.076
105	4811 Illinois Ave NW	Lead	2/11/2014	0.110
106	1436 S St NW	Partial Lead	3/26/2014	0.111
107	5923 33rd St NW	Lead	3/26/2014	0.151

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) The second draw samples were rejected from 4120 Grant St NE, 5024 7th St NW, 501 Webster St NW, and 322 Tennessee Ave NE because they did not follow the sampling criteria for collecting the second draw sample as described in the instructions.
- 3) Results expressed as "0.000" may have been reported by the laboratory as less than 0.001 mg/L or non-detect.

Appendix C – Additional Sampling Information

Table C.1 Sample Kit Distribution

No	Address	Bottle Delivery Date
1	1262 COLUMBIA RD NW	1/27/2014
2	1635 WEBSTER ST NW	1/27/2014
3	119 16TH ST NE	1/27/2014
4	1649 HARVARD ST NW	1/27/2014
5	125 Madison St NW	1/27/2014
6	2435 33RD ST SE	1/27/2014
7	228 V ST NE	1/27/2014
8	2007 37TH ST NW	1/27/2014
9	1424 S ST NW	1/27/2014
10	1315 FRANKLIN ST NE	1/27/2014
11	1706 NEW JERSEY AVE NW	1/27/2014
12	2212 38th St NW	1/27/2014
13	1003 Quebec Pl NW	1/27/2014
14	1357 C St NE	1/27/2014
15	2107 2nd St NE	1/27/2014
16	1331 Irving St NE	1/27/2014
17	1826 Jackson St NE	1/27/2014
18	1703 D St NE	1/27/2014
19	24 Evarts St NE	1/27/2014
20	1011 Taylor St NE	1/27/2014
21	213 49th St NE	1/27/2014
22	1003 Otis St NE	1/27/2014
23	1025 44th St NE	1/27/2014
24	1106 Allison St NW	1/27/2014
25	1434 Taylor St NW	1/27/2014
26	10 S St NW	1/27/2014
27	1620 Webster St NW	1/27/2014
28	1453 S St NW	1/27/2014
29	15 Milmarson Pl NW	1/27/2014
30	1318 Wallach Pl NW	1/27/2014
31	1519 Olive St NE	1/27/2014
32	1505 Buchanan St NW	1/27/2014
33	1378 Taylor St NW	1/27/2014
34	1346 F St NE	1/27/2014
35	1613 Webster St NW	1/27/2014
36	109 19th St SE	1/27/2014
37	1627 Gales St NE	1/27/2014
38	1705 D St NE	1/27/2014
39	12 14TH ST SE	1/27/2014
40	124 16TH ST NE	1/27/2014
41	1428 VARNUM ST NW	1/27/2014
42	1659 NEWTON ST NW	1/27/2014

No	Address	Bottle Delivery Date
43	1738 ALLISON ST NW	1/27/2014
44	1513 27TH ST NW	1/27/2014
45	1310 R ST NW	1/27/2014
46	1305 TAYLOR ST NW	1/27/2014
47	2719 O ST NW	1/27/2014
48	1375 MONROE ST NW	1/27/2014
49	1529 UPSHUR ST NW	1/27/2014
50	123 TENNESSEE AVE NE	1/27/2014
51	4811 Illinois Ave NW	2/10/2014
52	2923 Cathedral AVE NW	2/24/2014
53	4307 CHESAPEAKE ST NW	2/24/2014
54	3601 WARREN ST NW	2/24/2014
55	5318 9TH ST NW	2/24/2014
56	4131 YUMA ST NW	2/24/2014
57	3218 MACOMB ST NW	2/24/2014
58	4401 5TH ST NW	2/24/2014
59	424 Luray PI NW	2/24/2014
60	4613 9th St NW	2/24/2014
61	331 RALEIGH ST SE	2/24/2014
62	2830 BRENTWOOD RD NE	2/24/2014
63	3908 13TH ST NW	2/24/2014
64	4550 30TH ST NW	2/24/2014
65	3206 38th St NW	2/24/2014
66	3710 Huntington St NW	2/24/2014
67	4627 49th St NW	2/24/2014
68	4409 Lowell St NW	2/24/2014
69	4926 Glenbrook Rd NW	2/24/2014
70	3706 35th St NW	2/24/2014
71	4703 Macarthur Blvd NW	2/24/2014
72	4418 14th St NE	2/24/2014
73	3211 Central Ave NE	2/24/2014
74	4120 Grant St NE	2/24/2014
75	336 Quackenbos St NE	2/24/2014
76	307 7th St NE	2/24/2014
77	5024 7th St NW	2/24/2014
78	449 S St NW	2/24/2014
79	5234 Illinois Ave NW	2/24/2014
80	5517 7th St NW	2/24/2014
81	3361 Stuyvesant PI NW	2/24/2014
82	5226 7th St NW	2/24/2014
83	4214 8th St NW	2/24/2014
84	501 Webster St NW	2/24/2014
85	3727 T St NW	2/24/2014
86	2913 Brandywine St NW	2/24/2014
87	4310 37th St NW	2/24/2014
88	531 Tennessee Ave NE	2/24/2014

No	Address	Bottle Delivery Date
89	1613 Webster St NW	2/24/2014
90	3625 Albermarle St NW	2/24/2014
91	309 11TH ST SE	2/24/2014
92	450 Newton Pl NW	2/24/2014
93	3636 13TH ST NW	2/24/2014
94	421 Hamilton St NW	2/24/2014
95	4806 Kansas Ave NW	2/24/2014
96	561 23RD PL NE	2/24/2014
97	2904 P ST SE	2/24/2014
98	2832 BRENTWOOD RD NE	2/24/2014
99	5312 ILLINOIS AVE NW	2/24/2014
100	3724 CHESAPEAKE ST NW	2/24/2014
101	4719 9TH ST NW	2/24/2014
102	4447 HAWTHORNE ST NW	2/24/2014
103	822 Allison St NW	2/24/2014
104	4413 5th St NW	2/24/2014
105	2923 Cathedral AVE NW	3/24/2014
106	1319 POTOMAC AVE SE	3/24/2014
107	1222 HAMILTON ST NW	3/24/2014
108	1850 2ND ST NW	3/24/2014
109	3030 44TH ST NW	3/24/2014
110	834 Delafield Pl NW	3/24/2014
111	804 Delafield Pl NW	3/24/2014
112	926 Hamilton St NW	3/24/2014
113	641 Gallatin St NW	3/24/2014
114	234 Longfellow St NW	3/24/2014
115	1808 KEARNEY ST NE	3/24/2014
116	2007 37TH ST NW	3/24/2014
117	302 RITTENHOUSE ST NW	3/24/2014
118	1353 JEFFERSON ST NW	3/24/2014
119	1436 S St NW	3/24/2014
120	1412 S St NW	3/24/2014
121	1412 Shepherd St NW	3/24/2014
122	8 N St SW	3/24/2014
123	636 ROCK CRK CHURCH RD NW	3/24/2014
124	317 9th St SE	3/24/2014
125	702 9th St SE	3/24/2014
126	1736 Bay St SE	3/24/2014
127	1603 Massachusetts Ave SE	3/24/2014
128	1211 Carrollsburg Pl SW	3/24/2014
129	230 G St NE	3/24/2014
130	619 12th St NE	3/24/2014
131	1671 Rosedale St NE	3/24/2014
132	2408 2nd St NE	3/24/2014
133	905 Kent Pl NE	3/24/2014
134	223 14th Pl NE	3/24/2014

No	Address	Bottle Delivery Date
135	6105 Dix St NE	3/24/2014
136	1420 Hamlin St NE	3/24/2014
137	580 49th Pl NE	3/24/2014
138	617 6th St NE	3/24/2014
139	6210 8th St NW	3/24/2014
140	6001 33rd St NW	3/24/2014
141	3036 P St NW	3/24/2014
142	5923 33rd St NW	3/24/2014
143	912 Emerson St NW	3/24/2014
144	5731 3rd Pl NW	3/24/2014
145	5613 30th St NW	3/24/2014
146	75 Bates St NW	3/24/2014
147	6308 8th St NW	3/24/2014
148	87 S St NW	3/24/2014
149	910 Farragut St NW	3/24/2014
150	621 Upshur St NW	3/24/2014
151	308 9th St SE	3/24/2014
152	807 Buchanan St NW	3/24/2014
153	913 Hamlin St NE	3/24/2014
154	6209 30TH ST NW	3/24/2014
155	421 Hamilton St NW	3/24/2014
156	5812 7TH ST NW	3/24/2014
157	609 49TH PL NE	3/24/2014
158	4332 BRANDYWINE ST NW	4/28/2014
159	3202 38TH ST NW	4/28/2014
160	322 TENNESSEE AVE NE	4/28/2014
161	6213 7TH ST NW	4/28/2014
162	4818 ILLINOIS AVE NW	4/28/2014
163	5301 RENO RD NW	4/28/2014
164	4818 8th ST NW	4/28/2014
165	3913 8TH ST NW	4/28/2014
166	4111 INGOMAR ST NW	4/28/2014
167	3809 ALTON PL NW	4/28/2014
168	5404 39TH ST NW	4/28/2014
169	605 Columbia Rd NW	4/28/2014
170	420 Kenyon St NW	4/28/2014
171	605 ROCK CRK CHURCH RD NW	4/28/2014
172	3917 8th St NW	4/28/2014
173	205 TAYLOR ST NW	4/28/2014
174	3301 BROWN St NW	4/28/2014
175	4616 HUNT PL NE	4/28/2014
176	3218 MORRISON ST NW	4/28/2014
177	720 ALABAMA AVE SE	4/28/2014
178	3531 16TH ST NW	4/28/2014
179	3907 13th St NW	4/28/2014
180	3232 Klinge Rd NW	4/28/2014

No	Address	Bottle Delivery Date
181	3215 Mckinley St NW	4/28/2014
182	4215 39th St NW	4/28/2014
183	7721 14th St NW	4/28/2014
184	1346 Madison St NW	4/28/2014
185	53 V St NW	4/28/2014
186	231 K St NE	4/28/2014
187	1010 10th St NE	4/28/2014
188	1207 Trinidad Ave NE	4/28/2014
189	1705 2nd St NE	4/28/2014
190	3416 9th St NE	4/28/2014
191	201 13th St NE	4/28/2014
192	228 Randolph Pl NE	4/28/2014
193	617 M St NE	4/28/2014
194	619 Girard St NE	4/28/2014
195	1014 Douglas St NE	4/28/2014
196	333 34th St NE	4/28/2014
197	3612 34th St NW	4/28/2014
198	3216 Klinge Rd NW	4/28/2014
199	611 Roxboro Pl NW	4/28/2014
200	753 Gresham Pl NW	4/28/2014
201	53 P St NW	4/28/2014
202	413 4th St SE	4/28/2014
203	1614 V St SE	4/28/2014
204	524 10th St SE	4/28/2014
205	36 Florida Ave NW	4/28/2014
206	3722 MCKINLEY ST NW	4/28/2014
207	5003 7TH ST NW	4/28/2014
208	833 DECATUR ST NW	5/19/2014
209	661 MARYLAND AVE NE	5/19/2014
210	506 Irving St NW	5/19/2014
211	617 Kenyon St NW	5/19/2014
212	441 Quincy St NW	5/19/2014
213	924 Hamilton St NW	5/19/2014
214	335 17TH PL NE	5/19/2014
215	312 14TH ST NE	5/19/2014
216	3428 Brown St NW	5/19/2014
217	736 Fairmont St NW	5/19/2014
218	3105 34th St NW	5/19/2014
219	3721 Windom Pl NW	5/19/2014
220	5304 Reno Rd NW	5/19/2014
221	313 16th St SE	5/19/2014
222	42 Q St NE	5/19/2014
223	5316 28th St NW	5/19/2014
224	1855 CALIFORNIA ST NW	5/19/2014
225	2121 3RD ST NE	5/19/2014
226	1911 P ST SE	5/19/2014

No	Address	Bottle Delivery Date
227	5007 13TH ST NW	5/19/2014
228	412 BRANDYWINE ST SE	5/19/2014
229	313 10TH ST SE	5/19/2014
230	1715 IRVING ST NE	5/19/2014
231	1508 GOOD HOPE RD SE	5/19/2014
232	6205 14TH ST NW	6/2/2014
233	223 E ST NE	6/2/2014
234	907 L ST NE	6/2/2014
235	503 45TH ST NE	6/2/2014
236	6516 8TH ST NW	6/2/2014
237	1916 PARK RD NW	6/2/2014
238	1218 GALLATIN ST NW	6/2/2014
239	3322 17TH ST NW	6/2/2014
240	816 MADISON ST NW	6/2/2014
241	3033 CAMBRIDGE PL NW	6/2/2014
242	3615 ALABAMA AVE SE	6/2/2014
243	3761 W ST NW	6/2/2014
244	406 TENNESSEE AVE NE	6/2/2014
245	522 4TH ST SE	6/2/2014
246	100 KENNEDY ST NE	6/2/2014
247	4551 DIX ST NE	6/2/2014
248	4601 13TH ST NW	6/2/2014
249	1420 INGRAHAM ST NW	6/2/2014
250	414 G ST NE	6/2/2014
251	1223 PENNSYLVANIA AVE SE	6/2/2014
252	946 14TH ST SE	6/2/2014
253	4900 1ST ST NW	6/2/2014
254	1611 ALLISON ST NW	6/2/2014
255	1020 INDEPENDENCE AVE SE	6/2/2014
256	3215 MACOMB ST NW	6/2/2014
257	1113 STAPLES ST NE	6/2/2014
258	502 A ST SE	6/2/2014
259	4621 8TH ST NW	6/2/2014
260	4923 HILLBROOK LN NW	6/2/2014
261	3510 QUESADA ST NW	6/2/2014
262	120 VARNUM ST NW	6/2/2014
263	2804 6TH ST NE	6/2/2014
264	37 U ST NE	6/2/2014
265	4610 KANSAS AVE NW	6/2/2014
266	4716 15TH ST NW	6/2/2014
267	3309 35TH ST NW	6/2/2014
268	5223 KANSAS AVE NW	6/2/2014
269	1410 ALLISON ST NW	6/2/2014
270	4054 GRANT ST NE	6/2/2014
271	744 9TH ST SE	6/2/2014
272	804 FERN PL NW	6/2/2014

No	Address	Bottle Delivery Date
273	5220 CHEVY CHASE PKWY NW	6/2/2014
274	4525 15TH ST NW	6/2/2014
275	1805 2nd St NW	6/2/2014

Table C.2 Sample Kits Not Returned

No	Address	Bottle Delivery Date
1	1635 WEBSTER ST NW	1/27/2014
2	1649 HARVARD ST NW	1/27/2014
3	1424 S ST NW	1/27/2014
4	1315 FRANKLIN ST NE	1/27/2014
5	2212 38th St NW	1/27/2014
6	1003 Quebec PI NW	1/27/2014
7	1357 C St NE	1/27/2014
8	2107 2nd St NE	1/27/2014
9	1331 Irving St NE	1/27/2014
10	24 Evarts St NE	1/27/2014
11	213 49th St NE	1/27/2014
12	1025 44th St NE	1/27/2014
13	10 S St NW	1/27/2014
14	1453 S St NW	1/27/2014
15	15 Milmarson PI NW	1/27/2014
16	1519 Olive St NE	1/27/2014
17	1346 F St NE	1/27/2014
18	1627 Gales St NE	1/27/2014
19	1705 D St NE	1/27/2014
20	124 16TH ST NE	1/27/2014
21	1428 VARNUM ST NW	1/27/2014
22	1659 NEWTON ST NW	1/27/2014
23	1310 R ST NW	1/27/2014
24	1529 UPSHUR ST NW	1/27/2014
25	123 TENNESSEE AVE NE	1/27/2014
26	3601 WARREN ST NW	2/24/2014
27	3218 MACOMB ST NW	2/24/2014
28	424 Luray PI NW	2/24/2014
29	4409 Lowell St NW	2/24/2014
30	3706 35th St NW	2/24/2014
31	449 S St NW	2/24/2014
32	5234 Illinois Ave NW	2/24/2014
33	5517 7th St NW	2/24/2014
34	3361 Stuyvesant PI NW	2/24/2014
35	5226 7th St NW	2/24/2014
36	4214 8th St NW	2/24/2014
37	4310 37th St NW	2/24/2014
38	531 Tennessee Ave NE	2/24/2014
39	421 Hamilton St NW	2/24/2014
40	4447 HAWTHORNE ST NW	2/24/2014
41	1850 2ND ST NW	3/24/2014
42	926 Hamilton St NW	3/24/2014
43	641 Gallatin St NW	3/24/2014
44	234 Longfellow St NW	3/24/2014
45	302 RITTENHOUSE ST NW	3/24/2014

No	Address	Bottle Delivery Date
46	1353 JEFFERSON ST NW	3/24/2014
47	1412 S St NW	3/24/2014
48	636 ROCK CRK CHURCH RD NW	3/24/2014
49	317 9th St SE	3/24/2014
50	1736 Bay St SE	3/24/2014
51	1603 Massachusetts Ave SE	3/24/2014
52	230 G St NE	3/24/2014
53	1671 Rosedale St NE	3/24/2014
54	905 Kent Pl NE	3/24/2014
55	223 14th Pl NE	3/24/2014
56	6105 Dix St NE	3/24/2014
57	580 49th Pl NE	3/24/2014
58	6001 33rd St NW	3/24/2014
59	5731 3rd Pl NW	3/24/2014
60	5613 30th St NW	3/24/2014
61	75 Bates St NW	3/24/2014
62	87 S St NW	3/24/2014
63	910 Farragut St NW	3/24/2014
64	5812 7TH ST NW	3/24/2014
65	609 49TH PL NE	3/24/2014
66	4332 BRANDYWINE ST NW	4/28/2014
67	3202 38TH ST NW	4/28/2014
68	4818 ILLINOIS AVE NW	4/28/2014
69	4111 INGOMAR ST NW	4/28/2014
70	420 Kenyon St NW	4/28/2014
71	605 ROCK CRK CHURCH RD NW	4/28/2014
72	205 TAYLOR ST NW	4/28/2014
73	3301 BROWN St NW	4/28/2014
74	4616 HUNT PL NE	4/28/2014
75	720 ALABAMA AVE SE	4/28/2014
76	3232 Klinge Rd NW	4/28/2014
77	3215 Mckinley St NW	4/28/2014
78	7721 14th St NW	4/28/2014
79	1346 Madison St NW	4/28/2014
80	53 V St NW	4/28/2014
81	1207 Trinidad Ave NE	4/28/2014
82	1705 2nd St NE	4/28/2014
83	201 13th St NE	4/28/2014
84	617 M St NE	4/28/2014
85	619 Girard St NE	4/28/2014
86	1014 Douglas St NE	4/28/2014
87	3612 34th St NW	4/28/2014
88	3216 Klinge Rd NW	4/28/2014
89	611 Roxboro Pl NW	4/28/2014
90	753 Gresham Pl NW	4/28/2014
91	53 P St NW	4/28/2014
92	1614 V St SE	4/28/2014

No	Address	Bottle Delivery Date
93	524 10th St SE	4/28/2014
94	3722 MCKINLEY ST NW	4/28/2014
95	833 DECATUR ST NW	5/19/2014
96	661 MARYLAND AVE NE	5/19/2014
97	506 Irving St NW	5/19/2014
98	617 Kenyon St NW	5/19/2014
99	441 Quincy St NW	5/19/2014
100	924 Hamilton St NW	5/19/2014
101	335 17TH PL NE	5/19/2014
102	312 14TH ST NE	5/19/2014
103	3428 Brown St NW	5/19/2014
104	736 Fairmont St NW	5/19/2014
105	3105 34th St NW	5/19/2014
106	3721 Windom Pl NW	5/19/2014
107	5304 Reno Rd NW	5/19/2014
108	313 16th St SE	5/19/2014
109	42 Q St NE	5/19/2014
110	5316 28th St NW	5/19/2014
111	1855 CALIFORNIA ST NW	5/19/2014
112	223 E ST NE	6/2/2014
113	907 L ST NE	6/2/2014
114	503 45TH ST NE	6/2/2014
115	1218 GALLATIN ST NW	6/2/2014
116	3322 17TH ST NW	6/2/2014
117	3615 ALABAMA AVE SE	6/2/2014
118	406 TENNESSEE AVE NE	6/2/2014
119	100 KENNEDY ST NE	6/2/2014
120	4551 DIX ST NE	6/2/2014
121	4601 13TH ST NW	6/2/2014
122	1223 PENNSYLVANIA AVE SE	6/2/2014
123	946 14TH ST SE	6/2/2014
124	4900 1ST ST NW	6/2/2014
125	1611 ALLISON ST NW	6/2/2014
126	3215 MACOMB ST NW	6/2/2014
127	4621 8TH ST NW	6/2/2014
128	4923 HILLBROOK LN NW	6/2/2014
129	4716 15TH ST NW	6/2/2014
130	804 FERN PL NW	6/2/2014

Table C.3 Samples Returned but Rejected for Compliance Analysis

No	Address	Bottle Delivery Date	Reject Reason
1	1262 COLUMBIA RD NW	1/27/2014	Stagnation less than 6 hours
2	2007 37TH ST NW	1/27/2014	Stagnation period unknown
3	1011 Taylor St NE	1/27/2014	Incomplete chain of custody
4	1106 Allison St NW	1/27/2014	Incomplete chain of custody
5	1434 Taylor St NW	1/27/2014	No chain of custody provided
6	1620 Webster St NW	1/27/2014	Stagnation less than 6 hours
7	1378 Taylor St NW	1/27/2014	Leak in plumbing
8	1613 Webster St NW	1/27/2014	Water used during stagnation period
9	2719 O ST NW	1/27/2014	Incomplete chain of custody
10	2923 Cathedral AVE NW	2/24/2014	Bottle label error
11	4307 CHESAPEAKE ST NW	2/24/2014	Incomplete chain of custody
12	5318 9TH ST NW	2/24/2014	Water used during stagnation period
13	4613 9th St NW	2/24/2014	Water used during stagnation period
14	3908 13TH ST NW	2/24/2014	Incomplete chain of custody
15	561 23RD PL NE	2/24/2014	Incomplete chain of custody
16	834 Delafield PI NW	3/24/2014	Stagnation less than 6 hours
17	804 Delafield PI NW	3/24/2014	Ice maker on
18	1420 Hamlin St NE	3/24/2014	Leak in plumbing
19	6213 7TH ST NW	4/28/2014	Incomplete chain of custody
20	605 Columbia Rd NW	4/28/2014	Stagnation period unknown
21	3531 16TH ST NW	4/28/2014	Incomplete chain of custody
22	228 Randolph PI NE	4/28/2014	Incomplete chain of custody
23	5003 7TH ST NW	4/28/2014	Ice maker on
24	6516 8TH ST NW	6/2/2014	No chain of custody provided
25	1916 PARK RD NW	6/2/2014	Leak in plumbing
26	816 MADISON ST NW	6/2/2014	Stagnation less than 6 hours
27	1420 INGRAHAM ST NW	6/2/2014	Stagnation period unknown
28	2804 6TH ST NE	6/2/2014	No chain of custody provided
29	37 U ST NE	6/2/2014	Stagnation greater than 18 hours
30	4610 KANSAS AVE NW	6/2/2014	No chain of custody provided
31	1410 ALLISON ST NW	6/2/2014	Leak in plumbing
32	4054 GRANT ST NE	6/2/2014	No chain of custody provided
33	5220 CHEVY CHASE PKWY NW	6/2/2014	Stagnation greater than 18 hours
34	1805 2nd St NW	6/2/2014	Leak in plumbing

Table C.4 Deviations from Sample Order

No	Address	Priority	Scheduled Month	Deviation Reason
1	1613 Webster St NW	Primary	Jan	First sample rejected, delivered 2 nd set of bottles
2	2007 37TH ST NW	Primary	Jan	First sample rejected, delivered 2 nd set of bottles
3	2923 Cathedral AVE NW	Primary	Feb	First sample rejected, delivered 2 nd set of bottles
4	421 Hamilton St NW	Primary	Feb	First sample rejected, delivered 2 nd set of bottles
5	513 Florida Ave NE	Secondary	May	Customer removed, multi-residence
6	4413 5th St NW	NEW ^[1]	Feb	Added site this semester
7	4811 Illinois Ave NW	NEW ^[1]	Feb	Added site this semester
8	822 Allison St NW	NEW ^[1]	Feb	Added site this semester
9	1508 Good Hope Rd SE	NEW ^[2]	May	Added site this semester
10	1715 Irving St NE	NEW ^[2]	May	Added site this semester
11	1855 California St NW	NEW ^[2]	May	Added site this semester
12	1911 P St SE	NEW ^[2]	May	Added site this semester
13	2121 3rd St NE	NEW ^[2]	May	Added site this semester
14	313 10th St SE	NEW ^[2]	May	Added site this semester
15	412 Brandywine St SE	NEW ^[2]	May	Added site this semester
16	5007 13th St NW	NEW ^[2]	May	Added site this semester
17	6205 14TH ST NW	NEW ^[2]	June	Added site this semester
18	223 E ST NE	NEW ^[2]	June	Added site this semester
19	907 L ST NE	NEW ^[2]	June	Added site this semester
20	503 45TH ST NE	NEW ^[2]	June	Added site this semester
21	6516 8TH ST NW	NEW ^[2]	June	Added site this semester
22	1916 PARK RD NW	NEW ^[2]	June	Added site this semester
23	1218 GALLATIN ST NW	NEW ^[2]	June	Added site this semester
24	3322 17TH ST NW	NEW ^[2]	June	Added site this semester
25	816 MADISON ST NW	NEW ^[2]	June	Added site this semester
26	3033 CAMBRIDGE PL NW	NEW ^[2]	June	Added site this semester
27	3615 ALABAMA AVE SE	NEW ^[2]	June	Added site this semester
28	3761 W ST NW	NEW ^[2]	June	Added site this semester
29	406 TENNESSEE AVE NE	NEW ^[2]	June	Added site this semester
30	522 4TH ST SE	NEW ^[2]	June	Added site this semester
31	100 KENNEDY ST NE	NEW ^[2]	June	Added site this semester
32	4551 DIX ST NE	NEW ^[2]	June	Added site this semester
33	4601 13TH ST NW	NEW ^[2]	June	Added site this semester
34	1420 INGRAHAM ST NW	NEW ^[2]	June	Added site this semester
35	414 G ST NE	NEW ^[2]	June	Added site this semester
36	1223 PENNSYLVANIA AVE SE	NEW ^[2]	June	Added site this semester
37	946 14TH ST SE	NEW ^[2]	June	Added site this semester
38	4900 1ST ST NW	NEW ^[2]	June	Added site this semester
39	1611 ALLISON ST NW	NEW ^[2]	June	Added site this semester
40	1020 INDEPENDENCE AVE SE	NEW ^[2]	June	Added site this semester
41	3215 MACOMB ST NW	NEW ^[2]	June	Added site this semester
42	1113 STAPLES ST NE	NEW ^[2]	June	Added site this semester
43	502 A ST SE	NEW ^[2]	June	Added site this semester

No	Address	Priority	Scheduled Month	Deviation Reason
44	4621 8TH ST NW	NEW ^[2]	June	Added site this semester
45	4923 HILLBROOK LN NW	NEW ^[2]	June	Added site this semester
46	3510 QUESADA ST NW	NEW ^[2]	June	Added site this semester
47	120 VARNUM ST NW	NEW ^[2]	June	Added site this semester
48	2804 6TH ST NE	NEW ^[2]	June	Added site this semester
49	37 U ST NE	NEW ^[2]	June	Added site this semester
50	4610 KANSAS AVE NW	NEW ^[2]	June	Added site this semester
51	4716 15TH ST NW	NEW ^[2]	June	Added site this semester
52	3309 35TH ST NW	NEW ^[2]	June	Added site this semester
53	5223 KANSAS AVE NW	NEW ^[2]	June	Added site this semester
54	1410 ALLISON ST NW	NEW ^[2]	June	Added site this semester
55	4054 GRANT ST NE	NEW ^[2]	June	Added site this semester
56	744 9TH ST SE	NEW ^[2]	June	Added site this semester
57	804 FERN PL NW	NEW ^[2]	June	Added site this semester
58	5220 CHEVY CHASE PKWY NW	NEW ^[2]	June	Added site this semester
59	4525 15TH ST NW	NEW ^[2]	June	Added site this semester
60	1805 2ND ST NW	NEW ^[2]	June	Added site this semester

Notes:

[1] New participant: Customer contacted DC Water to request a lead test, and agreed to participate in the Lead and Copper Monitoring Program. DC Water confirmed that the address met Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structure with a full lead service line based on DC Water's customer information and service line inventory records.

[2] New participant: During the January-June 2014 monitoring period, DC Water exhausted its list of pre-approved sampling sites before meeting the required number of LCR sampling results for the monitoring period. DC Water randomly selected this address, which met the Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structure with a full lead service line based on DC Water's customer information and service line inventory records.

Table C.5 Sites with Compliance Results from January 2013 through December 2013 and No Results in January through June 2014

No	Address	Reason
1	10 S St NW	Did not return bottles; See Table C.2
2	1003 Quebec Pl NW	Did not return bottles; See Table C.2
3	1011 Taylor St NE	Sample rejected; See Table C.3
4	1203 Quincy St NW	Removed from Sample Pool prior to this semester
5	123 TENNESSEE AVE NE	Did not return bottles; See Table C.2
6	124 16TH ST NE	Did not return bottles; See Table C.2
7	1262 COLUMBIA RD NW	Sample rejected; See Table C.3
8	1310 R ST NW	Did not return bottles; See Table C.2
9	1331 Irving St NE	Did not return bottles; See Table C.2
10	1346 F St NE	Did not return bottles; See Table C.2
11	1353 JEFFERSON ST NW	Did not return bottles; See Table C.2
12	1357 C St NE	Did not return bottles; See Table C.2
13	1378 Taylor St NW	Sample rejected; See Table C.3
14	1412 S St NW	Did not return bottles; See Table C.2
15	1420 Hamlin St NE	Sample rejected; See Table C.3
16	1424 S ST NW	Did not return bottles; See Table C.2
17	1428 VARNUM ST NW	Did not return bottles; See Table C.2
18	1453 S St NW	Did not return bottles; See Table C.2
19	15 Milmarson Pl NW	Did not return bottles; See Table C.2
20	1519 Olive St NE	Did not return bottles; See Table C.2
21	1529 UPSHUR ST NW	Did not return bottles; See Table C.2
22	1603 Massachusetts Ave SE	Did not return bottles; See Table C.2
23	1620 Webster St NW	Sample rejected; See Table C.3
24	1627 Gales St NE	Did not return bottles; See Table C.2
25	1635 WEBSTER ST NW	Did not return bottles; See Table C.2
26	1649 HARVARD ST NW	Did not return bottles; See Table C.2
27	1659 NEWTON ST NW	Did not return bottles; See Table C.2
28	1671 Rosedale St NE	Did not return bottles; See Table C.2
29	1705 D St NE	Did not return bottles; See Table C.2
30	1736 Bay St SE	Did not return bottles; See Table C.2
31	1850 2ND ST NW	Did not return bottles; See Table C.2
32	2107 2nd St NE	Did not return bottles; See Table C.2
33	213 49th St NE	Did not return bottles; See Table C.2
34	2212 38th St NW	Did not return bottles; See Table C.2
35	223 14th Pl NE	Did not return bottles; See Table C.2
36	230 G St NE	Did not return bottles; See Table C.2
37	24 Evarts St NE	Did not return bottles; See Table C.2
38	2719 O ST NW	Sample rejected; See Table C.3
39	302 RITTENHOUSE ST NW	Did not return bottles; See Table C.2
40	317 9th St SE	Did not return bottles; See Table C.2
41	3202 38TH ST NW	Did not return bottles; See Table C.2
42	3215 Mckinley St NW	Did not return bottles; See Table C.2
43	3218 MACOMB ST NW	Did not return bottles; See Table C.2

No	Address	Reason
44	3301 BROWN St NW	Did not return bottles; See Table C.2
45	3361 Stuyvesant Pl NW	Did not return bottles; See Table C.2
46	3533 W Pl NW	Removed from Sample Pool prior to this semester
47	3601 WARREN ST NW	Did not return bottles; See Table C.2
48	3706 35th St NW	Did not return bottles; See Table C.2
49	3722 MCKINLEY ST NW	Did not return bottles; See Table C.2
50	3908 13TH ST NW	Sample rejected; See Table C.3
51	420 Kenyon St NW	Did not return bottles; See Table C.2
52	4214 8th St NW	Did not return bottles; See Table C.2
53	424 Luray Pl NW	Did not return bottles; See Table C.2
54	4307 CHESAPEAKE ST NW	Sample rejected; See Table C.3
55	4310 37th St NW	Did not return bottles; See Table C.2
56	4332 BRANDYWINE ST NW	Did not return bottles; See Table C.2
57	4447 HAWTHORNE ST NW	Did not return bottles; See Table C.2
58	449 S St NW	Did not return bottles; See Table C.2
59	4824 46th St NW	Removed from Sample Pool prior to this semester
60	5003 7TH ST NW	Sample rejected; See Table C.3
61	5226 7th St NW	Did not return bottles; See Table C.2
62	5234 Illinois Ave NW	Did not return bottles; See Table C.2
63	53 P St NW	Did not return bottles; See Table C.2
64	53 V St NW	Did not return bottles; See Table C.2
65	531 Tennessee Ave NE	Did not return bottles; See Table C.2
66	5318 9TH ST NW	Sample rejected; See Table C.3
67	5517 7th St NW	Did not return bottles; See Table C.2
68	561 23RD PL NE	Sample rejected; See Table C.3
69	5731 3rd Pl NW	Did not return bottles; See Table C.2
70	580 49th Pl NE	Did not return bottles; See Table C.2
71	6001 33rd St NW	Did not return bottles; See Table C.2
72	605 Columbia Rd NW	Sample rejected; See Table C.3
73	605 ROCK CRK CHURCH RD NW	Did not return bottles; See Table C.2
74	6105 Dix St NE	Did not return bottles; See Table C.2
75	617 M St NE	Did not return bottles; See Table C.2
76	6213 7TH ST NW	Sample rejected; See Table C.3
77	636 ROCK CRK CHURCH RD NW	Did not return bottles; See Table C.2
78	641 Gallatin St NW	Did not return bottles; See Table C.2
79	75 Bates St NW	Did not return bottles; See Table C.2
80	780 Fairmont St NW	Removed from Sample Pool prior to this semester
81	804 Delafield Pl NW	Sample rejected; See Table C.3
82	834 Delafield Pl NW	Sample rejected; See Table C.3
83	87 S St NW	Did not return bottles; See Table C.2
84	905 Kent Pl NE	Did not return bottles; See Table C.2
85	910 Farragut St NW	Did not return bottles; See Table C.2
86	926 Hamilton St NW	Did not return bottles; See Table C.2

Table C.6 Customer Notification of Results

No	Address	Collection Date	Date Received from WAD Lab	Date Letter Sent to Customer
1	119 16TH ST NE	1/29/2014	3/3/2014	3 /7 /2014
2	2435 33RD ST SE	1/29/2014	3/3/2014	3 /7 /2014
3	228 V ST NE	1/29/2014	3/3/2014	3 /7 /2014
4	1706 NEW JERSEY AVE NW	1/28/2014	3/3/2014	3 /7 /2014
5	125 Madison St NW	1/29/2014	3/3/2014	3 /7 /2014
6	1826 Jackson St NE	1/29/2014	3/3/2014	3 /7 /2014
7	1703 D St NE	1/27/2014	3/3/2014	3 /7 /2014
8	1003 Otis St NE	1/27/2014	3/3/2014	3 /7 /2014
9	1318 Wallach Pl NW	1/29/2014	3/3/2014	3 /7 /2014
10	1505 Buchanan St NW	1/28/2014	3/3/2014	3 /7 /2014
11	109 19th St SE	1/28/2014	3/3/2014	3 /7 /2014
12	12 14TH ST SE	1/27/2014	3/3/2014	3 /7 /2014
13	1738 ALLISON ST NW	1/30/2014	3/3/2014	3 /7 /2014
14	1513 27TH ST NW	1/28/2014	3/3/2014	3 /7 /2014
15	1305 TAYLOR ST NW	1/28/2014	3/3/2014	3 /7 /2014
16	1375 MONROE ST NW	1/27/2014	3/3/2014	3 /7 /2014
17	4131 YUMA ST NW	2/26/2014	3/31/2014	4 /8 /2014
18	4401 5TH ST NW	2/25/2014	3/31/2014	4 /8 /2014
19	331 RALEIGH ST SE	2/26/2014	3/31/2014	4 /8 /2014
20	2830 BRENTWOOD RD NE	2/25/2014	3/31/2014	4 /8 /2014
21	4550 30TH ST NW	2/25/2014	3/31/2014	4 /8 /2014
22	3206 38th St NW	2/26/2014	3/31/2014	4 /8 /2014
23	3710 Huntington St NW	2/26/2014	3/31/2014	4 /8 /2014
24	4627 49th St NW	2/27/2014	3/31/2014	4 /8 /2014
25	4926 Glenbrook Rd NW	2/27/2014	3/31/2014	4 /8 /2014
26	4703 Macarthur Blvd NW	2/26/2014	3/31/2014	4 /8 /2014
27	4418 14th St NE	2/26/2014	3/31/2014	4 /8 /2014
28	3211 Central Ave NE	2/25/2014	3/31/2014	4 /8 /2014
29	4120 Grant St NE	3/5/2014	3/31/2014	4 /8 /2014
30	336 Quackenbos St NE	2/26/2014	3/31/2014	4 /8 /2014
31	307 7th St NE	2/26/2014	3/31/2014	4 /8 /2014
32	5024 7th St NW	2/25/2014	3/31/2014	4 /8 /2014
33	501 Webster St NW	2/24/2014	3/31/2014	4 /8 /2014
34	3727 T St NW	2/26/2014	3/31/2014	4 /8 /2014
35	2913 Brandywine St NW	2/26/2014	3/31/2014	4 /8 /2014
36	1613 Webster St NW	2/27/2014	3/31/2014	4 /8 /2014
37	3625 Albermarle St NW	2/26/2014	3/31/2014	4 /8 /2014
38	309 11TH ST SE	2/26/2014	3/31/2014	4 /8 /2014
39	450 Newton Pl NW	3/2/2014	3/31/2014	4 /8 /2014
40	3636 13TH ST NW	2/25/2014	3/31/2014	4 /8 /2014
41	4806 Kansas Ave NW	2/25/2014	3/31/2014	4 /8 /2014
42	2904 P ST SE	2/25/2014	3/31/2014	4 /8 /2014
43	2832 BRENTWOOD RD NE	2/26/2014	3/31/2014	4 /8 /2014

No	Address	Collection Date	Date Received from WAD Lab	Date Letter Sent to Customer
44	5312 ILLINOIS AVE NW	2/25/2014	3/31/2014	4 /8 /2014
45	3724 CHESAPEAKE ST NW	2/25/2014	3/31/2014	4 /8 /2014
46	4719 9TH ST NW	2/25/2014	3/31/2014	4 /8 /2014
47	822 Allison St NW	2/26/2014	3/31/2014	4 /8 /2014
48	4413 5th St NW	2/25/2014	3/31/2014	4 /8 /2014
49	1319 POTOMAC AVE SE	3/26/2014	4/22/2014	4 /23/2014
50	1222 HAMILTON ST NW	3/25/2014	4/22/2014	4 /23/2014
51	3030 44TH ST NW	3/27/2014	4/22/2014	4 /23/2014
52	1808 KEARNEY ST NE	3/28/2014	4/22/2014	4 /23/2014
53	2007 37TH ST NW	3/31/2014	4/22/2014	4 /23/2014
54	1436 S St NW	3/26/2014	4/22/2014	4 /23/2014
55	1412 Shepherd St NW	3/25/2014	4/22/2014	4 /23/2014
56	702 9th St SE	3/25/2014	4/22/2014	4 /23/2014
57	1211 Carrollsburg Pl SW	3/25/2014	4/22/2014	4 /23/2014
58	619 12th St NE	3/26/2014	4/22/2014	4 /23/2014
59	2408 2nd St NE	3/24/2014	4/22/2014	4 /23/2014
60	617 6th St NE	3/26/2014	4/22/2014	4 /23/2014
61	6210 8th St NW	3/26/2014	4/22/2014	4 /23/2014
62	3036 P St NW	3/26/2014	4/22/2014	4 /23/2014
63	5923 33rd St NW	3/26/2014	4/22/2014	4 /23/2014
64	912 Emerson St NW	3/26/2014	4/22/2014	4 /23/2014
65	6308 8th St NW	3/27/2014	4/22/2014	4 /23/2014
66	621 Upshur St NW	3/26/2014	4/22/2014	4 /23/2014
67	308 9th St SE	3/24/2014	4/22/2014	4 /23/2014
68	8 N St SW	3/25/2014	4/22/2014	4 /23/2014
69	2923 Cathedral AVE NW	3/28/2014	4/22/2014	4 /23/2014
70	807 Buchanan St NW	3/26/2014	4/22/2014	4 /23/2014
71	913 Hamlin St NE	3/25/2014	4/22/2014	4 /23/2014
72	6209 30TH ST NW	3/29/2014	4/22/2014	4 /23/2014
73	421 Hamilton St NW	3/26/2014	4/22/2014	4 /23/2014
74	4811 Illinois Ave NW	2/11/2014	3/3/2014	3 /4 /2014
75	322 TENNESSEE AVE NE	4/30/2014	5/28/2014	5 /30/2014
76	5301 RENO RD NW	4/30/2014	5/28/2014	5 /30/2014
77	4818 8th ST NW	4/29/2014	5/28/2014	5 /30/2014
78	3913 8TH ST NW	4/29/2014	5/28/2014	5 /30/2014
79	3809 ALTON PL NW	4/30/2014	5/28/2014	5 /30/2014
80	5404 39TH ST NW	4/29/2014	5/28/2014	5 /30/2014
81	3218 MORRISON ST NW	4/30/2014	5/28/2014	5 /30/2014
82	3917 8th St NW	5/1/2014	5/28/2014	5 /30/2014
83	4215 39th St NW	4/28/2014	5/28/2014	5 /30/2014
84	231 K St NE	4/29/2014	5/28/2014	5 /30/2014
85	1010 10th St NE	4/30/2014	5/28/2014	5 /30/2014
86	3416 9th St NE	4/29/2014	5/28/2014	5 /30/2014
87	333 34th St NE	4/30/2014	5/28/2014	5 /30/2014
88	413 4th St SE	4/30/2014	5/28/2014	5 /30/2014
89	36 Florida Ave NW	4/30/2014	5/28/2014	5 /30/2014

No	Address	Collection Date	Date Received from WAD Lab	Date Letter Sent to Customer
90	3907 13th St NW	5/6/2014	6/10/2014	6 /12/2014
91	2121 3RD ST NE	5/21/2014	6/10/2014	6 /12/2014
92	1911 P ST SE	5/22/2014	6/10/2014	6 /12/2014
93	5007 13TH ST NW	5/20/2014	6/10/2014	6 /12/2014
94	412 BRANDYWINE ST SE	5/21/2014	6/10/2014	6 /12/2014
95	313 10TH ST SE	5/23/2014	6/10/2014	6 /12/2014
96	1715 IRVING ST NE	5/20/2014	6/10/2014	6 /12/2014
97	1508 GOOD HOPE RD SE	5/21/2014	6/10/2014	6 /12/2014
98	6205 14TH ST NW	6/3/2014	6/11/2014	6 /12/2014
99	3033 CAMBRIDGE PL NW	6/4/2014	6/11/2014	6 /12/2014
100	3761 W ST NW	6/3/2014	6/11/2014	6 /12/2014
101	522 4TH ST SE	6/3/2014	6/11/2014	6 /12/2014
102	414 G ST NE	6/3/2014	6/11/2014	6 /12/2014
103	1020 INDEPENDENCE AVE SE	6/2/2014	6/11/2014	6 /12/2014
104	1113 STAPLES ST NE	6/4/2014	6/11/2014	6 /12/2014
105	502 A ST SE	6/4/2014	6/11/2014	6 /12/2014
106	3510 QUESADA ST NW	6/4/2014	6/11/2014	6 /12/2014
107	120 VARNUM ST NW	6/3/2014	6/11/2014	6 /12/2014
108	3309 35TH ST NW	6/5/2014	6/11/2014	6 /12/2014
109	5223 KANSAS AVE NW	6/3/2014	6/11/2014	6 /12/2014
110	744 9TH ST SE	6/4/2014	6/11/2014	6 /12/2014
111	4525 15TH ST NW	6/11/2014	6/20/2014	6 /20/2014

Appendix D – Revisions to Sample Pool

Table D.1 Sample Pool for July to December 2014 Monitoring Period

No	Address	Pipe Material	Priority
1	10 S St NW	Lead	Primary
2	1003 Otis St NE	Lead	Primary
3	1003 Quebec Pl NW	Lead	Primary
4	1010 10th St NE	Lead	Primary
5	1011 Taylor St NE	Lead	Primary
6	1020 INDEPENDENCE AVE SE	Lead	Primary
7	109 19th St SE	Lead	Primary
8	1106 Allison St NW	Lead	Primary
9	1113 STAPLES ST NE	Lead	Primary
10	119 16TH ST NE	Lead	Primary
11	120 VARNUM ST NW	Lead	Primary
12	123 TENNESSEE AVE NE	Lead	Primary
13	125 Madison St NW	Lead	Primary
14	1262 COLUMBIA RD NW	Lead	Primary
15	1305 TAYLOR ST NW	Lead	Primary
16	1315 FRANKLIN ST NE	Lead	Primary
17	1318 Wallach Pl NW	Lead	Primary
18	1331 Irving St NE	Lead	Primary
19	1346 F St NE	Lead	Primary
20	1375 MONROE ST NW	Lead	Primary
21	1378 Taylor St NW	Lead	Primary
22	1410 ALLISON ST NW	Lead	Primary
23	1420 INGRAHAM ST NW	Lead	Primary
24	1424 S ST NW	Lead	Primary
25	1428 VARNUM ST NW	Lead	Primary
26	1434 Taylor St NW	Lead	Primary
27	15 Milmarson Pl NW	Lead	Primary
28	1505 Buchanan St NW	Lead	Primary
29	1508 GOOD HOPE RD SE	Lead	Primary
30	1513 27TH ST NW	Lead	Primary
31	1519 Olive St NE	Lead	Primary
32	1529 UPSHUR ST NW	Lead	Primary
33	1613 Webster St NW	Lead	Primary
34	1620 Webster St NW	Lead	Primary
35	1627 Gales St NE	Lead	Primary
36	1635 WEBSTER ST NW	Lead	Primary
37	1649 HARVARD ST NW	Lead	Primary

No	Address	Pipe Material	Priority
38	1659 NEWTON ST NW	Lead	Primary
39	1703 D St NE	Lead	Primary
40	1705 D St NE	Lead	Primary
41	1706 NEW JERSEY AVE NW	Lead	Primary
42	1715 IRVING ST NE	Lead	Primary
43	1738 ALLISON ST NW	Lead	Primary
44	1805 2nd St NW	Lead	Primary
45	1826 Jackson St NE	Lead	Primary
46	1911 P ST SE	Lead	Primary
47	1916 PARK RD NW	Lead	Primary
48	2007 37TH ST NW	Lead	Primary
49	2121 3RD ST NE	Lead	Primary
50	213 49th St NE	Lead	Primary
51	228 V ST NE	Lead	Primary
52	2435 33RD ST SE	Lead	Primary
53	2719 O ST NW	Lead	Primary
54	2804 6TH ST NE	Lead	Primary
55	2830 BRENTWOOD RD NE	Lead	Primary
56	2832 BRENTWOOD RD NE	Lead	Primary
57	2904 P ST SE	Lead	Primary
58	2913 Brandywine St NW	Lead	Primary
59	2923 Cathedral AVE NW	Lead	Primary
60	3033 CAMBRIDGE PL NW	Lead	Primary
61	307 7th St NE	Lead	Primary
62	309 11TH ST SE	Lead	Primary
63	313 10TH ST SE	Lead	Primary
64	3206 38th St NW	Lead	Primary
65	3211 Central Ave NE	Lead	Primary
66	3218 MACOMB ST NW	Lead	Primary
67	3218 MORRISON ST NW	Lead	Primary
68	322 TENNESSEE AVE NE	Lead	Primary
69	3309 35TH ST NW	Lead	Primary
70	331 RALEIGH ST SE	Lead	Primary
71	336 Quackenbos St NE	Lead	Primary
72	3361 Stuyvesant Pl NW	Lead	Primary
73	3510 QUESADA ST NW	Lead	Primary
74	3625 Albermarle St NW	Lead	Primary
75	3636 13TH ST NW	Lead	Primary
76	37 U ST NE	Lead	Primary
77	3706 35th St NW	Lead	Primary
78	3710 Huntington St NW	Lead	Primary

No	Address	Pipe Material	Priority
79	3724 CHESAPEAKE ST NW	Lead	Primary
80	3727 T St NW	Lead	Primary
81	3761 W ST NW	Lead	Primary
82	3908 13TH ST NW	Lead	Primary
83	4054 GRANT ST NE	Lead	Primary
84	412 BRANDYWINE ST SE	Lead	Primary
85	4120 Grant St NE	Lead	Primary
86	4131 YUMA ST NW	Lead	Primary
87	414 G ST NE	Lead	Primary
88	421 Hamilton St NW	Lead	Primary
89	4214 8th St NW	Lead	Primary
90	4307 CHESAPEAKE ST NW	Lead	Primary
91	4310 37th St NW	Lead	Primary
92	4401 5TH ST NW	Lead	Primary
93	4413 5th St NW	Lead	Primary
94	4418 14th St NE	Lead	Primary
95	4447 HAWTHORNE ST NW	Lead	Primary
96	449 S St NW	Lead	Primary
97	450 Newton Pl NW	Lead	Primary
98	4525 15TH ST NW	Lead	Primary
99	4550 30TH ST NW	Lead	Primary
100	4610 KANSAS AVE NW	Lead	Primary
101	4613 9th St NW	Lead	Primary
102	4627 49th St NW	Lead	Primary
103	4703 Macarthur Blvd NW	Lead	Primary
104	4719 9TH ST NW	Lead	Primary
105	4806 Kansas Ave NW	Lead	Primary
106	4811 Illinois Ave NW	Lead	Primary
107	4926 Glenbrook Rd NW	Lead	Primary
108	5007 13TH ST NW	Lead	Primary
109	501 Webster St NW	Lead	Primary
110	502 A ST SE	Lead	Primary
111	5024 7th St NW	Lead	Primary
112	522 4TH ST SE	Lead	Primary
113	5220 CHEVY CHASE PKWY NW	Lead	Primary
114	5223 KANSAS AVE NW	Lead	Primary
115	5234 Illinois Ave NW	Lead	Primary
116	531 Tennessee Ave NE	Lead	Primary
117	5312 ILLINOIS AVE NW	Lead	Primary
118	5318 9TH ST NW	Lead	Primary
119	561 23RD PL NE	Lead	Primary

No	Address	Pipe Material	Priority
120	5731 3rd PI NW	Lead	Primary
121	5812 7TH ST NW	Lead	Primary
122	5923 33rd St NW	Lead	Primary
123	6001 33rd St NW	Lead	Primary
124	609 49TH PL NE	Lead	Primary
125	6105 Dix St NE	Lead	Primary
126	617 6th St NE	Lead	Primary
127	619 12th St NE	Lead	Primary
128	6205 14TH ST NW	Lead	Primary
129	6209 30TH ST NW	Lead	Primary
130	621 Upshur St NW	Lead	Primary
131	6210 8th St NW	Lead	Primary
132	6308 8th St NW	Lead	Primary
133	636 ROCK CRK CHURCH RD NW	Lead	Primary
134	6516 8TH ST NW	Lead	Primary
135	702 9th St SE	Lead	Primary
136	744 9TH ST SE	Lead	Primary
137	75 Bates St NW	Lead	Primary
138	8 N St SW	Lead	Primary
139	804 Delafield PI NW	Lead	Primary
140	807 Buchanan St NW	Lead	Primary
141	816 MADISON ST NW	Lead	Primary
142	822 Allison St NW	Lead	Primary
143	834 Delafield PI NW	Lead	Primary
144	910 Farragut St NW	Lead	Primary
145	912 Emerson St NW	Lead	Primary
146	913 Hamlin St NE	Lead	Primary
147	926 Hamilton St NW	Lead	Primary
148	12 14TH ST SE	Partial Lead	Primary
149	1211 Carrollsburg PI SW	Partial Lead	Primary
150	1222 HAMILTON ST NW	Partial Lead	Primary
151	1319 POTOMAC AVE SE	Partial Lead	Primary
152	1353 JEFFERSON ST NW	Partial Lead	Primary
153	1412 S St NW	Partial Lead	Primary
154	1412 Shepherd St NW	Partial Lead	Primary
155	1420 Hamlin St NE	Partial Lead	Primary
156	1436 S St NW	Partial Lead	Primary
157	1671 Rosedale St NE	Partial Lead	Primary
158	1808 KEARNEY ST NE	Partial Lead	Primary
159	1850 2ND ST NW	Partial Lead	Primary
160	223 14th PI NE	Partial Lead	Primary

No	Address	Pipe Material	Priority
161	231 K St NE	Partial Lead	Primary
162	2408 2nd St NE	Partial Lead	Primary
163	3030 44TH ST NW	Partial Lead	Primary
164	3036 P St NW	Partial Lead	Primary
165	308 9th St SE	Partial Lead	Primary
166	317 9th St SE	Partial Lead	Primary
167	3202 38TH ST NW	Partial Lead	Primary
168	3301 BROWN St NW	Partial Lead	Primary
169	333 34th St NE	Partial Lead	Primary
170	3416 9th St NE	Partial Lead	Primary
171	3531 16TH ST NW	Partial Lead	Primary
172	36 Florida Ave NW	Partial Lead	Primary
173	3722 MCKINLEY ST NW	Partial Lead	Primary
174	3809 ALTON PL NW	Partial Lead	Primary
175	3907 13th St NW	Partial Lead	Primary
176	3913 8TH ST NW	Partial Lead	Primary
177	3917 8th St NW	Partial Lead	Primary
178	413 4th St SE	Partial Lead	Primary
179	420 Kenyon St NW	Partial Lead	Primary
180	4215 39th St NW	Partial Lead	Primary
181	4332 BRANDYWINE ST NW	Partial Lead	Primary
182	4818 8th ST NW	Partial Lead	Primary
183	5003 7TH ST NW	Partial Lead	Primary
184	53 P St NW	Partial Lead	Primary
185	53 V St NW	Partial Lead	Primary
186	5301 RENO RD NW	Partial Lead	Primary
187	5404 39TH ST NW	Partial Lead	Primary
188	617 M St NE	Partial Lead	Primary
189	6213 7TH ST NW	Partial Lead	Primary
190	1025 44th St NE	Lead	Secondary
191	1357 C St NE	Lead	Secondary
192	1453 S St NW	Lead	Secondary
193	2107 2nd St NE	Lead	Secondary
194	2212 38th St NW	Lead	Secondary
195	24 Evarts St NE	Lead	Secondary
196	3601 WARREN ST NW	Lead	Secondary
197	424 Luray Pl NW	Lead	Secondary
198	4409 Lowell St NW	Lead	Secondary
199	5226 7th St NW	Lead	Secondary
200	5517 7th St NW	Lead	Secondary
201	580 49th Pl NE	Lead	Secondary

No	Address	Pipe Material	Priority
202	641 Gallatin St NW	Lead	Secondary
203	87 S St NW	Lead	Secondary
204	905 Kent Pl NE	Lead	Secondary
205	1603 Massachusetts Ave SE	Partial Lead	Secondary
206	1736 Bay St SE	Partial Lead	Secondary
207	230 G St NE	Partial Lead	Secondary
208	302 RITTENHOUSE ST NW	Partial Lead	Secondary
209	605 ROCK CRK CHURCH RD NW	Partial Lead	Secondary

Table D.2 Site Changes – Sites Removed, Added, or Priority Status Changed

No	Address	Change	Reason
1	1014 Douglas St NE	Removed	Did not return samples in last four events
2	1207 Trinidad Ave NE	Removed	Did not return samples in last four events
3	1346 Madison St NW	Removed	Did not return samples in last four events
4	1614 V St SE	Removed	Did not return samples in last four events
5	1705 2nd St NE	Removed	Did not return samples in last four events
6	201 13th St NE	Removed	Did not return samples in last four events
7	205 TAYLOR ST NW	Removed	Did not return samples in last four events
8	3105 34th St NW	Removed	Did not return samples in last four events
9	312 14TH ST NE	Removed	Did not return samples in last four events
10	313 16th St SE	Removed	Did not return samples in last four events
11	3216 Klinge Rd NW	Removed	Did not return samples in last four events
12	3232 Klinge Rd NW	Removed	Did not return samples in last four events
13	335 17TH PL NE	Removed	Did not return samples in last four events
14	3428 Brown St NW	Removed	Did not return samples in last four events
15	3612 34th St NW	Removed	Did not return samples in last four events
16	3721 Windom Pl NW	Removed	Did not return samples in last four events
17	4111 INGOMAR ST NW	Removed	Did not return samples in last four events
18	42 Q St NE	Removed	Did not return samples in last four events
19	441 Quincy St NW	Removed	Did not return samples in last four events
20	4818 ILLINOIS AVE NW	Removed	Did not return samples in last four events
21	506 Irving St NW	Removed	Did not return samples in last four events
22	524 10th St SE	Removed	Did not return samples in last four events
23	5304 Reno Rd NW	Removed	Did not return samples in last four events
24	5316 28th St NW	Removed	Did not return samples in last four events
25	611 Roxboro Pl NW	Removed	Did not return samples in last four events
26	617 Kenyon St NW	Removed	Did not return samples in last four events
27	619 Girard St NE	Removed	Did not return samples in last four events
28	661 MARYLAND AVE NE	Removed	Did not return samples in last four events
29	720 ALABAMA AVE SE	Removed	Did not return samples in last four events
30	736 Fairmont St NW	Removed	Did not return samples in last four events
31	753 Gresham Pl NW	Removed	Did not return samples in last four events
32	833 DECATUR ST NW	Removed	Did not return samples in last four events
33	924 Hamilton St NW	Removed	Did not return samples in last four events
34	228 Randolph Pl NE	Removed	Did not return valid samples in last four events
35	234 Longfellow St NW	Removed	Did not return valid samples in last four events
36	4616 HUNT PL NE	Removed	Did not return valid samples in last four events
37	5613 30th St NW	Removed	Did not return valid samples in last four events
38	7721 14th St NW	Removed	Did not return valid samples in last four events
39	513 Florida Ave NE	Removed	Multi-family residence
40	124 16TH ST NE	Removed	No lead; full service line replacement March 2014

No	Address	Change	Reason
41	100 KENNEDY ST NE	Removed	Randomly added this semester but did not return bottles ^[1]
42	1218 GALLATIN ST NW	Removed	Randomly added this semester but did not return bottles ^[1]
43	1223 PENNSYLVANIA AVE SE	Removed	Randomly added this semester but did not return bottles ^[1]
44	1611 ALLISON ST NW	Removed	Randomly added this semester but did not return bottles ^[1]
45	1855 California St NW	Removed	Randomly added this semester but did not return bottles ^[1]
46	223 E ST NE	Removed	Randomly added this semester but did not return bottles ^[1]
47	3215 MACOMB ST NW	Removed	Randomly added this semester but did not return bottles ^[1]
48	3322 17TH ST NW	Removed	Randomly added this semester but did not return bottles ^[1]
49	3615 ALABAMA AVE SE	Removed	Randomly added this semester but did not return bottles ^[1]
50	406 TENNESSEE AVE NE	Removed	Randomly added this semester but did not return bottles ^[1]
51	4551 DIX ST NE	Removed	Randomly added this semester but did not return bottles ^[1]
52	4601 13TH ST NW	Removed	Randomly added this semester but did not return bottles ^[1]
53	4621 8TH ST NW	Removed	Randomly added this semester but did not return bottles ^[1]
54	4716 15TH ST NW	Removed	Randomly added this semester but did not return bottles ^[1]
55	4900 1ST ST NW	Removed	Randomly added this semester but did not return bottles ^[1]
56	4923 HILLBROOK LN NW	Removed	Randomly added this semester but did not return bottles ^[1]
57	503 45TH ST NE	Removed	Randomly added this semester but did not return bottles ^[1]
58	907 L ST NE	Removed	Randomly added this semester but did not return bottles ^[1]
59	946 14TH ST SE	Removed	Randomly added this semester but did not return bottles ^[1]
60	1310 R ST NW	Removed	Request to not participate
61	3215 Mckinley St NW	Removed	Request to not participate
62	605 Columbia Rd NW	Removed	Request to not participate
63	804 FERN PL NW	Removed	Request to not participate
64	1010 10th St NE	Secondary to Primary	Returned samples this semester

No	Address	Change	Reason
65	3218 MORRISON ST NW	Secondary to Primary	Returned samples this semester
66	322 TENNESSEE AVE NE	Secondary to Primary	Returned samples this semester
67	231 K St NE	Secondary to Primary	Returned samples this semester
68	1025 44th St NE	Primary to Secondary	Did not return samples in last two events
69	1357 C St NE	Primary to Secondary	Did not return samples in last two events
70	1453 S St NW	Primary to Secondary	Did not return samples in last two events
71	2107 2nd St NE	Primary to Secondary	Did not return samples in last two events
72	2212 38th St NW	Primary to Secondary	Did not return samples in last two events
73	24 Evarts St NE	Primary to Secondary	Did not return samples in last two events
74	3601 WARREN ST NW	Primary to Secondary	Did not return samples in last two events
75	424 Luray Pl NW	Primary to Secondary	Did not return samples in last two events
76	4409 Lowell St NW	Primary to Secondary	Did not return samples in last two events
77	5226 7th St NW	Primary to Secondary	Did not return samples in last two events
78	5517 7th St NW	Primary to Secondary	Did not return samples in last two events
79	580 49th Pl NE	Primary to Secondary	Did not return samples in last two events
80	641 Gallatin St NW	Primary to Secondary	Did not return samples in last two events
81	87 S St NW	Primary to Secondary	Did not return samples in last two events
82	905 Kent Pl NE	Primary to Secondary	Did not return samples in last two events
83	1603 Massachusetts Ave SE	Primary to Secondary	Did not return samples in last two events
84	1736 Bay St SE	Primary to Secondary	Did not return samples in last two events
85	230 G St NE	Primary to Secondary	Did not return samples in last two events
86	302 RITTENHOUSE ST NW	Primary to Secondary	Did not return samples in last two events

No	Address	Change	Reason
87	605 ROCK CRK CHURCH RD NW	Primary to Secondary	Did not return samples in last two events
88	4413 5th St NW	Added	New participant by customer-request
89	4811 Illinois Ave NW	Added	New participant by customer-request
90	822 Allison St NW	Added	New participant by customer-request
91	1020 INDEPENDENCE AVE SE	Added	New participant by random selection
92	1113 STAPLES ST NE	Added	New participant by random selection
93	120 VARNUM ST NW	Added	New participant by random selection
94	1410 ALLISON ST NW	Added	New participant by random selection
95	1420 INGRAHAM ST NW	Added	New participant by random selection
96	1508 GOOD HOPE RD SE	Added	New participant by random selection
97	1715 IRVING ST NE	Added	New participant by random selection
98	1805 2nd St NW	Added	New participant by random selection
99	1911 P ST SE	Added	New participant by random selection
100	1916 PARK RD NW	Added	New participant by random selection
101	2121 3RD ST NE	Added	New participant by random selection
102	2804 6TH ST NE	Added	New participant by random selection
103	3033 CAMBRIDGE PL NW	Added	New participant by random selection
104	313 10TH ST SE	Added	New participant by random selection
105	3309 35TH ST NW	Added	New participant by random selection
106	3510 QUESADA ST NW	Added	New participant by random selection
107	37 U ST NE	Added	New participant by random selection
108	3761 W ST NW	Added	New participant by random selection
109	4054 GRANT ST NE	Added	New participant by random selection
110	412 BRANDYWINE ST SE	Added	New participant by random selection
111	414 G ST NE	Added	New participant by random selection
112	4525 15TH ST NW	Added	New participant by random selection
113	4610 KANSAS AVE NW	Added	New participant by random selection
114	5007 13TH ST NW	Added	New participant by random selection
115	502 A ST SE	Added	New participant by random selection
116	522 4TH ST SE	Added	New participant by random selection
117	5220 CHEVY CHASE PKWY NW	Added	New participant by random selection
118	5223 KANSAS AVE NW	Added	New participant by random selection
119	6205 14TH ST NW	Added	New participant by random selection
120	6516 8TH ST NW	Added	New participant by random selection
121	744 9TH ST SE	Added	New participant by random selection
122	816 MADISON ST NW	Added	New participant by random selection


Notes:

[1] Site removed from July – December 2014 Sample Pool because customer did not return bottles during January – June 2014 sampling period.

Appendix E – Revised Template Notices for Customer LCR Results

This appendix contains revised template notices to customers regarding lead and copper monitoring results based on the following lead service line conditions:

- Service Line Lead Public and Non-lead Private
- Service Line Lead Public and Private
- Service Line Non-lead Public and Lead Private



DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY | 3900 DONALDSON PLACE, NW | WASHINGTON, DC 20016

Month, day, year

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»:

Thank you for participating in DC Water’s Lead and Copper Compliance Monitoring Program. Your participation helps us assess the effectiveness of the U.S. Army Corps of Engineers Washington Aqueduct corrosion control treatment to minimize corrosion of lead service pipes, household plumbing and fixtures that may contribute to lead and copper concentrations in drinking water.

Below are the test results from the two water samples that you collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential sources near the tap where the sample is collected. This sample is required by the Environmental Protection Agency (EPA).
- Second draw: Measures lead release from the lead service pipe and household plumbing. DC Water voluntarily collects this sample to assess the contribution of lead in water from the lead service line.

Sample	Lead Level (ppb)	Copper Level (ppb)
First Draw		
Second Draw		

Service Line Material

Public Space: Lead

Private Property: Non-lead

If this information is inaccurate, please contact the Drinking Water Division at 202-612-3440.

DC Water recommends that you filter your water to minimize potential lead exposure if lead is present in your drinking water, if you have pipes or plumbing fixtures that contain lead, or if you don’t know the material type. If you are pregnant, nursing or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free when it leaves the Washington Aqueduct treatment plant, but lead can enter water when it comes in contact with pipes or plumbing fixtures that contain lead. As noted above, your property has a lead service pipe, which connects the water main in the street to household plumbing. DC Water operates a lead service replacement program and will replace the public portion of the service line during a water main replacement, or if you agree to replace the portion on your private property.

Under the authority of the Safe Drinking Water Act, EPA set a Maximum Contaminant Level Goal (MCLG) for lead at zero and for copper at 1,300 parts per billion (ppb). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. EPA also set an action level for lead at 15 ppb and for copper at 1,300 ppb. The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. These requirements are triggered if more than 10 percent of all first draw samples collected during any monitoring period exceed the action levels. Your lead and copper results may be higher or lower than the action levels, which does not reflect DC Water’s compliance with the LCR. DC Water will notify all customers if the District’s water exceeds the lead or copper action level.

Lead can pose significant health risks if too much of it enters the body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead from other sources (such as lead-based paint and contaminated soil) can increase a person's overall exposure, which adds to the effects of lead in water.

The District Department of the Environment (DDOE) offers information on blood lead testing for young children, pregnant women and nursing mothers. For more information on minimizing lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov or visit EPA's website at www.epa.gov/lead.

DC Water strongly encourages residents to take the following steps to reduce lead exposure:

Remove lead sources

- Replace your lead service pipe with copper. For more information about lead pipe replacement, contact the Drinking Water Division at 202-612-3440.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). Effective in 2014, fixtures that are labeled "lead-free" cannot contain more than 0.25 percent lead. Flush cold water taps, with the aerator removed, at highest flow rate for 5 minutes once a day for 3 days after installing new household pipes or fixtures.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. Visit the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your water before using it for drinking or cooking. Once you notice a temperature change, continue running your water for 2 more minutes to receive fresh water from the water main.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators


- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

For more information, contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



Jessica Edwards-Brandt
Manager, Drinking Water Division



DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY | 3900 DONALDSON PLACE, NW | WASHINGTON, DC 20016

Month, day, year

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»:

Thank you for participating in DC Water’s Lead and Copper Compliance Monitoring Program. Your participation helps us assess the effectiveness of the U.S. Army Corps of Engineers Washington Aqueduct corrosion control treatment to minimize corrosion of lead service pipes, household plumbing and fixtures that may contribute to lead and copper concentrations in drinking water.

Below are the test results from the two water samples that you collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential sources near the tap where the sample is collected. This sample is required by the Environmental Protection Agency (EPA).
- Second draw: Measures lead release from the lead service pipe and household plumbing. DC Water voluntarily collects this sample to assess the contribution of lead in water from the lead service line.

Sample	Lead Level (ppb)	Copper Level (ppb)
First Draw		
Second Draw		

Service Line Material

Public Space: Lead
Private Property: Lead

If this information is inaccurate, please contact the Drinking Water Division at 202-612-3440.

DC Water recommends that you filter your water to minimize potential lead exposure if lead is present in your drinking water, if you have pipes or plumbing fixtures that contain lead, or if you don’t know the material type. If you are pregnant, nursing or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free when it leaves the Washington Aqueduct treatment plant, but lead can enter water when it comes in contact with pipes or plumbing fixtures that contain lead. As noted above, your property has a lead service pipe, which connects the water main in the street to household plumbing. DC Water operates a lead service replacement program and will replace the public portion of the service line during a water main replacement, or if you agree to replace the portion on your private property.

Under the authority of the Safe Drinking Water Act, EPA set a Maximum Contaminant Level Goal (MCLG) for lead at zero and for copper at 1,300 parts per billion (ppb). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. EPA also set an action level for lead at 15 ppb and for copper at 1,300 ppb. The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. These requirements are triggered if more than 10 percent of all first draw samples collected during any monitoring period exceed the action levels. Your lead and copper results may be higher or lower than the action levels, which does not reflect DC Water’s compliance with the LCR. DC Water will notify all customers if the District’s water exceeds the lead or copper action level.

Lead can pose significant health risks if too much of it enters the body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead from other sources (such as lead-based paint and contaminated soil) can increase a person's overall exposure, which adds to the effects of lead in water.

The District Department of the Environment (DDOE) offers information on blood lead testing for young children, pregnant women and nursing mothers. For more information on minimizing lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov or visit EPA's website at www.epa.gov/lead.

DC Water strongly encourages residents to take the following steps to reduce lead exposure:

Remove lead sources

- Replace your lead service pipe with copper. For more information about lead pipe replacement, contact the Drinking Water Division at 202-612-3440.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). Effective in 2014, fixtures that are labeled "lead-free" cannot contain more than 0.25 percent lead. Flush cold water taps, with the aerator removed, at highest flow rate for 5 minutes once a day for 3 days after installing new household pipes or fixtures.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. Visit the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your water before using it for drinking or cooking. Once you notice a temperature change, continue running your water for 2 more minutes to receive fresh water from the water main.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators


- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

For more information, contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



Jessica Edwards-Brandt
Manager, Drinking Water Division



DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY | 3900 DONALDSON PLACE, NW | WASHINGTON, DC 20016

Month, day, year

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»:

Thank you for participating in DC Water’s Lead and Copper Compliance Monitoring Program. Your participation helps us assess the effectiveness of the U.S. Army Corps of Engineers Washington Aqueduct corrosion control treatment to minimize corrosion of lead service pipes, household plumbing and fixtures that may contribute to lead and copper concentrations in drinking water.

Below are the test results from the two water samples that you collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential sources near the tap where the sample is collected. This sample is required by the Environmental Protection Agency (EPA).
- Second draw: Measures lead release from the lead service pipe and household plumbing. DC Water voluntarily collects this sample to assess the contribution of lead in water from the lead service line.

Sample	Lead Level (ppb)	Copper Level (ppb)
First Draw		
Second Draw		

Service Line Material
Public Space: Non-lead
Private Property: Lead

If this information is inaccurate, please contact the Drinking Water Division at 202-612-3440.

DC Water recommends that you filter your water to minimize potential lead exposure if lead is present in your drinking water, if you have pipes or plumbing fixtures that contain lead, or if you don’t know the material type. If you are pregnant, nursing or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free when it leaves the Washington Aqueduct treatment plant, but lead can enter water when it comes in contact with pipes or plumbing fixtures that contain lead. As noted above, your property has a lead service pipe, which connects the water main in the street to household plumbing. DC Water operates a lead service replacement program and will replace the public portion of the service line during a water main replacement, or if you agree to replace the portion on your private property.

Under the authority of the Safe Drinking Water Act, EPA set a Maximum Contaminant Level Goal (MCLG) for lead at zero and for copper at 1,300 parts per billion (ppb). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. EPA also set an action level for lead at 15 ppb and for copper at 1,300 ppb. The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. These requirements are triggered if more than 10 percent of all first draw samples collected during any monitoring period exceed the action levels. Your lead and copper results may be higher or lower than the action levels, which does not reflect DC Water’s compliance with the LCR. DC Water will notify all customers if the District’s water exceeds the lead or copper action level.

Lead can pose significant health risks if too much of it enters the body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead from other sources (such as lead-based paint and contaminated soil) can increase a person's overall exposure, which adds to the effects of lead in water.

The District Department of the Environment (DDOE) offers information on blood lead testing for young children, pregnant women and nursing mothers. For more information on minimizing lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov or visit EPA's website at www.epa.gov/lead.

DC Water strongly encourages residents to take the following steps to reduce lead exposure:

Remove lead sources

- Replace your lead service pipe with copper. For more information about lead pipe replacement, contact the Drinking Water Division at 202-612-3440.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). Effective in 2014, fixtures that are labeled "lead-free" cannot contain more than 0.25 percent lead. Flush cold water taps, with the aerator removed, at highest flow rate for 5 minutes once a day for 3 days after installing new household pipes or fixtures.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. Visit the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your water before using it for drinking or cooking. Once you notice a temperature change, continue running your water for 2 more minutes to receive fresh water from the water main.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

For more information, contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



Jessica Edwards-Brandt
Manager, Drinking Water Division

Attachment 1

Washington Aqueduct Test Results for LCR Compliance Samples

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-001

SAMPLE INFORMATION

Sample Number: 1402015-001 Customer Sample Number: 3075175 Project: LCR
Location: 1st draw 12 14TH ST SE Type: Dist.

Collection Date: 1/27/2014 Collection Time: 12:20 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-002

SAMPLE INFORMATION

Sample Number: 1402015-002 Customer Sample Number: 3075175 Project: LCR
Location: 2nd draw 12 14TH ST SE Type: Dist.

Collection Date: 1/27/2014 Collection Time: 12:21 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.039 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-003

SAMPLE INFORMATION

Sample Number: 1402015-003 Customer Sample Number: 3029133 Project: LCR
Location: 1st draw 1738 ALLISON ST NW Type: Dist.

Collection Date: 1/30/2014 Collection Time: 6:59 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.043 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.036 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-004

SAMPLE INFORMATION

Sample Number: 1402015-004 Customer Sample Number: 3029133 Project: LCR
Location: 2nd draw 1738 ALLISON ST NW Type: Dist.

Collection Date: 1/30/2014 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.037 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-005

SAMPLE INFORMATION

Sample Number: 1402015-005 Customer Sample Number: 3100985 Project: LCR
Location: 1st draw 1703 D ST NE Type: Dist.

Collection Date: 1/27/2014 Collection Time: 16:57 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-006

SAMPLE INFORMATION

Sample Number: 1402015-006 Customer Sample Number: 3100985 Project: LCR
Location: 2nd draw 1703 D ST NE Type: Dist.

Collection Date: 1/27/2014 Collection Time: 17:02 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.037 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-007

SAMPLE INFORMATION

Sample Number: 1402015-007 Customer Sample Number: 3075926 Project: LCR
Location: 1st draw 109 19TH ST SE Type: Dist.

Collection Date: 1/28/2014 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-008

SAMPLE INFORMATION

Sample Number: 1402015-008 Customer Sample Number: 3075926 Project: LCR
Location: 2nd draw 109 19TH ST SE Type: Dist.

Collection Date: 1/28/2014 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0074 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-009

SAMPLE INFORMATION

Sample Number: 1402015-009 Customer Sample Number: 3124875 Project: LCR
Location: 1st draw 228 V ST NE Type: Dist.

Collection Date: 1/29/2014 Collection Time: 19:55 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.073 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0023 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-010

Report revised on 6/18/2014 by MC.
For Lab Sample Number 1402015-010, the collection date was changed from 1/28/2014 to 1/29/2014 as reported on the chain of custody.

SAMPLE INFORMATION

Sample Number: 1402015-010
Location: 2nd draw 228 V ST NE

Customer Sample Number: 3124875
Type: Dist.

Project: LCR

Collection Date: 1/2J/2014
Collection Time: 20:03
Sampler: HOME OWNER
Received Date and Time: 2/4/2014 9:42:12 AM
Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.058 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Michael Chicoine, Laboratory Manager

6/18/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-011

SAMPLE INFORMATION

Sample Number: 1402015-011 Customer Sample Number: 3027905 Project: LCR
Location: 1st draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 1/28/2014 Collection Time: 5:16 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.031 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.071 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0090 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-012

SAMPLE INFORMATION

Sample Number: 1402015-012 Customer Sample Number: 3027905 Project: LCR
Location: 2nd draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 1/28/2014 Collection Time: 5:18 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.031 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0040 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-013

SAMPLE INFORMATION

Sample Number: 1402015-013 Customer Sample Number: 3029985 Project: LCR
Location: 1st draw 1375 MONROE ST NW Type: Dist.

Collection Date: 1/27/2014 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.036 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-014

SAMPLE INFORMATION

Sample Number: 1402015-014 Customer Sample Number: 3029985 Project: LCR
Location: 2nd draw 1375 MONROE ST NW Type: Dist.

Collection Date: 1/27/2014 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0023 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-015

SAMPLE INFORMATION

Sample Number: 1402015-015 Customer Sample Number: 3106027 Project: LCR
Location: 1st draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 1/29/2014 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.043 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-016

SAMPLE INFORMATION

Sample Number: 1402015-016 Customer Sample Number: 3106207 Project: LCR
Location: 2nd draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 1/29/2014 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-017

SAMPLE INFORMATION

Sample Number: 1402015-017 Customer Sample Number: 3028689 Project: LCR
Location: 1st draw 1305 TAYLOR ST NW Type: Dist.

Collection Date: 1/28/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-018

SAMPLE INFORMATION

Sample Number: 1402015-018 Customer Sample Number: 3028689 Project: LCR
Location: 2nd draw 1305 TAYLOR ST NW Type: Dist.

Collection Date: 1/28/2014 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-019

SAMPLE INFORMATION

Sample Number: 1402015-019 Customer Sample Number: 3025494 Project: LCR
Location: 1st draw 125 MADISON ST NW Type: Dist.

Collection Date: 1/29/2014 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.139 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0032 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-020

SAMPLE INFORMATION

Sample Number: 1402015-020 Customer Sample Number: 3025494 Project: LCR
Location: 2nd draw 125 MADISON ST NW Type: Dist.

Collection Date: 1/29/2014 Collection Time: 5:44 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.189 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-021

SAMPLE INFORMATION

Sample Number: 1402015-021 Customer Sample Number: 3002817 Project: LCR
Location: 1st draw 1318 WALLACH PL NW Type: Dist.

Collection Date: 1/29/2014 Collection Time: 7:48 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.049 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-022

SAMPLE INFORMATION

Sample Number: 1402015-022 Customer Sample Number: 3002817 Project: LCR
Location: 2nd draw 1318 WALLACH PL NW Type: Dist.

Collection Date: 1/29/2014 Collection Time: 7:51 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-023

SAMPLE INFORMATION

Sample Number: 1402015-023 Customer Sample Number: 3080372 Project: LCR
Location: 1st draw 2435 33RD ST SE Type: Dist.

Collection Date: 1/29/2014 Collection Time: 5:05 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.026 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-024

SAMPLE INFORMATION

Sample Number: 1402015-024 Customer Sample Number: 3080372 Project: LCR
Location: 2nd draw 2435 33RD ST SE Type: Dist.

Collection Date: 1/29/2014 Collection Time: 5:07 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.042 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-025

SAMPLE INFORMATION

Sample Number: 1402015-025 Customer Sample Number: 3111849 Project: LCR
Location: 1st draw 119 16TH ST NE Type: Dist.

Collection Date: 1/29/2014 Collection Time: 6:18 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.052 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-026

SAMPLE INFORMATION

Sample Number: 1402015-026 Customer Sample Number: 3111849 Project: LCR
Location: 2nd draw 119 16TH ST NE Type: Dist.

Collection Date: 1/29/2014 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-027

SAMPLE INFORMATION

Sample Number: 1402015-027 Customer Sample Number: 3006211 Project: LCR
Location: 1st draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 1/28/2014 Collection Time: 16:45 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-028

SAMPLE INFORMATION

Sample Number: 1402015-028 Customer Sample Number: 3006211 Project: LCR
Location: 2nd draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 1/28/2014 Collection Time: 16:46 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.002 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-029

SAMPLE INFORMATION

Sample Number: 1402015-029 Customer Sample Number: 3007205 Project: LCR
Location: 1st draw 1513 27TH ST NW Type: Dist.

Collection Date: 1/28/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.031 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-030

SAMPLE INFORMATION

Sample Number: 1402015-030 Customer Sample Number: 3007205 Project: LCR
Location: 2nd draw 1513 27TH ST NW Type: Dist.

Collection Date: 1/28/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.026 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0057 mg/L	2/27/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-031

SAMPLE INFORMATION

Sample Number: 1402015-031 Customer Sample Number: 3113400 Project: LCR
Location: 1st draw 1003 OTIS ST NE Type: Dist.

Collection Date: 1/27/2014 Collection Time: 16:05 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.039 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402015-032

SAMPLE INFORMATION

Sample Number: 1402015-032 Customer Sample Number: 3113400 Project: LCR
Location: 2nd draw 1003 OTIS ST NE Type: Dist.

Collection Date: 1/27/2014 Collection Time: 16:05 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:42:12 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 3/3/2014
Report Number: LC-W1402108-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-001 Customer Sample Number: 3058525 Project: LCR
Location: 1st draw 4811 ILLINOIS AVE NW Type: Dist.

Collection Date: 2/11/2014 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.249 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.158 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 3/3/2014
Report Number: LC-W1402108-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-002 Customer Sample Number: 3058525 Project: LCR
Location: 2nd draw 4811 ILLINOIS AVE NW Type: Dist.

Collection Date: 2/11/2014 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.238 mg/L	2/27/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.110 mg/L	2/27/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0044 mg/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/3/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-001

SAMPLE INFORMATION

Sample Number: 1403012-001 Customer Sample Number: 3040552 Project: LCR
Location: 1st draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-002

SAMPLE INFORMATION

Sample Number: 1403012-002 Customer Sample Number: 3040552 Project: LCR
Location: 2nd draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 7:06 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0027 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-003

SAMPLE INFORMATION

Sample Number: 1403012-003 Customer Sample Number: 3058437 Project: LCR
Location: 1st draw 4806 KANSAS AVE NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 20:30 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.078 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-004

SAMPLE INFORMATION

Sample Number: 1403012-004 Customer Sample Number: 3058437 Project: LCR
Location: 2nd draw 4806 KANSAS AVE NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 20:30 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.061 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-005

SAMPLE INFORMATION

Sample Number: 1403012-005 Customer Sample Number: 3104746 Project: LCR
Location: 1st draw 4418 14TH ST NE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.037 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-006

SAMPLE INFORMATION

Sample Number: 1403012-006 Customer Sample Number: 3104746 Project: LCR
Location: 2nd draw 4418 14TH ST NE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 18:05 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-007

SAMPLE INFORMATION

Sample Number: 1403012-007 Customer Sample Number: 3058228 Project: LCR
Location: 1st draw 2913 BRANDYWINE ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.098 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-008

SAMPLE INFORMATION

Sample Number: 1403012-008 Customer Sample Number: 3058228 Project: LCR
Location: 2nd draw 2913 BRANDYWINE ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 7:14 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.072 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-009

SAMPLE INFORMATION

Sample Number: 1403012-009 Customer Sample Number: 3021723 Project: LCR
Location: 1st draw 822 ALLISON ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:51 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-010

SAMPLE INFORMATION

Sample Number: 1403012-010 Customer Sample Number: 3021723 Project: LCR
Location: 2nd draw 822 ALLISON ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-011

SAMPLE INFORMATION

Sample Number: 1403012-011 Customer Sample Number: 3045865 Project: LCR
Location: 1st draw 4926 GLENBROOK RD NW Type: Dist.

Collection Date: 2/27/2014 Collection Time: 5:35 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-012

SAMPLE INFORMATION

Sample Number: 1403012-012 Customer Sample Number: 3045865 Project: LCR
Location: 2nd draw 4926 GLENBROOK RD NW Type: Dist.

Collection Date: 2/27/2014 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.040 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-013

SAMPLE INFORMATION

Sample Number: 1403012-013 Customer Sample Number: 3029605 Project: LCR
Location: 1st draw 3636 13TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 18:47 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-014

SAMPLE INFORMATION

Sample Number: 1403012-014 Customer Sample Number: 3029605 Project: LCR
Location: 2nd draw 3636 13TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 18:50 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0031 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-015

SAMPLE INFORMATION

Sample Number: 1403012-015 Customer Sample Number: 3029171 Project: LCR
Location: 1st draw 1613 WEBSTER ST. NW Type: Dist.

Collection Date: 2/27/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.060 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-016

SAMPLE INFORMATION

Sample Number: 1403012-016 Customer Sample Number: 3029171 Project: LCR
Location: 2nd draw 1613 WEBSTER ST. NW Type: Dist.

Collection Date: 2/27/2014 Collection Time: 7:31 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.053 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-017

SAMPLE INFORMATION

Sample Number: 1403012-017 Customer Sample Number: 3022216 Project: LCR
Location: 1st draw 4719 9TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-018

SAMPLE INFORMATION

Sample Number: 1403012-018 Customer Sample Number: 3022216 Project: LCR
Location: 2nd draw 4719 9TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-019

SAMPLE INFORMATION

Sample Number: 1403012-019 Customer Sample Number: 3022910 Project: LCR
Location: 1st draw 5024 7TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.032 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-020

SAMPLE INFORMATION

Sample Number: 1403012-020 Customer Sample Number: 3058406 Project: LCR
Location: 1st draw 4550 30TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-021

SAMPLE INFORMATION

Sample Number: 1403012-021 Customer Sample Number: 3058406 Project: LCR
Location: 2nd draw 4550 30TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 5:25 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.039 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-022

SAMPLE INFORMATION

Sample Number: 1403012-022 Customer Sample Number: 3035196 Project: LCR
Location: 1st draw 3206 38TH ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.228 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-023

SAMPLE INFORMATION

Sample Number: 1403012-023 Customer Sample Number: 3035196 Project: LCR
Location: 2nd draw 3206 38TH ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 8:05 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.076 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-024

SAMPLE INFORMATION

Sample Number: 1403012-024 Customer Sample Number: 3021581 Project: LCR
Location: 1st draw 4413 5TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 19:30 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-025

SAMPLE INFORMATION

Sample Number: 1403012-025 Customer Sample Number: 3021581 Project: LCR
Location: 2nd draw 4413 5TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 19:30 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-026

SAMPLE INFORMATION

Sample Number: 1403012-026 Customer Sample Number: 3073397 Project: LCR
Location: 1st draw 309 11TH ST SE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 18:09 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.065 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-027

SAMPLE INFORMATION

Sample Number: 1403012-027 Customer Sample Number: 3073397 Project: LCR
Location: 2nd draw 309 11TH ST SE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 18:10 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.075 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-028

SAMPLE INFORMATION

Sample Number: 1403012-028 Customer Sample Number: 3040894 Project: LCR
Location: 1st draw 3724 CHESAPEAKE ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.067 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-029

SAMPLE INFORMATION

Sample Number: 1403012-029 Customer Sample Number: 3040894 Project: LCR
Location: 2nd draw 3724 CHESAPEAKE ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.055 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-030

SAMPLE INFORMATION

Sample Number: 1403012-030 Customer Sample Number: 3051524 Project: LCR
Location: 1st draw 5312 ILLINOIS AVE NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 8:21 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.473 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-031

SAMPLE INFORMATION

Sample Number: 1403012-031 Customer Sample Number: 3051524 Project: LCR
Location: 2nd draw 5312 ILLINOIS AVE NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 8:23 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.039 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-032

SAMPLE INFORMATION

Sample Number: 1403012-032 Customer Sample Number: 3036642 Project: LCR
Location: 1st draw 3625 ALBEMARLE ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-033

SAMPLE INFORMATION

Sample Number: 1403012-033 Customer Sample Number: 3036642 Project: LCR
Location: 2nd draw 3625 ALBEMARLE ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-034

SAMPLE INFORMATION

Sample Number: 1403012-034 Customer Sample Number: 3107490 Project: LCR
Location: 1st draw 2830 BRENTWOOD RD NE Type: Dist.

Collection Date: 2/25/2014 Collection Time: 14:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.235 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.459 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0074 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-035

SAMPLE INFORMATION

Sample Number: 1403012-035 Customer Sample Number: 3107490 Project: LCR
Location: 2nd draw 2830 BRENTWOOD RD NE Type: Dist.

Collection Date: 2/25/2014 Collection Time: 14:04 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.118 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-036

SAMPLE INFORMATION

Sample Number: 1403012-036 Customer Sample Number: 3111675 Project: LCR
Location: 1st draw 307 7TH ST NE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-037

SAMPLE INFORMATION

Sample Number: 1403012-037 Customer Sample Number: 3111675 Project: LCR
Location: 2nd draw 307 7TH ST NE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-038

SAMPLE INFORMATION

Sample Number: 1403012-038 Customer Sample Number: 3021532 Project: LCR
Location: 1st draw 501 WEBSTER ST NW Type: Dist.

Collection Date: 2/24/2014 Collection Time: 11:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.082 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-039

SAMPLE INFORMATION

Sample Number: 1403012-039 Customer Sample Number: 3077795 Project: LCR
Location: 1st draw 2904 P ST SE Type: Dist.

Collection Date: 2/25/2014 Collection Time: 5:04 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.036 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-040

SAMPLE INFORMATION

Sample Number: 1403012-040 Customer Sample Number: 3077795 Project: LCR
Location: 2nd draw 2904 P ST SE Type: Dist.

Collection Date: 2/25/2014 Collection Time: 5:07 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-041

SAMPLE INFORMATION

Sample Number: 1403012-041 Customer Sample Number: 3070403 Project: LCR
Location: 1st draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.030 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-042

SAMPLE INFORMATION

Sample Number: 1403012-042 Customer Sample Number: 3070403 Project: LCR
Location: 2nd draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.037 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-043

SAMPLE INFORMATION

Sample Number: 1403012-043 Customer Sample Number: 3117544 Project: LCR
Location: 1st draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 5:53 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.194 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403012-044

SAMPLE INFORMATION

Sample Number: 1403012-044 Customer Sample Number: 3117544 Project: LCR
Location: 2nd draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 5:55 Sampler: HOME OWNER Received Date and Time: 3/4/2014 2:15:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.185 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-001

SAMPLE INFORMATION

Sample Number: 1403030-001 Customer Sample Number: 3108722 Project: LCR
Location: 1st draw 4120 GRANT ST NE Type: Dist.

Collection Date: 3/5/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.032 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-002

SAMPLE INFORMATION

Sample Number: 1403030-002 Customer Sample Number: 3055284 Project: LCR
Location: 1st draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.076 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-003

SAMPLE INFORMATION

Sample Number: 1403030-003 Customer Sample Number: 3055284 Project: LCR
Location: 2nd draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.059 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-004

SAMPLE INFORMATION

Sample Number: 1403030-004 Customer Sample Number: 3107489 Project: LCR
Location: 1st draw 2832 BRENTWOOD RD NE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.059 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.039 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-005

SAMPLE INFORMATION

Sample Number: 1403030-005 Customer Sample Number: 3107489 Project: LCR
Location: 2nd draw 2832 BRENTWOOD RD NE Type: Dist.

Collection Date: 2/26/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.086 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-006

SAMPLE INFORMATION

Sample Number: 1403030-006 Customer Sample Number: 3107442 Project: LCR
Location: 1st draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 2/25/2014 Collection Time: 15:07 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.042 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.058 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-007

SAMPLE INFORMATION

Sample Number: 1403030-007 Customer Sample Number: 3107442 Project: LCR
Location: 2nd draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 2/25/2014 Collection Time: 15:08 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.064 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-008

SAMPLE INFORMATION

Sample Number: 1403030-008 Customer Sample Number: 3043835 Project: LCR
Location: 1st draw 4627 49TH ST NW Type: Dist.

Collection Date: 2/27/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.033 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-009

SAMPLE INFORMATION

Sample Number: 1403030-009 Customer Sample Number: 3043835 Project: LCR
Location: 2nd draw 4627 49TH ST NW Type: Dist.

Collection Date: 2/27/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.028 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.037 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-010

SAMPLE INFORMATION

Sample Number: 1403030-010 Customer Sample Number: 3021575 Project: LCR
Location: 1st draw 4401 5TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 7:06 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.056 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-011

SAMPLE INFORMATION

Sample Number: 1403030-011 Customer Sample Number: 3021575 Project: LCR
Location: 2nd draw 4401 5TH ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.035 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-012

SAMPLE INFORMATION

Sample Number: 1403030-012 Customer Sample Number: 3052487 Project: LCR
Location: 1st draw 450 NEWTON PL NW Type: Dist.

Collection Date: 3/2/2014 Collection Time: 12:00 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.041 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-013

SAMPLE INFORMATION

Sample Number: 1403030-013 Customer Sample Number: 3052487 Project: LCR
Location: 2nd draw 450 NEWTON PL NW Type: Dist.

Collection Date: 3/2/2014 Collection Time: 12:00 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.057 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0036 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-014

SAMPLE INFORMATION

Sample Number: 1403030-014 Customer Sample Number: 3010741 Project: LCR
Location: 1st draw 3727 T ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.060 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-015

SAMPLE INFORMATION

Sample Number: 1403030-015 Customer Sample Number: 3010741 Project: LCR
Location: 2nd draw 3727 T ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 7:32 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.090 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0043 mg/L	3/28/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-016

SAMPLE INFORMATION

Sample Number: 1403030-016 Customer Sample Number: 3042399 Project: LCR
Location: 1st draw 4131 YUMA ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 3:30 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403030-017

SAMPLE INFORMATION

Sample Number: 1403030-017 Customer Sample Number: 3042399 Project: LCR
Location: 2nd draw 4131 YUMA ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 3:35 Sampler: HOME OWNER Received Date and Time: 3/6/2014 10:52:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	3/28/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	3/28/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0038 mg/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

3/31/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-001

SAMPLE INFORMATION

Sample Number: 1404003-001 Customer Sample Number: 3023353 Project: LCR
Location: 1st draw 421 HAMILTON ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 7:06 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.923 mg/L	4/11/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.047 mg/L	4/11/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	4/11/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-002

SAMPLE INFORMATION

Sample Number: 1404003-002 Customer Sample Number: 3023353 Project: LCR
Location: 2nd draw 421 HAMILTON ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 7:09 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.051 mg/L	4/11/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	4/11/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0023 mg/L	4/11/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-003

SAMPLE INFORMATION

Sample Number: 1404003-003 Customer Sample Number: 3056944 Project: LCR
Location: 1st draw 621 UPSHUR ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/11/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.055 mg/L	4/11/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/11/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-004

SAMPLE INFORMATION

Sample Number: 1404003-004 Customer Sample Number: 3056944 Project: LCR
Location: 2nd draw 621 UPSHUR ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 5:33 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/11/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	4/11/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/11/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-005

SAMPLE INFORMATION

Sample Number: 1404003-005 Customer Sample Number: 3087203 Project: LCR
Location: 1st draw 1319 POTOMAC AVE SE Type: Dist.

Collection Date: 3/26/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/11/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	4/11/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	4/11/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-006

SAMPLE INFORMATION

Sample Number: 1404003-006 Customer Sample Number: 3087203 Project: LCR
Location: 2nd draw 1319 POTOMAC AVE SE Type: Dist.

Collection Date: 3/26/2014 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/11/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	4/11/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/11/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-007

SAMPLE INFORMATION

Sample Number: 1404003-007 Customer Sample Number: 3049889 Project: LCR
Location: 1st draw 1222 HAMILTON ST NW Type: Dist.

Collection Date: 3/25/2014 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.025 mg/L	4/11/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	4/11/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0031 mg/L	4/11/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-008

SAMPLE INFORMATION

Sample Number: 1404003-008 Customer Sample Number: 3049889 Project: LCR
Location: 2nd draw 1222 HAMILTON ST NW Type: Dist.

Collection Date: 3/25/2014 Collection Time: 8:05 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-009

SAMPLE INFORMATION

Sample Number: 1404003-009 Customer Sample Number: 3030408 Project: LCR
Location: 1st draw 1412 SHEPHERD ST NW Type: Dist.

Collection Date: 3/25/2014 Collection Time: 18:10 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.184 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0027 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-010

SAMPLE INFORMATION

Sample Number: 1404003-010 Customer Sample Number: 3030408 Project: LCR
Location: 2nd draw 1412 SHEPHERD ST NW Type: Dist.

Collection Date: 3/25/2014 Collection Time: 18:11 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.115 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-011

SAMPLE INFORMATION

Sample Number: 1404003-011 Customer Sample Number: 3092716 Project: LCR
Location: 1st draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 3/25/2014 Collection Time: 7:58 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.025 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.096 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-012

SAMPLE INFORMATION

Sample Number: 1404003-012 Customer Sample Number: 3092716 Project: LCR
Location: 2nd draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 3/25/2014 Collection Time: 7:59 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.032 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.059 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0047 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-013

SAMPLE INFORMATION

Sample Number: 1404003-013 Customer Sample Number: 3026837 Project: LCR
Location: 1st draw 6210 8TH ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 5:09 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.133 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-014

SAMPLE INFORMATION

Sample Number: 1404003-014 Customer Sample Number: 3023837 Project: LCR
Location: 2nd draw 6210 8TH ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 5:12 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.086 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-015

SAMPLE INFORMATION

Sample Number: 1404003-015 Customer Sample Number: 3022524 Project: LCR
Location: 1st draw 912 EMERSON ST. NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 3:15 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-016

SAMPLE INFORMATION

Sample Number: 1404003-016 Customer Sample Number: 3022524 Project: LCR
Location: 2nd draw 912 EMERSON ST. NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 3:20 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-017

SAMPLE INFORMATION

Sample Number: 1404003-017 Customer Sample Number: 3120431 Project: LCR
Location: 1st draw 913 HAMLIN ST NE Type: Dist.

Collection Date: 3/25/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-018

SAMPLE INFORMATION

Sample Number: 1404003-018 Customer Sample Number: 3120431 Project: LCR
Location: 2nd draw 913 HAMLIN ST NE Type: Dist.

Collection Date: 3/25/2014 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-019

SAMPLE INFORMATION

Sample Number: 1404003-019 Customer Sample Number: 3099778 Project: LCR
Location: 1st draw 619 12TH ST NE Type: Dist.

Collection Date: 3/26/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-020

SAMPLE INFORMATION

Sample Number: 1404003-020 Customer Sample Number: 3099778 Project: LCR
Location: 2nd draw 619 12TH ST NE Type: Dist.

Collection Date: 3/26/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-021

SAMPLE INFORMATION

Sample Number: 1404003-021 Customer Sample Number: 3038936 Project: LCR
Location: 1st draw 5923 33RD ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.175 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-022

SAMPLE INFORMATION

Sample Number: 1404003-022 Customer Sample Number: 3038936 Project: LCR
Location: 2nd draw 5923 33RD ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.028 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.151 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-023

SAMPLE INFORMATION

Sample Number: 1404003-023 Customer Sample Number: 3037853 Project: LCR
Location: 1st draw 6209 30TH ST NW Type: Dist.

Collection Date: 3/29/2014 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.037 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.027 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-024

SAMPLE INFORMATION

Sample Number: 1404003-024 Customer Sample Number: 3037853 Project: LCR
Location: 2nd draw 6209 30TH ST NW Type: Dist.

Collection Date: 3/29/2014 Collection Time: 6:38 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-025

SAMPLE INFORMATION

Sample Number: 1404003-025 Customer Sample Number: 3055102 Project: LCR
Location: 1st draw 3030 44TH ST NW Type: Dist.

Collection Date: 3/27/2014 Collection Time: 6:01 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.029 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.065 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-026

SAMPLE INFORMATION

Sample Number: 1404003-026 Customer Sample Number: 3055102 Project: LCR
Location: 2nd draw 3030 44TH ST NW Type: Dist.

Collection Date: 3/27/2014 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.108 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0228 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-027

SAMPLE INFORMATION

Sample Number: 1404003-027 Customer Sample Number: 3073488 Project: LCR
Location: 1st draw 702 9TH ST SE Type: Dist.

Collection Date: 3/25/2014 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-028

SAMPLE INFORMATION

Sample Number: 1404003-028 Customer Sample Number: 3073488 Project: LCR
Location: 2nd draw 702 9TH ST SE Type: Dist.

Collection Date: 3/25/2014 Collection Time: 15:15 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0056 mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-029

SAMPLE INFORMATION

Sample Number: 1404003-029 Customer Sample Number: 3008069 Project: LCR
Location: 1st draw 3036 P ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.064 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-030

SAMPLE INFORMATION

Sample Number: 1404003-030 Customer Sample Number: 3008069 Project: LCR
Location: 2nd draw 3036 P ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 8:11 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-031

SAMPLE INFORMATION

Sample Number: 1404003-031 Customer Sample Number: 3092217 Project: LCR
Location: 1st draw 8 N ST SW Type: Dist.

Collection Date: 3/25/2014 Collection Time: 20:31 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.113 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-032

SAMPLE INFORMATION

Sample Number: 1404003-032 Customer Sample Number: 3092217 Project: LCR
Location: 2nd draw 8 N ST SW Type: Dist.

Collection Date: 3/25/2014 Collection Time: 20:33 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0044 mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-033

SAMPLE INFORMATION

Sample Number: 1404003-033 Customer Sample Number: 3026885 Project: LCR
Location: 1st draw 6308 8TH ST NW Type: Dist.

Collection Date: 3/27/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.044 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.049 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-034

SAMPLE INFORMATION

Sample Number: 1404003-034 Customer Sample Number: 3026885 Project: LCR
Location: 2nd draw 6308 8TH ST NW Type: Dist.

Collection Date: 3/27/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.058 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-035

SAMPLE INFORMATION

Sample Number: 1404003-035 Customer Sample Number: 3103161 Project: LCR
Location: 1st draw 2408 2ND ST NE Type: Dist.

Collection Date: 3/24/2014 Collection Time: 22:26 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-036

SAMPLE INFORMATION

Sample Number: 1404003-036 Customer Sample Number: 3103161 Project: LCR
Location: 2nd draw 2408 2ND ST NE Type: Dist.

Collection Date: 3/24/2014 Collection Time: 22:28 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.051 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-037

SAMPLE INFORMATION

Sample Number: 1404003-037 Customer Sample Number: 3022011 Project: LCR
Location: 1st draw 807 BUCHANAN ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 7:19 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	4/7/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

4/22/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-038

SAMPLE INFORMATION

Sample Number: 1404003-038 Customer Sample Number: 3022011 Project: LCR
Location: 2nd draw 807 BUCHANAN ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 7:22 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0035 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-039

SAMPLE INFORMATION

Sample Number: 1404003-039 Customer Sample Number: 3127230 Project: LCR
Location: 1st draw 617 6TH ST NE Type: Dist.

Collection Date: 3/26/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-040

SAMPLE INFORMATION

Sample Number: 1404003-040 Customer Sample Number: 3127230 Project: LCR
Location: 2nd draw 617 6TH ST NE Type: Dist.

Collection Date: 3/26/2014 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-041

SAMPLE INFORMATION

Sample Number: 1404003-041 Customer Sample Number: 3073211 Project: LCR
Location: 1st draw 308 9TH ST SE Type: Dist.

Collection Date: 3/24/2014 Collection Time: 17:59 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.036 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404003-042

SAMPLE INFORMATION

Sample Number: 1404003-042 Customer Sample Number: 3073211 Project: LCR
Location: 2nd draw 308 9TH ST SE Type: Dist.

Collection Date: 3/24/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:24:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.055 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404016-001

SAMPLE INFORMATION

Sample Number: 1404016-001 Customer Sample Number: 3009912 Project: LCR
Location: 1st draw 2007 37TH ST NW Type: Dist.

Collection Date: 3/31/2014 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 4/2/2014 11:51:22 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	4/8/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.092 mg/L	4/8/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/8/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404016-002

SAMPLE INFORMATION

Sample Number: 1404016-002 Customer Sample Number: 3009912 Project: LCR
Location: 2nd draw 2007 37TH ST NW Type: Dist.

Collection Date: 3/31/2014 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 4/2/2014 11:51:22 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	4/8/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	4/8/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/8/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404038-001

SAMPLE INFORMATION

Sample Number: 1404038-001 Customer Sample Number: 3106057 Project: LCR
Location: 1st draw 1808 KEARNY ST NE Type: Dist.

Collection Date: 3/28/2014 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 4/3/2014 3:49:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.036 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.092 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404038-002

SAMPLE INFORMATION

Sample Number: 1404038-002 Customer Sample Number: 3103057 Project: LCR
Location: 2nd draw 1808 KEARNY ST NE Type: Dist.

Collection Date: 3/28/2014 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 4/3/2014 3:49:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.066 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404038-003

SAMPLE INFORMATION

Sample Number: 1404038-003 Customer Sample Number: 3035494 Project: LCR
Location: 1st draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 3/28/2014 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 4/3/2014 3:49:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.087 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404038-004

SAMPLE INFORMATION

Sample Number: 1404038-004 Customer Sample Number: 3035494 Project: LCR
Location: 2nd draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 3/28/2014 Collection Time: 7:46 Sampler: HOME OWNER Received Date and Time: 4/3/2014 3:49:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	4/7/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	4/7/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/7/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404078-001

SAMPLE INFORMATION

Sample Number: 1404078-001 Customer Sample Number: 3002478 Project: LCR
Location: 1st draw 1436 S ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 5:58 Sampler: HOME OWNER Received Date and Time: 4/8/2014 4:22:08 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.031 mg/L	4/11/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.145 mg/L	4/11/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	4/11/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404078-002

SAMPLE INFORMATION

Sample Number: 1404078-002 Customer Sample Number: 3002478 Project: LCR
Location: 2nd draw 1436 S ST NW Type: Dist.

Collection Date: 3/26/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 4/8/2014 4:22:08 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	4/11/2014	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.111 mg/L	4/11/2014	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	4/11/2014	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-001

SAMPLE INFORMATION

Sample Number: 1405032-001 Customer Sample Number: 3037207 Project: LCR
Location: 1st draw 3218 MORRISON ST NW Type: Dist.

Collection Date: 4/30/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.045 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0003 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-002

SAMPLE INFORMATION

Sample Number: 1405032-002 Customer Sample Number: 3037207 Project: LCR
Location: 2nd draw 3218 MORRISON ST NW Type: Dist.

Collection Date: 4/30/2014 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.007 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-003

SAMPLE INFORMATION

Sample Number: 1405032-003 Customer Sample Number: 3022580 Project: LCR
Location: 1st draw 4818 8TH ST NW Type: Dist.

Collection Date: 4/29/2014 Collection Time: 18:10 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.056 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-004

SAMPLE INFORMATION

Sample Number: 1405032-004 Customer Sample Number: 3022580 Project: LCR
Location: 2nd draw 4818 8TH ST NW Type: Dist.

Collection Date: 4/29/2014 Collection Time: 18:14 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.033 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0006 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-005

SAMPLE INFORMATION

Sample Number: 1405032-005 Customer Sample Number: 3039888 Project: LCR
Location: 1st draw 5301 RENO RD NW Type: Dist.

Collection Date: 4/30/2014 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.031 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0005 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-006

SAMPLE INFORMATION

Sample Number: 1405032-006 Customer Sample Number: 3039888 Project: LCR
Location: 2nd draw 5301 RENO RD NW Type: Dist.

Collection Date: 4/30/2014 Collection Time: 7:06 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.013 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0008 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-007

SAMPLE INFORMATION

Sample Number: 1405032-007 Customer Sample Number: 3020687 Project: LCR
Location: 1st draw 3917 8TH ST NW Type: Dist.

Collection Date: 5/1/2014 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.077 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	5/21/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/28/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-008

SAMPLE INFORMATION

Sample Number: 1405032-008 Customer Sample Number: 3020687 Project: LCR
Location: 2nd draw 3917 8TH ST NW Type: Dist.

Collection Date: 5/1/2014 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.038 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0003 mg/L	5/21/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/28/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-009

SAMPLE INFORMATION

Sample Number: 1405032-009 Customer Sample Number: 3020685 Project: LCR
Location: 1st draw 3913 8TH ST NW Type: Dist.

Collection Date: 4/29/2014 Collection Time: 19:44 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.636 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.014 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-010

SAMPLE INFORMATION

Sample Number: 1405032-010 Customer Sample Number: 3020685 Project: LCR
Location: 2nd draw 3913 8TH ST NW Type: Dist.

Collection Date: 4/29/2014 Collection Time: 19:48 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.077 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.009 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-011

SAMPLE INFORMATION

Sample Number: 1405032-011 Customer Sample Number: 3006813 Project: LCR
Location: 1st draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 4/30/2014 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.725 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.203 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0066 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-012

SAMPLE INFORMATION

Sample Number: 1405032-012 Customer Sample Number: 3006813 Project: LCR
Location: 2nd draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 4/30/2014 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.047 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-013

SAMPLE INFORMATION

Sample Number: 1405032-013 Customer Sample Number: 3122315 Project: LCR
Location: 1st draw 322 TENNESSEE AVE NE Type: Dist.

Collection Date: 4/30/2014 Collection Time: 4:39 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.024 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.008 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0005 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-014

SAMPLE INFORMATION

Sample Number: 1405032-014 Customer Sample Number: 3041213 Project: LCR
Location: 1st draw 3809 ALTON PL NW Type: Dist.

Collection Date: 4/30/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.029 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-015

SAMPLE INFORMATION

Sample Number: 1405032-015 Customer Sample Number: 3041213 Project: LCR
Location: 2nd draw 3809 ALTON PL NW Type: Dist.

Collection Date: 4/30/2014 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.018 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0005 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-016

SAMPLE INFORMATION

Sample Number: 1405032-016 Customer Sample Number: 3097777 Project: LCR
Location: 1st draw 231 K ST NE Type: Dist.

Collection Date: 4/29/2014 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.033 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-017

SAMPLE INFORMATION

Sample Number: 1405032-017 Customer Sample Number: 3097777 Project: LCR
Location: 2nd draw 231 K ST NE Type: Dist.

Collection Date: 4/29/2014 Collection Time: 6:51 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.013 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-018

SAMPLE INFORMATION

Sample Number: 1405032-018 Customer Sample Number: 3099025 Project: LCR
Location: 1st draw 1010 10TH ST NE Type: Dist.

Collection Date: 4/30/2014 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.012 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.027 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0002 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-019

SAMPLE INFORMATION

Sample Number: 1405032-019 Customer Sample Number: 3099025 Project: LCR
Location: 2nd draw 1010 10TH ST NE Type: Dist.

Collection Date: 4/30/2014 Collection Time: 5:22 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.013 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-020

SAMPLE INFORMATION

Sample Number: 1405032-020 Customer Sample Number: 3103403 Project: LCR
Location: 1st draw 3416 9TH ST NE Type: Dist.

Collection Date: 4/29/2014 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.003 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	5/21/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/28/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-021

SAMPLE INFORMATION

Sample Number: 1405032-021 Customer Sample Number: 3103403 Project: LCR
Location: 2nd draw 3416 9TH ST NE Type: Dist.

Collection Date: 4/29/2014 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.003 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-022

SAMPLE INFORMATION

Sample Number: 1405032-022 Customer Sample Number: 3041124 Project: LCR
Location: 1st draw 4215 39TH ST NW Type: Dist.

Collection Date: 4/28/2014 Collection Time: 19:45 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.041 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.076 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0012 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-023

SAMPLE INFORMATION

Sample Number: 1405032-023 Customer Sample Number: 3041124 Project: LCR
Location: 2nd draw 4215 39TH ST NW Type: Dist.

Collection Date: 4/28/2014 Collection Time: 19:50 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.112 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.025 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0020 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-024

SAMPLE INFORMATION

Sample Number: 1405032-024 Customer Sample Number: 3108541 Project: LCR
Location: 1st draw 333 34TH ST NE Type: Dist.

Collection Date: 4/30/2014 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.026 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.033 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0005 mg/L	5/21/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/28/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-025

SAMPLE INFORMATION

Sample Number: 1405032-025 Customer Sample Number: 3108541 Project: LCR
Location: 2nd draw 333 34TH ST NE Type: Dist.

Collection Date: 4/30/2014 Collection Time: 6:18 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.021 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.025 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0003 mg/L	5/21/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/28/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-026

SAMPLE INFORMATION

Sample Number: 1405032-026 Customer Sample Number: 3072261 Project: LCR
Location: 1st draw 413 4TH ST SE Type: Dist.

Collection Date: 4/30/2014 Collection Time: 5:55 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.024 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405032-027

SAMPLE INFORMATION

Sample Number: 1405032-027 Customer Sample Number: 3072261 Project: LCR
Location: 2nd draw 413 4TH ST SE Type: Dist.

Collection Date: 4/30/2014 Collection Time: 5:57 Sampler: HOME OWNER Received Date and Time: 5/6/2014 10:26:29 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.018 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	5/21/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/28/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405071-001

SAMPLE INFORMATION

Sample Number: 1405071-001 Customer Sample Number: 3039963 Project: LCR
Location: 1st Draw 5404 39TH ST NW Type: Dist.

Collection Date: 4/29/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:16:24 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.067 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.037 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0024 mg/L	5/21/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

5/28/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/28/2014
Report Number: LC-W1405071-002

SAMPLE INFORMATION

Sample Number: 1405071-002 Customer Sample Number: 3039963 Project: LCR
Location: 2nd Draw 5404 39TH ST NW Type: Dist.

Collection Date: 4/29/2014 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:16:24 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.035 mg/L	5/21/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.023 mg/L	5/21/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0010 mg/L	5/21/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405088-001

SAMPLE INFORMATION

Sample Number: 1405088-001 Customer Sample Number: 3029267 Project: LCR
Location: 1st draw 3907 13TH ST NW Type: Dist.

Collection Date: 5/6/2014 Collection Time: 18:47 Sampler: HOME OWNER Received Date and Time: 5/13/2014 9:04:33 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.013 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.117 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0007 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405088-002

SAMPLE INFORMATION

Sample Number: 1405088-002 Customer Sample Number: 3029267 Project: LCR
Location: 2nd draw 3907 13TH ST NW Type: Dist.

Collection Date: 5/6/2014 Collection Time: 18:49 Sampler: HOME OWNER Received Date and Time: 5/13/2014 9:04:33 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.013 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.076 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0003 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-001

SAMPLE INFORMATION

Sample Number: 1405200-001 Customer Sample Number: 3049851 Project: LCR
Location: 1st draw 5007 13TH ST NW Type: Dist.

Collection Date: 5/20/2014 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.030 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0005 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-002

SAMPLE INFORMATION

Sample Number: 1405200-002 Customer Sample Number: 3049851 Project: LCR
Location: 2nd draw 5007 13TH ST NW Type: Dist.

Collection Date: 5/20/2014 Collection Time: 17:05 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.005 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0015 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-003

SAMPLE INFORMATION

Sample Number: 1405200-003 Customer Sample Number: 3082792 Project: LCR
Location: 1st draw 412 BRANDYWINE ST SE Type: Dist.

Collection Date: 5/21/2014 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.056 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.008 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0005 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-004

SAMPLE INFORMATION

Sample Number: 1405200-004 Customer Sample Number: 3082792 Project: LCR
Location: 2nd draw 412 BRANDYWINE ST SE Type: Dist.

Collection Date: 5/21/2014 Collection Time: 20:01 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.026 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.005 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-005

SAMPLE INFORMATION

Sample Number: 1405200-005 Customer Sample Number: 3105267 Project: LCR
Location: 1st draw 1715 IRVING ST NE Type: Dist.

Collection Date: 5/20/2014 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.101 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.027 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0011 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-006

SAMPLE INFORMATION

Sample Number: 1405200-006 Customer Sample Number: 3105267 Project: LCR
Location: 2nd draw 1715 IRVING ST NE Type: Dist.

Collection Date: 5/20/2014 Collection Time: 7:26 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.018 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.021 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0014 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-007

SAMPLE INFORMATION

Sample Number: 1405200-007 Customer Sample Number: 3073239 Project: LCR
Location: 1st draw 313 10TH ST SE Type: Dist.

Collection Date: 5/23/2014 Collection Time: 1:40 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.030 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0002 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-008

SAMPLE INFORMATION

Sample Number: 1405200-008 Customer Sample Number: 3073239 Project: LCR
Location: 2nd draw 313 10TH ST SE Type: Dist.

Collection Date: 5/23/2014 Collection Time: 1:41 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.012 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	5/30/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/10/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-009

SAMPLE INFORMATION

Sample Number: 1405200-009 Customer Sample Number: 3078121 Project: LCR
Location: 1st draw 1911 P ST SE Type: Dist.

Collection Date: 5/22/2014 Collection Time: 4:10 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.013 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0010 mg/L	5/30/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/10/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405200-010

SAMPLE INFORMATION

Sample Number: 1405200-010 Customer Sample Number: 3078121 Project: LCR
Location: 2nd draw 1911 P ST SE Type: Dist.

Collection Date: 5/22/2014 Collection Time: 4:11 Sampler: HOME OWNER Received Date and Time: 5/27/2014 12:03:40 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.009 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0016 mg/L	5/30/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/10/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405211-001

SAMPLE INFORMATION

Sample Number: 1405211-001 Customer Sample Number: 3103096 Project: LCR
Location: 1st draw 2121 3RD ST NE Type: Dist.

Collection Date: 5/21/2014 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 5/28/2014 11:02:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.029 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0010 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405211-002

SAMPLE INFORMATION

Sample Number: 1405211-002 Customer Sample Number: 3103096 Project: LCR
Location: 2nd draw 2121 3RD ST NE Type: Dist.

Collection Date: 5/21/2014 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 5/28/2014 11:02:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.034 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0009 mg/L	5/30/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/10/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405211-003

SAMPLE INFORMATION

Sample Number: 1405211-003 Customer Sample Number: 3078615 Project: LCR
Location: 1st draw 1508 GOOD HOPE RD SE Type: Dist.

Collection Date: 5/21/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 5/28/2014 11:02:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.053 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.039 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0022 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/10/2014
Report Number: LC-W1405211-004

SAMPLE INFORMATION

Sample Number: 1405211-004 Customer Sample Number: 3078615 Project: LCR
Location: 2nd draw 1508 GOOD HOPE RD SE Type: Dist.

Collection Date: 5/21/2014 Collection Time: 18:03 Sampler: HOME OWNER Received Date and Time: 5/28/2014 11:02:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.048 mg/L	5/30/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.020 mg/L	5/30/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0025 mg/L	5/30/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/10/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-001

SAMPLE INFORMATION

Sample Number: 1406038-001 Customer Sample Number: 3048790 Project: LCR
Location: 1st draw 6205 14TH ST NW Type: Dist.

Collection Date: 6/3/2014 Collection Time: 7:14 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.129 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.022 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0016 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-002

SAMPLE INFORMATION

Sample Number: 1406038-002 Customer Sample Number: 3048790 Project: LCR
Location: 2nd draw 6205 14TH ST NW Type: Dist.

Collection Date: 6/3/2014 Collection Time: 7:17 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.010 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0018 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-003

SAMPLE INFORMATION

Sample Number: 1406038-003 Customer Sample Number: 3072035 Project: LCR
Location: 1st draw 522 4TH ST SE Type: Dist.

Collection Date: 6/3/2014 Collection Time: 6:57 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.014 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0002 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-004

SAMPLE INFORMATION

Sample Number: 1406038-004 Customer Sample Number: 3072035 Project: LCR
Location: 2nd draw 522 4TH ST SE Type: Dist.

Collection Date: 6/3/2014 Collection Time: 6:58 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.025 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.006 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-005

SAMPLE INFORMATION

Sample Number: 1406038-005 Customer Sample Number: 3127684 Project: LCR
Location: 1st draw 414 G ST NE Type: Dist.

Collection Date: 6/3/2014 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.071 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.013 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-006

SAMPLE INFORMATION

Sample Number: 1406038-006 Customer Sample Number: 3127684 Project: LCR
Location: 2nd draw 414 G ST NE Type: Dist.

Collection Date: 6/3/2014 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.037 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.008 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	6/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-007

SAMPLE INFORMATION

Sample Number: 1406038-007 Customer Sample Number: 3086628 Project: LCR
Location: 1st draw 502 A ST SE Type: Dist.

Collection Date: 6/4/2014 Collection Time: 0:45 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.133 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0003 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-008

SAMPLE INFORMATION

Sample Number: 1406038-008 Customer Sample Number: 3086628 Project: LCR
Location: 2nd draw 502 A ST SE Type: Dist.

Collection Date: 6/4/2014 Collection Time: 0:50 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.042 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.020 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-009

SAMPLE INFORMATION

Sample Number: 1406038-009 Customer Sample Number: 3102110 Project: LCR
Location: 1st draw 1113 STAPLES ST NE Type: Dist.

Collection Date: 6/4/2014 Collection Time: 5:08 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.155 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.005 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0018 mg/L	6/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-010

SAMPLE INFORMATION

Sample Number: 1406038-010 Customer Sample Number: 3102110 Project: LCR
Location: 2nd draw 1113 STAPLES ST NE Type: Dist.

Collection Date: 6/4/2014 Collection Time: 5:11 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.013 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.005 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0031 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-011

Report revised on 6/18/14 by MC.
For Lab Sample Number 1406038-011, the address was changed from 749 9th St SE to 744 9th St SE as reported on the chain of custody.

SAMPLE INFORMATION

Sample Number: 1406038-011 Customer Sample Number: 3073506 Project: LCR
Location: 1st draw 744 9TH ST SE Type: Dist.

Collection Date: 6/4/2014 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.014 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0002 mg/L	6/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/18/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-012

Report revised on 6/18/14 by MC.
For Lab Sample Number 1406038-012, the address was changed from 749 9th St SE to 744 9th St SE as reported on the chain of custody.

SAMPLE INFORMATION

Sample Number: 1406038-012 Customer Sample Number: 3073506 Project: LCR
Location: 2nd draw 744 9TH ST SE Type: Dist.

Collection Date: 6/4/2014 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.009 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	< 0.0002 mg/L	6/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/18/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-013

SAMPLE INFORMATION

Sample Number: 1406038-013 Customer Sample Number: 3051648 Project: LCR
Location: 1st draw 5223 KANSAS AVE NW Type: Dist.

Collection Date: 6/3/2014 Collection Time: 11:50 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.030 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.048 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0015 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-014

SAMPLE INFORMATION

Sample Number: 1406038-014 Customer Sample Number: 3051648 Project: LCR
Location: 2nd draw 5223 KANSAS AVE NW Type: Dist.

Collection Date: 6/3/2014 Collection Time: 11:51 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.037 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.015 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0103 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-015

SAMPLE INFORMATION

Sample Number: 1406038-015 Customer Sample Number: 3010135 Project: LCR
Location: 1st draw 3761 W ST NW Type: Dist.

Collection Date: 6/3/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.004 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0009 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406038-016

SAMPLE INFORMATION

Sample Number: 1406038-016 Customer Sample Number: 3010135 Project: LCR
Location: 2nd draw 3761 W ST NW Type: Dist.

Collection Date: 6/3/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 6/5/2014 2:27:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.003 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0009 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406045-001

SAMPLE INFORMATION

Sample Number: 1406045-001 Customer Sample Number: 3073669 Project: LCR
Location: 1st Draw 1020 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 6/2/2014 Collection Time: 17:15 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:12:08 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.025 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0007 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406045-002

SAMPLE INFORMATION

Sample Number: 1406045-002 Customer Sample Number: 3073669 Project: LCR
Location: 2nd Draw 1020 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 6/2/2014 Collection Time: 17:15 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:12:08 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.006 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0048 mg/L	6/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406045-003

SAMPLE INFORMATION

Sample Number: 1406045-003 Customer Sample Number: 3038787 Project: LCR
Location: 1st Draw 3510 QUESADA ST NW Type: Dist.

Collection Date: 6/4/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:12:08 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.050 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0003 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406045-004

SAMPLE INFORMATION

Sample Number: 1406045-004 Customer Sample Number: 3038787 Project: LCR
Location: 2nd Draw 3510 QUESADA ST NW Type: Dist.

Collection Date: 6/4/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:12:08 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.007 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0002 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406045-005

SAMPLE INFORMATION

Sample Number: 1406045-005 Customer Sample Number: 3007718 Project: LCR
Location: 1st Draw 3033 CAMBRIDGE PL NW Type: Dist.

Collection Date: 6/4/2014 Collection Time: 22:00 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:12:08 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.015 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0004 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406045-006

SAMPLE INFORMATION

Sample Number: 1406045-006 Customer Sample Number: 3007718 Project: LCR
Location: 2nd Draw 3033 CAMBRIDGE PL NW Type: Dist.

Collection Date: 6/4/2014 Collection Time: 22:00 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:12:08 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	ND mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.008 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0003 mg/L	6/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406045-007

SAMPLE INFORMATION

Sample Number: 1406045-007 Customer Sample Number: 3041754 Project: LCR
Location: 1st Draw 3309 35TH ST NW Type: Dist.

Collection Date: 6/5/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:12:08 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.013 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.037 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0006 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406045-008

SAMPLE INFORMATION

Sample Number: 1406045-008 Customer Sample Number: 3041754 Project: LCR
Location: 2nd Draw 3309 35TH ST NW Type: Dist.

Collection Date: 6/5/2014 Collection Time: 5:32 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:12:08 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.021 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.010 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0010 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406057-001

SAMPLE INFORMATION

Sample Number: 1406057-001 Customer Sample Number: 3057130 Project: LCR
Location: 1st draw 120 VARNUM ST NW Type: Dist.

Collection Date: 6/3/2014 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 6/9/2014 11:28:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.039 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0017 mg/L	6/10/2014	RHoffa

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406057-002

SAMPLE INFORMATION

Sample Number: 1406057-002 Customer Sample Number: 3057130 Project: LCR
Location: 2nd draw 120 VARNUM ST NW Type: Dist.

Collection Date: 6/3/2014 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 6/9/2014 11:28:39 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	0.045 mg/L	6/10/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.014 mg/L	6/10/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0019 mg/L	6/10/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/11/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406139-001

SAMPLE INFORMATION

Sample Number: 1406139-001 Customer Sample Number: 3027830 Project: LCR
Location: 1st draw 4525 15TH ST NW Type: Dist.

Collection Date: 6/11/2014 Collection Time: 0:42 Sampler: HOME OWNER Received Date and Time: 6/17/2014 2:48:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/19/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.020 mg/L	6/19/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0019 mg/L	6/19/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/20/2014
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406139-002

SAMPLE INFORMATION

Sample Number: 1406139-002 Customer Sample Number: 3027830 Project: LCR
Location: 2nd draw 4525 15TH ST NW Type: Dist.

Collection Date: 6/11/2014 Collection Time: 0:45 Sampler: HOME OWNER Received Date and Time: 6/17/2014 2:48:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	0.9 ug/L	0.01 mg/L	< 0.01 mg/L	6/19/2014	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.03 ug/L	0.0002 mg/L	0.013 mg/L	6/19/2014	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.02 ug/L	0.0002 mg/L	0.0026 mg/L	6/19/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

6/20/2014
Date

Attachment 2

Other Addition Non-Regulated Monitoring Data

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312128-001

SAMPLE INFORMATION

Sample Number: 1312128-001 Customer Sample Number: 3124914 Program: DS
Location: 1st Draw 305 V ST NE Type: Dist.

Collection Date: 12/8/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 12/16/2013 8:59:10 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.2 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312128-002

SAMPLE INFORMATION

Sample Number: 1312128-002 Customer Sample Number: 3124914 Program: DS
Location: 2nd Draw 305 V ST NE Type: Dist.

Collection Date: 12/8/2013 Collection Time: 9:05 Sampler: HOME OWNER Received Date and Time: 12/16/2013 8:59:10 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312128-003

SAMPLE INFORMATION

Sample Number: 1312128-003 Customer Sample Number: 3023155 Program: DS
Location: 1st Draw 637 GALLATIN ST NW Type: Dist.

Collection Date: 12/9/2013 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 12/16/2013 8:59:10 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312128-004

SAMPLE INFORMATION

Sample Number: 1312128-004 Customer Sample Number: 3023155 Program: DS
Location: 2nd Draw 637 GALLATIN ST NW Type: Dist.

Collection Date: 12/9/2013 Collection Time: 7:48 Sampler: HOME OWNER Received Date and Time: 12/16/2013 8:59:10 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312128-005

SAMPLE INFORMATION

Sample Number: 1312128-005 Customer Sample Number: 3098638 Program: DS
Location: 1st Draw 1127 BUCHANAN ST NW Type: Dist.

Collection Date: 12/12/2013 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 12/16/2013 8:59:10 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312128-006

SAMPLE INFORMATION

Sample Number: 1312128-006 Customer Sample Number: 3098638 Program: DS
Location: 2nd Draw 1127 BUCHANAN ST NW Type: Dist.

Collection Date: 12/12/2013 Collection Time: 6:44 Sampler: HOME OWNER Received Date and Time: 12/16/2013 8:59:10 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312128-007

SAMPLE INFORMATION

Sample Number: 1312128-007 Customer Sample Number: 3035838 Program: DS
Location: 1st Draw 2756 WOODLEY PL NW Type: Dist.

Collection Date: 12/12/2013 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 12/16/2013 8:59:10 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312128-008

SAMPLE INFORMATION

Sample Number: 1312128-008 Customer Sample Number: 3035838 Program: DS
Location: 2nd Draw 2756 WOODLEY PL NW Type: Dist.

Collection Date: 12/12/2013 Collection Time: 8:33 Sampler: HOME OWNER Received Date and Time: 12/16/2013 8:59:10 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.6 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312187-001

SAMPLE INFORMATION

Sample Number: 1312187-001 Customer Sample Number: 3101913 Program: DS
Location: 1st draw 1765 LANG PL NE Type: Dist.

Collection Date: 12/20/2013 Collection Time: 7:07 Sampler: HOME OWNER Received Date and Time: 12/23/2013 8:27:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312187-002

SAMPLE INFORMATION

Sample Number: 1312187-002 Customer Sample Number: 3101913 Program: DS
Location: 2nd draw 1765 LANG PL NE Type: Dist.

Collection Date: 12/20/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 12/23/2013 8:27:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312187-003

SAMPLE INFORMATION

Sample Number: 1312187-003 Customer Sample Number: 3127437 Program: DS
Location: 1st draw 505 I ST NE Type: Dist.

Collection Date: 12/17/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 12/23/2013 8:27:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312217-001

SAMPLE INFORMATION

Sample Number: 1312217-001 Customer Sample Number: 3049391 Program: DS
Location: 1st draw 1322 LONGFELLOW ST., NW Type: Dist.

Collection Date: 12/21/2013 Collection Time: 8:08 Sampler: HOME OWNER Received Date and Time: 12/26/2013 11:22:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312217-002

SAMPLE INFORMATION

Sample Number: 1312217-002 Customer Sample Number: 3049391 Program: DS
Location: 2nd draw 1322 LONGFELLOW ST., NW Type: Dist.

Collection Date: 12/21/2013 Collection Time: 8:14 Sampler: HOME OWNER Received Date and Time: 12/26/2013 11:22:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312217-003

SAMPLE INFORMATION

Sample Number: 1312217-003 Customer Sample Number: 3062562 Program: DS250
Location: 1st draw 25 KENNEDY ST NW #106 Type: Dist.

Collection Date: 12/23/2013 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 12/26/2013 11:22:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312217-004

SAMPLE INFORMATION

Sample Number: 1312217-004 Customer Sample Number: 3062562 Program: DS250
Location: 2nd draw 25 KENNEDY ST NW #106 Type: Dist.

Collection Date: 12/23/2013 Collection Time: 7:42 Sampler: HOME OWNER Received Date and Time: 12/26/2013 11:22:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-001

SAMPLE INFORMATION

Sample Number: 1401020-001 Customer Sample Number: 3054642 Program: DS
Location: 1st Draw 1804 WYOMING AVE NW Type: Dist.

Collection Date: 12/24/2013 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-002

SAMPLE INFORMATION

Sample Number: 1401020-002 Customer Sample Number: 3054642 Program: DS
Location: 2nd Draw 1804 WYOMING AVE NW Type: Dist.

Collection Date: 12/24/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-003

SAMPLE INFORMATION

Sample Number: 1401020-003 Customer Sample Number: 3099760 Program: DS
Location: 1st Draw 1222 LINCOLN PL NE Type: Dist.

Collection Date: 12/29/2013 Collection Time: 10:00 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-004

SAMPLE INFORMATION

Sample Number: 1401020-004 Customer Sample Number: 3099760 Program: DS
Location: 2nd Draw 1222 LINCOLN PL NE Type: Dist.

Collection Date: 12/29/2013 Collection Time: 10:02 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-009

SAMPLE INFORMATION

Sample Number: 1401020-009 Customer Sample Number: 3044210 Program: DS
Location: 1st Draw 3114 45TH ST NW Type: Dist.

Collection Date: 12/31/2013 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.6 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-010

SAMPLE INFORMATION

Sample Number: 1401020-010 Customer Sample Number: 3044210 Program: DS
Location: 2nd Draw 3114 45TH ST NW Type: Dist.

Collection Date: 12/31/2013 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401060-003

SAMPLE INFORMATION

Sample Number: 1401060-003 Customer Sample Number: 3112472 Program: DS
Location: 1st draw 533 25TH PL NE Type: Dist.

Collection Date: 1/2/2014 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 1/9/2014 8:47:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401060-004

SAMPLE INFORMATION

Sample Number: 1401060-004 Customer Sample Number: 3112472 Program: DS
Location: 2nd draw 533 25TH PL NE Type: Dist.

Collection Date: 1/2/2014 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 1/9/2014 8:47:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401060-005

SAMPLE INFORMATION

Sample Number: 1401060-005 Customer Sample Number: 3074469 Program: DS
Location: 1st draw 1316 C STREET, SE Type: Dist.

Collection Date: 1/2/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 1/9/2014 8:47:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401060-006

SAMPLE INFORMATION

Sample Number: 1401060-006 Customer Sample Number: 3074469 Program: DS
Location: 2nd draw 1316 C STREET, SE Type: Dist.

Collection Date: 1/2/2014 Collection Time: 7:33 Sampler: HOME OWNER Received Date and Time: 1/9/2014 8:47:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401060-007

SAMPLE INFORMATION

Sample Number: 1401060-007 Customer Sample Number: 3003444 Program: DS
Location: 1st draw 2254 12TH ST NW Type: Dist.

Collection Date: 1/2/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 1/9/2014 8:47:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401060-008

SAMPLE INFORMATION

Sample Number: 1401060-008 Customer Sample Number: 3003444 Program: DS
Location: 2nd draw 2254 12TH ST NW Type: Dist.

Collection Date: 1/2/2014 Collection Time: 18:10 Sampler: HOME OWNER Received Date and Time: 1/9/2014 8:47:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	1/16/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-001

SAMPLE INFORMATION

Sample Number: 1401107-001 Customer Sample Number: 3127053 Program: DS
Location: 1st draw 919 6TH ST NE Type: Dist.

Collection Date: 1/5/2014 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-002

SAMPLE INFORMATION

Sample Number: 1401107-002 Customer Sample Number: 3127053 Program: DS
Location: 2nd draw 919 6TH ST NE Type: Dist.

Collection Date: 1/5/2014 Collection Time: 9:31 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-003

SAMPLE INFORMATION

Sample Number: 1401107-003 Customer Sample Number: 3141498 Program: DS
Location: 1st draw 3152 STANTON RD SE Type: Dist.

Collection Date: 1/6/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-004

SAMPLE INFORMATION

Sample Number: 1401107-004 Customer Sample Number: 3141498 Program: DS
Location: 2nd draw 3152 STANTON RD SE Type: Dist.

Collection Date: 1/6/2014 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-005

SAMPLE INFORMATION

Sample Number: 1401107-005 Customer Sample Number: 3106022 Program: DS
Location: 1st draw 1815 JACKSON ST NE Type: Dist.

Collection Date: 1/7/2014 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-006

SAMPLE INFORMATION

Sample Number: 1401107-006 Customer Sample Number: 3106022 Program: DS
Location: 2nd draw 1815 JACKSON ST NE Type: Dist.

Collection Date: 1/7/2014 Collection Time: 17:32 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.2 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-009

SAMPLE INFORMATION

Sample Number: 1401107-009 Customer Sample Number: 3052079 Program: DS
Location: 1st daw 37 V STREET NW Type: Dist.

Collection Date: 1/12/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-010

SAMPLE INFORMATION

Sample Number: 1401107-010 Customer Sample Number: 3052079 Program: DS
Location: 2nd draw 37 V STREET NW Type: Dist.

Collection Date: 1/12/2014 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.0 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401131-001

SAMPLE INFORMATION

Sample Number: 1401131-001 Customer Sample Number: 3073317 Program: DS
Location: 1st Draw 522 10TH ST SE Type: Dist.

Collection Date: 1/12/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 1/17/2014 9:34:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401131-002

SAMPLE INFORMATION

Sample Number: 1401131-002 Customer Sample Number: 3073317 Program: DS
Location: 2nd Draw 522 10TH ST SE Type: Dist.

Collection Date: 1/12/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 1/17/2014 9:34:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401131-003

SAMPLE INFORMATION

Sample Number: 1401131-003 Customer Sample Number: 3046755 Program: DS
Location: 1st Draw 800 FERN PL NW Type: Dist.

Collection Date: 1/14/2014 Collection Time: 19:40 Sampler: HOME OWNER Received Date and Time: 1/17/2014 9:34:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401131-004

SAMPLE INFORMATION

Sample Number: 1401131-004 Customer Sample Number: 3046755 Program: DS
Location: 2nd Draw 800 FERN PL NW Type: Dist.

Collection Date: 1/14/2014 Collection Time: 19:44 Sampler: HOME OWNER Received Date and Time: 1/17/2014 9:34:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.2 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401172-001

SAMPLE INFORMATION

Sample Number: 1401172-001 Customer Sample Number: 3120623 Program: DS
Location: 1st draw 906 KENT PL NE Type: Dist.

Collection Date: 1/14/2014 Collection Time: 18:09 Sampler: HOME OWNER Received Date and Time: 1/24/2014 9:48:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401172-002

SAMPLE INFORMATION

Sample Number: 1401172-002 Customer Sample Number: 3120623 Program: DS
Location: 2nd draw 906 KENT PL NE Type: Dist.

Collection Date: 1/14/2014 Collection Time: 18:11 Sampler: HOME OWNER Received Date and Time: 1/24/2014 9:48:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401172-003

SAMPLE INFORMATION

Sample Number: 1401172-003 Customer Sample Number: 3059275 Program: DS
Location: 1st draw 760 LAMONT ST NW Type: Dist.

Collection Date: 1/15/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 1/24/2014 9:48:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401172-004

SAMPLE INFORMATION

Sample Number: 1401172-004 Customer Sample Number: 3059275 Program: DS
Location: 2nd draw 760 LAMONT ST NW Type: Dist.

Collection Date: 1/15/2014 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 1/24/2014 9:48:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401172-005

SAMPLE INFORMATION

Sample Number: 1401172-005 Customer Sample Number: 3059589 Program: DS
Location: 1st draw 4220 45TH ST NW Type: Dist.

Collection Date: 1/16/2014 Collection Time: 9:31 Sampler: HOME OWNER Received Date and Time: 1/24/2014 9:48:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401172-006

SAMPLE INFORMATION

Sample Number: 1401172-006 Customer Sample Number: 3059589 Program: DS
Location: 2nd draw 4220 45TH ST NW Type: Dist.

Collection Date: 1/16/2014 Collection Time: 9:34 Sampler: HOME OWNER Received Date and Time: 1/24/2014 9:48:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	2/19/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401172-007

SAMPLE INFORMATION

Sample Number: 1401172-007 Customer Sample Number: 3025556 Program: DS
Location: 1st draw 5226 1ST ST NW Type: Dist.

Collection Date: 1/19/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 1/24/2014 9:48:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401172-008

SAMPLE INFORMATION

Sample Number: 1401172-008 Customer Sample Number: 3025556 Program: DS
Location: 2nd draw 5226 1ST ST NW Type: Dist.

Collection Date: 1/19/2014 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 1/24/2014 9:48:58 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401221-001

SAMPLE INFORMATION

Sample Number: 1401221-001 Customer Sample Number: 3047937 Program: DS
Location: 1st Draw 7511 13TH ST NW Type: Dist.

Collection Date: 1/24/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 1/31/2014 8:49:27 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401221-002

SAMPLE INFORMATION

Sample Number: 1401221-002 Customer Sample Number: 3047937 Program: DS
Location: 2nd Draw 7511 13TH ST NW Type: Dist.

Collection Date: 1/24/2014 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 1/31/2014 8:49:27 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401221-003

SAMPLE INFORMATION

Sample Number: 1401221-003 Customer Sample Number: 3019918 Program: DS
Location: 1st Draw 427 MANOR PL NW Type: Dist.

Collection Date: 1/26/2014 Collection Time: 9:36 Sampler: HOME OWNER Received Date and Time: 1/31/2014 8:49:27 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.0 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1401221-004

SAMPLE INFORMATION

Sample Number: 1401221-004 Customer Sample Number: 3019918 Program: DS
Location: 2nd Draw 427 MANOR PL NW Type: Dist.

Collection Date: 1/26/2014 Collection Time: 9:38 Sampler: HOME OWNER Received Date and Time: 1/31/2014 8:49:27 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.8 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1402043-001

SAMPLE INFORMATION

Sample Number: 1402043-001 Customer Sample Number: 3072380 Program: DS
Location: 1st Draw 419 7TH STREET, SE Type: Dist.

Collection Date: 2/1/2014 Collection Time: 6:38 Sampler: HOME OWNER Received Date and Time: 2/6/2014 9:17:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1402043-002

SAMPLE INFORMATION

Sample Number: 1402043-002 Customer Sample Number: 3072380 Program: DS
Location: 2nd Draw 419 7TH STREET, SE Type: Dist.

Collection Date: 2/1/2014 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 2/6/2014 9:17:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1402043-003

SAMPLE INFORMATION

Sample Number: 1402043-003 Customer Sample Number: Program: DS
Location: 1st Draw 4511 VERPLANCK PL NW Type: Dist.

Collection Date: 2/3/2014 Collection Time: 15:50 Sampler: HOME OWNER Received Date and Time: 2/6/2014 9:17:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1402043-004

SAMPLE INFORMATION

Sample Number: 1402043-004 Customer Sample Number: Program: DS
Location: 2nd Draw 4511 VERPLANCK PL NW Type: Dist.

Collection Date: 2/3/2014 Collection Time: 15:55 Sampler: HOME OWNER Received Date and Time: 2/6/2014 9:17:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1402043-005

SAMPLE INFORMATION

Sample Number: 1402043-005 Customer Sample Number: 3056911 Program: DS
Location: 1st Draw 4118 NEW HAMPSHIRE AVE NW Type: Dist.
Collection Date: 2/3/2014 Collection Time: 19:26 Sampler: HOME OWNER Received Date and Time: 2/6/2014 9:17:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.7 ug/L	2/19/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1402043-006

SAMPLE INFORMATION

Sample Number: 1402043-006 Customer Sample Number: 3056911 Program: DS
Location: 2nd Draw 4118 NEW HAMPSHIRE AVE NW Type: Dist.

Collection Date: 2/3/2014 Collection Time: 19:28 Sampler: HOME OWNER Received Date and Time: 2/6/2014 9:17:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1402043-007

SAMPLE INFORMATION

Sample Number: 1402043-007 Customer Sample Number: 3048131 Program: DS
Location: 1st Draw 1704 KALMIA RD NW Type: Dist.

Collection Date: 2/6/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 2/6/2014 9:17:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: LC-W1402043-008

SAMPLE INFORMATION

Sample Number: 1402043-008 Customer Sample Number: 3048131 Program: DS
Location: 2nd Draw 1704 KALMIA RD NW Type: Dist.

Collection Date: 2/6/2014 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 2/6/2014 9:17:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-003 Customer Sample Number: 3073715 Program: DS
Location: 1st draw 249 11TH ST SE Type: Dist.

Collection Date: 2/11/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-004 Customer Sample Number: 3073715 Program: DS
Location: 2nd draw 249 11TH ST SE Type: Dist.

Collection Date: 2/11/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-005 Customer Sample Number: 3001669 Program: DS
Location: 1st draw 1735 CHURCH ST NW Type: Dist.
Collection Date: 2/11/2014 Collection Time: 6:52 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-006 Customer Sample Number: 3001669 Program: DS
Location: 2nd draw 1735 CHURCH ST NW Type: Dist.

Collection Date: 2/11/2014 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-007 Customer Sample Number: 3040623 Program: DS
Location: 1st draw 5010 RENO ROAD NW Type: Dist.
Collection Date: 2/10/2014 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-008 Customer Sample Number: 3040623 Program: DS
Location: 2nd draw 5010 RENO ROAD NW Type: Dist.

Collection Date: 2/10/2014 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-009 Customer Sample Number: 3106716 Program: DS
Location: 1st draw 2231 TAYLOR ST NE Type: Dist.
Collection Date: 2/4/2014 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-010 Customer Sample Number: 3106716 Program: DS
Location: 2nd draw 2231 TAYLOR ST NE Type: Dist.

Collection Date: 2/4/2014 Collection Time: 6:26 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-011 Customer Sample Number: 3027054 Program: DS
Location: 1st draw 614 SHERIDAN ST NW Type: Dist.

Collection Date: 2/6/2014 Collection Time: 14:02 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/24/2014
Report Number: LC-W1402108-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1402108-012 Customer Sample Number: 3027054 Program: DS
Location: 2nd draw 614 SHERIDAN ST NW Type: Dist.

Collection Date: 2/6/2014 Collection Time: 14:03 Sampler: HOME OWNER Received Date and Time: 2/18/2014 8:49:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/28/2014
Report Number: LC-W1402188-001

SAMPLE INFORMATION

Sample Number: 1402188-001 Customer Sample Number: Program: DS
Location: 1st draw 4010 RENO RD NW Type: Dist.
Collection Date: 2/25/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 2/25/2014 3:33:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/28/2014
Report Number: LC-W1402188-002

SAMPLE INFORMATION

Sample Number: 1402188-002 Customer Sample Number: Program: DS
Location: 2nd draw 4010 RENO RD NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 5:33 Sampler: HOME OWNER Received Date and Time: 2/25/2014 3:33:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

2/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402014-001

SAMPLE INFORMATION

Sample Number: 1402014-001 Customer Sample Number: 3097017 Program: DS
Location: 1st draw 1266 SIMMS PL NE Type: Dist.

Collection Date: 1/29/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:31:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402014-002

SAMPLE INFORMATION

Sample Number: 1402014-002 Customer Sample Number: 3097017 Program: DS
Location: 2nd draw 1266 SIMMS PL NE Type: Dist.

Collection Date: 1/29/2014 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:31:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402014-003

SAMPLE INFORMATION

Sample Number: 1402014-003 Customer Sample Number: 3052233 Program: DS
Location: 1st draw 340 ELM ST NW Type: Dist.

Collection Date: 1/29/2014 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:31:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402014-004

SAMPLE INFORMATION

Sample Number: 1402014-004 Customer Sample Number: 3052233 Program: DS
Location: 2nd draw 340 ELM ST NW Type: Dist.

Collection Date: 1/29/2014 Collection Time: 18:34 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:31:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-001

SAMPLE INFORMATION

Sample Number: 1402164-001 Customer Sample Number: Program: DS250
Location: 1st draw 3821 2ND ST APT D SE Type: Dist.
Collection Date: 2/21/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-002

SAMPLE INFORMATION

Sample Number: 1402164-002 Customer Sample Number: Program: DS250
Location: 2nd draw 3821 2ND ST APT D SE Type: Dist.
Collection Date: 2/21/2014 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-003

SAMPLE INFORMATION

Sample Number: 1402164-003 Customer Sample Number: 3045682 Program: DS
Location: 1st draw 4951 ESKRIDGE TERR NW Type: Dist.

Collection Date: 2/16/2014 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-004

SAMPLE INFORMATION

Sample Number: 1402164-004 Customer Sample Number: 3045682 Program: DS
Location: 2nd draw 4951 ESKRIDGE TERR NW Type: Dist.

Collection Date: 2/16/2014 Collection Time: 8:18 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-005

SAMPLE INFORMATION

Sample Number: 1402164-005 Customer Sample Number: 3012244 Program: DS
Location: 1st draw 1239 31ST ST NW Type: Dist.

Collection Date: 2/16/2014 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-006

SAMPLE INFORMATION

Sample Number: 1402164-006 Customer Sample Number: 3012244 Program: DS
Location: 2nd draw 1239 31ST ST NW Type: Dist.

Collection Date: 2/16/2014 Collection Time: 7:26 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-007

SAMPLE INFORMATION

Sample Number: 1402164-007 Customer Sample Number: 3102372 Program: DS
Location: 1st draw 1230 TRINIDAD AVE NE Type: Dist.

Collection Date: 2/11/2014 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-008

SAMPLE INFORMATION

Sample Number: 1402164-008 Customer Sample Number: 3102372 Program: DS
Location: 2nd draw 1230 TRINIDAD AVE NE Type: Dist.

Collection Date: 2/11/2014 Collection Time: 5:10 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-009

SAMPLE INFORMATION

Sample Number: 1402164-009 Customer Sample Number: 3095920 Program: DS250
Location: 1st draw 611 EDGEWOOD STREET NE #1101 Type: Dist.

Collection Date: 2/11/2014 Collection Time: 21:52 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402164-010

SAMPLE INFORMATION

Sample Number: 1402164-010 Customer Sample Number: 3095920 Program: DS250
Location: 2nd draw 611 EDGEWOOD STREET NE #1101 Type: Dist.

Collection Date: 2/11/2014 Collection Time: 21:52 Sampler: HOME OWNER Received Date and Time: 2/24/2014 10:55:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402187-001

SAMPLE INFORMATION

Sample Number: 1402187-001 Customer Sample Number: 3113347 Program: DS
Location: 1st draw 2711 6TH ST NE Type: Dist.

Collection Date: 2/13/2014 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 2/25/2014 3:28:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.0 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402187-002

SAMPLE INFORMATION

Sample Number: 1402187-002 Customer Sample Number: 3113347 Program: DS
Location: 2nd draw 2711 6TH ST NE Type: Dist.

Collection Date: 2/13/2014 Collection Time: 8:32 Sampler: HOME OWNER Received Date and Time: 2/25/2014 3:28:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402187-003

SAMPLE INFORMATION

Sample Number: 1402187-003 Customer Sample Number: 3020593 Program: DS
Location: 1st draw 3927 ILLINOIS AVE NW Type: Dist.

Collection Date: 2/20/2014 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 2/25/2014 3:28:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	2/27/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402187-004

SAMPLE INFORMATION

Sample Number: 1402187-004 Customer Sample Number: 3020593 Program: DS
Location: 2nd draw 3927 ILLINOIS AVE NW Type: Dist.

Collection Date: 2/20/2014 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 2/25/2014 3:28:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403010-001

SAMPLE INFORMATION

Sample Number: 1403010-001 Customer Sample Number: 3058630 Program: DS
Location: 1st draw 3280 CHESTNUT ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 3/4/2014 12:53:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403010-002

SAMPLE INFORMATION

Sample Number: 1403010-002 Customer Sample Number: 3058630 Program: DS
Location: 2nd draw 3280 CHESTNUT ST NW Type: Dist.

Collection Date: 2/26/2014 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 3/4/2014 12:53:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403010-003

SAMPLE INFORMATION

Sample Number: 1403010-003 Customer Sample Number: 3046266 Program: DS
Location: 1st draw 627 WHITTIER ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/4/2014 12:53:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403010-004

SAMPLE INFORMATION

Sample Number: 1403010-004 Customer Sample Number: 3046266 Program: DS
Location: 2nd draw 627 WHITTIER ST NW Type: Dist.

Collection Date: 2/25/2014 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 3/4/2014 12:53:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403010-005

SAMPLE INFORMATION

Sample Number: 1403010-005 Customer Sample Number: 3049701 Program: DS
Location: 1st draw 1341 HAMILTON ST NW Type: Dist.

Collection Date: 2/21/2014 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 12:53:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403010-006

SAMPLE INFORMATION

Sample Number: 1403010-006 Customer Sample Number: 3049701 Program: DS
Location: 2nd draw 1341 HAMILTON ST NW Type: Dist.

Collection Date: 2/21/2014 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 3/4/2014 12:53:29 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403031-001

SAMPLE INFORMATION

Sample Number: 1403031-001 Customer Sample Number: 3044206 Program: DS
Location: 1st draw 3224 45TH ST NW Type: Dist.

Collection Date: 3/2/2014 Collection Time: 7:24 Sampler: HOME OWNER Received Date and Time: 3/6/2014 11:03:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403031-002

SAMPLE INFORMATION

Sample Number: 1403031-002 Customer Sample Number: 3044206 Program: DS
Location: 2nd draw 3224 45TH ST NW Type: Dist.

Collection Date: 3/2/2014 Collection Time: 7:24 Sampler: HOME OWNER Received Date and Time: 3/6/2014 11:03:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403031-003

SAMPLE INFORMATION

Sample Number: 1403031-003 Customer Sample Number: 3021362 Program: DS
Location: 1st draw 709 VARNUM ST. NW Type: Dist.

Collection Date: 3/2/2014 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 3/6/2014 11:03:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403031-004

SAMPLE INFORMATION

Sample Number: 1403031-004 Customer Sample Number: 3021362 Program: DS
Location: 2nd draw 709 VARNUM ST. NW Type: Dist.

Collection Date: 3/2/2014 Collection Time: 8:02 Sampler: HOME OWNER Received Date and Time: 3/6/2014 11:03:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403062-001

SAMPLE INFORMATION

Sample Number: 1403062-001 Customer Sample Number: 3020551 Program: DS
Location: 1st draw 438 RANDOLPH ST NW Type: Dist.

Collection Date: 3/6/2014 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 3/11/2014 8:41:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.6 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403062-002

SAMPLE INFORMATION

Sample Number: 1403062-002 Customer Sample Number: 3020551 Program: DS
Location: 2nd draw 438 RANDOLPH ST NW Type: Dist.

Collection Date: 3/6/2014 Collection Time: 4:05 Sampler: HOME OWNER Received Date and Time: 3/11/2014 8:41:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.8 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403062-003

SAMPLE INFORMATION

Sample Number: 1403062-003 Customer Sample Number: 3065268 Program: DS
Location: 1st draw 4801 W ST NW Type: Dist.

Collection Date: 3/6/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/11/2014 8:41:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403062-004

SAMPLE INFORMATION

Sample Number: 1403062-004 Customer Sample Number: 3065268 Program: DS
Location: 2nd draw 4801 W ST NW Type: Dist.

Collection Date: 3/6/2014 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 3/11/2014 8:41:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403062-005

SAMPLE INFORMATION

Sample Number: 1403062-005 Customer Sample Number: 3055587 Program: DS
Location: 1st draw 4456 Q ST NW Type: Dist.

Collection Date: 3/6/2014 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 3/11/2014 8:41:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403062-006

SAMPLE INFORMATION

Sample Number: 1403062-006 Customer Sample Number: 3055587 Program: DS
Location: 2nd draw 4456 Q ST NW Type: Dist.

Collection Date: 3/6/2014 Collection Time: 7:22 Sampler: HOME OWNER Received Date and Time: 3/11/2014 8:41:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403106-001

SAMPLE INFORMATION

Sample Number: 1403106-001 Customer Sample Number: 3044926 Program: DS
Location: 1st Draw 4737 MACARTHUR BLVD NW Type: Dist.

Collection Date: 3/11/2014 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 3/14/2014 1:00:14 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403106-002

SAMPLE INFORMATION

Sample Number: 1403106-002 Customer Sample Number: 3044926 Program: DS
Location: 2nd Draw 4737 MACARTHUR BLVD NW Type: Dist.

Collection Date: 3/11/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/14/2014 1:00:14 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403106-003

SAMPLE INFORMATION

Sample Number: 1403106-003 Customer Sample Number: 3061429 Program: DS
Location: 1st Draw 1854 BILTMORE ST NW Type: Dist.

Collection Date: 3/11/2014 Collection Time: 16:00 Sampler: HOME OWNER Received Date and Time: 3/14/2014 1:00:14 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403106-004

SAMPLE INFORMATION

Sample Number: 1403106-004 Customer Sample Number: 3061429 Program: DS
Location: 2nd Draw 1854 BILTMORE ST NW Type: Dist.

Collection Date: 3/11/2014 Collection Time: 16:15 Sampler: HOME OWNER Received Date and Time: 3/14/2014 1:00:14 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403152-001

SAMPLE INFORMATION

Sample Number: 1403152-001 Customer Sample Number: 3022464 Program: DS
Location: 1st draw 827 DELAFIELD PL. NW Type: Dist.

Collection Date: 3/14/2014 Collection Time: 16:46 Sampler: HOME OWNER Received Date and Time: 3/21/2014 9:59:31 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	14.7 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403152-002

SAMPLE INFORMATION

Sample Number: 1403152-002 Customer Sample Number: 3022464 Program: DS
Location: 2nd draw 827 DELAFIELD PL. NW Type: Dist.

Collection Date: 3/14/2014 Collection Time: 16:48 Sampler: HOME OWNER Received Date and Time: 3/21/2014 9:59:31 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	33.3 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403152-003

SAMPLE INFORMATION

Sample Number: 1403152-003 Customer Sample Number: 3036888 Program: DS
Location: 1st draw 3621 EVERETT ST NW Type: Dist.

Collection Date: 3/15/2014 Collection Time: 7:28 Sampler: HOME OWNER Received Date and Time: 3/21/2014 9:59:31 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403152-004

SAMPLE INFORMATION

Sample Number: 1403152-004 Customer Sample Number: 3036888 Program: DS
Location: 2nd draw 3621 EVERETT ST NW Type: Dist.

Collection Date: 3/15/2014 Collection Time: 7:31 Sampler: HOME OWNER Received Date and Time: 3/21/2014 9:59:31 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1403211-003

SAMPLE INFORMATION

Sample Number: 1403211-003 Customer Sample Number: 3031416 Program: DS
Location: 1st draw 1813 KILBOURNE PL NW Type: Dist.

Collection Date: 3/27/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 3/31/2014 10:30:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.5 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1403211-004

SAMPLE INFORMATION

Sample Number: 1403211-004 Customer Sample Number: 3031416 Program: DS
Location: 2nd draw 1813 KILBOURNE PL NW Type: Dist.

Collection Date: 3/27/2014 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 3/31/2014 10:30:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.2 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404002-003

SAMPLE INFORMATION

Sample Number: 1404002-003 Customer Sample Number: 3042587 Program: DS
Location: 1st draw 4323 WARREN ST NW Type: Dist.

Collection Date: 3/30/2014 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:15:24 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404002-004

SAMPLE INFORMATION

Sample Number: 1404002-004 Customer Sample Number: 3042587 Program: DS
Location: 2nd draw 4323 WARREN ST NW Type: Dist.

Collection Date: 3/30/2014 Collection Time: 8:01 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:15:24 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404017-001

SAMPLE INFORMATION

Sample Number: 1404017-001 Customer Sample Number: 3124832 Program: DS
Location: 1st draw 315 SEATON PL NE Type: Dist.

Collection Date: 3/27/2014 Collection Time: 4:25 Sampler: HOME OWNER Received Date and Time: 4/2/2014 12:20:21 PM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404017-002

SAMPLE INFORMATION

Sample Number: 1404017-002 Customer Sample Number: 3124832 Program: DS
Location: 2nd draw 315 SEATON PL NE Type: Dist.

Collection Date: 3/27/2014 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 4/2/2014 12:20:21 PM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.2 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404047-001

SAMPLE INFORMATION

Sample Number: 1404047-001 Customer Sample Number: 3103548 Program: DS
Location: 1st draw 2909 10TH ST NE Type: Dist.

Collection Date: 3/26/2014 Collection Time: 19:15 Sampler: HOME OWNER Received Date and Time: 4/7/2014 8:55:56 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404047-002

SAMPLE INFORMATION

Sample Number: 1404047-002 Customer Sample Number: 3103548 Program: DS
Location: 2nd draw 2909 10TH ST NE Type: Dist.

Collection Date: 3/26/2014 Collection Time: 19:17 Sampler: HOME OWNER Received Date and Time: 4/7/2014 8:55:56 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404047-003

SAMPLE INFORMATION

Sample Number: 1404047-003 Customer Sample Number: 3087421 Program: DS
Location: 1st draw 1634 MASSACHUSETTS AVE SE Type: Dist.

Collection Date: 3/31/2014 Collection Time: 5:19 Sampler: HOME OWNER Received Date and Time: 4/7/2014 8:55:56 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404047-004

SAMPLE INFORMATION

Sample Number: 1404047-004 Customer Sample Number: 3087421 Program: DS
Location: 2nd draw 1634 MASSACHUSETTS AVE SE Type: Dist.

Collection Date: 3/31/2014 Collection Time: 5:21 Sampler: HOME OWNER Received Date and Time: 4/7/2014 8:55:56 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404047-005

SAMPLE INFORMATION

Sample Number: 1404047-005 Customer Sample Number: 3039990 Program: DS
Location: 1st draw 3805 MILITARY RD NW Type: Dist.

Collection Date: 4/2/2014 Collection Time: 18:27 Sampler: HOME OWNER Received Date and Time: 4/7/2014 8:55:56 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.3 ug/L	4/8/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404047-006

SAMPLE INFORMATION

Sample Number: 1404047-006 Customer Sample Number: 3039990 Program: DS
Location: 2nd draw 3805 MILITARY RD NW Type: Dist.

Collection Date: 4/2/2014 Collection Time: 18:29 Sampler: HOME OWNER Received Date and Time: 4/7/2014 8:55:56 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/8/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404092-001

SAMPLE INFORMATION

Sample Number: 1404092-001 Customer Sample Number: 3043789 Program: DS
Location: 1st draw 4834 BUTTERWORTH PL NW Type: Dist.

Collection Date: 4/6/2014 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 4/9/2014 3:42:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/11/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404092-002

SAMPLE INFORMATION

Sample Number: 1404092-002 Customer Sample Number: 3043789 Program: DS
Location: 2nd draw 4834 BUTTERWORTH PL NW Type: Dist.

Collection Date: 4/6/2014 Collection Time: 9:03 Sampler: HOME OWNER Received Date and Time: 4/9/2014 3:42:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	4/11/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404092-003

SAMPLE INFORMATION

Sample Number: 1404092-003 Customer Sample Number: 3115074 Program: DS
Location: 1st draw 1639 WEBSTER ST NE Type: Dist.

Collection Date: 4/7/2014 Collection Time: 7:24 Sampler: HOME OWNER Received Date and Time: 4/9/2014 3:42:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/11/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404092-004

SAMPLE INFORMATION

Sample Number: 1404092-004 Customer Sample Number: 3115074 Program: DS
Location: 2nd draw 1639 WEBSTER ST NE Type: Dist.

Collection Date: 4/7/2014 Collection Time: 7:26 Sampler: HOME OWNER Received Date and Time: 4/9/2014 3:42:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	4/11/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2014
Report Number: LC-W1404131-003

SAMPLE INFORMATION

Sample Number: 1404131-003 Customer Sample Number: 3020220 Program: DS
Location: 1st draw 621 PRINCETON PLACE NW Type: Dist.

Collection Date: 4/7/2014 Collection Time: 10:05 Sampler: HOME OWNER Received Date and Time: 4/14/2014 3:55:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2014
Report Number: LC-W1404131-004

SAMPLE INFORMATION

Sample Number: 1404131-004 Customer Sample Number: 3020220 Program: DS
Location: 2nd draw 621 PRINCETON PLACE NW Type: Dist.

Collection Date: 4/7/2014 Collection Time: 10:10 Sampler: HOME OWNER Received Date and Time: 4/14/2014 3:55:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/29/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404167-001

SAMPLE INFORMATION

Sample Number: 1404167-001 Customer Sample Number: 3001394 Program: DS
Location: 1st draw 1731 SWANN ST NW Type: Dist.

Collection Date: 4/4/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/18/2014 1:55:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	1.5 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404167-002

SAMPLE INFORMATION

Sample Number: 1404167-002 Customer Sample Number: 3001394 Program: DS
Location: 2nd draw 1731 SWANN ST NW Type: Dist.

Collection Date: 4/4/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/18/2014 1:55:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404167-003

SAMPLE INFORMATION

Sample Number: 1404167-003 Customer Sample Number: 3044789 Program: DS
Location: 1st draw 4406 VOLTA PL NW Type: Dist.
Collection Date: 4/14/2014 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 4/18/2014 1:55:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404167-004

SAMPLE INFORMATION

Sample Number: 1404167-004 Customer Sample Number: 3044789 Program: DS
Location: 2nd draw 4406 VOLTA PL NW Type: Dist.
Collection Date: 4/14/2014 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 4/18/2014 1:55:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404167-005

SAMPLE INFORMATION

Sample Number: 1404167-005 Customer Sample Number: 3122431 Program: DS
Location: 1st draw 28 14TH ST NE Type: Dist.

Collection Date: 4/15/2014 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 4/18/2014 1:55:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	1.5 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404167-006

SAMPLE INFORMATION

Sample Number: 1404167-006 Customer Sample Number: 3122431 Program: DS
Location: 2nd draw 28 14TH ST NE Type: Dist.

Collection Date: 4/15/2014 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 4/18/2014 1:55:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404167-007

SAMPLE INFORMATION

Sample Number: 1404167-007 Customer Sample Number: 3128304 Program: DS
Location: 1st draw 627 FRANKIN ST NE Type: Dist.
Collection Date: 4/16/2014 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 4/18/2014 1:55:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404167-008

SAMPLE INFORMATION

Sample Number: 1404167-008 Customer Sample Number: 3128304 Program: DS
Location: 2nd draw 627 FRANKIN ST NE Type: Dist.

Collection Date: 4/16/2014 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 4/18/2014 1:55:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404197-001

SAMPLE INFORMATION

Sample Number: 1404197-001 Customer Sample Number: 3026449 Program: DS
Location: 1st draw 502 RITTENHOUSE ST NW Type: Dist.
Collection Date: 4/10/2014 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 4/23/2014 12:22:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404197-002

SAMPLE INFORMATION

Sample Number: 1404197-002 Customer Sample Number: 3026449 Program: DS
Location: 2nd draw 502 RITTENHOUSE ST NW Type: Dist.

Collection Date: 4/10/2014 Collection Time: 18:31 Sampler: HOME OWNER Received Date and Time: 4/23/2014 12:22:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404197-004

SAMPLE INFORMATION

Sample Number: 1404197-004 Customer Sample Number: 3049734 Program: DS
Location: 1st draw 1336 JEFFERSON ST NW Type: Dist.

Collection Date: 4/17/2014 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 4/23/2014 12:22:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404197-005

SAMPLE INFORMATION

Sample Number: 1404197-005 Customer Sample Number: 3049734 Program: DS
Location: 2nd draw 1336 JEFFERSON ST NW Type: Dist.

Collection Date: 4/17/2014 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 4/23/2014 12:22:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404197-006

SAMPLE INFORMATION

Sample Number: 1404197-006 Customer Sample Number: 3120919 Program: DS
Location: 1st draw 425 4TH ST NE Type: Dist.

Collection Date: 4/21/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 4/23/2014 12:22:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404197-007

SAMPLE INFORMATION

Sample Number: 1404197-007 Customer Sample Number: 3120919 Program: DS
Location: 2nd draw 425 4TH ST NE Type: Dist.
Collection Date: 4/21/2014 Collection Time: 7:12 Sampler: HOME OWNER Received Date and Time: 4/23/2014 12:22:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/23/2014
Report Number: LC-W1404220-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1404220-001 Customer Sample Number: 3072617 Program: DS
Location: 1st draw 626 C ST SE Type: Dist.

Collection Date: 4/20/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/25/2014 2:50:39 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/23/2014
Report Number: LC-W1404220-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1404220-002 Customer Sample Number: 3072617 Program: DS
Location: 2nd draw 626 C ST SE Type: Dist.

Collection Date: 4/20/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 4/25/2014 2:50:39 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority

Report Date: 5/23/2014
Report Number: LC-W1404220-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1404220-003 Customer Sample Number: 3007097 Program: DS
Location: 1st draw 1343 1ST ST NW Type: Dist.
Collection Date: 4/22/2014 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 4/25/2014 2:50:39 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/23/2014
Report Number: LC-W1404220-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1404220-004 Customer Sample Number: 3007097 Program: DS
Location: 2nd draw 1343 1ST ST NW Type: Dist.
Collection Date: 4/22/2014 Collection Time: 15:05 Sampler: HOME OWNER Received Date and Time: 4/25/2014 2:50:39 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority

Report Date: 5/23/2014
Report Number: LC-W1404220-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1404220-005 Customer Sample Number: 3041437 Program: DS
Location: 1st draw 3649 UPTON ST NW Type: Dist.
Collection Date: 4/22/2014 Collection Time: 7:12 Sampler: HOME OWNER Received Date and Time: 4/25/2014 2:50:39 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/23/2014
Report Number: LC-W1404220-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1404220-006 Customer Sample Number: 3041437 Program: DS
Location: 2nd draw 3649 UPTON ST NW Type: Dist.

Collection Date: 4/22/2014 Collection Time: 7:14 Sampler: HOME OWNER Received Date and Time: 4/25/2014 2:50:39 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/23/2014
Report Number: LC-W1404220-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1404220-007 Customer Sample Number: 3041436 Program: DS
Location: 1st draw 3643 UPTON ST NW Type: Dist.
Collection Date: 4/19/2014 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 4/25/2014 2:50:39 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/23/2014
Report Number: LC-W1404220-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1404220-008 Customer Sample Number: 3041436 Program: DS
Location: 2nd draw 3643 UPTON ST NW Type: Dist.

Collection Date: 4/19/2014 Collection Time: 15:03 Sampler: HOME OWNER Received Date and Time: 4/25/2014 2:50:39 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405006-001

SAMPLE INFORMATION

Sample Number: 1405006-001 Customer Sample Number: 3112761 Program: DS
Location: 1st draw 1225 18TH ST NE Type: Dist.

Collection Date: 4/22/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/1/2014 2:41:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	8.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405006-002

SAMPLE INFORMATION

Sample Number: 1405006-002 Customer Sample Number: 3112761 Program: DS
Location: 2nd draw 1225 18TH ST NE Type: Dist.

Collection Date: 4/22/2014 Collection Time: 6:01 Sampler: HOME OWNER Received Date and Time: 5/1/2014 2:41:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	17.4 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405006-003

SAMPLE INFORMATION

Sample Number: 1405006-003 Customer Sample Number: 3126125 Program: DS
Location: 1st draw 4403 2ND ST NE #2 Type: Dist.

Collection Date: 4/26/2014 Collection Time: 8:55 Sampler: HOME OWNER Received Date and Time: 5/1/2014 2:41:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405006-004

SAMPLE INFORMATION

Sample Number: 1405006-004 Customer Sample Number: 3126125 Program: DS
Location: 2nd draw 4403 2ND ST NE #2 Type: Dist.

Collection Date: 4/26/2014 Collection Time: 8:56 Sampler: HOME OWNER Received Date and Time: 5/1/2014 2:41:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405006-005

SAMPLE INFORMATION

Sample Number: 1405006-005 Customer Sample Number: 3053579 Program: DS
Location: 1st draw 4020 RENO RD NW Type: Dist.

Collection Date: 4/26/2014 Collection Time: 14:29 Sampler: HOME OWNER Received Date and Time: 5/1/2014 2:41:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405006-006

SAMPLE INFORMATION

Sample Number: 1405006-006 Customer Sample Number: 3053579 Program: DS
Location: 2nd draw 4020 RENO RD NW Type: Dist.

Collection Date: 4/26/2014 Collection Time: 14:30 Sampler: HOME OWNER Received Date and Time: 5/1/2014 2:41:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405070-001

SAMPLE INFORMATION

Sample Number: 1405070-001 Customer Sample Number: 3072266 Program: DS
Location: 1st Draw 423 4TH ST SE Type: Dist.

Collection Date: 4/29/2014 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:08:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405070-002

SAMPLE INFORMATION

Sample Number: 1405070-002 Customer Sample Number: 3072266 Program: DS
Location: 2nd Draw 423 4TH ST SE Type: Dist.

Collection Date: 4/29/2014 Collection Time: 7:07 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:08:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405070-003

SAMPLE INFORMATION

Sample Number: 1405070-003 Customer Sample Number: 3075950 Program: DS
Location: 1st Draw 1628 POTOMAC AVE SE Type: Dist.

Collection Date: 5/4/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:08:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	5/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405070-004

SAMPLE INFORMATION

Sample Number: 1405070-004 Customer Sample Number: 3075950 Program: DS
Location: 2nd Draw 1628 POTOMAC AVE SE Type: Dist.

Collection Date: 5/4/2014 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:08:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405070-005

SAMPLE INFORMATION

Sample Number: 1405070-005 Customer Sample Number: 3051188 Program: DS
Location: 1st Draw 4205 ILLINOIS AVE NW Type: Dist.

Collection Date: 5/5/2014 Collection Time: 5:50 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:08:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	1.8 ug/L	5/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405070-006

SAMPLE INFORMATION

Sample Number: 1405070-006 Customer Sample Number: 3051188 Program: DS
Location: 2nd Draw 4205 ILLINOIS AVE NW Type: Dist.

Collection Date: 5/5/2014 Collection Time: 5:52 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:08:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	5/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405070-007

SAMPLE INFORMATION

Sample Number: 1405070-007 Customer Sample Number: 3127096 Program: DS
Location: 1st Draw 640 ORLEANS PLACE NE Type: Dist.

Collection Date: 5/7/2014 Collection Time: 13:35 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:08:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	1.4 ug/L	5/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405070-008

SAMPLE INFORMATION

Sample Number: 1405070-008 Customer Sample Number: 3127096 Program: DS
Location: 2nd Draw 640 ORLEANS PLACE NE Type: Dist.

Collection Date: 5/7/2014 Collection Time: 13:40 Sampler: HOME OWNER Received Date and Time: 5/9/2014 3:08:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	2.9 ug/L	5/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/28/2014
Report Number: LC-W1403163-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1403163-003 Customer Sample Number: 3020442 Program: DS
Location: 1st draw 618 QUINCY ST NW Type: Dist.
Collection Date: 3/11/2014 Collection Time: 21:30 Sampler: HOME OWNER Received Date and Time: 3/24/2014 12:33:08 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/28/2014
Report Number: LC-W1403163-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1403163-004 Customer Sample Number: 3020442 Program: DS
Location: 2nd draw 618 QUINCY ST NW Type: Dist.

Collection Date: 3/11/2014 Collection Time: 21:30 Sampler: HOME OWNER Received Date and Time: 3/24/2014 12:33:08 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/28/2014
Report Number: LC-W1403163-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1403163-005 Customer Sample Number: 3111477 Program: DS
Location: 1st draw 5 KENNEDY ST NE Type: Dist.

Collection Date: 3/12/2014 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 3/24/2014 12:33:08 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/28/2014
Report Number: LC-W1403163-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1403163-006 Customer Sample Number: 3111477 Program: DS
Location: 2nd draw 5 KENNEDY ST NE Type: Dist.

Collection Date: 3/12/2014 Collection Time: 9:45 Sampler: HOME OWNER Received Date and Time: 3/24/2014 12:33:08 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.0 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1404131-001

SAMPLE INFORMATION

Sample Number: 1404131-001 Customer Sample Number: 3111748 Program: DS
Location: 1st draw 709 D ST NE Type: Dist.

Collection Date: 4/6/2014 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 4/14/2014 3:55:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	2.8 ug/L	6/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1404131-002

SAMPLE INFORMATION

Sample Number: 1404131-002 Customer Sample Number: 3111748 Program: DS
Location: 2nd draw 709 D ST NE Type: Dist.

Collection Date: 4/6/2014 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 4/14/2014 3:55:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405153-001

SAMPLE INFORMATION

Sample Number: 1405153-001 Customer Sample Number: 3043039 Program: DS
Location: 1st draw 4633 47TH ST NW Type: Dist.

Collection Date: 5/13/2014 Collection Time: 6:51 Sampler: HOME OWNER Received Date and Time: 5/19/2014 3:53:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	68.0 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405153-002

SAMPLE INFORMATION

Sample Number: 1405153-002 Customer Sample Number: 3043039 Program: DS
Location: 2nd draw 4633 47TH ST NW Type: Dist.

Collection Date: 5/13/2014 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 5/19/2014 3:53:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	4.3 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405171-001

SAMPLE INFORMATION

Sample Number: 1405171-001 Customer Sample Number: 3056169 Program: DS
Location: 1st draw 4833 RODMAN ST NW Type: Dist.

Collection Date: 5/19/2014 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 5/21/2014 1:56:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405171-002

SAMPLE INFORMATION

Sample Number: 1405171-002 Customer Sample Number: 3056169 Program: DS
Location: 2nd draw 4833 RODMAN ST NW Type: Dist.

Collection Date: 5/19/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 5/21/2014 1:56:28 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405212-001

SAMPLE INFORMATION

Sample Number: 1405212-001 Customer Sample Number: 3020467 Program: DS
Location: 1st draw 435 QUINCY ST NW Type: Dist.

Collection Date: 5/21/2014 Collection Time: 4:55 Sampler: HOME OWNER Received Date and Time: 5/28/2014 11:06:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405212-002

SAMPLE INFORMATION

Sample Number: 1405212-002 Customer Sample Number: 3020467 Program: DS
Location: 2nd draw 435 QUINCY ST NW Type: Dist.

Collection Date: 5/21/2014 Collection Time: 4:57 Sampler: HOME OWNER Received Date and Time: 5/28/2014 11:06:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405221-001

SAMPLE INFORMATION

Sample Number: 1405221-001 Customer Sample Number: 3041886 Program: DS
Location: 1st draw 3622 NORTON PL NW Type: Dist.

Collection Date: 5/27/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/28/2014 3:40:05 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	1.2 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405221-002

SAMPLE INFORMATION

Sample Number: 1405221-002 Customer Sample Number: 3041886 Program: DS
Location: 2nd draw 3622 NORTON PL NW Type: Dist.

Collection Date: 5/27/2014 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 5/28/2014 3:40:05 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406046-001

SAMPLE INFORMATION

Sample Number: 1406046-001 Customer Sample Number: 3020471 Program: DS
Location: 1st Draw 445 QUINCY ST NW Type: Dist.

Collection Date: 5/29/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:25:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	6/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406046-002

SAMPLE INFORMATION

Sample Number: 1406046-002 Customer Sample Number: 3020471 Program: DS
Location: 2nd Draw 445 QUINCY ST NW Type: Dist.

Collection Date: 5/29/2014 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:25:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	6/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406046-005

SAMPLE INFORMATION

Sample Number: 1406046-005 Customer Sample Number: 3027731 Program: DS
Location: 1st Draw 4601 13TH ST NW Type: Dist.

Collection Date: 6/4/2014 Collection Time: 6:42 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:25:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406046-006

SAMPLE INFORMATION

Sample Number: 1406046-006 Customer Sample Number: 3027731 Program: DS
Location: 2nd Draw 4601 13TH ST NW Type: Dist.

Collection Date: 6/4/2014 Collection Time: 6:43 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:25:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406058-001

SAMPLE INFORMATION

Sample Number: 1406058-001 Customer Sample Number: 3022383 Program: DS
Location: 1st draw 414 DELAFIELD PL NW Type: Dist.
Collection Date: 6/3/2014 Collection Time: 16:51 Sampler: HOME OWNER Received Date and Time: 6/9/2014 11:36:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	6/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406058-002

SAMPLE INFORMATION

Sample Number: 1406058-002 Customer Sample Number: 3022383 Program: DS
Location: 2nd draw 414 DELAFIELD PL NW Type: Dist.
Collection Date: 6/3/2014 Collection Time: 16:53 Sampler: HOME OWNER Received Date and Time: 6/9/2014 11:36:27 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.2 ug/L	6/10/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406116-001

SAMPLE INFORMATION

Sample Number: 1406116-001 Customer Sample Number: 3042916 Program: DS
Location: 1st Draw 4714 CHESAPEAKE ST NW Type: Dist.

Collection Date: 6/10/2014 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 6/16/2014 8:55:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	1.3 ug/L	6/19/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406116-002

SAMPLE INFORMATION

Sample Number: 1406116-002 Customer Sample Number: 3042916 Program: DS
Location: 2nd Draw 4714 CHESAPEAKE ST NW Type: Dist.

Collection Date: 6/10/2014 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 6/16/2014 8:55:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/19/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406116-003

SAMPLE INFORMATION

Sample Number: 1406116-003 Customer Sample Number: 3020958 Program: DS
Location: 1st Draw 4122 7TH ST NW Type: Dist.

Collection Date: 6/11/2014 Collection Time: 18:58 Sampler: HOME OWNER Received Date and Time: 6/16/2014 8:55:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	4.9 ug/L	6/19/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406116-004

SAMPLE INFORMATION

Sample Number: 1406116-004 Customer Sample Number: 3020958 Program: DS
Location: 2nd Draw 4122 7TH ST NW Type: Dist.

Collection Date: 6/11/2014 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 6/16/2014 8:55:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	18.6 ug/L	6/19/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406116-005

SAMPLE INFORMATION

Sample Number: 1406116-005 Customer Sample Number: 3095394 Program: DS
Location: 1st Draw 4036 8TH ST NE Type: Dist.

Collection Date: 6/13/2014 Collection Time: 5:42 Sampler: HOME OWNER Received Date and Time: 6/16/2014 8:55:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/19/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406116-006

SAMPLE INFORMATION

Sample Number: 1406116-006 Customer Sample Number: 3095394 Program: DS
Location: 2nd Draw 4036 8TH ST NE Type: Dist.

Collection Date: 6/13/2014 Collection Time: 5:46 Sampler: HOME OWNER Received Date and Time: 6/16/2014 8:55:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/19/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off 4.5 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312171-001

SAMPLE INFORMATION

Sample Number: 1312171-001 Customer Sample Number: 3023652 Program: Post-LSR
Location: 1st draw 928 INGRAHAM ST NW Type: Dist.
Collection Date: 12/8/2013 Collection Time: 9:35 Sampler: HOME OWNER Received Date and Time: 12/19/2013 9:50:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	1/16/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312171-002

SAMPLE INFORMATION

Sample Number: 1312171-002 Customer Sample Number: 3023652 Program: Post-LSR
Location: 2nd draw 928 INGRAHAM ST NW Type: Dist.
Collection Date: 12/8/2013 Collection Time: 9:37 Sampler: HOME OWNER Received Date and Time: 12/19/2013 9:50:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	1/16/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312171-003

SAMPLE INFORMATION

Sample Number: 1312171-003 Customer Sample Number: 3054012 Program: Post-LSR
Location: 1st draw 3112 SHERMAN AVE NW Type: Dist.
Collection Date: 12/16/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 12/19/2013 9:50:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1312171-004

SAMPLE INFORMATION

Sample Number: 1312171-004 Customer Sample Number: 3054012 Program: Post-LSR
Location: 2nd draw 3112 SHERMAN AVE NW Type: Dist.

Collection Date: 12/16/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 12/19/2013 9:50:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-005

SAMPLE INFORMATION

Sample Number: 1401020-005 Customer Sample Number: 3104209 Program: Post-LSR
Location: 1st Draw 1228 BRENTWOOD RD. N.E. Type: Dist.

Collection Date: 12/30/2013 Collection Time: 6:27 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	30.4 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-006

SAMPLE INFORMATION

Sample Number: 1401020-006 Customer Sample Number: 3104209 Program: Post-LSR
Location: 2nd Draw 1228 BRENTWOOD RD. N.E. Type: Dist.

Collection Date: 12/30/2013 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	11.8 ug/L	1/16/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-007

SAMPLE INFORMATION

Sample Number: 1401020-007 Customer Sample Number: 3021724 Program: Post-LSR
Location: 1st Draw 820 ALLISON ST. NW Type: Dist.

Collection Date: 12/31/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	1/16/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401020-008

SAMPLE INFORMATION

Sample Number: 1401020-008 Customer Sample Number: 3021724 Program: Post-LSR
Location: 2nd Draw 820 ALLISON ST. NW Type: Dist.

Collection Date: 12/31/2013 Collection Time: 6:06 Sampler: HOME OWNER Received Date and Time: 1/3/2014 11:05:27 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	15.1 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401060-001

SAMPLE INFORMATION

Sample Number: 1401060-001 Customer Sample Number: 3020300 Program: Post-LSR
Location: 1st draw 711 OTIS PLACE NW Type: Dist.

Collection Date: 12/27/2013 Collection Time: 8:31 Sampler: HOME OWNER Received Date and Time: 1/9/2014 8:47:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	27.6 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401060-002

SAMPLE INFORMATION

Sample Number: 1401060-002 Customer Sample Number: 3020300 Program: Post-LSR
Location: 2nd draw 711 OTIS PLACE NW Type: Dist.

Collection Date: 12/27/2013 Collection Time: 8:31 Sampler: HOME OWNER Received Date and Time: 1/9/2014 8:47:32 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.7 ug/L	1/16/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-008

SAMPLE INFORMATION

Sample Number: 1401107-008 Customer Sample Number: 3030946 Program: Post-LSR
Location: 2nd draw 3426 17TH ST NW Type: Dist.
Collection Date: 1/9/2014 Collection Time: 18:50 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: LC-W1401107-007

SAMPLE INFORMATION

Sample Number: 1401107-007 Customer Sample Number: 3030946 Program: Post-LSR
Location: 1st draw 3426 17TH ST NW Type: Dist.
Collection Date: 1/9/2014 Collection Time: 18:50 Sampler: HOME OWNER Received Date and Time: 1/15/2014 10:00:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	1/14/2016	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402014-005

SAMPLE INFORMATION

Sample Number: 1402014-005 Customer Sample Number: 3011631 Program: Post-LSR
Location: 1st draw 18 O ST NW APT A Type: Dist.

Collection Date: 1/30/2014 Collection Time: 20:15 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:31:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/3/2014
Report Number: LC-W1402014-006

SAMPLE INFORMATION

Sample Number: 1402014-006 Customer Sample Number: 3011631 Program: Post-LSR
Location: 2nd draw 18 O ST NW APT A Type: Dist.

Collection Date: 1/30/2014 Collection Time: 20:20 Sampler: HOME OWNER Received Date and Time: 2/4/2014 9:31:59 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	2/27/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/3/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403106-005

SAMPLE INFORMATION

Sample Number: 1403106-005 Customer Sample Number: 3106249 Program: Post-LSR
Location: 1st Draw 2000 JACKSON ST., NE Type: Dist.

Collection Date: 3/13/2014 Collection Time: 7:34 Sampler: HOME OWNER Received Date and Time: 3/14/2014 1:00:14 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403106-006

SAMPLE INFORMATION

Sample Number: 1403106-006 Customer Sample Number: 3106249 Program: Post-LSR
Location: 2nd Draw 2000 JACKSON ST., NE Type: Dist.

Collection Date: 3/13/2014 Collection Time: 7:37 Sampler: HOME OWNER Received Date and Time: 3/14/2014 1:00:14 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403152-005

SAMPLE INFORMATION

Sample Number: 1403152-005 Customer Sample Number: 3122842 Program: Post-LSR
Location: 1st draw 920- K-ST. NE Type: Dist.

Collection Date: 3/14/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/21/2014 9:59:31 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.0 ug/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403152-006

SAMPLE INFORMATION

Sample Number: 1403152-006 Customer Sample Number: 3122842 Program: Post-LSR
Location: 2nd draw 920- K-ST. NE Type: Dist.

Collection Date: 3/14/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/21/2014 9:59:31 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.2 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403152-007

SAMPLE INFORMATION

Sample Number: 1403152-007 Customer Sample Number: 3002000 Program: Post-LSR
Location: 1st draw 1910 16TH ST. NW Type: Dist.

Collection Date: 3/16/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/21/2014 9:59:31 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/31/2014
Report Number: LC-W1403152-008

SAMPLE INFORMATION

Sample Number: 1403152-008 Customer Sample Number: 3002000 Program: Post-LSR
Location: 2nd draw 1910 16TH ST. NW Type: Dist.

Collection Date: 3/16/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/21/2014 9:59:31 AM Received By: BSmith

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	3/28/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/31/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1403201-001

SAMPLE INFORMATION

Sample Number: 1403201-001 Customer Sample Number: 3127592 Program: Post-LSR
Location: 1st Draw 1036 6TH ST NE #102 Type: Dist.

Collection Date: 3/17/2014 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/28/2014 10:22:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	4/8/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1403201-002

SAMPLE INFORMATION

Sample Number: 1403201-002 Customer Sample Number: 3127592 Program: Post-LSR
Location: 2nd Draw 1036 6TH ST NE #102 Type: Dist.

Collection Date: 3/17/2014 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 3/28/2014 10:22:06 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/8/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1403211-001

SAMPLE INFORMATION

Sample Number: 1403211-001 Customer Sample Number: 3097831 Program: Post-LSR
Location: 1st draw 228 F ST NE Type: Dist.

Collection Date: 3/23/2014 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 3/31/2014 10:30:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1403211-002

SAMPLE INFORMATION

Sample Number: 1403211-002 Customer Sample Number: 3097831 Program: Post-LSR
Location: 2nd draw 228 F ST NE Type: Dist.

Collection Date: 3/23/2014 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 3/31/2014 10:30:50 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.7 ug/L	4/8/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404002-001

SAMPLE INFORMATION

Sample Number: 1404002-001 Customer Sample Number: 3021275 Program: Post-LSR
Location: 1st draw 4310 4TH ST NW Type: Dist.
Collection Date: 3/24/2014 Collection Time: 18:40 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:15:24 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/8/2014	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/22/2014
Report Number: LC-W1404002-002

SAMPLE INFORMATION

Sample Number: 1404002-002 Customer Sample Number: 3021275 Program: Post-LSR
Location: 2nd draw 4310 4TH ST NW Type: Dist.

Collection Date: 3/24/2014 Collection Time: 18:45 Sampler: HOME OWNER Received Date and Time: 4/1/2014 10:15:24 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	4/8/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/22/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1404197-003

SAMPLE INFORMATION

Sample Number: 1404197-003 Customer Sample Number: 3077213 Program: Post-LSR
Location: 1st draw 732 CROISSANT PL SE Type: Dist.
Collection Date: 4/14/2014 Collection Time: 11:19 Sampler: HOME OWNER Received Date and Time: 4/23/2014 12:22:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	20.5 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405006-007

SAMPLE INFORMATION

Sample Number: 1405006-007 Customer Sample Number: 3077241 Program: Post-LSR
Location: 1st draw 3021 G ST SE Type: Dist.

Collection Date: 4/28/2014 Collection Time: 6:13 Sampler: HOME OWNER Received Date and Time: 5/1/2014 2:41:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/23/2014
Report Number: LC-W1405006-008

SAMPLE INFORMATION

Sample Number: 1405006-008 Customer Sample Number: 3077241 Program: Post-LSR
Location: 2nd draw 3021 G ST SE Type: Dist.

Collection Date: 4/28/2014 Collection Time: 6:13 Sampler: HOME OWNER Received Date and Time: 5/1/2014 2:41:42 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	5/9/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/23/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/28/2014
Report Number: LC-W1403163-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1403163-001 Customer Sample Number: 3034986 Program: Post-LSR
Location: 1st draw 68 OBSERVATORY CIRCLE NW Type: Dist.
Collection Date: 3/19/2014 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 3/24/2014 12:33:08 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/28/2014
Report Number: LC-W1403163-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1403163-002 Customer Sample Number: 3034986 Program: Post-LSR
Location: 2nd draw 68 OBSERVATORY CIRCLE NW Type: Dist.
Collection Date: 3/19/2014 Collection Time: 8:17 Sampler: HOME OWNER Received Date and Time: 3/24/2014 12:33:08 PM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	3/28/2014	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

5/28/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405087-001

SAMPLE INFORMATION

Sample Number: 1405087-001 Customer Sample Number: 3101057 Program: Post-LSR
Location: 1st draw 1716 C ST NE Type: Dist.
Collection Date: 5/8/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 5/13/2014 9:02:17 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	3.2 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1405087-002

SAMPLE INFORMATION

Sample Number: 1405087-002 Customer Sample Number: 3101057 Program: Post-LSR
Location: 2nd draw 1716 C ST NE Type: Dist.

Collection Date: 5/8/2014 Collection Time: 7:37 Sampler: HOME OWNER Received Date and Time: 5/13/2014 9:02:17 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	5/30/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406046-003

SAMPLE INFORMATION

Sample Number: 1406046-003 Customer Sample Number: 3030920 Program: Post-LSR
Location: 1st Draw 1751 PARK RD, NW Type: Dist.
Collection Date: 6/2/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:25:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2014
Report Number: LC-W1406046-004

SAMPLE INFORMATION

Sample Number: 1406046-004 Customer Sample Number: 3030920 Program: Post-LSR
Location: 2nd Draw 1751 PARK RD, NW Type: Dist.

Collection Date: 6/2/2014 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 6/6/2014 10:25:47 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	6/10/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/11/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406138-001

SAMPLE INFORMATION

Sample Number: 1406138-001 Customer Sample Number: 3072634 Program: Post-LSR
Location: 1st draw 612 D ST SE Type: Dist.

Collection Date: 6/16/2014 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 6/17/2014 2:47:12 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/19/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: LC-W1406138-002

SAMPLE INFORMATION

Sample Number: 1406138-002 Customer Sample Number: 3072634 Program: Post-LSR
Location: 2nd draw 612 D ST SE Type: Dist.

Collection Date: 6/16/2014 Collection Time: 9:01 Sampler: HOME OWNER Received Date and Time: 6/17/2014 2:47:12 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/19/2014	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

Lead Profile Information

DC Water surveys the plumbing of customers' homes and collects consecutive samples to identify the sources of lead. The homes are those that had elevated lead from previous samples collected for compliance monitoring or from other programs.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-001

SAMPLE INFORMATION

Sample Number: 1401087-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-002

SAMPLE INFORMATION

Sample Number: 1401087-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-003

SAMPLE INFORMATION

Sample Number: 1401087-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-004

SAMPLE INFORMATION

Sample Number: 1401087-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-005

SAMPLE INFORMATION

Sample Number: 1401087-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-006

SAMPLE INFORMATION

Sample Number: 1401087-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-007

SAMPLE INFORMATION

Sample Number: 1401087-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-008

SAMPLE INFORMATION

Sample Number: 1401087-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-010

SAMPLE INFORMATION

Sample Number: 1401087-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-011

SAMPLE INFORMATION

Sample Number: 1401087-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-012

SAMPLE INFORMATION

Sample Number: 1401087-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-013

SAMPLE INFORMATION

Sample Number: 1401087-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-014

SAMPLE INFORMATION

Sample Number: 1401087-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: 1/10/2014 Collection Time: 8:00 Sampler: MS/CW Received Date and Time: 1/13/2014 1:38:44 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.67 ug/L	1/16/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	1/16/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	49.0 ug/L	1/16/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	1/16/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-014

SAMPLE INFORMATION

Sample Number: 1401087-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-015

SAMPLE INFORMATION

Sample Number: 1401087-015
Location: 05
LPR 3907 13TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/10/2014
Collection Time: 8:00
Sampler: MS/CW
Received Date and Time: 1/13/2014 1:38:44 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.69 ug/L	1/16/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	41.7 ug/L	1/16/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.8 ug/L	1/16/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.1 ug/L	1/16/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-015

SAMPLE INFORMATION

Sample Number: 1401087-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-016

SAMPLE INFORMATION

Sample Number: 1401087-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-017

SAMPLE INFORMATION

Sample Number: 1401087-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: 1/10/2014 Collection Time: 8:00 Sampler: MS/CW Received Date and Time: 1/13/2014 1:38:44 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.78 ug/L	1/16/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	41.5 ug/L	1/16/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	43.2 ug/L	1/16/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	1/16/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-017

SAMPLE INFORMATION

Sample Number: 1401087-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-018

SAMPLE INFORMATION

Sample Number: 1401087-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: 1/10/2014 Collection Time: 8:00 Sampler: MS/CW Received Date and Time: 1/13/2014 1:38:44 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-019

SAMPLE INFORMATION

Sample Number: 1401087-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.85 ug/L	1/16/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	43.5 ug/L	1/16/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	48.8 ug/L	1/16/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	1/16/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-019

SAMPLE INFORMATION

Sample Number: 1401087-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-020

SAMPLE INFORMATION

Sample Number: 1401087-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-021

SAMPLE INFORMATION

Sample Number: 1401087-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-022

SAMPLE INFORMATION

Sample Number: 1401087-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-023

SAMPLE INFORMATION

Sample Number: 1401087-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-024

SAMPLE INFORMATION

Sample Number: 1401087-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-025

SAMPLE INFORMATION

Sample Number: 1401087-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-026

SAMPLE INFORMATION

Sample Number: 1401087-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-027

SAMPLE INFORMATION

Sample Number: 1401087-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-028

SAMPLE INFORMATION

Sample Number: 1401087-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-029

SAMPLE INFORMATION

Sample Number: 1401087-029
Location: 12
LPR 3907 13TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/10/2014 Collection Time: 8:00 Sampler: MS/CW Received Date and Time: 1/13/2014 1:38:44 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-030

SAMPLE INFORMATION

Sample Number: 1401087-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: 1/10/2014 Collection Time: 8:00 Sampler: MS/CW Received Date and Time: 1/13/2014 1:38:44 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.85 ug/L	1/16/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	1/16/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.1 ug/L	1/16/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	1/16/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	1/16/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-030

SAMPLE INFORMATION

Sample Number: 1401087-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-031

SAMPLE INFORMATION

Sample Number: 1401087-031 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-032

SAMPLE INFORMATION

Sample Number: 1401087-032 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-033

SAMPLE INFORMATION

Sample Number: 1401087-033 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.88 ug/L	1/16/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	70.2 ug/L	1/16/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.2 ug/L	1/16/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	17.1 ug/L	1/16/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	1/16/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-033

SAMPLE INFORMATION

Sample Number: 1401087-033 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-034

SAMPLE INFORMATION

Sample Number: 1401087-034 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.90 ug/L	1/16/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	76.5 ug/L	1/16/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	18.0 ug/L	1/16/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	1/16/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	1/16/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-034

SAMPLE INFORMATION

Sample Number: 1401087-034 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-035

SAMPLE INFORMATION

Sample Number: 1401087-035 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-036

SAMPLE INFORMATION

Sample Number: 1401087-036 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-037

SAMPLE INFORMATION

Sample Number: 1401087-037 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-038

SAMPLE INFORMATION

Sample Number: 1401087-038 Customer Sample Number:
Location: H20 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-039

SAMPLE INFORMATION

Sample Number: 1401087-039 Customer Sample Number:
Location: H21 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-040

SAMPLE INFORMATION

Sample Number: 1401087-040 Customer Sample Number:
Location: H22 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-041

SAMPLE INFORMATION

Sample Number: 1401087-041 Customer Sample Number:
Location: X Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 8:00 MS/CW 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-042

SAMPLE INFORMATION

Sample Number: 1401087-042 Customer Sample Number:
Location: 00 Type: Dist.
LPR 3907 13TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 2:00 HOME OWNER 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2014
Report Number: M- W1401087-043

SAMPLE INFORMATION

Sample Number: 1401087-043 Customer Sample Number:
Location: 00F Type: Dist.
LPR 3907 13TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/10/2014 2:00 HOME OWNER 1/13/2014 1:38:44 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-001

SAMPLE INFORMATION

Sample Number: 1401204-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-002

SAMPLE INFORMATION

Sample Number: 1401204-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-003

SAMPLE INFORMATION

Sample Number: 1401204-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-004

SAMPLE INFORMATION

Sample Number: 1401204-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-005

SAMPLE INFORMATION

Sample Number: 1401204-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-006

SAMPLE INFORMATION

Sample Number: 1401204-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	13.3 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	43.1 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.0 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-006

SAMPLE INFORMATION

Sample Number: 1401204-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-007

SAMPLE INFORMATION

Sample Number: 1401204-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	15.0 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.9 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.04 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-007

SAMPLE INFORMATION

Sample Number: 1401204-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-008

SAMPLE INFORMATION

Sample Number: 1401204-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-009

SAMPLE INFORMATION

Sample Number: 1401204-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-010

SAMPLE INFORMATION

Sample Number: 1401204-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-011

SAMPLE INFORMATION

Sample Number: 1401204-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-012

SAMPLE INFORMATION

Sample Number: 1401204-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-013

SAMPLE INFORMATION

Sample Number: 1401204-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-014

SAMPLE INFORMATION

Sample Number: 1401204-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	132 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-014

SAMPLE INFORMATION

Sample Number: 1401204-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-015

SAMPLE INFORMATION

Sample Number: 1401204-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-016

SAMPLE INFORMATION

Sample Number: 1401204-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-017

SAMPLE INFORMATION

Sample Number: 1401204-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	16.3 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	142 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-017

SAMPLE INFORMATION

Sample Number: 1401204-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-018

SAMPLE INFORMATION

Sample Number: 1401204-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-019

SAMPLE INFORMATION

Sample Number: 1401204-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	16.4 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	135 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-019

SAMPLE INFORMATION

Sample Number: 1401204-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-020

SAMPLE INFORMATION

Sample Number: 1401204-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-021

SAMPLE INFORMATION

Sample Number: 1401204-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-022

SAMPLE INFORMATION

Sample Number: 1401204-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	107 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-022

SAMPLE INFORMATION

Sample Number: 1401204-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-023

SAMPLE INFORMATION

Sample Number: 1401204-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-024

SAMPLE INFORMATION

Sample Number: 1401204-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-025

SAMPLE INFORMATION

Sample Number: 1401204-025 Customer Sample Number:
Location: H13 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-026

SAMPLE INFORMATION

Sample Number: 1401204-026 Customer Sample Number:
Location: H14 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	18.8 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	42.1 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.47 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-026

SAMPLE INFORMATION

Sample Number: 1401204-026 Customer Sample Number:
Location: H14 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-027

SAMPLE INFORMATION

Sample Number: 1401204-027 Customer Sample Number:
Location: H15 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.9 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	37.1 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	40.9 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.31 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-027

SAMPLE INFORMATION

Sample Number: 1401204-027 Customer Sample Number:
Location: H15 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

2/24/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-028

SAMPLE INFORMATION

Sample Number: 1401204-028 Customer Sample Number:
Location: H16 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-029

SAMPLE INFORMATION

Sample Number: 1401204-029 Customer Sample Number:
Location: H17 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-030

SAMPLE INFORMATION

Sample Number: 1401204-030 Customer Sample Number:
Location: H18 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	20.6 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	18.9 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.03 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-030

SAMPLE INFORMATION

Sample Number: 1401204-030 Customer Sample Number:
Location: H18 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-031

SAMPLE INFORMATION

Sample Number: 1401204-031 Customer Sample Number:
Location: H19 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-032

SAMPLE INFORMATION

Sample Number: 1401204-032 Customer Sample Number:
Location: H20 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-033

SAMPLE INFORMATION

Sample Number: 1401204-033 Customer Sample Number:
Location: H21 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	18.8 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	18.9 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.80 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-033

SAMPLE INFORMATION

Sample Number: 1401204-033 Customer Sample Number:
Location: H21 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-034

SAMPLE INFORMATION

Sample Number: 1401204-034 Customer Sample Number:
Location: H22 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/28/2014 Collection Time: 14:00 Sampler: DM/IC Received Date and Time: 1/29/2014 11:50:24 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	2/19/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	19.1 ug/L	2/19/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	19.3 ug/L	2/19/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	2/19/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.01 ug/L	2/19/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1401204-034

SAMPLE INFORMATION

Sample Number: 1401204-034 Customer Sample Number:
Location: H22 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/28/2014 14:00 DM/IC 1/29/2014 11:50:24 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/24/2014
Report Number: M- W1402013-001

SAMPLE INFORMATION

Sample Number: 1402013-001 Customer Sample Number:
Location: 00 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 1/29/2014 Collection Time: 7:18 Sampler: CUSTOMER Received Date and Time: 2/4/2014 9:29:57 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/24/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-001

SAMPLE INFORMATION

Sample Number: 1403011-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-002

SAMPLE INFORMATION

Sample Number: 1403011-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-003

SAMPLE INFORMATION

Sample Number: 1403011-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-004

SAMPLE INFORMATION

Sample Number: 1403011-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-005

SAMPLE INFORMATION

Sample Number: 1403011-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-006

SAMPLE INFORMATION

Sample Number: 1403011-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-007

SAMPLE INFORMATION

Sample Number: 1403011-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-008

SAMPLE INFORMATION

Sample Number: 1403011-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-010

SAMPLE INFORMATION

Sample Number: 1403011-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-011

SAMPLE INFORMATION

Sample Number: 1403011-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-012

SAMPLE INFORMATION

Sample Number: 1403011-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-013

SAMPLE INFORMATION

Sample Number: 1403011-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-014

SAMPLE INFORMATION

Sample Number: 1403011-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-015

SAMPLE INFORMATION

Sample Number: 1403011-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-016

SAMPLE INFORMATION

Sample Number: 1403011-016

Customer Sample Number:

Location: 08F

Type: Dist.

LPR 820 ALLISON ST NW FILTERED

Collection Date:
2/28/2014

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
3/4/2014 12:57:31 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	4/7/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	4/7/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	107 ug/L	4/7/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/7/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	4/7/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-016

SAMPLE INFORMATION

Sample Number: 1403011-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 2/28/2014 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 3/4/2014 12:57:31 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-017

SAMPLE INFORMATION

Sample Number: 1403011-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED

Collection Date: 2/28/2014 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 3/4/2014 12:57:31 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	4/7/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	21.6 ug/L	4/7/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	131 ug/L	4/7/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/7/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	4/7/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-017

SAMPLE INFORMATION

Sample Number: 1403011-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-018

SAMPLE INFORMATION

Sample Number: 1403011-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-019

SAMPLE INFORMATION

Sample Number: 1403011-019
Location: 10
LPR 820 ALLISON ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/28/2014 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 3/4/2014 12:57:31 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-020

SAMPLE INFORMATION

Sample Number: 1403011-020
Customer Sample Number:
Location: 10F
Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: 2/28/2014
Collection Time: 8:30
Sampler: AB/YT
Received Date and Time: 3/4/2014 12:57:31 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-021

SAMPLE INFORMATION

Sample Number: 1403011-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-022

SAMPLE INFORMATION

Sample Number: 1403011-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-023

SAMPLE INFORMATION

Sample Number: 1403011-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-024

SAMPLE INFORMATION

Sample Number: 1403011-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 820 ALLISON ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-025

SAMPLE INFORMATION

Sample Number: 1403011-025 Customer Sample Number:
Location: H13 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-026

SAMPLE INFORMATION

Sample Number: 1403011-026 Customer Sample Number:
Location: H14 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-027

SAMPLE INFORMATION

Sample Number: 1403011-027 Customer Sample Number:
Location: H15 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-028

SAMPLE INFORMATION

Sample Number: 1403011-028 Customer Sample Number:
Location: H16 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 4/9/2014
 Report Number: M- W1403011-029

SAMPLE INFORMATION

Sample Number: 1403011-029
 Location: H17
 LPR 820 ALLISON ST NW UNFILTERED
 Customer Sample Number:
 Type: Dist.
 Collection Date: 2/28/2014 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 3/4/2014 12:57:31 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	4/7/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	24.7 ug/L	4/7/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	18.7 ug/L	4/7/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/7/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	4/7/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-029

SAMPLE INFORMATION

Sample Number: 1403011-029 Customer Sample Number:
Location: H17 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-030

SAMPLE INFORMATION

Sample Number: 1403011-030 Customer Sample Number:
Location: H18 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED

Collection Date: 2/28/2014 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 3/4/2014 12:57:31 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	4/7/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	26.6 ug/L	4/7/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.8 ug/L	4/7/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/7/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	4/7/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-030

SAMPLE INFORMATION

Sample Number: 1403011-030
Customer Sample Number:
Location: H18
Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 2/28/2014
Collection Time: 8:30
Sampler: AB/YT
Received Date and Time: 3/4/2014 12:57:31 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-031

SAMPLE INFORMATION

Sample Number: 1403011-031 Customer Sample Number:
Location: H19 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	4/7/2014	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	21.9 ug/L	4/7/2014	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	17.5 ug/L	4/7/2014	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	4/7/2014	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.66 ug/L	4/7/2014	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-031

SAMPLE INFORMATION

Sample Number: 1403011-031 Customer Sample Number:
Location: H19 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-032

SAMPLE INFORMATION

Sample Number: 1403011-032 Customer Sample Number:
Location: H20 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-033

SAMPLE INFORMATION

Sample Number: 1403011-033 Customer Sample Number:
Location: H21 Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/28/2014 8:30 AB/YT 3/4/2014 12:57:31 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  4/9/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/9/2014
Report Number: M- W1403011-034

SAMPLE INFORMATION

Sample Number: 1403011-034
Customer Sample Number:
Location: H22
Type: Dist.
LPR 820 ALLISON ST NW UNFILTERED
Collection Date: 2/28/2014
Collection Time: 8:30
Sampler: AB/YT
Received Date and Time: 3/4/2014 12:57:31 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

4/9/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-001

SAMPLE INFORMATION

Sample Number: 1404163-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-002

SAMPLE INFORMATION

Sample Number: 1404163-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-003

SAMPLE INFORMATION

Sample Number: 1404163-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-004

SAMPLE INFORMATION

Sample Number: 1404163-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-006

SAMPLE INFORMATION

Sample Number: 1404163-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-007

SAMPLE INFORMATION

Sample Number: 1404163-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	67.7 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	10.3 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.66 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-007

SAMPLE INFORMATION

Sample Number: 1404163-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-008

SAMPLE INFORMATION

Sample Number: 1404163-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-009

SAMPLE INFORMATION

Sample Number: 1404163-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	57.5 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.71 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-009

SAMPLE INFORMATION

Sample Number: 1404163-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-010

SAMPLE INFORMATION

Sample Number: 1404163-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-011

SAMPLE INFORMATION

Sample Number: 1404163-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED

Collection Date: 4/17/2014 Collection Time: 8:00 Sampler: AB/IC Received Date and Time: 4/17/2014 3:12:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	51.7 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.71 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-011

SAMPLE INFORMATION

Sample Number: 1404163-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-012

SAMPLE INFORMATION

Sample Number: 1404163-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-013

SAMPLE INFORMATION

Sample Number: 1404163-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-014

SAMPLE INFORMATION

Sample Number: 1404163-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-015

SAMPLE INFORMATION

Sample Number: 1404163-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-016

SAMPLE INFORMATION

Sample Number: 1404163-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-017

SAMPLE INFORMATION

Sample Number: 1404163-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	39.9 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.52 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-017

SAMPLE INFORMATION

Sample Number: 1404163-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-018

SAMPLE INFORMATION

Sample Number: 1404163-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: 4/17/2014 Collection Time: 8:00 Sampler: AB/IC Received Date and Time: 4/17/2014 3:12:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-019

SAMPLE INFORMATION

Sample Number: 1404163-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	83.5 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.51 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-019

SAMPLE INFORMATION

Sample Number: 1404163-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-020

SAMPLE INFORMATION

Sample Number: 1404163-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-021

SAMPLE INFORMATION

Sample Number: 1404163-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	110 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.08 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-021

SAMPLE INFORMATION

Sample Number: 1404163-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-022

SAMPLE INFORMATION

Sample Number: 1404163-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-023

SAMPLE INFORMATION

Sample Number: 1404163-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-024

SAMPLE INFORMATION

Sample Number: 1404163-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-025

SAMPLE INFORMATION

Sample Number: 1404163-025
Location: 10
LPR 827 DELAFIELD PL NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 4/17/2014
Collection Time: 8:00
Sampler: AB/IC
Received Date and Time: 4/17/2014 3:12:24 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	129 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.39 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-025

SAMPLE INFORMATION

Sample Number: 1404163-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-026

SAMPLE INFORMATION

Sample Number: 1404163-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: 4/17/2014 Collection Time: 8:00 Sampler: AB/IC Received Date and Time: 4/17/2014 3:12:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	105 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-026

SAMPLE INFORMATION

Sample Number: 1404163-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: 4/17/2014 Collection Time: 8:00 Sampler: AB/IC Received Date and Time: 4/17/2014 3:12:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-027

SAMPLE INFORMATION

Sample Number: 1404163-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	ND ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	102 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.17 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-027

SAMPLE INFORMATION

Sample Number: 1404163-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-028

SAMPLE INFORMATION

Sample Number: 1404163-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-029

SAMPLE INFORMATION

Sample Number: 1404163-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-030

SAMPLE INFORMATION

Sample Number: 1404163-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 827 DELAFIELD PL NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-031

SAMPLE INFORMATION

Sample Number: 1404163-031 Customer Sample Number:
Location: H13 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	58.4 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	10.3 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.86 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-031

SAMPLE INFORMATION

Sample Number: 1404163-031 Customer Sample Number:
Location: H13 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-032

SAMPLE INFORMATION

Sample Number: 1404163-032 Customer Sample Number:
Location: H14 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-033

SAMPLE INFORMATION

Sample Number: 1404163-033 Customer Sample Number:
Location: H15 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	35.5 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.62 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-033

SAMPLE INFORMATION

Sample Number: 1404163-033 Customer Sample Number:
Location: H15 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-034

SAMPLE INFORMATION

Sample Number: 1404163-034 Customer Sample Number:
Location: H16 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-035

SAMPLE INFORMATION

Sample Number: 1404163-035 Customer Sample Number:
Location: H17 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-036

SAMPLE INFORMATION

Sample Number: 1404163-036 Customer Sample Number:
Location: H18 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/23/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/23/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	26.2 ug/L	5/23/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	12.8 ug/L	5/23/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.20 ug/L	5/23/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-038

SAMPLE INFORMATION

Sample Number: 1404163-038 Customer Sample Number:
Location: H20 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-039

SAMPLE INFORMATION

Sample Number: 1404163-039 Customer Sample Number:
Location: H21 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/4/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/4/2014
Report Number: M- W1404163-040

SAMPLE INFORMATION

Sample Number: 1404163-040 Customer Sample Number:
Location: H22 Type: Dist.
LPR 827 DELAFIELD PL NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/17/2014 8:00 AB/IC 4/17/2014 3:12:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/4/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-001

SAMPLE INFORMATION

Sample Number: 1405222-001
Location: 01
LPR 2102 2ND ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-002

SAMPLE INFORMATION

Sample Number: 1405222-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-003

SAMPLE INFORMATION

Sample Number: 1405222-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-004

SAMPLE INFORMATION

Sample Number: 1405222-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-005

SAMPLE INFORMATION

Sample Number: 1405222-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-006

SAMPLE INFORMATION

Sample Number: 1405222-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-007

SAMPLE INFORMATION

Sample Number: 1405222-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-008

SAMPLE INFORMATION

Sample Number: 1405222-008
Location: 04F
LPR 2102 2ND ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/28/2014
Collection Time: 8:05
Sampler: YT/IC
Received Date and Time: 5/28/2014 3:42:12 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/30/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/30/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	24.0 ug/L	5/30/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	11.3 ug/L	5/30/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.59 ug/L	5/30/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-008

SAMPLE INFORMATION

Sample Number: 1405222-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-009

SAMPLE INFORMATION

Sample Number: 1405222-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-010

SAMPLE INFORMATION

Sample Number: 1405222-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-011

SAMPLE INFORMATION

Sample Number: 1405222-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-012

SAMPLE INFORMATION

Sample Number: 1405222-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-013

SAMPLE INFORMATION

Sample Number: 1405222-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/30/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/30/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	8.86 ug/L	5/30/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/30/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	9.14 ug/L	5/30/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-013

SAMPLE INFORMATION

Sample Number: 1405222-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-014

SAMPLE INFORMATION

Sample Number: 1405222-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-015

SAMPLE INFORMATION

Sample Number: 1405222-015
Customer Sample Number:
Location: 08
Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014
Collection Time: 8:05
Sampler: YT/IC
Received Date and Time: 5/28/2014 3:42:12 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-016

SAMPLE INFORMATION

Sample Number: 1405222-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-017

SAMPLE INFORMATION

Sample Number: 1405222-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-018

SAMPLE INFORMATION

Sample Number: 1405222-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/30/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/30/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	7.77 ug/L	5/30/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/30/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.49 ug/L	5/30/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-018

SAMPLE INFORMATION

Sample Number: 1405222-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-019

SAMPLE INFORMATION

Sample Number: 1405222-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-020

SAMPLE INFORMATION

Sample Number: 1405222-020
Location: 10F
LPR 2102 2ND ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/28/2014
Collection Time: 8:05
Sampler: YT/IC
Received Date and Time: 5/28/2014 3:42:12 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/30/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/30/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.60 ug/L	5/30/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	10.4 ug/L	5/30/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.80 ug/L	5/30/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-020

SAMPLE INFORMATION

Sample Number: 1405222-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-021

SAMPLE INFORMATION

Sample Number: 1405222-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-022

SAMPLE INFORMATION

Sample Number: 1405222-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	5/30/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	5/30/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.36 ug/L	5/30/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/30/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.32 ug/L	5/30/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-022

SAMPLE INFORMATION

Sample Number: 1405222-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-023

SAMPLE INFORMATION

Sample Number: 1405222-023
Location: 12
LPR 2102 2ND ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-024

SAMPLE INFORMATION

Sample Number: 1405222-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2102 2ND ST NW FILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-025

SAMPLE INFORMATION

Sample Number: 1405222-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-026

SAMPLE INFORMATION

Sample Number: 1405222-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-027

SAMPLE INFORMATION

Sample Number: 1405222-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-028

SAMPLE INFORMATION

Sample Number: 1405222-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.0 ug/L	5/30/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	5/30/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	20.8 ug/L	5/30/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/30/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	6.63 ug/L	5/30/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-028

SAMPLE INFORMATION

Sample Number: 1405222-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-029

SAMPLE INFORMATION

Sample Number: 1405222-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	5/30/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	5/30/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	15.3 ug/L	5/30/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/30/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.86 ug/L	5/30/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-029

SAMPLE INFORMATION

Sample Number: 1405222-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-030

SAMPLE INFORMATION

Sample Number: 1405222-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-031

SAMPLE INFORMATION

Sample Number: 1405222-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-032

SAMPLE INFORMATION

Sample Number: 1405222-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-033

SAMPLE INFORMATION

Sample Number: 1405222-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	5/30/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	5/30/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	10.3 ug/L	5/30/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	5/30/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.11 ug/L	5/30/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-033

SAMPLE INFORMATION

Sample Number: 1405222-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: 5/28/2014 Collection Time: 8:05 Sampler: YT/IC Received Date and Time: 5/28/2014 3:42:12 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-034

SAMPLE INFORMATION

Sample Number: 1405222-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-035

SAMPLE INFORMATION

Sample Number: 1405222-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405222-036

SAMPLE INFORMATION

Sample Number: 1405222-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2102 2ND ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/28/2014 8:05 YT/IC 5/28/2014 3:42:12 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-001

SAMPLE INFORMATION

Sample Number: 1405234-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-003

SAMPLE INFORMATION

Sample Number: 1405234-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-004

SAMPLE INFORMATION

Sample Number: 1405234-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-005

SAMPLE INFORMATION

Sample Number: 1405234-005
Location: 03
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.4 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	15.6 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	10.1 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.66 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-005

SAMPLE INFORMATION

Sample Number: 1405234-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-006

SAMPLE INFORMATION

Sample Number: 1405234-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-007

SAMPLE INFORMATION

Sample Number: 1405234-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	18.3 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	5.97 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.00 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-007

SAMPLE INFORMATION

Sample Number: 1405234-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-008

SAMPLE INFORMATION

Sample Number: 1405234-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-009

SAMPLE INFORMATION

Sample Number: 1405234-009
Location: 05
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	17.8 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.52 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.25 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-009

SAMPLE INFORMATION

Sample Number: 1405234-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-010

SAMPLE INFORMATION

Sample Number: 1405234-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-011

SAMPLE INFORMATION

Sample Number: 1405234-011
Location: 06
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	17.5 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.15 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.07 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-012

SAMPLE INFORMATION

Sample Number: 1405234-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-013

SAMPLE INFORMATION

Sample Number: 1405234-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	18.3 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.37 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.89 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-013

SAMPLE INFORMATION

Sample Number: 1405234-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-014

SAMPLE INFORMATION

Sample Number: 1405234-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.16 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.33 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-014

SAMPLE INFORMATION

Sample Number: 1405234-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-015

SAMPLE INFORMATION

Sample Number: 1405234-015
Location: 08
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	18.3 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.67 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.23 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-015

SAMPLE INFORMATION

Sample Number: 1405234-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-016

SAMPLE INFORMATION

Sample Number: 1405234-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-017

SAMPLE INFORMATION

Sample Number: 1405234-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	16.9 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.73 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.76 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-017

SAMPLE INFORMATION

Sample Number: 1405234-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-018

SAMPLE INFORMATION

Sample Number: 1405234-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-019

SAMPLE INFORMATION

Sample Number: 1405234-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.02 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	17.1 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	7.60 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.88 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-019

SAMPLE INFORMATION

Sample Number: 1405234-019
Location: 10
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-020

SAMPLE INFORMATION

Sample Number: 1405234-020
Location: 10F
LPR 5442 31ST ST. NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/30/2014
Collection Time: 8:00
Sampler: IC/ IB
Received Date and Time: 5/30/2014 12:55:26 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.0 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.96 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	11.4 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.20 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-020

SAMPLE INFORMATION

Sample Number: 1405234-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-021

SAMPLE INFORMATION

Sample Number: 1405234-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-022

SAMPLE INFORMATION

Sample Number: 1405234-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.0 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	6.04 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.25 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-022

SAMPLE INFORMATION

Sample Number: 1405234-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-023

SAMPLE INFORMATION

Sample Number: 1405234-023
Location: 12
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	16.5 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.85 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.27 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-023

SAMPLE INFORMATION

Sample Number: 1405234-023
Location: 12
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-024

SAMPLE INFORMATION

Sample Number: 1405234-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 5442 31ST ST. NW FILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-025

SAMPLE INFORMATION

Sample Number: 1405234-025
Location: H1
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.0 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	18.9 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	4.22 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	4.56 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-025

SAMPLE INFORMATION

Sample Number: 1405234-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-026

SAMPLE INFORMATION

Sample Number: 1405234-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-027

SAMPLE INFORMATION

Sample Number: 1405234-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-028

SAMPLE INFORMATION

Sample Number: 1405234-028
Location: H4
LPR 5442 31ST ST. NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/30/2014
Collection Time: 8:00
Sampler: IC/ IB
Received Date and Time: 5/30/2014 12:55:26 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.16 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	17.2 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.94 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.70 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-028

SAMPLE INFORMATION

Sample Number: 1405234-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-029

SAMPLE INFORMATION

Sample Number: 1405234-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.18 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	17.3 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	3.40 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.41 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-029

SAMPLE INFORMATION

Sample Number: 1405234-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-030

SAMPLE INFORMATION

Sample Number: 1405234-030
Location: H6
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.16 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	16.3 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	2.97 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.25 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-030

SAMPLE INFORMATION

Sample Number: 1405234-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-031

SAMPLE INFORMATION

Sample Number: 1405234-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-032

SAMPLE INFORMATION

Sample Number: 1405234-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-033

SAMPLE INFORMATION

Sample Number: 1405234-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-034

SAMPLE INFORMATION

Sample Number: 1405234-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2014 8:00 IC/IB 5/30/2014 12:55:26 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-035

SAMPLE INFORMATION

Sample Number: 1405234-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/16/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-036

SAMPLE INFORMATION

Sample Number: 1405234-036
Location: H12
LPR 5442 31ST ST. NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/30/2014 Collection Time: 8:00 Sampler: IC/ IB Received Date and Time: 5/30/2014 12:55:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.26 ug/L	6/3/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	17.2 ug/L	6/3/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	2.84 ug/L	6/3/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/3/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.9 ug/L	6/3/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/16/2014
Report Number: M- W1405234-036

SAMPLE INFORMATION

Sample Number: 1405234-036
Customer Sample Number:
Location: H12
Type: Dist.
LPR 5442 31ST ST. NW UNFILTERED
Collection Date: 5/30/2014
Collection Time: 8:00
Sampler: IC/IB
Received Date and Time: 5/30/2014 12:55:26 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/16/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-001

SAMPLE INFORMATION

Sample Number: 1406094-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-002

SAMPLE INFORMATION

Sample Number: 1406094-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-003

SAMPLE INFORMATION

Sample Number: 1406094-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-004

SAMPLE INFORMATION

Sample Number: 1406094-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-005

SAMPLE INFORMATION

Sample Number: 1406094-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-006

SAMPLE INFORMATION

Sample Number: 1406094-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-007

SAMPLE INFORMATION

Sample Number: 1406094-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-008

SAMPLE INFORMATION

Sample Number: 1406094-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-009

SAMPLE INFORMATION

Sample Number: 1406094-009
Location: 05
LPR 732 CROISSANT PL SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/6/2014
Collection Time: 9:00
Sampler: AB/DM
Received Date and Time: 6/11/2014 4:03:00 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.3 ug/L	6/13/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	18.6 ug/L	6/13/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.33 ug/L	6/13/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-009

SAMPLE INFORMATION

Sample Number: 1406094-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-010

SAMPLE INFORMATION

Sample Number: 1406094-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	< 0.2 ug/L	6/13/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/13/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	16.0 ug/L	6/13/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.13 ug/L	6/13/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-010

SAMPLE INFORMATION

Sample Number: 1406094-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-011

SAMPLE INFORMATION

Sample Number: 1406094-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-012

SAMPLE INFORMATION

Sample Number: 1406094-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-013

SAMPLE INFORMATION

Sample Number: 1406094-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-014

SAMPLE INFORMATION

Sample Number: 1406094-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-015

SAMPLE INFORMATION

Sample Number: 1406094-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED

Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	6/13/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	26.1 ug/L	6/13/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.91 ug/L	6/13/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-015

SAMPLE INFORMATION

Sample Number: 1406094-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-016

SAMPLE INFORMATION

Sample Number: 1406094-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-017

SAMPLE INFORMATION

Sample Number: 1406094-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-018

SAMPLE INFORMATION

Sample Number: 1406094-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/20/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-019

SAMPLE INFORMATION

Sample Number: 1406094-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/20/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-020

SAMPLE INFORMATION

Sample Number: 1406094-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-021

SAMPLE INFORMATION

Sample Number: 1406094-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED

Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	6/13/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	95.0 ug/L	6/13/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.87 ug/L	6/13/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-021

SAMPLE INFORMATION

Sample Number: 1406094-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-022

SAMPLE INFORMATION

Sample Number: 1406094-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	6/13/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	ND ug/L	6/13/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	78.7 ug/L	6/13/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	1.02 ug/L	6/13/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-022

SAMPLE INFORMATION

Sample Number: 1406094-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-023

SAMPLE INFORMATION

Sample Number: 1406094-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-024

SAMPLE INFORMATION

Sample Number: 1406094-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 732 CROISSANT PL SE FILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/20/2014
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-025

SAMPLE INFORMATION

Sample Number: 1406094-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	6/13/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	94.7 ug/L	6/13/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.23 ug/L	6/13/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-025

SAMPLE INFORMATION

Sample Number: 1406094-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-026

SAMPLE INFORMATION

Sample Number: 1406094-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-027

SAMPLE INFORMATION

Sample Number: 1406094-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.7 ug/L	6/13/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	58.1 ug/L	6/13/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	3.08 ug/L	6/13/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-027

SAMPLE INFORMATION

Sample Number: 1406094-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-028

SAMPLE INFORMATION

Sample Number: 1406094-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.6 ug/L	6/13/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	37.6 ug/L	6/13/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	2.46 ug/L	6/13/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-028

SAMPLE INFORMATION

Sample Number: 1406094-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-029

SAMPLE INFORMATION

Sample Number: 1406094-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-030

SAMPLE INFORMATION

Sample Number: 1406094-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-031

SAMPLE INFORMATION

Sample Number: 1406094-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-032

SAMPLE INFORMATION

Sample Number: 1406094-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-033

SAMPLE INFORMATION

Sample Number: 1406094-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-034

SAMPLE INFORMATION

Sample Number: 1406094-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-035

SAMPLE INFORMATION

Sample Number: 1406094-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: 6/6/2014 Collection Time: 9:00 Sampler: AB/DM Received Date and Time: 6/11/2014 4:03:00 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	0.5 ug/L	6/13/2014	RHoffa
Iron	EPA 200.8	ug/L	0.9 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Copper	EPA 200.8	ug/L	0.03 ug/L	0.2 ug/L	20.0 ug/L	6/13/2014	RHoffa
Zinc	EPA 200.8	ug/L	0.2 ug/L	10 ug/L	< 10 ug/L	6/13/2014	RHoffa
Lead	EPA 200.8	ug/L	0.02 ug/L	0.2 ug/L	5.05 ug/L	6/13/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-035

SAMPLE INFORMATION

Sample Number: 1406094-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/20/2014
Report Number: M- W1406094-036

SAMPLE INFORMATION

Sample Number: 1406094-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 732 CROISSANT PL SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/6/2014 9:00 AB/DM 6/11/2014 4:03:00 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

6/20/2014

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401


Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

Attachment 3

Customer Letter Distribution Certification



July 8, 2014

William Arguto
U.S. Environmental Protection Agency Region III
1650 Arch Street
Philadelphia, PA 19103-2029

RE: Certification of Consumer Notification of Tap Results

Dear Mr. Arguto,

The District of Columbia Water and Sewer Authority (PWSID: DC0000002) hereby certifies that for the lead and copper compliance monitoring period ending June 30, 2014, the “consumer notification of test results” have been distributed to the participating Lead and Copper Compliance monitoring customers in a manner consistent with the requirements of 40 CFR §141.85(d).

Water System Name: DC Water and Sewer Authority (DC Water)

PWSID: DC0000002

Monitoring Period to which the notice applies: January 2014 – June 2014


Dates results were received from laboratory: See Table C.6 of Report

Dates results were provided to customers: See Table C.6 of Report

The water system names above hereby certifies that its lead consumer notice has been provided to each person it serves at the specific sampling site from which the sample was tested. The water system also certifies that these results and the following information were provided to such persons within 30 days of receiving the test results from the laboratory:

- X Individual tap results from lead tap water monitoring carried out under the requirements of §141.86.
- X An explanation of the health effects of lead.
- X Steps that consumers can take to reduce exposure to lead in drinking water.
- X Contact information for your water utility.
- X The maximum contaminant level goals and action levels for lead, and the definitions of these two term from §141.153(c).

Pursuant to 40 CFR § 141.90(f)(3), attached are copies of sample consumer notification letters distributed by mail.



DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY | 3900 DONALDSON PLACE, NW | WASHINGTON, DC 20016

Certified by:

Name	<u>Jessica Edwards-Brandt</u>
Title	<u>Manager, Water Quality, Drinking Water Division</u>
Phone #	<u>202-364-3123</u> Date <u>July 8, 2014</u>

Sincerely,

A handwritten signature in black ink, appearing to read 'Jessica Edwards-Brandt'. The signature is stylized and includes a long horizontal line extending to the right.

Jessica Edwards-Brandt
Manager, Drinking Water Division

cc: Charles Kiely
Gregory Hope
Randy Hayman



June 30, 2014

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead and copper levels were below the Environmental Protection Agency (EPA) action levels.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

If you are pregnant or have children under age six, you should consider using cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Some people who drink water containing copper in excess of the action level may, with short term

exposure, experience gastrointestinal distress, and with long-term exposure may experience liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager



June 30, 2014

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead level was above the Environmental Protection Agency (EPA) action level. DC Water recommends that you take steps to minimize potential lead exposure. You should filter your water until lead levels decline in your drinking water. If you are pregnant or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The first draw water sample was above the lead action level. The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

Short-term exposure to copper levels above the action level may cause gastrointestinal distress, and long-term exposure may contribute to liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dwater.com/lead.

Sincerely,



George S. Hawkins, General Manager



June 30, 2014

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead level was above the Environmental Protection Agency (EPA) action level. DC Water recommends that you take steps to minimize potential lead exposure. You should filter your water until lead levels decline in your drinking water. If you are pregnant or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. According to our records, your home has a full or partial lead service pipe. (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
• Second draw: Measures lead release from the lead service pipe and household plumbing.

The second draw water sample was above the lead action level. The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. A n action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Table with 3 columns: Sample, Lead Level (ppb), Copper Level (ppb). Rows include First, Second, and EPA Action Level.

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

Short-term exposure to copper levels above the action level may cause gastrointestinal distress, and long-term exposure may contribute to liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.doe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager